

**GREATER CLARK COUNTY SCHOOLS**

**PARKWOOD ELEMENTARY SCHOOL**

**AHERA**

**ASBESTOS MANAGEMENT PLAN**

**DESIGNATED PERSON  
TRUTH AND CORRECT STATEMENT**

**Local Education Agency –** Greater Clark County Schools  
2112 Utica-Sellersburg Road  
Jeffersonville, Indiana 47130

**Designated Person -** Alliance Environmental Group, Inc.  
Sandra Shadley  
5153 Commerce Square Drive, Suite E  
Indianapolis, Indiana 46237

This Truth and Correct Statement, as outlined in 40 CFR 763.93(i), certifies that the general, local education agency responsibilities, as stipulated by 40 CFR 763.84, have been or will be met. These responsibilities include:

1. Ensure that the activities of any persons who perform inspections, reinspections, and periodic surveillance, develop and update management plans, and develop and implement response actions, including operations and maintenance, are carried out in accordance with 40 CFR 763 Subpart E.
2. Ensure all custodial and maintenance employees are properly trained as required by 40 CFR 763 Subpart E and other applicable Federal and/or State regulations (e.g., the Occupational Safety and Health Administration Asbestos Standard for Construction, the EPA Worker Protection Rule, or applicable State regulations).
3. Ensure that workers and building occupants, or their legal guardians, are informed at least once each school year about inspections, response actions, and post-response action activities, including periodic reinspection and surveillance activities that are planned or in progress.
4. Ensure that short-term workers (e.g., telephone repair workers, utility workers, or exterminators) who may come in contact with asbestos in a school are provided information regarding the locations of ACBM and suspected ACBM assumed to be ACM.
5. Ensure that warning labels are posted in accordance with Section 763.95.
6. Ensure management plans are available for inspection and notification of such availability has been provided as specified in the management plan under Section 763.93(g).
7. The undersigned person designated by the LEA pursuant to Section 763.84(g) (1) has received adequate training as stipulated in Section 763.84(g) (2).
8. The LEA has and will consider whether any conflict of interest may arise from the interrelationship among accredited personnel and whether that should influence the selection of accredited personnel to perform activities under Part 763.

Signature:  Date: November 6, 2016

Sandra S. Shadley

**ASBESTOS PROGRAM MASTER INDEX**

The following volumes are part of the Asbestos Program for the **GREATER CLARK COUNTY SCHOOLS**:

- A. Original Asbestos Management Plan for each school building.
- B. Asbestos Management Plan Supplement for each school building.
  - 1. Amendments to Management Plan
  - 2. Remaining Materials Report
  - 3. Surveillance, Reinspection and Additional Bulk Sampling Information
  - 4. Annual Notifications, Accreditations and Training Records
  - 5. Operations and Maintenance Records
  - 6. Asbestos Removal Projects
  - 7. Short Term Worker Program

Copies of both volumes are found in the respective buildings. The Administration Building also contains duplicate copies of both volumes for each building in their entirety.

GREATER CLARK COUNTY SCHOOLS

PARKWOOD ELEMENTARY SCHOOL

TABLE OF CONTENTS

AMENDMENTS TO MANAGEMENT PLAN	1
REMAINING MATERIALS REPORT	2
SURVEILLANCE, REINSPECTION AND ADDITIONAL BULK SAMPLING INFORMATION	3
ANNUAL NOTIFICATIONS, ACCREDITATIONS, AND TRAINING	4
OPERATIONS AND MAINTENANCE RECORDS	5
ASBESTOS REMOVAL PROJECTS	6
SHORT TERM WORKER INFORMATION	7

*AMENDMENTS TO THE MANAGEMENT PLAN*

**GREATER CLARK COUNTY SCHOOLS**  
**PARKWOOD ELEMENTARY SCHOOL**

**LEA RESPONSIBILITY CERTIFICATION**

LEA Designated Person - ALLIANCE INDIANA, INC.

  
Signature - Bruce Wallace, President/CEO

May 1, 1995  
Date

**ACCREDITATION STATEMENT**

The Greater Clark County Schools ensures that the following items will be carried out:

Activities of any persons who perform inspections, reinspections, and periodic surveillance, develop and update management plans, and develop and implement response actions, including operations and maintenance, are carried out in accordance with Subpart E of this part.

All custodial and maintenance employees are properly trained as required by this Subpart E and other applicable Federal and/or State regulations (e.g., the OSHA asbestos standard for construction, the EPA worker protection rule, or applicable State regulations).

Workers and building occupants, or their legal guardians, are informed at least once each school year about inspections, response actions, and post response action activities, including periodic reinspection and surveillance activities that are planned or in progress.

Short-term workers (e.g., telephone repair workers, utility workers, or exterminators) who may come in contact with asbestos in a school are provided information regarding the locations of ACBM and suspected ACBM assumed to be ACM.

Warning labels are posted in accordance with 763.95.

Management plans are available for inspection and notification of such availability has been provided as specified in the management plan under 763.93(g).

Designate a person to ensure that requirements under this section are properly implemented.

Designated person receives adequate training to perform duties assigned under this section. Such training shall provide, as necessary, basic knowledge of:

Health effects of asbestos

Detection, identification, and assessment of ACM

Options for controlling ACBM

Asbestos management programs

Relevant Federal and State regulations concerning asbestos, including those in this Subpart E and those of the OSHA, U.S. Department of Labor, the U.S. Department of Transportation and the U.S. Environmental Protection Agency.

Consider whether any conflict of interest may arise from the interrelationship among accredited personnel and whether that should influence the selection of accredited personnel to perform activities under this subpart.

**AMENDMENT TO THE MANAGEMENT PLAN**

**LEA Name -** Greater Clark County Schools

**Building -** Parkwood Elementary School

**Subject -** LEA Designated Person Change

Effective May 1, 1995 the Designated Person for the  
Greater Clark County Schools is:

Alliance Indiana, Inc.  
1433 Sadlier Circle West Drive  
Indianapolis, Indiana 46239  
(317) 351-5600

---

Management Planner: Rex Gaddis

Accreditation No. 192218025

  
\_\_\_\_\_  
Signature

May 1, 1995  
Date

**AMENDMENT TO THE  
AHERA MANAGEMENT PLAN**

**Building -** Parkwood Elementary School

**Subject-** New material

**Reference -** HA A Cove Base

**Original Assessment -** No assessment in original inspection.

**Amended Assessment -** The cove base in the building was not addressed in the original inspection. The material is considered to be suspect by EPA. The material will be assumed to contain asbestos and treated as such until a future renovation when it will be sampled.


---


Management Planner

Rex Gaddis

Indiana Department of Environmental Management Accreditation

192218025

  
\_\_\_\_\_  
Signature

  
\_\_\_\_\_  
Date



**AMENDMENT TO THE  
AHERA MANAGEMENT PLAN**

**Building -** Parkwood Elementary School

**Subject-** New material

**Reference -** HA B Cove Base Mastic

**Original Assessment -** No assessment in original inspection.

**Amended Assessment -** The cove base mastic in the building was not addressed in the original inspection. The material is considered to be suspect by EPA. The material will be assumed to contain asbestos and treated as such until a future renovation when it will be sampled.

---

Management Planner

Rex Gaddis

Indiana Department of Environmental Management Accreditation

192218025

  
\_\_\_\_\_  
Signature

  
\_\_\_\_\_  
Date

**AMENDMENT TO THE  
AHERA MANAGEMENT PLAN**

**Building -** Parkwood Elementary School

**Subject-** New material

**Reference -** HA D Shock Joint Material

**Original Assessment -** No assessment in original inspection.

**Amended Assessment -** The shock joint material on the air handlers in the building was not addressed in the original inspection. The material is considered to be suspect by EPA. The material will be assumed to contain asbestos and treated as such until a future renovation when it will be sampled.


---

Management Planner

Rex Gaddis

Indiana Department of Environmental Management Accreditation

192218025

  
\_\_\_\_\_  
Signature

  
\_\_\_\_\_  
Date

**AMENDMENT TO THE  
AHERA MANAGEMENT PLAN**

**Building -** Parkwood Elementary School

**Subject-** New material

**Reference -** HA E Firebrick

**Original Assessment -** No assessment in original inspection.

**Amended Assessment -** The firebrick in the incinerator in the boiler room was not addressed in the original inspection. The material is considered to be suspect by EPA. The material will be assumed to contain asbestos and treated as such until a future renovation when it will be sampled.


---


Management Planner

Rex Gaddis

Indiana Department of Environmental Management Accreditation

192218025

  
\_\_\_\_\_  
Signature

  
\_\_\_\_\_  
Date

**AMENDMENT TO MANAGEMENT PLAN**

**LEA Name -** Greater Clark County Schools  
**Subject -** LEA Designated Person Change  
**Amendment -** Effective March 2005, the Designated Person for the Greater Clark County Schools is:

Alliance Environmental Group, Inc.  
5340 Commerce Circle, Suite E  
Indianapolis, Indiana 46237  
(317) 865-3400


Personnel contributing to this Management Plan are licensed in according with 40 CFR 763.93(e)(12).

---

Management Planner: Sandra S. Shadley

Accreditation Number: 19A002720

  
Signature

  
Date

**AMENDMENT TO MANAGEMENT PLAN**


**Building Name -** Parkwood Elementary School


**Subject -** Removal of Homogeneous Area D

**Amendment -** Green shock joints on AHU in the gym and cafeteria were sampled by a licensed inspector and found to be a non-asbestos containing material by an accredited laboratory. Therefore, this homogeneous area is being removed from the Management Plan.

Management Planner: Sandra Shadley

Accreditation Number: 19A002720

  
Signature

  
Date

**REMAINING MATERIALS**

**Greater Clark County School Corporation**

**Remaining Materials Report**

**4/23/2020**

HA ID	HA Description	Quantity		Asbestos	HA Location	Planned Response Action
<b><u>Parkwood Elementary School</u></b>						
01	Fittings	Unquantified	LF	Known	Above ceiling from boiler room to kitchen area. (halls, classrooms, storage room, restrooms) Behind refrigerator in custodial room.	O&M
02-A	9"X9" tan floor tile (OLD)	Unquantified	SF	Assumed	Custodial Room & Classrooms	O&M
02-B	12"X12" Floor tile (NEWER) Light Blue	Unquantified	SF	Assumed	Gym	O&M
02-C	12" X 12" Floor tile (NEWER) White	Unquantified	SF	Assumed	Cafeteria + custodial room	O&M
02-D	12" X 12" Floor tile (NEWER) Dark Blue	Unquantified	SF	Assumed	Cafeteria	O&M
02-E	12" X 12" Floor tile Light gray	Unquantified	SF	Assumed	Stage	O&M
A	Cove Base	Unquantified	LF	Assumed	Throughout building	O&M
B	Cove Base Mastic	Approx 900	SF	No	Throughout building	O&M
C	Transite Soffite	2114	SF	Assumed	Outside building soffit	O&M
D	Green shock joints on AHU	0	SF	No	Gymnasium and cafeteria	O&M

**Greater Clark County School Corporation**

**Remaining Materials Report**

**1/14/2020**

HA ID	HA Description	Quantity		Asbestos	HA Location	Planned Response Action
<b><u>Parkwood Elementary School</u></b>						
01	Fittings	Unquantified	LF	Known	Above ceiling from boiler room to kitchen area. (halls, classrooms, storage room, restrooms) Behind refrigerator in custodial room.	O&M
02-A	9"X9" tan floor tile (OLD)	Unquantified	SF	Assumed	Custodial Room & Classrooms	O&M
02-B	12"X12" Floor tile (NEWER) Light Blue	Unquantified	SF	Assumed	Gym	O&M
02-C	12" X 12" Floor tile (NEWER) White	Unquantified	SF	Assumed	Cafeteria + custodial room	O&M
02-D	12" X 12" Floor tile (NEWER) Dark Blue	Unquantified	SF	Assumed	Cafeteria	O&M
02-E	12" X 12" Floor tile Light gray	Unquantified	SF	Assumed	Stage	O&M
A	Cove Base	Unquantified	LF	Assumed	Throughout building	O&M
B	Cove Base Mastic	Approx 900	SF	No	Throughout building	O&M
C	Transite Soffite	2114	SF	Assumed	Outside building soffit	O&M
D	Green shock joints on AHU	0	SF	No	Gymnasium and cafeteria	O&M



**Greater Clark County School Corporation**

**Remaining Materials Report**

**5/16/2019**

HA ID	HA Description	Quantity		Asbestos	HA Location	Planned Response Action
<b><u>Parkwood Elementary School</u></b>						
01	Fittings	Unquantified	LF	Known	Above ceiling from boiler room to kitchen area. (halls, classrooms, storage room, restrooms) Behind refrigerator in custodial room.	O&M
02-A	9"X9" tan floor tile (OLD)	Unquantified	SF	Assumed	Custodial Room & Classrooms	O&M
02-B	12"X12" Floor tile (NEWER) Light Blue	Unquantified	SF	Assumed	Gym	O&M
02-C	12" X 12" Floor tile (NEWER) White	Unquantified	SF	Assumed	Cafeteria + custodial room	O&M
02-D	12" X 12" Floor tile (NEWER) Dark Blue	Unquantified	SF	Assumed	Cafeteria	O&M
02-E	12" X 12" Floor tile Light gray	Unquantified	SF	Assumed	Stage	O&M
A	Cove Base	Unquantified	LF	Assumed	Throughout building	O&M
B	Cove Base Mastic	Approx 900	SF	No	Throughout building	O&M
C	Transite Soffite	2114	SF	Assumed	Outside building soffit	O&M
D	Green shock joints on AHU	0	SF	No	Gymnasium and cafeteria	O&M

**Greater Clark County School Corporation**

**Remaining Materials Report**

**11/13/2018**

HA ID	HA Description	Quantity		Asbestos	HA Location	Planned Response Action
<b><u>Parkwood Elementary School</u></b>						
01	Fittings	Unquantified	LF	Known	Above ceiling from boiler room to kitchen area. (halls, classrooms, storage room, restrooms) Behind refrigerator in custodial room.	O&M
02-A	9"X9" tan floor tile (OLD)	Unquantified	SF	Assumed	Custodial Room & Classrooms	O&M
02-B	12"X12" Floor tile (NEWER) Light Blue	Unquantified	SF	Assumed	Gym	O&M
02-C	12" X 12" Floor tile (NEWER) White	Unquantified	SF	Assumed	Cafeteria + custodial room	O&M
02-D	12" X 12" Floor tile (NEWER) Dark Blue	Unquantified	SF	Assumed	Cafeteria	O&M
02-E	12" X 12" Floor tile Light gray	Unquantified	SF	Assumed	Stage	O&M
A	Cove Base	Unquantified	LF	Assumed	Throughout building	O&M
B	Cove Base Mastic	Approx 900	SF	No	Throughout building	O&M
C	Transite Soffite	2114	SF	Assumed	Outside building soffit	O&M
D	Green shock joints on AHU	0	SF	No	Gymnasium and cafeteria	O&M

**Greater Clark County School Corporation**

**Remaining Materials Report**

**5/2/2018**

HA ID	HA Description	Quantity		Asbestos	HA Location	Planned Response Action
<b><u>Parkwood Elementary School</u></b>						
01	Fittings	Unquantified	LF	Known	Above ceiling from boiler room to kitchen area. (halls, classrooms, storage room, restrooms) Behind refrigerator in custodial room.	O&M
02-A	9"X9" tan floor tile (OLD)	Unquantified	SF	Assumed	Custodial Room & Classrooms	O&M
02-B	12"X12" Floor tile (NEWER) Light Blue	Unquantified	SF	Assumed	Gym	O&M
02-C	12" X 12" Floor tile (NEWER) White	Unquantified	SF	Assumed	Cafeteria + custodial room	O&M
02-D	12" X 12" Floor tile (NEWER) Dark Blue	Unquantified	SF	Assumed	Cafeteria	O&M
02-E	12" X 12" Floor tile Light gray	Unquantified	SF	Assumed	Stage	O&M
A	Cove Base	Unquantified	LF	Assumed	Throughout building	O&M
B	Cove Base Mastic	Approx 900	SF	No	Throughout building	O&M
C	Transite Soffite	2114	SF	Assumed	Outside building soffit	O&M
D	Green shock joints on AHU	0	SF	No	Gymnasium and cafeteria	O&M

**Greater Clark County School Corporation**

**Remaining Materials Report**

**10/18/2017**

HA ID	HA Description	Quantity		Asbestos	HA Location	Planned Response Action
<b><u>Parkwood Elementary School</u></b>						
01	Fittings	Unquantified	LF	Known	Above ceiling from boiler room to kitchen area. (halls, classrooms, storage room, restrooms) Behind refrigerator in custodial room.	O&M
02-A	9"X9" tan floor tile (OLD)	Unquantified	SF	Assumed	Custodial Room & Classrooms	O&M
02-B	12"X12" Floor tile (NEWER) Light Blue	Unquantified	SF	Assumed	Gym	O&M
02-C	12" X 12" Floor tile (NEWER) White	Unquantified	SF	Assumed	Cafeteria + custodial room	O&M
02-D	12" X 12" Floor tile (NEWER) Dark Blue	Unquantified	SF	Assumed	Cafeteria	O&M
02-E	12" X 12" Floor tile Light gray	Unquantified	SF	Assumed	Stage	O&M
A	Cove Base	Unquantified	LF	Assumed	Throughout building	O&M
B	Cove Base Mastic	Approx 900	SF	No	Throughout building	O&M
C	Transite Soffite	2114	SF	Assumed	Outside building soffit	O&M
D	Green shock joints on AHU	0	SF	No	Gymnasium and cafeteria	O&M

**Greater Clark County School Corporation**

**Remaining Materials Report**

**4/13/2017**

HA ID	HA Description	Quantity		Asbestos	HA Location	Planned Response Action
<b><u>Parkwood Elementary School</u></b>						
01	Fittings	Unquantified	LF	Known	Above ceiling from boiler room to kitchen area. (halls, classrooms, storage room, restrooms) Behind refrigerator in custodial room.	O&M
02-A	9"X9" tan floor tile (OLD)	Unquantified	SF	Assumed	Custodial Room & Classrooms	O&M
02-B	12"X12" Floor tile (NEWER) Light Blue	Unquantified	SF	Assumed	Gym	O&M
02-C	12" X 12" Floor tile (NEWER) White	Unquantified	SF	Assumed	Cafeteria + custodial room	O&M
02-D	12" X 12" Floor tile (NEWER) Dark Blue	Unquantified	SF	Assumed	Cafeteria	O&M
02-E	12" X 12" Floor tile Light gray	Unquantified	SF	Assumed	Stage	O&M
A	Cove Base	Unquantified	LF	Assumed	Throughout building	O&M
B	Cove Base Mastic	Approx 900	SF	No	Throughout building	O&M
C	Transite Soffite	2114	SF	Assumed	Outside building soffit	O&M
D	Green shock joints on AHU	0	SF	No	Gymnasium and cafeteria	O&M

**Greater Clark County School Corporation**

**Remaining Materials Report**

**4/28/2016**

HA ID	HA Description	Quantity		Asbestos	HA Location	Planned Response Action
<b><u>Parkwood Elementary School</u></b>						
01	Fittings	Unquantified	LF	Known	Above ceiling from boiler room to kitchen area. (halls, classrooms, storage room, restrooms) Behind refrigerator in custodial room.	O&M
02-A	9"X9" tan floor tile (OLD)	Unquantified	SF	Assumed	Custodial Room & Classrooms	O&M
02-B	12"X12" Floor tile (NEWER) Light Blue	Unquantified	SF	Assumed	Gym	O&M
02-C	12" X 12" Floor tile (NEWER) White	Unquantified	SF	Assumed	Cafeteria + custodial room	O&M
02-D	12" X 12" Floor tile (NEWER) Dark Blue	Unquantified	SF	Assumed	Cafeteria	O&M
02-E	12" X 12" Floor tile Light gray	Unquantified	SF	Assumed	Stage	O&M
A	Cove Base	Unquantified	LF	Assumed	Throughout building	O&M
B	Cove Base Mastic	Approx 900	SF	No	Throughout building	O&M
C	Transite Soffite	2114	SF	Assumed	Outside building soffit	O&M
D	Green shock joints on AHU	0	SF	No	Gymnasium and cafeteria	O&M

**Greater Clark County School Corporation**

**Remaining Materials Report**

**10/20/2015**

HA ID	HA Description	Quantity		Asbestos	HA Location	Planned Response Action
<b><u>Parkwood Elementary School</u></b>						
01	Fittings	Unquantified	LF	Known	Above ceiling from boiler room to kitchen area. (halls, classrooms, storage room, restrooms) Behind refrigerator in custodial room.	O&M
02-A	9"X9" tan floor tile (OLD)	Unquantified	SF	Assumed	Custodial Room & Classrooms	O&M
02-B	12"X12" Floor tile (NEWER) Light Blue	Unquantified	SF	Assumed	Gym	O&M
02-C	12" X 12" Floor tile (NEWER) White	Unquantified	SF	Assumed	Cafeteria + custodial room	O&M
02-D	12" X 12" Floor tile (NEWER) Dark Blue	Unquantified	SF	Assumed	Cafeteria	O&M
02-E	12" X 12" Floor tile Light gray	Unquantified	SF	Assumed	Stage	O&M
A	Cove Base	Unquantified	LF	Assumed	Throughout building	O&M
B	Cove Base Mastic	Approx 900	SF	No	Throughout building	O&M
C	Transite Soffite	2114	SF	Assumed	Outside building soffit	O&M
D	Green shock joints on AHU	0	SF	No	Gymnasium and cafeteria	O&M

**Greater Clark County Schools**  
**Remaining Materials Report**  
**April 22, 2015**

HA#	Material	Quantity	ACBM Y/A	Location	Planned Activities
<b><u>Parkwood Elementary School</u></b>					
01	Fittings	Unquantified LF	Y	Above ceiling from boiler room to kitchen area. (halls, classrooms, storage room, restrooms) Behind refrigerator in custodial room.	O & M
02-A	9"X9" tan floor tile (OLD)	Unquantified SF	A	Custodial Room & Classrooms	O & M
02-B	12"X12" Floor tile (NEWER) Light Blue	Unquantified SF	A	Gym	O & M
02-C	12" X 12" Floor tile (NEWER) White	Unquantified SF	A	Cafeteria + custodial room	O & M
02-D	12" X 12" Floor tile (NEWER) Dark Blue	Unquantified SF	A	Cafeteria	O & M
02-E	12" X 12" Floor tile Light gray	Unquantified SF	A	Stage	O & M
A	Cove base	Unquantified LF	A	Throughout the building	O & M
B	Cove base mastic	Approx 900 SF	N	Throughout the building	O & M
C	Transite soffit	2,114 SF	A	Outside building soffit	O & M



**Greater Clark County Schools**  
**Remaining Materials Report**  
**October 22, 2014**

HA#	Material	Quantity	ACBM Y/A	Location	Planned Activities
<b><u>Parkwood Elementary School</u></b>					
01	Fittings	Unquantified LF	Y	Above ceiling from boiler room to kitchen area. (halls, classrooms, storage room, restrooms) Behind refrigerator in custodial room.	O & M
02-A	9"X9" tan floor tile (OLD)	Unquantified SF	A	Custodial Room & Classrooms	O & M
02-B	12"X12" Floor tile (NEWER) Light Blue	Unquantified SF	A	Gym	O & M
02-C	12" X 12" Floor tile (NEWER) White	Unquantified SF	A	Cafeteria + custodial room	O & M
02-D	12" X 12" Floor tile (NEWER) Dark Blue	Unquantified SF	A	Cafeteria	O & M
02-E	12" X 12" Floor tile Light gray	Unquantified SF	A	Stage	O & M
A	Cove base	Unquantified LF	A	Throughout the building	O & M
B	Cove base mastic	Approx 900 SF	N	Throughout the building	O & M
C	Transite soffit	2,114 SF	A	Outside building soffit	O & M

**Greater Clark County Schools  
Remaining Materials Report  
April 21, 2014**

HA#	Material	Quantity	ACBM Y/A	Location	Planned Activities
<b><u>Parkwood Elementary School</u></b>					
01	Fittings	Unquantified LF	Y	Above ceiling from boiler room to kitchen area. (halls, classrooms, storage room, restrooms) Behind refrigerator in custodial room.	O & M
02-A	9"X9" tan floor tile (OLD)	Unquantified SF	A	Custodial Room & Classrooms	O & M
02-B	12"X12" Floor tile (NEWER) Light Blue	Unquantified SF	A	Gym	O & M
02-C	12" X 12" Floor tile (NEWER) White	Unquantified SF	A	Cafeteria + custodial room	O & M
02-D	12" X 12" Floor tile (NEWER) Dark Blue	Unquantified SF	A	Cafeteria	O & M
02-E	12" X 12" Floor tile Light gray	Unquantified SF	A	Stage	O & M
A	Cove base	Unquantified LF	A	Throughout the building	O & M
B	Cove base mastic	Approx 900 SF	N	Throughout the building	O & M
C	Transite soffit	2,114 SF	A	Outside building soffit	O & M

**Greater Clark County Schools  
Remaining Materials Report  
October 24, 2013**

HA#	Material	Quantity	ACBM Y/A	Location	Planned Activities
<b><u>Parkwood Elementary School</u></b>					
01	Fittings	Unquantified LF	Y	Above ceiling from boiler room to kitchen area. (halls, classrooms, storage room, restrooms) Behind refrigerator in custodial room.	O & M
02-A	9"X9" tan floor tile (OLD)	Unquantified SF	A	Custodial Room & Classrooms	O & M
02-B	12"X12" Floor tile (NEWER) Light Blue	Unquantified SF	A	Gym	O & M
02-C	12" X 12" Floor tile (NEWER) White	Unquantified SF	A	Cafeteria + custodial room	O & M
02-D	12" X 12" Floor tile (NEWER) Dark Blue	Unquantified SF	A	Cafeteria	O & M
02-E	12" X 12" Floor tile Light gray	Unquantified SF	A	Stage	O & M
A	Cove base	Unquantified LF	A	Throughout the building	O & M
B	Cove base mastic	Approx 900 SF	N	Throughout the building	O & M
C	Transite soffit	2,114 SF	A	Outside building soffit	O & M

**Greater Clark County Schools  
Remaining Materials Report  
April 24, 2013**

HA#	Material	Quantity	ACBM Y/A	Location	Planned Activities
<b><u>Parkwood Elementary School</u></b>					
01	Fittings	Unquantified LF	Y	Above ceiling from boiler room to kitchen area. (halls, classrooms, storage room, restrooms) Behind refrigerator in custodial room.	O & M
02-A	9"X9" tan floor tile (OLD)	Unquantified SF	A	Custodial Room & Classrooms	O & M
02-B	12"X12" Floor tile (NEWER) Light Blue	Unquantified SF	A	Gym	O & M
02-C	12" X 12" Floor tile (NEWER) White	Unquantified SF	A	Cafeteria + custodial room	O & M
02-D	12" X 12" Floor tile (NEWER) Dark Blue	Unquantified SF	A	Cafeteria	O & M
02-E	12" X 12" Floor tile Light gray	Unquantified SF	A	Stage	O & M
A	Cove base	Unquantified LF	A	Throughout the building	O & M
B	Cove base mastic	Approx 900 SF	N	Throughout the building	O & M
C	Transite soffit	2,114 SF	A	Outside building soffit	O & M

**Greater Clark County Schools  
Remaining Materials Report  
October 24, 2012**

HA#	Material	Quantity	ACBM Y/A	Location	Planned Activities
<b><u>Parkwood Elementary School</u></b>					
01	Fittings	Unquantified LF	Y	Above ceiling from boiler room to kitchen area. (halls, classrooms, storage room, restrooms) Behind refrigerator in custodial room.	O & M
02-A	9"X9" tan floor tile (OLD)	Unquantified SF	A	Custodial Room & Classrooms	O & M
02-B	12"X12" Floor tile (NEWER) Light Blue	Unquantified SF	A	Gym	O & M
02-C	12" X 12" Floor tile (NEWER) White	Unquantified SF	A	Cafeteria + custodial room	O & M
02-D	12" X 12" Floor tile (NEWER) Dark Blue	Unquantified SF	A	Cafeteria	O & M
02-E	12" X 12" Floor tile Light gray	Unquantified SF	A	Stage	O & M
A	Cove base	Unquantified LF	A	Throughout the building	O & M
B	Cove base mastic	Approx 900 SF	N	Throughout the building	O & M
C	Transite soffit	2,114 SF	A	Outside building soffit	O & M

**Greater Clark County Schools  
Remaining Materials Report  
June 25, 2012**

HA#	Material	Quantity	ACBM Y/A	Location	Planned Activities
<b><u>Parkwood Elementary School</u></b>					
01	Fittings	Unquantified LF	Y	Above ceiling from boiler room to kitchen area. (halls, classrooms, storage room, restrooms) Behind refrigerator in custodial room.	O & M
02-A	9"X9" tan floor tile (OLD)	Unquantified SF	A	Custodial Room & Classrooms	O & M
02-B	12"X12" Floor tile (NEWER) Light Blue	Unquantified SF	A	Gym	O & M
02-C	12" X 12" Floor tile (NEWER) White	Unquantified SF	A	Cafeteria + custodial room	O & M
02-D	12" X 12" Floor tile (NEWER) Dark Blue	Unquantified SF	A	Cafeteria	O & M
02-E	12" X 12" Floor tile Light gray	Unquantified SF	A	Stage	O & M
A	Cove base	Unquantified LF	A	Throughout the building	O & M
B	Cove base mastic	Approx 900 SF	N	Throughout the building	O & M
C	Transite soffit	2,114 SF	A	Outside building soffit	O & M

**Greater Clark County Schools  
Remaining Materials Report  
June 27, 2011**

HA#	Material	Quantity	ACBM Y/A	Location	Planned Activities
<b><u>Parkwood Elementary School</u></b>					
01	Fittings	Unquantified LF	Y	Above ceiling from boiler room to kitchen area. (halls, classrooms, storage room, restrooms) Behind refrigerator in custodial room.	O & M
02-A	9"X9" Floor tile (OLD)	Unquantified SF	A	Custodial Room & Classrooms	O & M
02-B	12"X12" Floor tile (NEWER) Light Blue	Unquantified SF	A	Gym	O & M
02-C	12" X 12" Floor tile (NEWER) White	Unquantified SF	A	Cafeteria + custodial room	O & M
02-D	12" X 12" Floor tile (NEWER) Dark Blue	Unquantified SF	A	Cafeteria	O & M
02-E	12" X 12" Floor tile Light gray	Unquantified SF	A	Stage	O & M
A	Cove base	Unquantified LF	A	Throughout the building	O & M
B	Cove base mastic	Approx 900 SF	N	Throughout the building	O & M
C	Transite soffit	2,114 SF	A	Outside building soffit	O & M

**Greater Clark County Schools  
Remaining Materials Report  
December 6, 2010**

HA#	Material	Quantity	ACBM Y/A	Location	Planned Activities
<b><u>Parkwood Elementary School</u></b>					
01	Fittings	Unquantified LF	Y	Above ceiling from boiler room to kitchen area. (halls, classrooms, boiler room/mechanical room, storage room, restrooms) Behind refrigerator in custodial room.	O & M
02	Floor tile	Unquantified SF	A	Throughout the building	O & M
A	Cove base	Unquantified LF	A	Throughout the building	O & M
B	Cove base mastic	Approx. 900 SF	A	Throughout the building	O & M
C	Transite soffit	2,114 SF	A	Outside building soffit	O & M
D	Green shock joints on AHU	120 SF	A	Gymnasium and cafeteria	O & M



**Greater Clark County Schools  
Remaining Materials Report  
June 30, 2010**

HA#	Material	Quantity	ACBM Y/A	Location	Planned Activities
<b><u>Parkwood Elementary School</u></b>					
01	Fittings	Unquantified LF	Y	Above ceiling from boiler room to kitchen area. (halls, classrooms, boiler room/mechanical room, storage room, restrooms) Behind refrigerator in custodial room.	O & M
02	Floor tile	Unquantified SF	A	Throughout the building	O & M
A	Cove base	Unquantified LF	A	Throughout the building	O & M
B	Cove base mastic	Approx. 900 SF	A	Throughout the building	O & M
C	Transite soffit	2,114 SF	A	Outside building soffit	O & M
D	Green shock joints on AHU	120 SF	A	Gymnasium and cafeteria	O & M

**Greater Clark County Schools  
Remaining Materials Report  
December 7, 2009**

HA#	Material	Quantity	ACBM Y/A	Location	Planned Activities
<b><u>Parkwood Elementary School</u></b>					
01	Fittings	Unquantified LF	Y	Above ceiling from boiler room to kitchen area. (halls, classrooms, boiler room/mechanical room, storage room, restrooms)	O & M
02	Floor tile	Unquantified SF	A	Throughout the building	O & M
A	Cove base	Approx. 2,800 LF	A	Throughout the building	O & M
B	Cove base mastic	Approx. 900 SF	A	Throughout the building	O & M
C	Transite soffit	2,114 SF	A	Outside building soffit	O & M
D	Green shock joints on AHU	120 SF	A	Gymnasium and cafeteria	O & M

**Greater Clark County Schools  
Remaining Materials Report  
June 10, 2009**

<b>HA#</b>	<b>Material</b>	<b>Quantity</b>	<b>ACBM Y/A</b>	<b>Location</b>	<b>Planned Activities</b>
<b><u>Parkwood Elementary School</u></b>					
01	Fittings	Unquantified LF	Y	Above ceiling from boiler room to kitchen area. (halls, classrooms, boiler room/mechanical room, storage room, restrooms)	O & M
02	Floor tile	Unquantified SF	A	Throughout the building	O & M
A	Cove base	Approx. 2,800 LF	A	Throughout the building	O & M
B	Cove base mastic	Approx. 900 SF	A	Throughout the building	O & M
C	Transite soffit	2,114 SF	A	Outside building soffit	O & M
D	Green shock joints on AHU	120 SF	A	Gymnasium and cafeteria	O & M

**Greater Clark County Schools  
Remaining Materials Report  
December 10, 2008**

HA#	Material	Quantity	ACBM Y/A	Location	Planned Activities
<b><u>Parkwood Elementary School</u></b>					
01	Fittings	Unquantified LF	Y	Above ceiling from boiler room to kitchen area. (halls, classrooms, boiler room/mechanical room, storage room, restrooms)	O & M
02	Floor tile	Unquantified SF	A	Throughout the building	O & M
A	Cove base	Approx. 2,800 LF	A	Throughout the building	O & M
B	Cove base mastic	Approx. 900 SF	A	Throughout the building	O & M
C	Transite soffit	2,114 SF	A	Outside building soffit	O & M
D	Green shock joints on AHU	120 SF	A	Gymnasium and cafeteria	O & M

**Greater Clark County Schools  
Remaining Materials Report  
June 30, 2008**

<b>HA#</b>	<b>Material</b>	<b>Quantity</b>	<b>ACBM Y/A</b>	<b>Location</b>	<b>Planned Activities</b>
<b><u>Parkwood Elementary School</u></b>					
01	Fittings	Unquantified LF	Y	Above ceiling from boiler room to kitchen area. (halls, classrooms, boiler room/mechanical room, storage room, restrooms)	O & M
02	Floor tile	Unquantified SF	A	Throughout the building	O & M
A	Cove base	Approx. 2,800 LF	A	Throughout the building	O & M
B	Cove base mastic	Approx. 900 SF	A	Throughout the building	O & M
C	Transite soffit	2,114 SF	A	Outside building soffit	O & M
D	Green shock joints on AHU	120 SF	A	Gymnasium and cafeteria	O & M

**Greater Clark County Schools  
Remaining Materials Report  
December 14, 2007**

HA#	Material	Quantity	ACBM Y/A	Location	Planned Activities
<b><u>Parkwood Elementary School</u></b>					
01	Fittings	Unquantified LF	Y	Above ceiling from boiler room to kitchen area. (halls, classrooms, boiler room/mechanical room, storage room, restrooms)	O & M
02	Floor tile	Unquantified SF	A	Throughout the building	O & M
A	Cove base	Approx. 2,800 LF	A	Throughout the building	O & M
B	Cove base mastic	Approx. 900 SF	A	Throughout the building	O & M
C	Transite soffit	2,114 SF	A	Outside building soffit	O & M
D	Green shock joints on AHU	120 SF	A	Gymnasium and cafeteria	O & M

**Greater Clark County Schools  
Remaining Materials Report  
August 1, 2007**

HA#	Material	Quantity	ACBM Y/A	Location	Planned Activities
<b><u>Parkwood Elementary School</u></b>					
01	Fittings	Unquantified LF	Y	Above ceiling from boiler room to kitchen area. (halls, classrooms, boiler room/mechanical room, storage room, restrooms)	O & M
02	Floor tile	Unquantified SF	A	Throughout the building	O & M
A	Cove base	Approx. 2,800 LF	A	Throughout the building	O & M
B	Cove base mastic	Approx. 900 SF	A	Throughout the building	O & M
C	Transite soffit	2,114 SF	A	Outside building soffit	O & M
D	Green shock joints on AHU	120 SF	A	Gymnasium and cafeteria	O & M

**Greater Clark County Schools  
Remaining Materials Report  
July 9, 2007**

<b>HA#</b>	<b>Material</b>	<b>Quantity</b>	<b>ACBM Y/A</b>	<b>Location</b>	<b>Planned Activities</b>
<b><u>Parkwood Elementary School</u></b>					
01	Fittings	Unquantified LF	Y	Above ceiling from boiler room to kitchen area. (halls, classrooms, boiler room/mechanical room, storage room, restrooms)	O & M
02	Floor tile	Unquantified SF	A	Throughout the building	O & M
A	Cove base	Approx. 2,800 LF	A	Throughout the building	O & M
B	Cove base mastic	Approx. 900 SF	A	Throughout the building	O & M
C	Transite soffit	2,114 SF	A	Outside building soffit	O & M
D	Green shock joints on AHU	120 SF	A	Gymnasium and cafeteria	O & M



**Greater Clark County Schools  
Remaining Materials Report  
December 18, 2006**

HA#	Material	Quantity	ACBM Y/A	Location	Planned Activities
<b><u>Parkwood Elementary School</u></b>					
01	Fittings	Unquantified LF	Y	Above ceiling from boiler room to kitchen area. (halls, classrooms, boiler room/mechanical room, storage room, restrooms)	O & M
02	Floor tile	Unquantified SF	A	Throughout the building	O & M
A	Cove base	Approx. 2,800 LF	A	Throughout the building	O & M
B	Cove base mastic	Approx. 900 SF	A	Throughout the building	O & M
C	Transite soffit	2,114 SF	A	Outside building soffit	O & M
D	Green shock joints on AHU	120 SF	A	Gymnasium and cafeteria	O & M

**Greater Clark County Schools  
Remaining Materials Report  
June 28, 2006**

HA#	Material	Quantity	ACBM Y/A	Location	Planned Activities
<b><u>Parkwood Elementary School</u></b>					
01	Fittings	Unquantified LF	Y	Above ceiling from boiler room to kitchen area. (halls, classrooms, boiler room/mechanical room, storage room, restrooms)	O & M
02	Floor tile	Unquantified SF	A	Throughout the building	O & M
A	Cove base	Approx. 2,800 LF	A	Throughout the building	O & M
B	Cove base mastic	Approx. 900 SF	A	Throughout the building	O & M
C	Transite soffit	2,114 SF	A	Outside building soffit	O & M
D	Green shock joints on AHU	120 SF	A	Gymnasium and cafeteria	O & M

**Greater Clark County Schools  
Remaining Materials Report  
January 25, 2006**

<b>HA#</b>	<b>Material</b>	<b>Quantity</b>	<b>ACBM Y/A</b>	<b>Location</b>	<b>Planned Activities</b>
<b><u>Parkwood Elementary School</u></b>					
01	Fittings	Unquantified LF	Y	Above ceiling from boiler room to kitchen area. (halls, classrooms, boiler room/mechanical room, storage room, restrooms)	O & M
02	Floor tile	Unquantified SF	A	Throughout the building	O & M
A	Cove base	Approx. 2,800 LF	A	Throughout the building	O & M
B	Cove base mastic	Approx. 900 SF	A	Throughout the building	O & M
C	Transite soffit	2,114 SF	A	Outside building soffit	O & M
D	Green shock joints on AHU	120 SF	A	Gymnasium and cafeteria	O & M

**Greater Clark County Schools  
 Remaining Materials Report  
 July 20, 2005**

<b>HA#</b>	<b>Material</b>	<b>Quantity</b>	<b>ACBM Y/A</b>	<b>Location</b>	<b>Planned Activities</b>	
<b><u>Parkwood Elementary School</u></b>						
01	Fittings	Unquantified	LF	Y	Above ceiling from boiler room to kitchen area. (halls, classrooms, boiler room/mechanical room, storage room, restrooms)	O & M
02	Floor tile	Unquantified	SF	A	Throughout the building	O & M
A	Cove base	Approx. 2,800	LF	A	Throughout the building	O & M
B	Cove base mastic	Approx. 900	SF	A	Throughout the building	O & M
C	Transite soffit	2,114	SF	A	Outside building soffit	O & M
D	Green shock joints on AHU	120	SF	A	Gymnasium and cafeteria	O & M

Greater Clark County Schools  
 Remaining Materials Report  
 December 9, 2004

HA#	Material	Quantity		ACBM Y/A	Location	Planned Activities
<b><u>Parkwood Elementary School</u></b>						
01	Fittings	Unquantified	LF	Y	Above ceiling from boiler room to kitchen area. (halls, classrooms, boiler room/mechanical room, storage room, restrooms)	O & M
02	Floor tile	Unquantified	SF	A	Throughout the building	O & M
A	Cove base	Approx. 2,800	LF	A	Throughout the building	O & M
B	Cove base mastic	Approx. 900	' SF	A	Throughout the building	O & M
C	Transite soffit	2,114	SF	A	Outside building soffit	O & M
D	Green shock joints on AHU	120	SF	A	Gymnasium and cafeteria	O & M

Greater Clark County Schools  
 Remaining Materials Report  
 July 2, 2004

HA#	Material	Quantity	ACBM	Y/A	Location	Planned Activities
<b><u>Parkwood Elementary School</u></b>						
01	Fittings	Unquantified	LF	Y	Above ceiling from boiler room to kitchen area. (halls, classrooms, boiler room/mechanical room, storage room, restrooms)	O & M
02	Floor tile	Unquantified	SF	A	Throughout the building	O & M
A	Cove base	Approx. 2,800	LF	A	Throughout the building	O & M
B	Cove base mastic	Approx. 900	SF	A	Throughout the building	O & M
C	Transite soffit	2,114	SF	A	Outside building soffit	O & M
D	Green shock joints on AHU	120	SF	A	Gymnasium and cafeteria	O & M

Greater Clark County Schools  
 Remaining Materials Report  
 December 9, 2003

HA#	Material	Quantity	ACBM Y/A	Location	Planned Activities	
<b><u>Parkwood Elementary School</u></b>						
01	Fittings	Unquantified	LF	Y	Above ceiling from boiler room to kitchen area. (halls, classrooms, boiler room/mechanical room, storage room, restrooms)	O & M
02	Floor tile	Unquantified	SF	A	Throughout the building	O & M
A	Cove base	Approx. 2,800	LF	A	Throughout the building	O & M
B	Cove base mastic	Approx. 900	SF	A	Throughout the building	O & M
C	Transite soffit	2,114	SF	A	Outside building soffit	O & M
D	Green shock joints on AHU	120	SF	A	Gymnasium and cafeteria	O & M

**Greater Clark County Schools  
Remaining Materials Report  
June 13, 2003**

HA#	Material	Quantity	ACBM	Y/A	Location	Planned Activities
<b><u>Parkwood Elementary School</u></b>						
01	Fittings	Unquantified	LF	Y	Above ceiling from boiler room to kitchen area. (halls, classrooms, boiler room, storage room, restrooms)	O & M
02	Floor tile	Unquantified	SF	A	Throughout the building	O & M
A	Cove base	Approx. 2,800	LF	A	Throughout the building	O & M
B	Cove base mastic	Approx. 900	SF	A	Throughout the building	O & M
C	Transite soffit	2,114	SF	A	Outside building soffit	O & M
D	Green shock joints on AHU	120	SF	A	Gymnasium and cafeteria	O & M



Greater Clark County Schools  
 Remaining Materials Report  
 December 18, 2003

HA#	Material	Quantity		ACBM Y/A	Location	Planned Activities
<b><u>Parkwood Elementary School</u></b>						
01	Fittings	Unquantified	LF	Y	Above ceiling from boiler room to kitchen area. (halls, classrooms, boiler room, storage room, restrooms)	O & M
02	Floor tile	Unquantified	SF	A	Throughout the building	O & M
A	Cove base	Approx. 2,800	LF	A	Throughout the building	O & M
B	Cove base mastic	Approx. 900	SF	A	Throughout the building	O & M
C	Transite soffit	2,114	SF	A	Outside building soffit	O & M
D	Green shock joints on AHU	120	SF	A	Gymnasium and cafeteria	O & M

**Greater Clark County Schools  
Remaining Materials Report  
June 19, 2002**

HA#	Material	Quantity		ACBM Y/A	Location	Planned Activities
<b><u>Parkwood Elementary School</u></b>						
01	Fittings	Unquantified	LF	Y	Above ceiling from boiler room to kitchen area. (halls, classrooms, boiler room, storage room, restrooms)	O & M
02	Floor tile	Unquantified	SF	A	Throughout the building	O & M
A	Cove base	Approx. 2,800	LF	A	Throughout the building	O & M
B	Cove base mastic	Approx. 900	SF	A	Throughout the building	O & M
C	Transite soffit	2,114	SF	A	Outside building soffit	O & M
D	Green shock joints on AHU	120	SF	A	Gymnasium and cafeteria	O & M

Greater Clark County Schools  
 Remaining Materials Report  
 December 12, 2001

HA#	Material	Quantity		ACBM Y/A	Location	Planned Activities
<b><u>Parkwood Elementary School</u></b>						
01	Fittings	Unquantified	LF	Y	Above ceiling from boiler room to kitchen area. (halls, classrooms, boiler room, storage room, restrooms)	O & M
02	Floor tile	Unquantified	SF	A	Throughout the building	O & M
A	Cove base	Approx. 2,800	LF	A	Throughout the building	O & M
B	Cove base mastic	Approx. 900	SF	A	Throughout the building	O & M
C	Transite soffit	2,114	SF	A	Outside building soffit	O & M
D	Green shock joints on AHU	120	SF	A	Gymnasium and cafeteria	O & M

**Greater Clark County Schools  
 Remaining Materials Report  
 July 12, 2001**

<b>HA#</b>	<b>Material</b>	<b>Quantity</b>	<b>ACBM Y/A</b>	<b>Location</b>	<b>Planned Activities</b>	
<b><u>Parkwood Elementary School</u></b>						
01	Fittings	Unquantified	LF	Y	Above ceiling from boiler room to kitchen area. (halls, classrooms, boiler room, storage room, restrooms)	O & M
02	Floor tile	Unquantified	SF	A	Throughout the building	O & M
A	Cove base	Approx. 2,800	LF	A	Throughout the building	O & M
B	Cove base mastic	Approx. 900	SF	A	Throughout the building	O & M
C	Transite soffit	2,114	SF	A	Outside building soffit	O & M
D	Green shock joints on AHU	120	SF	A	Gymnasium and cafeteria	O & M

**Greater Clark County Schools**  
**Remaining Materials Report**  
**January 11, 2001**

HA#	Material	Quantity		ACBM Y/A	Location	Planned Activities
<b><u>Parkwood Elementary School</u></b>						
01	Fittings	Unquantified	LF	Y	Above ceiling from boiler room to kitchen area. (halls, classrooms, boiler room, storage room, restrooms)	O & M
02	Floor tile	Unquantified	SF	A	Throughout the building	O & M
A	Cove base	Approx. 2,800	LF	A	Throughout the building	O & M
B	Cove base mastic	Approx. 900	SF	A	Throughout the building	O & M
C	Transite soffit	2,114	SF	A	Outside building soffit	O & M
D	Green shock joints on AHU	120	SF	A	Gymnasium and cafeteria	O & M

**Greater Clark County Schools  
Remaining Materials Report  
June 29, 2000**

HA#	Material	Quantity		ACBM Y/A	Location	Planned Activities
<b><u>Parkwood Elementary School</u></b>						
01	Fittings	Unquantified	SF	Y	Above Ceiling from Boiler Room to Kitchen Area. (Halls, Classrooms, Boiler Room, Storage Room, Restrooms)	O & M
02	Floor Tile	Unquantified	SF	A	Throughout the building	O & M
A	Cove Base	Unquantified	LF	A	Throughout the building	O & M
B	Cove Base Mastic	Unquantified	LF	A	Throughout the building	O & M
C	Transite Soffit	2,114	SF	A	Outside building soffit	O & M
D	Green Shock Joints on AHU	Unquantified	SF	A	Gymnasium and Cafeteria	O & M

**Greater Clark County Schools  
 Remaining Materials Report  
 February 23, 2000**

<b>HA#</b>	<b>Material</b>	<b>Quantity</b>	<b>ACBM Y/A</b>	<b>Location</b>	<b>Planned Activities</b>	
<b><u>Parkwood Elementary School</u></b>						
01	Fittings	Unquantified	SF	Y	Above Ceiling from Boiler Room to Kitchen Area. (Halls, Classrooms, Boiler Room, Storage Room, Restrooms)	O & M
02	Floor Tile	Unquantified	SF	A	Throughout the building	O & M
A	Cove Base	Unquantified	LF	A	Throughout the building	O & M
B	Cove Base Mastic	Unquantified	LF	A	Throughout the building	O & M
C	Transite Soffit	Unquantified	SF	A	Throughout the building	O & M
D	Shock Joints on AHV	Unquantified	SF	A	Gymnasium and Cafeteria	O & M

Greater Clark County Schools  
 Remaining Materials Report  
 July 6, 1999

HA#	Material	Quantity	ACBM	Y/A	Location	Planned Activities
<b><u>Parkwood Elementary School</u></b>						
01	Fittings	Unquantified	SF	Y	Above Ceiling from Boiler Room to Kitchen Area. (Halls, Classrooms, Boiler Room, Storage Room, Restrooms)	O & M
02	Floor Tile	Unquantified	SF	A	Throughout the building	O & M
A	Cove Base	Unquantified	LF	A	Throughout the building	O & M
B	Cove Base Mastic	Unquantified	LF	A	Throughout the building	O & M
C	Transite Soffit	Unquantified	SF	A	Throughout the building	O & M
D	Shock Joints on AHV	Unquantified	SF	A	Gymnasium and Cafeteria	O & M



**PERIODIC SURVEILLANCE  
REINSPECTION  
ADDITIONAL BULK SAMPLING  
INFORMATION**

## ASSESSMENTS FOR AHERA

1. Damaged or significantly damaged thermal systems insulation.
2. Damaged friable surfacing ACM.
3. Significantly damaged friable surfacing ACM.
4. Damaged or significantly damaged friable miscellaneous ACM.
5. ACBM with potential for damage.
6. ACBM with potential for significant damage.
7. Any remaining friable ACBM or friable suspected ACBM.

If a material is non-friable, it does not require an assessment rating under AHERA.

Due to the differences in what is required of the LEA for damaged material compared to significantly damaged material, Alliance has modified the assessment scale to the following:

- 1A. Significantly damaged thermal systems insulation.
- 1B. Damaged thermal systems insulation.
- 4A. Significantly damaged friable miscellaneous ACM.
- 4B. Damaged friable miscellaneous ACM.

*PERIODIC SURVEILLANCES*













# SURVEILLANCE INFORMATION

## PERIODIC SURVEILLANCE PLAN

### GREATER CLARK COUNTY SCHOOLS

The ACBM in this building will be periodically inspected to determine any change in the condition of the materials for as long as the material remain in the building, as required by the Asbestos Hazard Emergency Response Act (AHERA). This periodic surveillance shall be conducted on a semi-annual basis as required by law.

Records of each re-inspection will be maintained in this binder.

<u>DATE PLANNED</u>	<u>DATE COMPLETED</u>	<u>COMPLETED BY</u>
<u>October 2014</u>	October 22, 2014	
<u>April 2015</u>	April 22, 2015	
<u>October 2015</u>	October 20, 2016	
<u>April 2016</u>	RE-INSPECTION	
<u>October 2016</u>	November 3, 2016	
<u>April 2017</u>	April 13, 2017	
<u>October 2017</u>	October 18, 2017	
<u>April 2018</u>	May 2, 2018	
<u>October 2018</u>	November 13, 2018	
<u>April 2019</u>	RE-INSPECTION	
<u>October 2019</u>	January 14 2020	
<u>April 2020</u>	April 23, 2020	
<u>October 2020</u>		

# SURVEILLANCE INFORMATION

## PERIODIC SURVEILLANCE PLAN

### GREATER CLARK COUNTY SCHOOLS

The ACBM in this building will be periodically inspected to determine any change in the condition of the materials for as long as the material remain in the building, as required by the Asbestos Hazard Emergency Response Act (AHERA). This periodic surveillance shall be conducted on a semi-annual basis as required by law.

Records of each re-inspection will be maintained in this binder.

<u>April 2021</u>	_____	_____
<u>October 2021</u>	_____	_____
<u>April 2022</u>	RE-INSPECTION	_____
<u>October 2022</u>	_____	_____
<u>April 2023</u>	_____	_____
<u>October 2023</u>	_____	_____
<u>April 2024</u>	_____	_____
<u>October 2024</u>	_____	_____
<u>April 2025</u>	RE-INSPECTION	_____
<u>October 2025</u>	_____	_____
<u>April 2026</u>	_____	_____
<u>October 2026</u>	_____	_____

## SURVEILLANCE INFORMATION

### PERIODIC SURVEILLANCE PLAN SCHEDULE

#### GREATER CLARK COUNTY SCHOOLS

The ACBM in this building will be periodically inspected to determine any change in the condition of the materials for as long as the material remain in the building, as required by the Asbestos Hazard Emergency Response Act (AHERA). This periodic surveillance shall be conducted on a semi-annual basis as required by law.

Records of each re-inspection will be maintained in this binder.

<u>DATE PLANNED</u>	<u>DATE COMPLETED</u>	<u>COMPLETED BY</u>
<u>JUNE 2009</u>	<u>JUNE 2009</u>	<u>BILL OGLE</u>
<u>DECEMBER 2009</u>	<u>Dec 2009</u>	<u>Bill Ogle</u>
<u>JUNE 2010</u>	<u>Reinspection</u>	<u>Sandy Shadley</u>
<u>DECEMBER 2010</u>	<u>December 2010</u>	<u>Paul Krick</u>
<u>JUNE 2011</u>	<u>June 2011</u>	<u>Sandy Shadley</u>
<u>DECEMBER 2011</u>	<u>_____</u>	<u>_____</u>
<u>JUNE 2012</u>	<u>June 2012</u>	<u>Jeff Hechtin</u>
<u>DECEMBER 2012</u>	<u>October 2012</u>	<u>Jeff Hechtin</u>
<u>JUNE 2013</u>	<u>Reinspection</u>	<u>Jeff Hechtin</u>
<u>DECEMBER 2013</u>	<u>_____</u>	<u>_____</u>

## PERIODIC SURVEILLANCE PLAN

## GREATER CLARK COUNTY SCHOOLS

The ACBM in this building will be periodically inspected to determine any change in the condition of the materials for as long as the material remain in the building, as required by the Asbestos Hazard Emergency Response Act (AHERA). This periodic surveillance shall be conducted on a semi-annual basis as required by law.

Records of each reinspection will be maintained in this binder.

<u>DATE PLANNED</u>	<u>DATE COMPLETED</u>	<u>COMPLETED BY</u>
<u>JUNE 2003</u>	<u>June '03</u>	<u>C Sparks</u>
<u>DECEMBER 2003</u>	<u>Dec '03</u>	<u>C Sparks</u>
<u>JUNE 2004</u>	<u>REINSPECTION</u>	<u>C Sparks</u>
<u>DECEMBER 2004</u>	<u>Dec '04</u>	<u>C Sparks</u>
<u>JUNE 2005</u>	<u>July '05</u>	<u>J. Ogle</u>
<u>DECEMBER 2005</u>	<u>Jan 06</u>	<u>Boyle</u>
<u>JUNE 2006</u>	<u>June 06</u>	<u>C Amos</u>
<u>DECEMBER 2006</u>	<u>Dec 06</u>	<u>Boyle</u>
<u>JUNE 2007</u>	<u>July 2007</u> <u>REINSPECTION</u>	<u>Bill Ogle</u>
<u>DECEMBER 2007</u>	<u>December 2007</u>	<u>Bill Ogle</u>
<u>JUNE 2008</u>	<u>June 2008</u>	<u>Bill Ogle</u>
<u>DECEMBER 2008</u>	<u>December 2008</u>	<u>Bill Ogle</u>

PERIODIC SURVEILLANCE PLAN

## GREATER CLARK COUNTY SCHOOLS

## PARKWOOD ELEMENTARY SCHOOL

The ACBM in this building will be periodically inspected to determine any change in the condition of the materials for as long they remain in the building. This inspection will be conducted semi-annually.

The following table outlines the dates on which these inspections should take place in this school building.

PERIODIC SURVEILLANCE SCHEDULE

<u>DATE PLANNED</u>	<u>DATE COMPLETED</u>	<u>COMPLETED BY</u>
<u>DECEMBER 1995</u>	<u>12-95</u>	<u>Alliance</u>
<u>JUNE 1996</u>	<u>6-96</u>	<u>Alliance</u>
<u>DECEMBER 1996</u>	<u>12-96</u>	<u>Alliance</u>
<u>JUNE 1997</u>	<u>7-97</u>	<u>Alliance</u>
<u>DECEMBER 1997</u>	<u>1-98</u>	<u>Alliance</u>
<u>JUNE 1998</u>	<u>REINSPECTION</u>	<u>Alliance</u>
<u>DECEMBER 1998</u>	<u>12-98</u>	<u>Alliance</u>
<u>JUNE 1999</u>	<u>June '99</u>	<u>Alliance</u>
<u>DECEMBER 1999</u>	<u>Dec. '99</u>	<u>Alliance</u>
<u>JUNE 2000</u>	<u>June 2000</u>	<u>Alliance</u>
<u>DECEMBER 2000</u>	<u>Jan. '01</u>	<u>Pat Wilson</u>
<u>JUNE 2001</u>	<u>REINSPECTION</u>	<u>P. Wilson</u>
<u>DECEMBER 2001</u>	<u>Dec. '01</u>	<u>A. Kimbrough</u>
<u>JUNE 2002</u>	<u>June '02</u>	<u>R. Calveet</u>
<u>DECEMBER 2002</u>	<u>Dec. '02</u>	<u>C Sparks</u>



# Periodic Surveillance

**LEA Name** Greater Clark County School Corporation  
**Building Name** Parkwood Elementary School  
**Building Number** 19  
**HA ID** 01  
**HA Description** Fittings  
**HA Type** Thermal System Insulation (TSI)  
**HA Location** Above ceiling from boiler room to kitchen area. (halls, classrooms, storage room, restrooms) Behind refrigerator in custodial room.

**Quantity** Unquantified LF  
**Comments** This material was not in poor condition. It is seen above ceiling in the main hallway.  
**Asbestos** Known  
**Friable** No

**Original Inspection** 6/1/1992  
**Current Inspection** 4/23/2020

## Material Assessment

**Assessment Rating** 5 ACBM with potential for damage

## Damage Assessment and Potential for Damage

<b>Percent Damaged</b>	%	Good Condition
<b>Physical Contact</b>	<b>Vibration</b>	<b>Air</b>
Low/None	Low/None	Low/None

**Planned Response Action** O&M

**Inspector**



Michael J. Ardis

**State** IN

**Accreditation Number** 19A007304

# Periodic Surveillance

**LEA Name** Greater Clark County School Corporation  
**Building Name** Parkwood Elementary School  
**Building Number** 19  
**HA ID** 02-A  
**HA Description** 9"X9" tan floor tile (OLD)  
**HA Type** Miscellaneous Material  
**HA Location** Custodial Room & Classrooms

**Quantity** Unquantified SF  
**Comments** 9"X9" floor tile was removed and replaced by 12"X12" floor tile in the custodial closet.  
Most of this material is under carpet. This material shows normal wear, but was not in poor condition overall.

**Asbestos** Assumed  
**Friable** No

**Original Inspection** 6/1/1992  
**Current Inspection** 4/23/2020

## Material Assessment

**Assessment Rating** 5 ACBM with potential for damage

## Damage Assessment and Potential for Damage

**Percent Damaged** % Good Condition

<u>Physical Contact</u>	<u>Vibration</u>	<u>Air</u>
Low/None	Low/None	Low/None

**Planned Response Action** O&M

Inspector



Michael J. Ardis

**State IN**

**Accreditation Number 19A007304**

# Periodic Surveillance

**LEA Name** Greater Clark County School Corporation  
**Building Name** Parkwood Elementary School  
**Building Number** 19  
**HA ID** 02-B  
**HA Description** 12"X12" Floor tile (NEWER) Light Blue  
**HA Type** Miscellaneous Material  
**HA Location** Gym

**Quantity** Unquantified SF  
**Comments** This material was not in poor condition overall.  
**Asbestos** Assumed  
**Friable** No

**Original Inspection** 6/27/2011  
**Current Inspection** 4/23/2020

## Material Assessment

**Assessment Rating** 5 ACBM with potential for damage

## Damage Assessment and Potential for Damage

<b>Percent Damaged</b>	%	Good Condition	
<b>Physical Contact</b>		<b>Vibration</b>	<b>Air</b>
Low/None		Low/None	Low/None

**Planned Response Action** O&M

**Inspector**



Michael J. Ardis

**State** IN

**Accreditation Number** 19A007304

# Periodic Surveillance

**LEA Name** Greater Clark County School Corporation  
**Building Name** Parkwood Elementary School  
**Building Number** 19  
**HA ID** 02-C  
**HA Description** 12" X 12" Floor tile (NEWER) White  
**HA Type** Miscellaneous Material  
**HA Location** Cafeteria + custodial room

**Quantity** Unquantified SF  
**Comments** This material was not in poor condition overall.  
**Asbestos** Assumed  
**Friable** No

**Original Inspection** 6/27/2011  
**Current Inspection** 4/23/2020

## Material Assessment

**Assessment Rating** 5 ACBM with potential for damage

## Damage Assessment and Potential for Damage

<b>Percent Damaged</b>	%	Good Condition	
<b>Physical Contact</b>		<b>Vibration</b>	<b>Air</b>
Low/None		Low/None	Low/None

**Planned Response Action** O&M

**Inspector**



Michael J. Ardis

**State** IN

**Accreditation Number** 19A007304

# Periodic Surveillance

**LEA Name** Greater Clark County School Corporation  
**Building Name** Parkwood Elementary School  
**Building Number** 19  
**HA ID** 02-D  
**HA Description** 12" X 12" Floor tile (NEWER) Dark Blue  
**HA Type** Miscellaneous Material  
**HA Location** Cafeteria

**Quantity** Unquantified SF  
**Comments** This material was not in poor condition overall.  
**Asbestos** Assumed  
**Friable** No

**Original Inspection** 6/27/2011  
**Current Inspection** 4/23/2020

## Material Assessment

**Assessment Rating** 5 ACBM with potential for damage

## Damage Assessment and Potential for Damage

<b>Percent Damaged</b>	%	Good Condition
<b>Physical Contact</b>	Low/None	<b>Vibration</b> Low/None
		<b>Air</b> Low/None

**Planned Response Action** O&M

**Inspector**



Michael J. Ardis

**State** IN

**Accreditation Number** 19A007304

# Periodic Surveillance

**LEA Name** Greater Clark County School Corporation  
**Building Name** Parkwood Elementary School  
**Building Number** 19  
**HA ID** 02-E  
**HA Description** 12" X 12" Floor tile Light gray  
**HA Type** Miscellaneous Material  
**HA Location** Stage

**Quantity** Unquantified SF  
**Comments** This material was not in poor condition overall.  
**Asbestos** Assumed  
**Friable** No

**Original Inspection** 6/27/2011  
**Current Inspection** 4/23/2020

## Material Assessment

**Assessment Rating** 5 ACBM with potential for damage

## Damage Assessment and Potential for Damage

<b>Percent Damaged</b>	%	Good Condition	
<b>Physical Contact</b>		<b>Vibration</b>	<b>Air</b>
Low/None		Low/None	Low/None

**Planned Response Action** O&M

**Inspector**



Michael J. Ardis

**State** IN

**Accreditation Number** 19A007304

# Periodic Surveillance

**LEA Name** Greater Clark County School Corporation  
**Building Name** Parkwood Elementary School  
**Building Number** 19  
**HA ID** A  
**HA Description** Cove Base  
**HA Type** Miscellaneous Material  
**HA Location** Throughout building

**Quantity** Unquantified LF  
**Comments** There are minor signs of wear but this material was not in poor condition overall. Some has been replaced with new cove base.  
**Asbestos** Assumed  
**Friable** No  
**Original Inspection** 5/31/1995  
**Current Inspection** 4/23/2020

## Material Assessment

**Assessment Rating** 5 ACBM with potential for damage

## Damage Assessment and Potential for Damage

<b>Percent Damaged</b>	%	Good Condition
<b>Physical Contact</b>	<b>Vibration</b>	<b>Air</b>
Low/None	Low/None	Low/None

**Planned Response Action** O&M

**Inspector**



Michael J. Ardis

**State** IN

**Accreditation Number** 19A007304



# Periodic Surveillance

**LEA Name** Greater Clark County School Corporation  
**Building Name** Parkwood Elementary School  
**Building Number** 19  
**HA ID** B  
**HA Description** Cove Base Mastic  
**HA Type** Miscellaneous Material  
**HA Location** Throughout building

**Quantity** Approx 900 SF  
**Comments** Mastic was exposed to inspect in the library (By door) & gym and it was not in poor condition.  
**Asbestos** No  
**Friable** No  
**Original Inspection** 5/31/1995  
**Current Inspection** 4/23/2020

## Material Assessment

**Assessment Rating** 5 ACBM with potential for damage

## Damage Assessment and Potential for Damage

**Percent Damaged** % Good Condition

<u>Physical Contact</u>	<u>Vibration</u>	<u>Air</u>
Low/None	Low/None	Low/None

**Planned Response Action** O&M

**Inspector**



Michael J. Ardis

**State** IN

**Accreditation Number** 19A007304

# Periodic Surveillance

**LEA Name** Greater Clark County School Corporation  
**Building Name** Parkwood Elementary School  
**Building Number** 19  
**HA ID** C  
**HA Description** Transite Soffite  
**HA Type** Miscellaneous Material  
**HA Location** Outside building soffit

**Quantity** 2114 SF

**Comments** This material is not in poor condition with some minor cracking around the edges. The first panel by the entrance has been replaced with grey material (possibly plywood). The 5th one from the left has a long crack in it but is still in place.

**Asbestos** Assumed  
**Friable** No

**Original Inspection** 5/31/1995  
**Current Inspection** 4/23/2020

## Material Assessment

**Assessment Rating** 5 ACBM with potential for damage

## Damage Assessment and Potential for Damage

**Percent Damaged** % Good Condition

<u>Physical Contact</u>	<u>Vibration</u>	<u>Air</u>
Low/None	Low/None	Low/None

**Planned Response Action** O&M

Inspector



Michael J. Ardis

**State IN**

**Accreditation Number 19A007304**

# Periodic Surveillance

**LEA Name** Greater Clark County School Corporation  
**Building Name** Parkwood Elementary School  
**Building Number** 19  
**HA ID** D  
**HA Description** Green shock joints on AHU  
**HA Type** Miscellaneous Material  
**HA Location** Gymnasium and cafeteria

**Quantity** 0 SF  
**Comments** This material was not in poor condition. Four locations of material above gymnasium.  
This material was sampled by a licensed inspector and found to be a non-asbestos material by an accredited laboratory. Therefore, it is being removed from the management plan.

**Asbestos** No  
**Friable** No

**Original Inspection** 5/31/1995  
**Current Inspection** 4/23/2020

## Material Assessment

**Assessment Rating** 5 ACBM with potential for damage

## Damage Assessment and Potential for Damage

**Percent Damaged** % Good Condition

<b><u>Physical Contact</u></b>	<b><u>Vibration</u></b>	<b><u>Air</u></b>
Low/None	Low/None	Low/None

**Planned Response Action** O&M

**Inspector**



Michael J. Ardis

**State IN**

**Accreditation Number 19A007304**

# Periodic Surveillance

**LEA Name** Greater Clark County School Corporation  
**Building Name** Parkwood Elementary School  
**Building Number** 19  
**HA ID** 01  
**HA Description** Fittings  
**HA Type** Thermal System Insulation (TSI)  
**HA Location** Above ceiling from boiler room to kitchen area. (halls, classrooms, storage room, restrooms) Behind refrigerator in custodial room.

**Quantity** Unquantified LF  
**Comments** This material was not in poor condition. It is seen above ceiling in the main hallway.  
**Asbestos** Known  
**Friable** No

**Original Inspection** 6/1/1992  
**Current Inspection** 1/14/2020

## Material Assessment

**Assessment Rating** 5 ACBM with potential for damage

## Damage Assessment and Potential for Damage

<b>Percent Damaged</b>	%	Good Condition	
<b>Physical Contact</b>		<b>Vibration</b>	<b>Air</b>
Low/None		Low/None	Low/None

**Planned Response Action** O&M

**Inspector** 

Michael J. Ardis

**State** IN

**Accreditation Number** 19A007304

# Periodic Surveillance

**LEA Name** Greater Clark County School Corporation  
**Building Name** Parkwood Elementary School  
**Building Number** 19  
**HA ID** 02-A  
**HA Description** 9"X9" tan floor tile (OLD)  
**HA Type** Miscellaneous Material  
**HA Location** Custodial Room & Classrooms

**Quantity** Unquantified SF  
**Comments** 9"X9" floor tile was removed and replaced by 12"X12" floor tile in the custodial closet.  
Most of this material is under carpet. This material shows normal wear, but was not in poor condition overall.

**Asbestos** Assumed  
**Friable** No

**Original Inspection** 6/1/1992  
**Current Inspection** 1/14/2020

## Material Assessment

**Assessment Rating** 5 ACBM with potential for damage

## Damage Assessment and Potential for Damage

<b>Percent Damaged</b>	%	Good Condition	
<b>Physical Contact</b>		<b>Vibration</b>	<b>Air</b>
Low/None		Low/None	Low/None
<b>Planned Response Action</b>	O&M		

Inspector



Michael J. Ardis

**State IN**

**Accreditation Number 19A007304**



# Periodic Surveillance

**LEA Name** Greater Clark County School Corporation  
**Building Name** Parkwood Elementary School  
**Building Number** 19  
**HA ID** 02-B  
**HA Description** 12"X12" Floor tile (NEWER) Light Blue  
**HA Type** Miscellaneous Material  
**HA Location** Gym

**Quantity** Unquantified SF  
**Comments** This material was not in poor condition overall.  
**Asbestos** Assumed  
**Friable** No

**Original Inspection** 6/27/2011  
**Current Inspection** 1/14/2020

## Material Assessment

**Assessment Rating** 5 ACBM with potential for damage

## Damage Assessment and Potential for Damage

<b>Percent Damaged</b>	%	Good Condition
<b>Physical Contact</b>	<b>Vibration</b>	<b>Air</b>
Low/None	Low/None	Low/None

**Planned Response Action** O&M

**Inspector**



Michael J. Ardis

**State** IN

**Accreditation Number** 19A007304

# Periodic Surveillance

**LEA Name** Greater Clark County School Corporation  
**Building Name** Parkwood Elementary School  
**Building Number** 19  
**HA ID** 02-C  
**HA Description** 12" X 12" Floor tile (NEWER) White  
**HA Type** Miscellaneous Material  
**HA Location** Cafeteria + custodial room

**Quantity** Unquantified SF  
**Comments** This material was not in poor condition overall.  
**Asbestos** Assumed  
**Friable** No

**Original Inspection** 6/27/2011  
**Current Inspection** 1/14/2020

## Material Assessment

**Assessment Rating** 5 ACBM with potential for damage

## Damage Assessment and Potential for Damage

<b>Percent Damaged</b>	%	Good Condition	
<b>Physical Contact</b>		<b>Vibration</b>	<b>Air</b>
Low/None		Low/None	Low/None

**Planned Response Action** O&M

**Inspector**



Michael J. Ardis

**State** IN

**Accreditation Number** 19A007304

# Periodic Surveillance

**LEA Name** Greater Clark County School Corporation  
**Building Name** Parkwood Elementary School  
**Building Number** 19  
**HA ID** 02-D  
**HA Description** 12" X 12" Floor tile (NEWER) Dark Blue  
**HA Type** Miscellaneous Material  
**HA Location** Cafeteria

**Quantity** Unquantified SF  
**Comments** This material was not in poor condition overall.  
**Asbestos** Assumed  
**Friable** No

**Original Inspection** 6/27/2011  
**Current Inspection** 1/14/2020

## Material Assessment

**Assessment Rating** 5 ACBM with potential for damage

## Damage Assessment and Potential for Damage

<b>Percent Damaged</b>	%	Good Condition	
<b>Physical Contact</b>		<b>Vibration</b>	<b>Air</b>
Low/None		Low/None	Low/None

**Planned Response Action** O&M

**Inspector**



Michael J. Ardis

**State** IN

**Accreditation Number** 19A007304

# Periodic Surveillance

**LEA Name** Greater Clark County School Corporation  
**Building Name** Parkwood Elementary School  
**Building Number** 19  
**HA ID** 02-E  
**HA Description** 12" X 12" Floor tile Light gray  
**HA Type** Miscellaneous Material  
**HA Location** Stage

**Quantity** Unquantified SF  
**Comments** This material was not in poor condition overall.  
**Asbestos** Assumed  
**Friable** No

**Original Inspection** 6/27/2011  
**Current Inspection** 1/14/2020

## Material Assessment

**Assessment Rating** 5 ACBM with potential for damage

## Damage Assessment and Potential for Damage

<b>Percent Damaged</b>	%	Good Condition	
<b>Physical Contact</b>		<b>Vibration</b>	<b>Air</b>
Low/None		Low/None	Low/None

**Planned Response Action** O&M

**Inspector**



Michael J. Ardis

**State** IN

**Accreditation Number** 19A007304

# Periodic Surveillance

**LEA Name** Greater Clark County School Corporation  
**Building Name** Parkwood Elementary School  
**Building Number** 19  
**HA ID** A  
**HA Description** Cove Base  
**HA Type** Miscellaneous Material  
**HA Location** Throughout building

**Quantity** Unquantified LF

**Comments** There are minor signs of wear but this material was not in poor condition overall. Some has been replaced with new cove base.

**Asbestos** Assumed

**Friable** No

**Original Inspection** 5/31/1995  
**Current Inspection** 1/14/2020

## Material Assessment

**Assessment Rating** 5 ACBM with potential for damage

## Damage Assessment and Potential for Damage

<b>Percent Damaged</b>	%	Good Condition	
<b>Physical Contact</b>		<b>Vibration</b>	<b>Air</b>
Low/None		Low/None	Low/None

**Planned Response Action** O&M

**Inspector**



Michael J. Ardis

**State** IN

**Accreditation Number** 19A007304

# Periodic Surveillance

**LEA Name** Greater Clark County School Corporation  
**Building Name** Parkwood Elementary School  
**Building Number** 19  
**HA ID** B  
**HA Description** Cove Base Mastic  
**HA Type** Miscellaneous Material  
**HA Location** Throughout building

**Quantity** Approx 900 SF  
**Comments** Mastic was exposed to inspect in the library (By door) & gym and it was not in poor condition.  
**Asbestos** No  
**Friable** No  
**Original Inspection** 5/31/1995  
**Current Inspection** 1/14/2020

## Material Assessment

**Assessment Rating** 5 ACBM with potential for damage

## Damage Assessment and Potential for Damage

**Percent Damaged** % Good Condition

<u>Physical Contact</u>	<u>Vibration</u>	<u>Air</u>
Low/None	Low/None	Low/None

**Planned Response Action** O&M

**Inspector**



Michael J. Ardis

**State** IN

**Accreditation Number** 19A007304

# Periodic Surveillance

**LEA Name** Greater Clark County School Corporation  
**Building Name** Parkwood Elementary School  
**Building Number** 19  
**HA ID** C  
**HA Description** Transite Soffite  
**HA Type** Miscellaneous Material  
**HA Location** Outside building soffit

**Quantity** 2114 SF

**Comments** This material is not in poor condition with some minor cracking around the edges. The first panel by the entrance has been replaced with grey material (possibly plywood). The 5th one from the left has a long crack in it but is still in place.

**Asbestos** Assumed  
**Friable** No

**Original Inspection** 5/31/1995  
**Current Inspection** 1/14/2020

## Material Assessment

**Assessment Rating** 5 ACBM with potential for damage

## Damage Assessment and Potential for Damage

**Percent Damaged** % Good Condition

<u>Physical Contact</u>	<u>Vibration</u>	<u>Air</u>
Low/None	Low/None	Low/None

**Planned Response Action** O&M

Inspector



Michael J. Ardis

**State IN**

**Accreditation Number 19A007304**



# Periodic Surveillance

**LEA Name** Greater Clark County School Corporation  
**Building Name** Parkwood Elementary School  
**Building Number** 19  
**HA ID** D  
**HA Description** Green shock joints on AHU  
**HA Type** Miscellaneous Material  
**HA Location** Gymnasium and cafeteria

**Quantity** 0 SF  
**Comments** This material was not in poor condition. Four locations of material above gymnasium.  
This material was sampled by a licensed inspector and found to be a non-asbestos material by an accredited laboratory. Therefore, it is being removed from the management plan.

**Asbestos** No  
**Friable** No

**Original Inspection** 5/31/1995  
**Current Inspection** 1/14/2020

## Material Assessment

**Assessment Rating** 5 ACBM with potential for damage

## Damage Assessment and Potential for Damage

**Percent Damaged** % Good Condition

<b><u>Physical Contact</u></b>	<b><u>Vibration</u></b>	<b><u>Air</u></b>
Low/None	Low/None	Low/None

**Planned Response Action** O&M

**Inspector**



Michael J. Ardis

**State IN**

**Accreditation Number 19A007304**

# Periodic Surveillance

**LEA Name** Greater Clark County School Corporation  
**Building Name** Parkwood Elementary School  
**Building Number** 19  
**HA ID** 01  
**HA Description** Fittings  
**HA Type** Thermal System Insulation (TSI)  
**HA Location** Above ceiling from boiler room to kitchen area. (halls, classrooms, storage room, restrooms) Behind refrigerator in custodial room.

**Quantity** Unquantified LF  
**Comments** This material was not in poor condition. It is seen above ceiling in the main hallway.  
**Asbestos** Known  
**Friable** No

**Original Inspection** 6/1/1992  
**Current Inspection** 11/13/2018

## Material Assessment

**Assessment Rating** 5 ACBM with potential for damage

## Damage Assessment and Potential for Damage

<b><u>Percent Damaged</u></b>	%	Good Condition	
<b><u>Physical Contact</u></b>		<b><u>Vibration</u></b>	<b><u>Air</u></b>
Low/None		Low/None	Low/None

**Planned Response Action** O&M

**Inspector**



Benjamin S. Hood

**State** IN

**Accreditation Number** 19A001039

# Periodic Surveillance

**LEA Name** Greater Clark County School Corporation  
**Building Name** Parkwood Elementary School  
**Building Number** 19  
**HA ID** 02-A  
**HA Description** 9"X9" tan floor tile (OLD)  
**HA Type** Miscellaneous Material  
**HA Location** Custodial Room & Classrooms

**Quantity** Unquantified SF  
**Comments** 9"X9" floor tile was removed and replaced by 12"X12" floor tile in the custodial closet.  
Most of this material is under carpet. This material shows normal wear, but was not in poor condition overall.

**Asbestos** Assumed  
**Friable** No

**Original Inspection** 6/1/1992  
**Current Inspection** 11/13/2018

## Material Assessment


**Assessment Rating** 5 ACBM with potential for damage

## Damage Assessment and Potential for Damage

<b>Percent Damaged</b>	%	Good Condition	
<b>Physical Contact</b>		<b>Vibration</b>	<b>Air</b>
Low/None		Low/None	Low/None

**Planned Response Action** O&M

**Inspector**



Benjamin S. Hood

**State** IN

**Accreditation Number** 19A001039

# Periodic Surveillance

**LEA Name** Greater Clark County School Corporation  
**Building Name** Parkwood Elementary School  
**Building Number** 19  
**HA ID** 02-B  
**HA Description** 12"X12" Floor tile (NEWER) Light Blue  
**HA Type** Miscellaneous Material  
**HA Location** Gym

**Quantity** Unquantified SF  
**Comments** This material was not in poor condition overall.  
**Asbestos** Assumed  
**Friable** No

**Original Inspection** 6/27/2011  
**Current Inspection** 11/13/2018

## Material Assessment

**Assessment Rating** 5 ACBM with potential for damage

## Damage Assessment and Potential for Damage

<b>Percent Damaged</b>	%	Good Condition	
<b>Physical Contact</b>		<b>Vibration</b>	<b>Air</b>
Low/None		Low/None	Low/None

**Planned Response Action** O&M

**Inspector**



Benjamin S. Hood

**State** IN

**Accreditation Number** 19A001039

# Periodic Surveillance

**LEA Name** Greater Clark County School Corporation  
**Building Name** Parkwood Elementary School  
**Building Number** 19  
**HA ID** 02-C  
**HA Description** 12" X 12" Floor tile (NEWER) White  
**HA Type** Miscellaneous Material  
**HA Location** Cafeteria + custodial room

**Quantity** Unquantified SF  
**Comments** This material was not in poor condition overall.  
**Asbestos** Assumed  
**Friable** No

**Original Inspection** 6/27/2011  
**Current Inspection** 11/13/2018

## Material Assessment

**Assessment Rating** 5 ACBM with potential for damage

## Damage Assessment and Potential for Damage

<b>Percent Damaged</b>	%	Good Condition	
<b>Physical Contact</b>		<b>Vibration</b>	<b>Air</b>
Low/None		Low/None	Low/None

**Planned Response Action** O&M

**Inspector**



Benjamin S. Hood

**State** IN

**Accreditation Number** 19A001039

# Periodic Surveillance

**LEA Name** Greater Clark County School Corporation  
**Building Name** Parkwood Elementary School  
**Building Number** 19  
**HA ID** 02-D  
**HA Description** 12" X 12" Floor tile (NEWER) Dark Blue  
**HA Type** Miscellaneous Material  
**HA Location** Cafeteria

**Quantity** Unquantified SF  
**Comments** This material was not in poor condition overall.  
**Asbestos** Assumed  
**Friable** No

**Original Inspection** 6/27/2011  
**Current Inspection** 11/13/2018

## Material Assessment


**Assessment Rating** 5 ACBM with potential for damage

## Damage Assessment and Potential for Damage

<b>Percent Damaged</b>	%	Good Condition	
<b>Physical Contact</b>		<b>Vibration</b>	<b>Air</b>
Low/None		Low/None	Low/None

**Planned Response Action** O&M

**Inspector**



Benjamin S. Hood

**State** IN

**Accreditation Number** 19A001039



# Periodic Surveillance

**LEA Name** Greater Clark County School Corporation  
**Building Name** Parkwood Elementary School  
**Building Number** 19  
**HA ID** 02-E  
**HA Description** 12" X 12" Floor tile Light gray  
**HA Type** Miscellaneous Material  
**HA Location** Stage

**Quantity** Unquantified SF  
**Comments** This material was not in poor condition overall.  
**Asbestos** Assumed  
**Friable** No

**Original Inspection** 6/27/2011  
**Current Inspection** 11/13/2018

## Material Assessment

**Assessment Rating** 5 ACBM with potential for damage

## Damage Assessment and Potential for Damage

<b>Percent Damaged</b>	%	Good Condition	
<b>Physical Contact</b>		<b>Vibration</b>	<b>Air</b>
Low/None		Low/None	Low/None

**Planned Response Action** O&M

**Inspector**



Benjamin S. Hood

**State** IN

**Accreditation Number** 19A001039

# Periodic Surveillance

**LEA Name** Greater Clark County School Corporation  
**Building Name** Parkwood Elementary School  
**Building Number** 19  
**HA ID** A  
**HA Description** Cove Base  
**HA Type** Miscellaneous Material  
**HA Location** Throughout building

**Quantity** Unquantified LF

**Comments** There are minor signs of wear but this material was not in poor condition overall. Some has been replaced with new cove base.

**Asbestos** Assumed

**Friable** No

**Original Inspection** 5/31/1995  
**Current Inspection** 11/13/2018

## Material Assessment


**Assessment Rating** 5 ACBM with potential for damage

## Damage Assessment and Potential for Damage

**Percent Damaged** % Good Condition

<u>Physical Contact</u>	<u>Vibration</u>	<u>Air</u>
Low/None	Low/None	Low/None

**Planned Response Action** O&M

**Inspector**   
\_\_\_\_\_  
Benjamin S. Hood

**State** IN  
**Accreditation Number** 19A001039

# Periodic Surveillance

**LEA Name** Greater Clark County School Corporation  
**Building Name** Parkwood Elementary School  
**Building Number** 19  
**HA ID** B  
**HA Description** Cove Base Mastic  
**HA Type** Miscellaneous Material  
**HA Location** Throughout building

**Quantity** Approx 900 SF  
**Comments** Mastic was exposed to inspect in the library (By door) & gym and it was not in poor condition.  
**Asbestos** No  
**Friable** No  
**Original Inspection** 5/31/1995  
**Current Inspection** 11/13/2018

## Material Assessment


**Assessment Rating** 5 ACBM with potential for damage

## Damage Assessment and Potential for Damage

**Percent Damaged** % Good Condition

<u>Physical Contact</u>	<u>Vibration</u>	<u>Air</u>
Low/None	Low/None	Low/None

**Planned Response Action** O&M

**Inspector**   
\_\_\_\_\_  
Benjamin S. Hood

**State** IN  
**Accreditation Number** 19A001039

# Periodic Surveillance

**LEA Name** Greater Clark County School Corporation  
**Building Name** Parkwood Elementary School  
**Building Number** 19  
**HA ID** C  
**HA Description** Transite Soffite  
**HA Type** Miscellaneous Material  
**HA Location** Outside building soffit

**Quantity** 2114 SF

**Comments** This material is not in poor condition with some minor cracking around the edges. The first panel by the entrance has been replaced with grey material (possibly plywood). The 5th one from the left has a long crack in it but is still in place.

**Asbestos** Assumed  
**Friable** No

**Original Inspection** 5/31/1995  
**Current Inspection** 11/13/2018


## Material Assessment

**Assessment Rating** 5 ACBM with potential for damage

## Damage Assessment and Potential for Damage

<b>Percent Damaged</b>	%	Good Condition	
<b>Physical Contact</b>		<b>Vibration</b>	<b>Air</b>
Low/None		Low/None	Low/None
<b>Planned Response Action</b>		O&M	

**Inspector**



Benjamin S. Hood

**State** IN

**Accreditation Number** 19A001039

# Periodic Surveillance

**LEA Name** Greater Clark County School Corporation  
**Building Name** Parkwood Elementary School  
**Building Number** 19  
**HA ID** D  
**HA Description** Green shock joints on AHU  
**HA Type** Miscellaneous Material  
**HA Location** Gymnasium and cafeteria

**Quantity** 0 SF

**Comments** This material was not in poor condition. Four locations of material above gymnasium.  
This material was sampled by a licensed inspector and found to be a non-asbestos material by an accredited laboratory. Therefore, it is being removed from the management plan.

**Asbestos** No  
**Friable** No

**Original Inspection** 5/31/1995  
**Current Inspection** 11/13/2018

## Material Assessment


**Assessment Rating** 5 ACBM with potential for damage

## Damage Assessment and Potential for Damage

<b><u>Percent Damaged</u></b>	%	Good Condition	
<b><u>Physical Contact</u></b>		<b><u>Vibration</u></b>	<b><u>Air</u></b>
Low/None		Low/None	Low/None

**Planned Response Action** O&M

**Inspector**



Benjamin S. Hood

**State** IN

**Accreditation Number** 19A001039

# Periodic Surveillance

**LEA Name** Greater Clark County School Corporation  
**Building Name** Parkwood Elementary School  
**Building Number** 19  
**HA ID** 01  
**HA Description** Fittings  
**HA Type** Thermal System Insulation (TSI)  
**HA Location** Above ceiling from boiler room to kitchen area. (halls, classrooms, storage room, restrooms) Behind refrigerator in custodial room.

**Quantity** Unquantified LF  
**Comments** This material was not in poor condition. It is seen above ceiling in the main hallway.  
**Asbestos** Known  
**Friable** No

**Original Inspection** 6/1/1992  
**Current Inspection** 5/2/2018

## Material Assessment

**Assessment Rating** 5 ACBM with potential for damage

## Damage Assessment and Potential for Damage

<b>Percent Damaged</b>	%	Good Condition
<b>Physical Contact</b>	Low/None	<b>Vibration</b> Low/None
		<b>Air</b> Low/None

**Planned Response Action** O&M

**Inspector**



Benjamin S. Hood

**State** IN

**Accreditation Number** 19A001039



# Periodic Surveillance

**LEA Name** Greater Clark County School Corporation  
**Building Name** Parkwood Elementary School  
**Building Number** 19  
**HA ID** 02-A  
**HA Description** 9"X9" tan floor tile (OLD)  
**HA Type** Miscellaneous Material  
**HA Location** Custodial Room & Classrooms

**Quantity** Unquantified SF  
**Comments** 9"X9" floor tile was removed and replaced by 12"X12" floor tile in the custodial closet.  
Most of this material is under carpet. This material shows normal wear, but was not in poor condition overall.

**Asbestos** Assumed  
**Friable** No

**Original Inspection** 6/1/1992  
**Current Inspection** 5/2/2018

## Material Assessment

**Assessment Rating** 5 ACBM with potential for damage

## Damage Assessment and Potential for Damage

**Percent Damaged** % Good Condition

<u>Physical Contact</u>	<u>Vibration</u>	<u>Air</u>
Low/None	Low/None	Low/None

**Planned Response Action** O&M

**Inspector**



Benjamin S. Hood

**State IN**

**Accreditation Number 19A001039**

# Periodic Surveillance

**LEA Name** Greater Clark County School Corporation  
**Building Name** Parkwood Elementary School  
**Building Number** 19  
**HA ID** 02-B  
**HA Description** 12"X12" Floor tile (NEWER) Light Blue  
**HA Type** Miscellaneous Material  
**HA Location** Gym

**Quantity** Unquantified SF  
**Comments** This material was not in poor condition overall.  
**Asbestos** Assumed  
**Friable** No

**Original Inspection** 6/27/2011  
**Current Inspection** 5/2/2018

## Material Assessment

**Assessment Rating** 5 ACBM with potential for damage

## Damage Assessment and Potential for Damage

**Percent Damaged** % Good Condition

<b>Physical Contact</b>	<b>Vibration</b>	<b>Air</b>
Low/None	Low/None	Low/None

**Planned Response Action** O&M

**Inspector**



Benjamin S. Hood

**State** IN

**Accreditation Number** 19A001039

# Periodic Surveillance

**LEA Name** Greater Clark County School Corporation  
**Building Name** Parkwood Elementary School  
**Building Number** 19  
**HA ID** 02-C  
**HA Description** 12" X 12" Floor tile (NEWER) White  
**HA Type** Miscellaneous Material  
**HA Location** Cafeteria + custodial room

**Quantity** Unquantified SF  
**Comments** This material was not in poor condition overall.  
**Asbestos** Assumed  
**Friable** No

**Original Inspection** 6/27/2011  
**Current Inspection** 5/2/2018

## Material Assessment

**Assessment Rating** 5 ACBM with potential for damage

## Damage Assessment and Potential for Damage

<b><u>Percent Damaged</u></b>	%	Good Condition	
<b><u>Physical Contact</u></b>		<b><u>Vibration</u></b>	<b><u>Air</u></b>
Low/None		Low/None	Low/None

**Planned Response Action** O&M

**Inspector**



Benjamin S. Hood

**State** IN

**Accreditation Number** 19A001039

# Periodic Surveillance

**LEA Name** Greater Clark County School Corporation  
**Building Name** Parkwood Elementary School  
**Building Number** 19  
**HA ID** 02-D  
**HA Description** 12" X 12" Floor tile (NEWER) Dark Blue  
**HA Type** Miscellaneous Material  
**HA Location** Cafeteria

**Quantity** Unquantified SF  
**Comments** This material was not in poor condition overall.  
**Asbestos** Assumed  
**Friable** No

**Original Inspection** 6/27/2011  
**Current Inspection** 5/2/2018

## Material Assessment


**Assessment Rating** 5 ACBM with potential for damage

## Damage Assessment and Potential for Damage

<b>Percent Damaged</b>	%	Good Condition	
<b>Physical Contact</b>		<b>Vibration</b>	<b>Air</b>
Low/None		Low/None	Low/None

**Planned Response Action** O&M

**Inspector**



Benjamin S. Hood

**State** IN

**Accreditation Number** 19A001039

# Periodic Surveillance

**LEA Name** Greater Clark County School Corporation  
**Building Name** Parkwood Elementary School  
**Building Number** 19  
**HA ID** 02-E  
**HA Description** 12" X 12" Floor tile Light gray  
**HA Type** Miscellaneous Material  
**HA Location** Stage

**Quantity** Unquantified SF  
**Comments** This material was not in poor condition overall.  
**Asbestos** Assumed  
**Friable** No

**Original Inspection** 6/27/2011  
**Current Inspection** 5/2/2018


## Material Assessment

**Assessment Rating** 5 ACBM with potential for damage

## Damage Assessment and Potential for Damage

<b>Percent Damaged</b>	%	Good Condition	
<b>Physical Contact</b>		<b>Vibration</b>	<b>Air</b>
Low/None		Low/None	Low/None

**Planned Response Action** O&M

**Inspector**   
\_\_\_\_\_  
Benjamin S. Hood

**State** IN

**Accreditation Number** 19A001039

# Periodic Surveillance

**LEA Name** Greater Clark County School Corporation  
**Building Name** Parkwood Elementary School  
**Building Number** 19  
**HA ID** A  
**HA Description** Cove Base  
**HA Type** Miscellaneous Material  
**HA Location** Throughout building

**Quantity** Unquantified LF

**Comments** There are minor signs of wear but this material was not in poor condition overall. Some has been replaced with new cove base.

**Asbestos** Assumed  
**Friable** No

**Original Inspection** 5/31/1995  
**Current Inspection** 5/2/2018

## Material Assessment


**Assessment Rating** 5 ACBM with potential for damage

## Damage Assessment and Potential for Damage

**Percent Damaged** % Good Condition

<u>Physical Contact</u>	<u>Vibration</u>	<u>Air</u>
Low/None	Low/None	Low/None

**Planned Response Action** O&M

**Inspector**   
\_\_\_\_\_  
Benjamin S. Hood

**State** IN  
**Accreditation Number** 19A001039

# Periodic Surveillance

**LEA Name** Greater Clark County School Corporation  
**Building Name** Parkwood Elementary School  
**Building Number** 19  
**HA ID** B  
**HA Description** Cove Base Mastic  
**HA Type** Miscellaneous Material  
**HA Location** Throughout building

**Quantity** Approx 900 SF  
**Comments** Mastic was exposed to inspect in the library (By door) & gym and it was not in poor condition.  
**Asbestos** No  
**Friable** No  
**Original Inspection** 5/31/1995  
**Current Inspection** 5/2/2018

## Material Assessment


**Assessment Rating** 5 ACBM with potential for damage

## Damage Assessment and Potential for Damage

**Percent Damaged** % Good Condition

<b>Physical Contact</b>	<b>Vibration</b>	<b>Air</b>
Low/None	Low/None	Low/None

**Planned Response Action** O&M

**Inspector**   
\_\_\_\_\_  
Benjamin S. Hood

**State** IN  
**Accreditation Number** 19A001039



# Periodic Surveillance

**LEA Name** Greater Clark County School Corporation  
**Building Name** Parkwood Elementary School  
**Building Number** 19  
**HA ID** C  
**HA Description** Transite Soffite  
**HA Type** Miscellaneous Material  
**HA Location** Outside building soffit

**Quantity** 2114 SF

**Comments** This material is not in poor condition with some minor cracking around the edges. The first panel by the entrance has been replaced with grey material (possibly plywood). The 5th one from the left has a long crack in it but is still in place.

**Asbestos** Assumed  
**Friable** No

**Original Inspection** 5/31/1995  
**Current Inspection** 5/2/2018

## Material Assessment

**Assessment Rating** 5 ACBM with potential for damage

## Damage Assessment and Potential for Damage

**Percent Damaged** % Good Condition

<u>Physical Contact</u>	<u>Vibration</u>	<u>Air</u>
Low/None	Low/None	Low/None

**Planned Response Action** O&M

**Inspector**



Benjamin S. Hood

**State IN**

**Accreditation Number 19A001039**

# Periodic Surveillance

**LEA Name** Greater Clark County School Corporation  
**Building Name** Parkwood Elementary School  
**Building Number** 19  
**HA ID** D  
**HA Description** Green shock joints on AHU  
**HA Type** Miscellaneous Material  
**HA Location** Gymnasium and cafeteria

**Quantity** 0 SF  
**Comments** This material was not in poor condition. Four locations of material above gymnasium.  
This material was sampled by a licensed inspector and found to be a non-asbestos material by an accredited laboratory. Therefore, it is being removed from the management plan.

**Asbestos** No  
**Friable** No

**Original Inspection** 5/31/1995  
**Current Inspection** 5/2/2018

## Material Assessment

**Assessment Rating** 5 ACBM with potential for damage

## Damage Assessment and Potential for Damage

**Percent Damaged** % Good Condition

<b><u>Physical Contact</u></b>	<b><u>Vibration</u></b>	<b><u>Air</u></b>
Low/None	Low/None	Low/None

**Planned Response Action** O&M

**Inspector**



Benjamin S. Hood

**State IN**

**Accreditation Number 19A001039**

# Periodic Surveillance

**LEA Name** Greater Clark County School Corporation  
**Building Name** Parkwood Elementary School  
**Building Number** 19  
**HA ID** 01  
**HA Description** Fittings  
**HA Type** Thermal System Insulation (TSI)  
**HA Location** Above ceiling from boiler room to kitchen area. (halls, classrooms, storage room, restrooms) Behind refrigerator in custodial room.

**Quantity** Unquantified LF  
**Comments** This material was not in poor condition. It is seen above ceiling in the main hallway.  
**Asbestos** Known  
**Friable** No

**Original Inspection** 6/1/1992  
**Current Inspection** 10/18/2017

## Material Assessment

**Assessment Rating** 5 ACBM with potential for damage

## Damage Assessment and Potential for Damage

<b>Percent Damaged</b>	%	Good Condition	
<b>Physical Contact</b>		<b>Vibration</b>	<b>Air</b>
Low/None		Low/None	Low/None

**Planned Response Action** O&M



**Inspector** \_\_\_\_\_  
Dustin Hawkins

**State** IN

**Accreditation Number** 19A007194

# Periodic Surveillance

**LEA Name** Greater Clark County School Corporation  
**Building Name** Parkwood Elementary School  
**Building Number** 19  
**HA ID** 02-A  
**HA Description** 9"X9" tan floor tile (OLD)  
**HA Type** Miscellaneous Material  
**HA Location** Custodial Room & Classrooms

**Quantity** Unquantified SF  
**Comments** 9"X9" floor tile was removed and replaced by 12"X12" floor tile in the custodial closet.  
Most of this material is under carpet. This material shows normal wear, but was not in poor condition overall.

**Asbestos** Assumed  
**Friable** No

**Original Inspection** 6/1/1992  
**Current Inspection** 10/18/2017

## Material Assessment

**Assessment Rating** 5 ACBM with potential for damage

## Damage Assessment and Potential for Damage

**Percent Damaged** % Good Condition

<u>Physical Contact</u>	<u>Vibration</u>	<u>Air</u>
Low/None	Low/None	Low/None

**Planned Response Action** O&M



**Inspector** \_\_\_\_\_  
Dustin Hawkins

**State IN**

**Accreditation Number 19A007194**

# Periodic Surveillance

**LEA Name** Greater Clark County School Corporation  
**Building Name** Parkwood Elementary School  
**Building Number** 19  
**HA ID** 02-B  
**HA Description** 12"X12" Floor tile (NEWER) Light Blue  
**HA Type** Miscellaneous Material  
**HA Location** Gym

**Quantity** Unquantified SF  
**Comments** This material was not in poor condition overall.  
**Asbestos** Assumed  
**Friable** No

**Original Inspection** 6/27/2011  
**Current Inspection** 10/18/2017

## Material Assessment

**Assessment Rating** 5 ACBM with potential for damage

## Damage Assessment and Potential for Damage

<b>Percent Damaged</b>	%	Good Condition	
<b>Physical Contact</b>		<b>Vibration</b>	<b>Air</b>
Low/None		Low/None	Low/None

**Planned Response Action** O&M



**Inspector**

\_\_\_\_\_  
Dustin Hawkins

**State** IN

**Accreditation Number** 19A007194



# Periodic Surveillance

**LEA Name** Greater Clark County School Corporation  
**Building Name** Parkwood Elementary School  
**Building Number** 19  
**HA ID** 02-C  
**HA Description** 12" X 12" Floor tile (NEWER) White  
**HA Type** Miscellaneous Material  
**HA Location** Cafeteria + custodial room

**Quantity** Unquantified SF  
**Comments** This material was not in poor condition overall.  
**Asbestos** Assumed  
**Friable** No

**Original Inspection** 6/27/2011  
**Current Inspection** 10/18/2017

## Material Assessment

**Assessment Rating** 5 ACBM with potential for damage

## Damage Assessment and Potential for Damage

<b>Percent Damaged</b>	%	Good Condition	
<b>Physical Contact</b>		<b>Vibration</b>	<b>Air</b>
Low/None		Low/None	Low/None

**Planned Response Action** O&M



**Inspector** \_\_\_\_\_  
Dustin Hawkins

**State** IN  
**Accreditation Number** 19A007194

# Periodic Surveillance

**LEA Name** Greater Clark County School Corporation  
**Building Name** Parkwood Elementary School  
**Building Number** 19  
**HA ID** 02-D  
**HA Description** 12" X 12" Floor tile (NEWER) Dark Blue  
**HA Type** Miscellaneous Material  
**HA Location** Cafeteria

**Quantity** Unquantified SF  
**Comments** This material was not in poor condition overall.  
**Asbestos** Assumed  
**Friable** No

**Original Inspection** 6/27/2011  
**Current Inspection** 10/18/2017

## Material Assessment

**Assessment Rating** 5 ACBM with potential for damage

## Damage Assessment and Potential for Damage

<b>Percent Damaged</b>	%	Good Condition	
<b>Physical Contact</b>		<b>Vibration</b>	<b>Air</b>
Low/None		Low/None	Low/None

**Planned Response Action** O&M



**Inspector** \_\_\_\_\_  
Dustin Hawkins

**State** IN  
**Accreditation Number** 19A007194

# Periodic Surveillance

**LEA Name** Greater Clark County School Corporation  
**Building Name** Parkwood Elementary School  
**Building Number** 19  
**HA ID** 02-E  
**HA Description** 12" X 12" Floor tile Light gray  
**HA Type** Miscellaneous Material  
**HA Location** Stage

**Quantity** Unquantified SF  
**Comments** This material was not in poor condition overall.  
**Asbestos** Assumed  
**Friable** No

**Original Inspection** 6/27/2011  
**Current Inspection** 10/18/2017

## Material Assessment

**Assessment Rating** 5 ACBM with potential for damage

## Damage Assessment and Potential for Damage

<b>Percent Damaged</b>	%	Good Condition	
<b>Physical Contact</b>		<b>Vibration</b>	<b>Air</b>
Low/None		Low/None	Low/None

**Planned Response Action** O&M



**Inspector**

\_\_\_\_\_  
Dustin Hawkins

**State** IN

**Accreditation Number** 19A007194

# Periodic Surveillance

**LEA Name** Greater Clark County School Corporation  
**Building Name** Parkwood Elementary School  
**Building Number** 19  
**HA ID** A  
**HA Description** Cove Base  
**HA Type** Miscellaneous Material  
**HA Location** Throughout building

**Quantity** Unquantified LF  
**Comments** There are minor signs of wear but this material was not in poor condition overall. Some has been replaced with new cove base.  
**Asbestos** Assumed  
**Friable** No  
**Original Inspection** 5/31/1995  
**Current Inspection** 10/18/2017

## Material Assessment

**Assessment Rating** 5 ACBM with potential for damage

## Damage Assessment and Potential for Damage

**Percent Damaged** % Good Condition

<u>Physical Contact</u>	<u>Vibration</u>	<u>Air</u>
Low/None	Low/None	Low/None

**Planned Response Action** O&M



**Inspector** \_\_\_\_\_  
Dustin Hawkins

**State** IN

**Accreditation Number** 19A007194

# Periodic Surveillance

**LEA Name** Greater Clark County School Corporation  
**Building Name** Parkwood Elementary School  
**Building Number** 19  
**HA ID** B  
**HA Description** Cove Base Mastic  
**HA Type** Miscellaneous Material  
**HA Location** Throughout building

**Quantity** Approx 900 SF  
**Comments** Mastic was exposed to inspect in the library (By door) & gym and it was not in poor condition.  
**Asbestos** No  
**Friable** No  
**Original Inspection** 5/31/1995  
**Current Inspection** 10/18/2017

## Material Assessment

**Assessment Rating** 5 ACBM with potential for damage

## Damage Assessment and Potential for Damage

**Percent Damaged** % Good Condition

<b><u>Physical Contact</u></b>	<b><u>Vibration</u></b>	<b><u>Air</u></b>
Low/None	Low/None	Low/None

**Planned Response Action** O&M

**Inspector**



Dustin Hawkins

**State** IN

**Accreditation Number** 19A007194

# Periodic Surveillance

**LEA Name** Greater Clark County School Corporation  
**Building Name** Parkwood Elementary School  
**Building Number** 19  
**HA ID** C  
**HA Description** Transite Soffite  
**HA Type** Miscellaneous Material  
**HA Location** Outside building soffit

**Quantity** 2114 SF

**Comments** This material is not in poor condition with some minor cracking around the edges. The first panel by the entrance has been replaced with grey material (possibly plywood). The 5th one from the left has a long crack in it but is still in place.

**Asbestos** Assumed  
**Friable** No

**Original Inspection** 5/31/1995  
**Current Inspection** 10/18/2017

## Material Assessment

**Assessment Rating** 5 ACBM with potential for damage

## Damage Assessment and Potential for Damage

**Percent Damaged** % Good Condition

<u>Physical Contact</u>	<u>Vibration</u>	<u>Air</u>
Low/None	Low/None	Low/None

**Planned Response Action** O&M



**Inspector** \_\_\_\_\_  
Dustin Hawkins

**State IN**

**Accreditation Number 19A007194**

# Periodic Surveillance

**LEA Name** Greater Clark County School Corporation  
**Building Name** Parkwood Elementary School  
**Building Number** 19  
**HA ID** D  
**HA Description** Green shock joints on AHU  
**HA Type** Miscellaneous Material  
**HA Location** Gymnasium and cafeteria

**Quantity** 0 SF  
**Comments** This material was not in poor condition. Four locations of material above gymnasium.  
This material was sampled by a licensed inspector and found to be a non-asbestos material by an accredited laboratory. Therefore, it is being removed from the management plan.

**Asbestos** No  
**Friable** No

**Original Inspection** 5/31/1995  
**Current Inspection** 10/18/2017

## Material Assessment

**Assessment Rating** 5 ACBM with potential for damage

## Damage Assessment and Potential for Damage

<b><u>Percent Damaged</u></b>	%	Good Condition	
<b><u>Physical Contact</u></b>		<b><u>Vibration</u></b>	<b><u>Air</u></b>
Low/None		Low/None	Low/None

**Planned Response Action** O&M



**Inspector** \_\_\_\_\_  
Dustin Hawkins



**State IN**

**Accreditation Number 19A007194**

# Periodic Surveillance

**LEA Name** Greater Clark County School Corporation  
**Building Name** Parkwood Elementary School  
**Building Number** 19  
**HA ID** D  
**HA Description** Green shock joints on AHU  
**HA Type** Miscellaneous Material  
**HA Location** Gymnasium and cafeteria

**Quantity** 0 SF

**Comments** This material was not in poor condition. Four locations of material above gymnasium.  
This material was sampled by a licensed inspector and found to be a non-asbestos material by an accredited laboratory. Therefore, it is being removed from the management plan.

**Asbestos** No  
**Friable** No

**Original Inspection** 5/31/1995  
**Current Inspection** 4/13/2017

## Material Assessment


**Assessment Rating** 5 ACBM with potential for damage

## Damage Assessment and Potential for Damage

<b><u>Percent Damaged</u></b>	%	Good Condition	
<b><u>Physical Contact</u></b>		<b><u>Vibration</u></b>	<b><u>Air</u></b>
Low/None		Low/None	Low/None

**Planned Response Action** O&M

**Inspector**

  
\_\_\_\_\_  
Jamie Hosier

**State** Indiana

**Accreditation Number** 19A007179

# Periodic Surveillance

**LEA Name** Greater Clark County School Corporation  
**Building Name** Parkwood Elementary School  
**Building Number** 19  
**HA ID** 01  
**HA Description** Fittings  
**HA Type** Thermal System Insulation (TSI)  
**HA Location** Above ceiling from boiler room to kitchen area. (halls, classrooms, storage room, restrooms) Behind refrigerator in custodial room.

**Quantity** Unquantified LF  
**Comments** This material was not in poor condition. It is seen above ceiling in the main hallway.  
**Asbestos** Known  
**Friable** No

**Original Inspection** 6/1/1992  
**Current Inspection** 4/13/2017

## Material Assessment

**Assessment Rating** 5 ACBM with potential for damage

## Damage Assessment and Potential for Damage

**Percent Damaged** % Good Condition

<u>Physical Contact</u>	<u>Vibration</u>	<u>Air</u>
Low/None	Low/None	Low/None

**Planned Response Action** O&M

**Inspector**



Jamie Hosier

**State** Indiana

**Accreditation Number** 19A007179

# Periodic Surveillance

**LEA Name** Greater Clark County School Corporation  
**Building Name** Parkwood Elementary School  
**Building Number** 19  
**HA ID** 02-A  
**HA Description** 9"X9" tan floor tile (OLD)  
**HA Type** Miscellaneous Material  
**HA Location** Custodial Room & Classrooms

**Quantity** Unquantified SF  
**Comments** 9"X9" floor tile was removed and replaced by 12"X12" floor tile in the custodial closet.  
Most of this material is under carpet. This material shows normal wear, but was not in poor condition overall.  
**Asbestos** Assumed  
**Friable** No  
**Original Inspection** 6/1/1992  
**Current Inspection** 4/13/2017

## Material Assessment

**Assessment Rating** 5 ACBM with potential for damage

## Damage Assessment and Potential for Damage

**Percent Damaged** % Good Condition

<u>Physical Contact</u>	<u>Vibration</u>	<u>Air</u>
Low/None	Low/None	Low/None

**Planned Response Action** O&M



**Inspector**

Jamie Hosier

**State** Indiana

**Accreditation Number** 19A007179

# Periodic Surveillance

**LEA Name** Greater Clark County School Corporation  
**Building Name** Parkwood Elementary School  
**Building Number** 19  
**HA ID** 02-B  
**HA Description** 12"X12" Floor tile (NEWER) Light Blue  
**HA Type** Miscellaneous Material  
**HA Location** Gym

**Quantity** Unquantified SF  
**Comments** This material was not in poor condition overall.  
**Asbestos** Assumed  
**Friable** No

**Original Inspection** 6/27/2011  
**Current Inspection** 4/13/2017

## Material Assessment

**Assessment Rating** 5 ACBM with potential for damage

## Damage Assessment and Potential for Damage

<b>Percent Damaged</b>	%	Good Condition	
<b>Physical Contact</b>		<b>Vibration</b>	<b>Air</b>
Low/None		Low/None	Low/None

**Planned Response Action** O&M

**Inspector**



Jamie Hosier

**State** Indiana

**Accreditation Number** 19A007179

# Periodic Surveillance

**LEA Name** Greater Clark County School Corporation  
**Building Name** Parkwood Elementary School  
**Building Number** 19  
**HA ID** 02-C  
**HA Description** 12" X 12" Floor tile (NEWER) White  
**HA Type** Miscellaneous Material  
**HA Location** Cafeteria + custodial room

**Quantity** Unquantified SF  
**Comments** This material was not in poor condition overall.  
**Asbestos** Assumed  
**Friable** No

**Original Inspection** 6/27/2011  
**Current Inspection** 4/13/2017

## Material Assessment

**Assessment Rating** 5 ACBM with potential for damage

## Damage Assessment and Potential for Damage

<b>Percent Damaged</b>	%	Good Condition	
<b>Physical Contact</b>		<b>Vibration</b>	<b>Air</b>
Low/None		Low/None	Low/None

**Planned Response Action** O&M

**Inspector**



Jamie Hosier

**State** Indiana

**Accreditation Number** 19A007179



# Periodic Surveillance

**LEA Name** Greater Clark County School Corporation  
**Building Name** Parkwood Elementary School  
**Building Number** 19  
**HA ID** 02-D  
**HA Description** 12" X 12" Floor tile (NEWER) Dark Blue  
**HA Type** Miscellaneous Material  
**HA Location** Cafeteria

**Quantity** Unquantified SF  
**Comments** This material was not in poor condition overall.  
**Asbestos** Assumed  
**Friable** No

**Original Inspection** 6/27/2011  
**Current Inspection** 4/13/2017

## Material Assessment

**Assessment Rating** 5 ACBM with potential for damage

## Damage Assessment and Potential for Damage

<b>Percent Damaged</b>	%	Good Condition	
<b>Physical Contact</b>		<b>Vibration</b>	<b>Air</b>
Low/None		Low/None	Low/None

**Planned Response Action** O&M

**Inspector**



Jamie Hosier

**State** Indiana

**Accreditation Number** 19A007179

# Periodic Surveillance

**LEA Name** Greater Clark County School Corporation  
**Building Name** Parkwood Elementary School  
**Building Number** 19  
**HA ID** 02-E  
**HA Description** 12" X 12" Floor tile Light gray  
**HA Type** Miscellaneous Material  
**HA Location** Stage

**Quantity** Unquantified SF  
**Comments** This material was not in poor condition overall.  
**Asbestos** Assumed  
**Friable** No

**Original Inspection** 6/27/2011  
**Current Inspection** 4/13/2017

## Material Assessment

**Assessment Rating** 5 ACBM with potential for damage

## Damage Assessment and Potential for Damage

<b>Percent Damaged</b>	%	Good Condition	
<b>Physical Contact</b>		<b>Vibration</b>	<b>Air</b>
Low/None		Low/None	Low/None

**Planned Response Action** O&M

**Inspector**



\_\_\_\_\_  
Jamie Hosier

**State** Indiana

**Accreditation Number** 19A007179

# Periodic Surveillance

**LEA Name** Greater Clark County School Corporation  
**Building Name** Parkwood Elementary School  
**Building Number** 19  
**HA ID** A  
**HA Description** Cove Base  
**HA Type** Miscellaneous Material  
**HA Location** Throughout building

**Quantity** Unquantified LF

**Comments** There are minor signs of wear but this material was not in poor condition overall. Some has been replaced with new cove base.

**Asbestos** Assumed

**Friable** No

**Original Inspection** 5/31/1995  
**Current Inspection** 4/13/2017

## Material Assessment

**Assessment Rating** 5 ACBM with potential for damage

## Damage Assessment and Potential for Damage

<b><u>Percent Damaged</u></b>	%	Good Condition	
<b><u>Physical Contact</u></b>		<b><u>Vibration</u></b>	<b><u>Air</u></b>
Low/None		Low/None	Low/None

**Planned Response Action** O&M

**Inspector**



\_\_\_\_\_  
Jamie Hosier

**State** Indiana

**Accreditation Number** 19A007179

# Periodic Surveillance

**LEA Name** Greater Clark County School Corporation  
**Building Name** Parkwood Elementary School  
**Building Number** 19  
**HA ID** B  
**HA Description** Cove Base Mastic  
**HA Type** Miscellaneous Material  
**HA Location** Throughout building

**Quantity** Approx 900 SF  
**Comments** Mastic was exposed to inspect in the library (By door) & gym and it was not in poor condition.  
**Asbestos** No  
**Friable** No  
**Original Inspection** 5/31/1995  
**Current Inspection** 4/13/2017

## Material Assessment


**Assessment Rating** 5 ACBM with potential for damage

## Damage Assessment and Potential for Damage

**Percent Damaged** % Good Condition

<b>Physical Contact</b>	<b>Vibration</b>	<b>Air</b>
Low/None	Low/None	Low/None

**Planned Response Action** O&M

**Inspector**   
\_\_\_\_\_  
Jamie Hosier

**State** Indiana  
**Accreditation Number** 19A007179

# Periodic Surveillance

**LEA Name** Greater Clark County School Corporation  
**Building Name** Parkwood Elementary School  
**Building Number** 19  
**HA ID** C  
**HA Description** Transite Soffite  
**HA Type** Miscellaneous Material  
**HA Location** Outside building soffit

**Quantity** 2114 SF

**Comments** This material is not in poor condition with some minor cracking around the edges. The first panel by the entrance has been replaced with grey material (possibly plywood). The 5th one from the left has a long crack in it but is still in place.

**Asbestos** Assumed  
**Friable** No

**Original Inspection** 5/31/1995  
**Current Inspection** 4/13/2017

## Material Assessment

**Assessment Rating** 5 ACBM with potential for damage

## Damage Assessment and Potential for Damage

**Percent Damaged** % Good Condition

<u>Physical Contact</u>	<u>Vibration</u>	<u>Air</u>
Low/None	Low/None	Low/None

**Planned Response Action** O&M



**Inspector**

\_\_\_\_\_  
Jamie Hosier

**State** Indiana

**Accreditation Number** 19A007179

# Periodic Surveillance

**LEA Name** Greater Clark County School Corporation  
**Building Name** Parkwood Elementary School  
**Building Number** 19  
**HA ID** 01  
**HA Description** Fittings  
**HA Type** Thermal System Insulation (TSI)  
**HA Location** Above ceiling from boiler room to kitchen area. (halls, classrooms, storage room, restrooms) Behind refrigerator in custodial room.

**Quantity** Unquantified LF  
**Comments** This material was not in poor condition. It is seen above ceiling in the main hallway.  
**Asbestos** Known  
**Friable** No

**Original Inspection** 6/1/1992  
**Current Inspection** 11/3/2016

## Material Assessment

**Assessment Rating** 5 ACBM with potential for damage

## Damage Assessment and Potential for Damage

<b><u>Percent Damaged</u></b>	%	Good Condition	
<b><u>Physical Contact</u></b>		<b><u>Vibration</u></b>	<b><u>Air</u></b>
Low/None		Low/None	Low/None

**Planned Response Action** O&M

**Inspector**



\_\_\_\_\_  
Dustin Hawkins

**State** IN

**Accreditation Number** 19A007194

# Periodic Surveillance

**LEA Name** Greater Clark County School Corporation  
**Building Name** Parkwood Elementary School  
**Building Number** 19  
**HA ID** 02-A  
**HA Description** 9"X9" tan floor tile (OLD)  
**HA Type** Miscellaneous Material  
**HA Location** Custodial Room & Classrooms

**Quantity** Unquantified SF  
**Comments** 9"X9" floor tile was removed and replaced by 12"X12" floor tile in the custodial closet.  
Most of this material is under carpet. This material shows normal wear, but was not in poor condition overall.

**Asbestos** Assumed  
**Friable** No

**Original Inspection** 6/1/1992  
**Current Inspection** 11/3/2016

## Material Assessment

**Assessment Rating** 5 ACBM with potential for damage

## Damage Assessment and Potential for Damage

**Percent Damaged** % Good Condition

<u>Physical Contact</u>	<u>Vibration</u>	<u>Air</u>
Low/None	Low/None	Low/None

**Planned Response Action** O&M



**Inspector**

Dustin Hawkins



**State** IN

**Accreditation Number** 19A007194

# Periodic Surveillance

**LEA Name** Greater Clark County School Corporation  
**Building Name** Parkwood Elementary School  
**Building Number** 19  
**HA ID** 02-B  
**HA Description** 12"X12" Floor tile (NEWER) Light Blue  
**HA Type** Miscellaneous Material  
**HA Location** Gym

**Quantity** Unquantified SF  
**Comments** This material was not in poor condition overall.  
**Asbestos** Assumed  
**Friable** No

**Original Inspection** 6/27/2011  
**Current Inspection** 11/3/2016

## Material Assessment

**Assessment Rating** 5 ACBM with potential for damage

## Damage Assessment and Potential for Damage

<b>Percent Damaged</b>	%	Good Condition	
<b>Physical Contact</b>		<b>Vibration</b>	<b>Air</b>
Low/None		Low/None	Low/None

**Planned Response Action** O&M



**Inspector**

Dustin Hawkins

**State** IN

**Accreditation Number** 19A007194

# Periodic Surveillance

**LEA Name** Greater Clark County School Corporation  
**Building Name** Parkwood Elementary School  
**Building Number** 19  
**HA ID** 02-C  
**HA Description** 12" X 12" Floor tile (NEWER) White  
**HA Type** Miscellaneous Material  
**HA Location** Cafeteria + custodial room

**Quantity** Unquantified SF  
**Comments** This material was not in poor condition overall.  
**Asbestos** Assumed  
**Friable** No

**Original Inspection** 6/27/2011  
**Current Inspection** 11/3/2016

## Material Assessment

**Assessment Rating** 5 ACBM with potential for damage

## Damage Assessment and Potential for Damage

<b>Percent Damaged</b>	%	Good Condition	
<b>Physical Contact</b>		<b>Vibration</b>	<b>Air</b>
Low/None		Low/None	Low/None

**Planned Response Action** O&M



**Inspector**

\_\_\_\_\_  
Dustin Hawkins

**State** IN

**Accreditation Number** 19A007194

# Periodic Surveillance

**LEA Name** Greater Clark County School Corporation  
**Building Name** Parkwood Elementary School  
**Building Number** 19  
**HA ID** 02-D  
**HA Description** 12" X 12" Floor tile (NEWER) Dark Blue  
**HA Type** Miscellaneous Material  
**HA Location** Cafeteria

**Quantity** Unquantified SF  
**Comments** This material was not in poor condition overall.  
**Asbestos** Assumed  
**Friable** No

**Original Inspection** 6/27/2011  
**Current Inspection** 11/3/2016

## Material Assessment

**Assessment Rating** 5 ACBM with potential for damage

## Damage Assessment and Potential for Damage

<b>Percent Damaged</b>	%	Good Condition	
<b>Physical Contact</b>		<b>Vibration</b>	<b>Air</b>
Low/None		Low/None	Low/None

**Planned Response Action** O&M



**Inspector**

Dustin Hawkins

**State** IN

**Accreditation Number** 19A007194

# Periodic Surveillance

**LEA Name** Greater Clark County School Corporation  
**Building Name** Parkwood Elementary School  
**Building Number** 19  
**HA ID** 02-E  
**HA Description** 12" X 12" Floor tile Light gray  
**HA Type** Miscellaneous Material  
**HA Location** Stage

**Quantity** Unquantified SF  
**Comments** This material was not in poor condition overall.  
**Asbestos** Assumed  
**Friable** No

**Original Inspection** 6/27/2011  
**Current Inspection** 11/3/2016

## Material Assessment

**Assessment Rating** 5 ACBM with potential for damage

## Damage Assessment and Potential for Damage

<b>Percent Damaged</b>	%	Good Condition	
<b>Physical Contact</b>		<b>Vibration</b>	<b>Air</b>
Low/None		Low/None	Low/None

**Planned Response Action** O&M



**Inspector**

\_\_\_\_\_  
Dustin Hawkins

**State** IN

**Accreditation Number** 19A007194

# Periodic Surveillance

**LEA Name** Greater Clark County School Corporation  
**Building Name** Parkwood Elementary School  
**Building Number** 19  
**HA ID** A  
**HA Description** Cove Base  
**HA Type** Miscellaneous Material  
**HA Location** Throughout building

**Quantity** Unquantified LF

**Comments** There are minor signs of wear but this material was not in poor condition overall. Some has been replaced with new cove base.

**Asbestos** Assumed  
**Friable** No

**Original Inspection** 5/31/1995  
**Current Inspection** 11/3/2016

## Material Assessment

**Assessment Rating** 5 ACBM with potential for damage

## Damage Assessment and Potential for Damage

<b>Percent Damaged</b>	%	Good Condition	
<b>Physical Contact</b>	Low/None	<b>Vibration</b> Low/None	<b>Air</b> Low/None

**Planned Response Action** O&M



**Inspector** \_\_\_\_\_  
Dustin Hawkins

**State** IN

**Accreditation Number** 19A007194

# Periodic Surveillance

**LEA Name** Greater Clark County School Corporation  
**Building Name** Parkwood Elementary School  
**Building Number** 19  
**HA ID** B  
**HA Description** Cove Base Mastic  
**HA Type** Miscellaneous Material  
**HA Location** Throughout building

**Quantity** Approx 900 SF  
**Comments** Mastic was exposed to inspect in the library (By door) & gym and it was not in poor condition.  
**Asbestos** No  
**Friable** No

**Original Inspection** 5/31/1995  
**Current Inspection** 11/3/2016

## Material Assessment


**Assessment Rating** 5 ACBM with potential for damage

## Damage Assessment and Potential for Damage

**Percent Damaged** % Good Condition

<b><u>Physical Contact</u></b>	<b><u>Vibration</u></b>	<b><u>Air</u></b>
Low/None	Low/None	Low/None

**Planned Response Action** O&M

**Inspector**   
\_\_\_\_\_  
Dustin Hawkins

**State** IN  
**Accreditation Number** 19A007194

# Periodic Surveillance

**LEA Name** Greater Clark County School Corporation  
**Building Name** Parkwood Elementary School  
**Building Number** 19  
**HA ID** C  
**HA Description** Transite Soffite  
**HA Type** Miscellaneous Material  
**HA Location** Outside building soffit

**Quantity** 2114 SF

**Comments** This material is not in poor condition with some minor cracking around the edges. The first panel by the entrance has been replaced with grey material (possibly plywood). The 5th one from the left has a long crack in it but is still in place.

**Asbestos** Assumed  
**Friable** No

**Original Inspection** 5/31/1995  
**Current Inspection** 11/3/2016

## Material Assessment

**Assessment Rating** 5 ACBM with potential for damage

## Damage Assessment and Potential for Damage

**Percent Damaged** % Good Condition

<u>Physical Contact</u>	<u>Vibration</u>	<u>Air</u>
Low/None	Low/None	Low/None

**Planned Response Action** O&M



**Inspector**

Dustin Hawkins



**State** IN

**Accreditation Number** 19A007194

# Periodic Surveillance

**LEA Name** Greater Clark County School Corporation  
**Building Name** Parkwood Elementary School  
**Building Number** 19  
**HA ID** D  
**HA Description** Green shock joints on AHU  
**HA Type** Miscellaneous Material  
**HA Location** Gymnasium and cafeteria

**Quantity** 0 SF  
**Comments** This material was not in poor condition. Four locations of material above gymnasium.  
This material was sampled by a licensed inspector and found to be a non-asbestos material by an accredited laboratory. Therefore, it is being removed from the management plan.

**Asbestos** No  
**Friable** No

**Original Inspection** 5/31/1995  
**Current Inspection** 11/3/2016

## Material Assessment

**Assessment Rating** 5 ACBM with potential for damage

## Damage Assessment and Potential for Damage

<b><u>Percent Damaged</u></b>	%	Good Condition	
<b><u>Physical Contact</u></b>		<b><u>Vibration</u></b>	<b><u>Air</u></b>
Low/None		Low/None	Low/None

**Planned Response Action** O&M



**Inspector**

\_\_\_\_\_  
Dustin Hawkins

**State** IN

**Accreditation Number** 19A007194

# Periodic Surveillance

**LEA Name** Greater Clark County School Corporation  
**Building Name** Parkwood Elementary School  
**Building Number** 19  
**HA ID** 01  
**HA Description** Fittings  
**HA Type** Thermal System Insulation (TSI)  
**HA Location** Above ceiling from boiler room to kitchen area. (halls, classrooms, storage room, restrooms) Behind refrigerator in custodial room.

**Quantity** Unquantified LF  
**Comments** This material was not in poor condition. It is seen above ceiling in the main hallway.  
**Asbestos** Known  
**Friable** No

**Original Inspection** 6/1/1992  
**Current Inspection** 10/20/2015


## Material Assessment

**Assessment Rating** 5 ACBM with potential for damage

## Damage Assessment and Potential for Damage

<b><u>Percent Damaged</u></b>	%	Good Condition	
<b><u>Physical Contact</u></b>		<b><u>Vibration</u></b>	<b><u>Air</u></b>
Low/None		Low/None	Low/None

**Planned Response Action** O&M

**Inspector**   
\_\_\_\_\_  
Benjamin S. Hood

**State** IN

**Accreditation Number** 19A001039

# Periodic Surveillance

**LEA Name** Greater Clark County School Corporation  
**Building Name** Parkwood Elementary School  
**Building Number** 19  
**HA ID** 02-A  
**HA Description** 9"X9" tan floor tile (OLD)  
**HA Type** Miscellaneous Material  
**HA Location** Custodial Room & Classrooms

**Quantity** Unquantified SF  
**Comments** 9"X9" floor tile was removed and replaced by 12"X12" floor tile in the custodial closet.  
Most of this material is under carpet. This material shows normal wear, but was not in poor condition overall.

**Asbestos** Assumed  
**Friable** No

**Original Inspection** 6/1/1992  
**Current Inspection** 10/20/2015

## Material Assessment

**Assessment Rating** 5 ACBM with potential for damage


## Damage Assessment and Potential for Damage

**Percent Damaged** % Good Condition

<u>Physical Contact</u>	<u>Vibration</u>	<u>Air</u>
Low/None	Low/None	Low/None

**Planned Response Action** O&M

**Inspector**



Benjamin S. Hood

**State IN**

**Accreditation Number 19A001039**

# Periodic Surveillance

**LEA Name** Greater Clark County School Corporation  
**Building Name** Parkwood Elementary School  
**Building Number** 19  
**HA ID** 02-B  
**HA Description** 12"X12" Floor tile (NEWER) Light Blue  
**HA Type** Miscellaneous Material  
**HA Location** Gym

**Quantity** Unquantified SF  
**Comments** This material was not in poor condition overall.  
**Asbestos** Assumed  
**Friable** No

**Original Inspection** 6/27/2011  
**Current Inspection** 10/20/2015

## Material Assessment

**Assessment Rating** 5 ACBM with potential for damage

## Damage Assessment and Potential for Damage

<b>Percent Damaged</b>	%	Good Condition	
<b>Physical Contact</b>		<b>Vibration</b>	<b>Air</b>
Low/None		Low/None	Low/None

**Planned Response Action** O&M

**Inspector**



Benjamin S. Hood

**State** IN

**Accreditation Number** 19A001039

# Periodic Surveillance

**LEA Name** Greater Clark County School Corporation  
**Building Name** Parkwood Elementary School  
**Building Number** 19  
**HA ID** 02-C  
**HA Description** 12" X 12" Floor tile (NEWER) White  
**HA Type** Miscellaneous Material  
**HA Location** Cafeteria + custodial room

**Quantity** Unquantified SF  
**Comments** This material was not in poor condition overall.  
**Asbestos** Assumed  
**Friable** No

**Original Inspection** 6/27/2011  
**Current Inspection** 10/20/2015

## Material Assessment

**Assessment Rating** 5 ACBM with potential for damage

## Damage Assessment and Potential for Damage

<b>Percent Damaged</b>	%	Good Condition	
<b>Physical Contact</b>		<b>Vibration</b>	<b>Air</b>
Low/None		Low/None	Low/None

**Planned Response Action** O&M

**Inspector**



Benjamin S. Hood

**State** IN

**Accreditation Number** 19A001039



# Periodic Surveillance

**LEA Name** Greater Clark County School Corporation  
**Building Name** Parkwood Elementary School  
**Building Number** 19  
**HA ID** 02-D  
**HA Description** 12" X 12" Floor tile (NEWER) Dark Blue  
**HA Type** Miscellaneous Material  
**HA Location** Cafeteria

**Quantity** Unquantified SF  
**Comments** This material was not in poor condition overall.  
**Asbestos** Assumed  
**Friable** No

**Original Inspection** 6/27/2011  
**Current Inspection** 10/20/2015

## Material Assessment

**Assessment Rating** 5 ACBM with potential for damage

## Damage Assessment and Potential for Damage

<b>Percent Damaged</b>	%	Good Condition	
<b>Physical Contact</b>		<b>Vibration</b>	<b>Air</b>
Low/None		Low/None	Low/None

**Planned Response Action** O&M

**Inspector**



Benjamin S. Hood

**State** IN

**Accreditation Number** 19A001039

# Periodic Surveillance

**LEA Name** Greater Clark County School Corporation  
**Building Name** Parkwood Elementary School  
**Building Number** 19  
**HA ID** 02-E  
**HA Description** 12" X 12" Floor tile Light gray  
**HA Type** Miscellaneous Material  
**HA Location** Stage

**Quantity** Unquantified SF  
**Comments** This material was not in poor condition overall.  
**Asbestos** Assumed  
**Friable** No

**Original Inspection** 6/27/2011  
**Current Inspection** 10/20/2015

## Material Assessment

**Assessment Rating** 5 ACBM with potential for damage

## Damage Assessment and Potential for Damage

<b>Percent Damaged</b>	%	Good Condition	
<b>Physical Contact</b>		<b>Vibration</b>	<b>Air</b>
Low/None		Low/None	Low/None

**Planned Response Action** O&M

**Inspector**



Benjamin S. Hood

**State** IN

**Accreditation Number** 19A001039

# Periodic Surveillance

**LEA Name** Greater Clark County School Corporation  
**Building Name** Parkwood Elementary School  
**Building Number** 19  
**HA ID** A  
**HA Description** Cove Base  
**HA Type** Miscellaneous Material  
**HA Location** Throughout building

**Quantity** Unquantified LF

**Comments** There are minor signs of wear but this material was not in poor condition overall. Some has been replaced with new cove base.

**Asbestos** Assumed

**Friable** No

**Original Inspection** 5/31/1995  
**Current Inspection** 10/20/2015

## Material Assessment


**Assessment Rating** 5 ACBM with potential for damage

## Damage Assessment and Potential for Damage

**Percent Damaged** % Good Condition

<u>Physical Contact</u>	<u>Vibration</u>	<u>Air</u>
Low/None	Low/None	Low/None

**Planned Response Action** O&M

**Inspector**   
\_\_\_\_\_  
Benjamin S. Hood

**State** IN  
**Accreditation Number** 19A001039

# Periodic Surveillance

**LEA Name** Greater Clark County School Corporation  
**Building Name** Parkwood Elementary School  
**Building Number** 19  
**HA ID** B  
**HA Description** Cove Base Mastic  
**HA Type** Miscellaneous Material  
**HA Location** Throughout building

**Quantity** Approx 900 SF  
**Comments** Mastic was exposed to inspect in the library (By door) & gym and it was not in poor condition.  
**Asbestos** No  
**Friable** No  
**Original Inspection** 5/31/1995  
**Current Inspection** 10/20/2015

## Material Assessment


**Assessment Rating** 5 ACBM with potential for damage

## Damage Assessment and Potential for Damage

**Percent Damaged** % Good Condition

<b>Physical Contact</b>	<b>Vibration</b>	<b>Air</b>
Low/None	Low/None	Low/None

**Planned Response Action** O&M

**Inspector**   
\_\_\_\_\_  
Benjamin S. Hood

**State** IN  
**Accreditation Number** 19A001039

# Periodic Surveillance

**LEA Name** Greater Clark County School Corporation  
**Building Name** Parkwood Elementary School  
**Building Number** 19  
**HA ID** C  
**HA Description** Transite Soffite  
**HA Type** Miscellaneous Material  
**HA Location** Outside building soffit

**Quantity** 2114 SF

**Comments** This material is not in poor condition with some minor cracking around the edges. The first panel by the entrance has been replaced with grey material (possibly plywood). The 5th one from the left has a long crack in it but is still in place.

**Asbestos** Assumed  
**Friable** No

**Original Inspection** 5/31/1995  
**Current Inspection** 10/20/2015

## Material Assessment

**Assessment Rating** 5 ACBM with potential for damage


## Damage Assessment and Potential for Damage

**Percent Damaged** % Good Condition

<u>Physical Contact</u>	<u>Vibration</u>	<u>Air</u>
Low/None	Low/None	Low/None

**Planned Response Action** O&M

**Inspector**



Benjamin S. Hood

**State IN**

**Accreditation Number 19A001039**

# Periodic Surveillance

**LEA Name** Greater Clark County School Corporation  
**Building Name** Parkwood Elementary School  
**Building Number** 19  
**HA ID** D  
**HA Description** Green shock joints on AHU  
**HA Type** Miscellaneous Material  
**HA Location** Gymnasium and cafeteria

**Quantity** 0 SF  
**Comments** This material was not in poor condition. Four locations of material above gymnasium.  
This material was sampled by a licensed inspector and found to be a non-asbestos material by an accredited laboratory. Therefore, it is being removed from the management plan.

**Asbestos** No  
**Friable** No

**Original Inspection** 5/31/1995  
**Current Inspection** 10/20/2015

## Material Assessment

**Assessment Rating** 5 ACBM with potential for damage

## Damage Assessment and Potential for Damage

<b><u>Percent Damaged</u></b>	%	Good Condition	
<b><u>Physical Contact</u></b>		<b><u>Vibration</u></b>	<b><u>Air</u></b>
Low/None		Low/None	Low/None

**Planned Response Action** O&M

**Inspector**



Benjamin S. Hood

**State IN**

**Accreditation Number 19A001039**



# PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools

**Building Name** Parkwood Elementary School

**HA#** 01

**Type of Material** Thermal Material

**Quantity of Material** Unquantified LF

**Material Location**

Above ceiling from boiler room to kitchen area. (halls, classrooms, storage room, restrooms) Behind refrigerator in custodial room.

**Material Description**

Fittings

**Comments**

This material was not in poor condition. It is seen above ceiling in the main hallway.

**Does Material Contain Asbestos?** Yes

**Is it Friable?** No

**Original Inspection Date** 6/1/1992

**Current Surveillance Date** 4/22/2015

**Current Assessment Rating** NR Not Rated


**Cause of Damage** No Damage

**Accessible** Yes

**Potential for Damage** Low

**Removed** No

**Planned Response Action** O & M



**Inspector**

---

Benjamin S. Hood

**State** Indiana

**Accreditation Number** 19A001039

# PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Parkwood Elementary School  
**HA#** 02-A  
**Type of Material** Miscellaneous Material  
**Quantity of Material** Unquantified SF  
**Material Location**  
Custodial Room & Classrooms


**Material Description**

9"X9" tan floor tile (OLD)

**Comments**

9"X9" floor tile was removed and replaced by 12"X12" floor tile in the custodial closet. Most of this material is under carpet. This material shows normal wear, but was not in poor condition overall.

**Does Material Contain Asbestos?** Assumed  
**Is it Friable?** No  
**Original Inspection Date** 6/1/1992  
**Current Surveillance Date** 4/22/2015  
**Current Assessment Rating** NR Not Rated  
**Cause of Damage** No Damage  
**Accessible** Yes  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M



**Inspector**


---

Benjamin S. Hood

**State** Indiana  
**Accreditation Number** 19A001039

# PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Parkwood Elementary School  
**HA#** 02-B  
**Type of Material** Miscellaneous Material  
**Quantity of Material** Unquantified SF  
**Material Location**  
Gym  
**Material Description**  
12"X12" Floor tile (NEWER) Light Blue  
**Comments**  
This material was not in poor condition overall.  
**Does Material Contain Asbestos?** Assumed  
**Is it Friable?** No  
**Original Inspection Date** 6/27/2011  
**Current Surveillance Date** 4/22/2015  
**Current Assessment Rating** NA Not Applicable  
**Cause of Damage** No Damage  
**Accessible** Yes  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M



**Inspector**


---

Benjamin S. Hood

**State** Indiana  
**Accreditation Number** 19A001039

# PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Parkwood Elementary School  
**HA#** 02-C  
**Type of Material** Miscellaneous Material  
**Quantity of Material** Unquantified SF  
**Material Location**  
Cafeteria + custodial room  
**Material Description**  
12" X 12" Floor tile (NEWER) White  
**Comments**  
This material was not in poor condition overall.  
**Does Material Contain Asbestos?** Assumed  
**Is it Friable?** No  
**Original Inspection Date** 6/27/2011  
**Current Surveillance Date** 4/22/2015  
**Current Assessment Rating** NA Not Applicable  
**Cause of Damage** No Damage  
**Accessible** Yes  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M



**Inspector**


---

Benjamin S. Hood

**State** Indiana  
**Accreditation Number** 19A001039

# PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Parkwood Elementary School  
**HA#** 02-D  
**Type of Material** Miscellaneous Material  
**Quantity of Material** Unquantified SF  
**Material Location**  
Cafeteria  
**Material Description**  
12" X 12" Floor tile (NEWER) Dark Blue  
**Comments**  
This material was not in poor condition overall.  
**Does Material Contain Asbestos?** Assumed  
**Is it Friable?** No  
**Original Inspection Date** 6/27/2011  
**Current Surveillance Date** 4/22/2015  
**Current Assessment Rating** NA Not Applicable  
**Cause of Damage** No Damage  
**Accessible** Yes  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M



**Inspector**


---

Benjamin S. Hood

**State** Indiana  
**Accreditation Number** 19A001039

# PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Parkwood Elementary School  
**HA#** 02-E  
**Type of Material** Miscellaneous Material  
**Quantity of Material** Unquantified SF  
**Material Location**  
Stage  
**Material Description**  
12" X 12" Floor tile Light gray  
**Comments**  
This material was not in poor condition overall.  
**Does Material Contain Asbestos?** Assumed  
**Is it Friable?** No  
**Original Inspection Date** 6/27/2011  
**Current Surveillance Date** 4/22/2015  
**Current Assessment Rating** NA Not Applicable  
**Cause of Damage** No Damage  
**Accessible** Yes  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M



**Inspector**

---

Benjamin S. Hood

**State** Indiana  
**Accreditation Number** 19A001039

# PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools

**Building Name** Parkwood Elementary School

**HA#** A

**Type of Material** Miscellaneous Material

**Quantity of Material** Unquantified LF

**Material Location**

Throughout the building

**Material Description**

Cove base

**Comments**

There are minor signs of wear but this material was not in poor condition overall. Some has been replaced with new cove base.

**Does Material Contain Asbestos?** Assumed

**Is it Friable?** No

**Original Inspection Date** 5/31/1995

**Current Surveillance Date** 4/22/2015

**Current Assessment Rating** NR Not Rated


**Cause of Damage** No Damage

**Accessible** Yes

**Potential for Damage** Low

**Removed** No

**Planned Response Action** O & M



**Inspector**

---

Benjamin S. Hood

**State** Indiana

**Accreditation Number** 19A001039

# PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools

**Building Name** Parkwood Elementary School

**HA#** B

**Type of Material** Miscellaneous Material

**Quantity of Material** Approx 900 SF

**Material Location**  
Throughout the building

**Material Description**  
Cove base mastic

**Comments**  
Mastic was exposed to inspect in the library (By door) & gym and it was not in poor condition.

**Does Material Contain Asbestos?** No

**Is it Friable?** No

**Original Inspection Date** 5/31/1995

**Current Surveillance Date** 4/22/2015

**Current Assessment Rating** NR Not Rated


**Cause of Damage** No Damage

**Accessible** No

**Potential for Damage** Low

**Removed** No

**Planned Response Action** O & M



**Inspector**

---

Benjamin S. Hood

**State** Indiana

**Accreditation Number** 19A001039



# PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools

**Building Name** Parkwood Elementary School

**HA#** C

**Type of Material** Miscellaneous Material

**Quantity of Material** 2,114 SF

**Material Location**

Outside building soffit

**Material Description**

Transite soffit

**Comments**

This material is not in poor condition with some minor cracking around the edges. The first panel by the entrance has been replaced with grey material (possibly plywood). The 5th one from the left has a long crack in it but is still in place.

**Does Material Contain Asbestos?** Assumed

**Is it Friable?** No

**Original Inspection Date** 5/31/1995

**Current Surveillance Date** 4/22/2015

**Current Assessment Rating** NR Not Rated


**Cause of Damage** No Damage

**Accessible** Yes

**Potential for Damage** Low

**Removed** No

**Planned Response Action** O & M



**Inspector**

---

Benjamin S. Hood

**State** Indiana

**Accreditation Number** 19A001039

# PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools

**Building Name** Parkwood Elementary School

**HA#** D

**Type of Material** Miscellaneous Material

**Quantity of Material** 0 SF

**Material Location**

Gymnasium and cafeteria

**Material Description**

Green shock joints on AHU

**Comments**

This material was not in poor condition. Four locations of material above gymnasium. This material was sampled by a licensed inspector and found to be a non-asbestos material by an accredited laboratory. Therefore, it is being removed from the management plan.

**Does Material Contain Asbestos?** No

**Is it Friable?** No

**Original Inspection Date** 5/31/1995

**Current Surveillance Date** 4/22/2015

**Current Assessment Rating** NR Not Rated


**Cause of Damage** No Damage

**Accessible** Yes

**Potential for Damage** Low

**Removed** Yes

**Planned Response Action** Remove



**Inspector**

---

Benjamin S. Hood

**State** Indiana

**Accreditation Number** 19A001039

# PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools

**Building Name** Parkwood Elementary School

**HA#** 01

**Type of Material** Thermal Material

**Quantity of Material** Unquantified LF

**Material Location**

Above ceiling from boiler room to kitchen area. (halls, classrooms, storage room, restrooms) Behind refrigerator in custodial room.

**Material Description**

Fittings

**Comments**

This material was not in poor condition. It is seen above ceiling in the main hallway.

**Does Material Contain Asbestos?** Yes

**Is it Friable?** No

**Original Inspection Date** 6/1/1992

**Current Surveillance Date** 10/22/2014

**Current Assessment Rating** NR Not Rated


**Cause of Damage** No Damage

**Accessible** Yes

**Potential for Damage** Low

**Removed** No

**Planned Response Action** O & M



**Inspector**

---

Benjamin S. Hood

**State** Indiana

**Accreditation Number** 19A001039

# PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools

**Building Name** Parkwood Elementary School

**HA#** 02-A

**Type of Material** Miscellaneous Material

**Quantity of Material** Unquantified SF

**Material Location**  
Custodial Room & Classrooms

**Material Description**  
9"X9" tan floor tile (OLD)

**Comments**  
Most of this material is under carpet. This material shows normal wear, but was not in poor condition overall.

**Does Material Contain Asbestos?** Assumed

**Is it Friable?** No

**Original Inspection Date** 6/1/1992

**Current Surveillance Date** 10/22/2014

**Current Assessment Rating** NR Not Rated

**Cause of Damage** No Damage

**Accessible** Yes

**Potential for Damage** Low

**Removed** No

**Planned Response Action** O & M



**Inspector**

---


Benjamin S. Hood

**State** Indiana

**Accreditation Number** 19A001039

# PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Parkwood Elementary School  
**HA#** 02-B  
**Type of Material** Miscellaneous Material  
**Quantity of Material** Unquantified SF  
**Material Location**  
Gym  
**Material Description**  
12"X12" Floor tile (NEWER) Light Blue  
**Comments**  
This material was not in poor condition overall.  
**Does Material Contain Asbestos?** Assumed  
**Is it Friable?** No  
**Original Inspection Date** 6/27/2011  
**Current Surveillance Date** 10/22/2014  
**Current Assessment Rating** NA Not Applicable  
**Cause of Damage** No Damage  
**Accessible** Yes  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M



**Inspector**


---

Benjamin S. Hood

**State** Indiana  
**Accreditation Number** 19A001039

# PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Parkwood Elementary School  
**HA#** 02-C  
**Type of Material** Miscellaneous Material  
**Quantity of Material** Unquantified SF  
**Material Location**  
Cafeteria + custodial room  
**Material Description**  
12" X 12" Floor tile (NEWER) White  
**Comments**  
This material was not in poor condition overall.  
**Does Material Contain Asbestos?** Assumed  
**Is it Friable?** No  
**Original Inspection Date** 6/27/2011  
**Current Surveillance Date** 10/22/2014  
**Current Assessment Rating** NA Not Applicable  
**Cause of Damage** No Damage  
**Accessible** Yes  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M



**Inspector**


---

Benjamin S. Hood

**State** Indiana  
**Accreditation Number** 19A001039

# PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Parkwood Elementary School  
**HA#** 02-D  
**Type of Material** Miscellaneous Material  
**Quantity of Material** Unquantified SF  
**Material Location**  
Cafeteria  
**Material Description**  
12" X 12" Floor tile (NEWER) Dark Blue  
**Comments**  
This material was not in poor condition overall.  
**Does Material Contain Asbestos?** Assumed  
**Is it Friable?** No  
**Original Inspection Date** 6/27/2011  
**Current Surveillance Date** 10/22/2014  
**Current Assessment Rating** NA Not Applicable  
**Cause of Damage** No Damage  
**Accessible** Yes  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M



**Inspector**

---

Benjamin S. Hood

**State** Indiana  
**Accreditation Number** 19A001039


# PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Parkwood Elementary School  
**HA#** 02-E  
**Type of Material** Miscellaneous Material  
**Quantity of Material** Unquantified SF  
**Material Location**  
Stage

**Material Description**  
12" X 12" Floor tile Light gray

**Comments**  
This material was not in poor condition overall.

**Does Material Contain Asbestos?** Assumed  
**Is it Friable?** No  
**Original Inspection Date** 6/27/2011  
**Current Surveillance Date** 10/22/2014  
**Current Assessment Rating** NA Not Applicable  
**Cause of Damage** No Damage  
**Accessible** Yes  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M



**Inspector**

---

Benjamin S. Hood

**State** Indiana  
**Accreditation Number** 19A001039



# PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools

**Building Name** Parkwood Elementary School

**HA#** A

**Type of Material** Miscellaneous Material

**Quantity of Material** Unquantified LF

**Material Location**

Throughout the building

**Material Description**

Cove base

**Comments**

There are minor signs of wear but this material was not in poor condition overall. Some has been replaced with new cove base.

**Does Material Contain Asbestos?** Assumed

**Is it Friable?** No

**Original Inspection Date** 5/31/1995

**Current Surveillance Date** 10/22/2014

**Current Assessment Rating** NR Not Rated


**Cause of Damage** No Damage

**Accessible** Yes

**Potential for Damage** Low

**Removed** No

**Planned Response Action** O & M



**Inspector**

---

Benjamin S. Hood

**State** Indiana

**Accreditation Number** 19A001039

# PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools

**Building Name** Parkwood Elementary School

**HA#** B

**Type of Material** Miscellaneous Material

**Quantity of Material** Approx 900 SF

**Material Location**  
Throughout the building

**Material Description**  
Cove base mastic

**Comments**  
Mastic was exposed to inspect in the library (By door) & gym and it was not in poor condition.

**Does Material Contain Asbestos?** No

**Is it Friable?** No

**Original Inspection Date** 5/31/1995

**Current Surveillance Date** 10/22/2014

**Current Assessment Rating** NR Not Rated


**Cause of Damage** No Damage

**Accessible** No

**Potential for Damage** Low

**Removed** No

**Planned Response Action** O & M



**Inspector**

---

Benjamin S. Hood

**State** Indiana

**Accreditation Number** 19A001039

# PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools

**Building Name** Parkwood Elementary School

**HA#** C

**Type of Material** Miscellaneous Material

**Quantity of Material** 2,114 SF


**Material Location**  
Outside building soffit

**Material Description**  
Transite soffit

**Comments**

This material is not in poor condition with some minor cracking around the edges. The first panel by the entrance has been replaced with grey material (possibly plywood). The 5th one from the left has a long crack in it but is still in place.

**Does Material Contain Asbestos?** Assumed  
**Is it Friable?** No  
**Original Inspection Date** 5/31/1995  
**Current Surveillance Date** 10/22/2014  
**Current Assessment Rating** NR Not Rated  
**Cause of Damage** No Damage  
**Accessible** Yes  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M



**Inspector**

---

Benjamin S. Hood

**State** Indiana

**Accreditation Number** 19A001039

# PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools

**Building Name** Parkwood Elementary School

**HA#** D

**Type of Material** Miscellaneous Material


**Quantity of Material** 0 SF

**Material Location**  
Gymnasium and cafeteria

**Material Description**  
Green shock joints on AHU

**Comments**  
This material was not in poor condition. Four locations of material above gymnasium. This material was sampled by a licensed inspector and found to be a non-asbestos material by an accredited laboratory. Therefore, it is being removed from the management plan.

<b>Does Material Contain Asbestos?</b>	No	
<b>Is it Friable?</b>	No	
<b>Original Inspection Date</b>	5/31/1995	
<b>Current Surveillance Date</b>	10/22/2014	
<b>Current Assessment Rating</b>	NR	Not Rated
<b>Cause of Damage</b>	No Damage	
<b>Accessible</b>	Yes	
<b>Potential for Damage</b>	Low	
<b>Removed</b>	Yes	
<b>Planned Response Action</b>	Remove	



**Inspector**

---

Benjamin S. Hood

**State** Indiana

**Accreditation Number** 19A001039

# PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools

**Building Name** Parkwood Elementary School

**HA#** 01

**Type of Material** Thermal Material

**Quantity of Material** Unquantified LF

**Material Location**

Above ceiling from boiler room to kitchen area. (halls, classrooms, storage room, restrooms) Behind refrigerator in custodial room.

**Material Description**

Fittings

**Comments**

This material was not in poor condition. It is seen above ceiling in the main hallway.

**Does Material Contain Asbestos?** Yes

**Is it Friable?** No

**Original Inspection Date** 6/1/1992

**Current Surveillance Date** 4/21/2014

**Current Assessment Rating** NR Not Rated

**Cause of Damage** No Damage

**Accessible** Yes

**Potential for Damage** Low

**Removed** No

**Planned Response Action** O & M

**Inspector**



---

Jeffrey P. Rehtin

**State** Indiana

**Accreditation Number** 19A003594

# PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools

**Building Name** Parkwood Elementary School

**HA#** 02-A

**Type of Material** Miscellaneous Material

**Quantity of Material** Unquantified SF

**Material Location**  
Custodial Room & Classrooms

**Material Description**  
9"X9" tan floor tile (OLD)

**Comments**  
Most of this material is under carpet. This material shows normal wear, but was not in poor condition overall.

**Does Material Contain Asbestos?** Assumed

**Is it Friable?** No

**Original Inspection Date** 6/1/1992

**Current Surveillance Date** 4/21/2014

**Current Assessment Rating** NR Not Rated

**Cause of Damage** No Damage

**Accessible** Yes

**Potential for Damage** Low

**Removed** No

**Planned Response Action** O & M

**Inspector**



---

Jeffrey P. Rehtin

**State** Indiana

**Accreditation Number** 19A003594

# PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Parkwood Elementary School  
**HA#** 02-B  
**Type of Material** Miscellaneous Material  
**Quantity of Material** Unquantified SF  
**Material Location**  
Gym  
**Material Description**  
12"X12" Floor tile (NEWER) Light Blue  
**Comments**  
This material was not in poor condition overall.  
**Does Material Contain Asbestos?** Assumed  
**Is it Friable?** No  
**Original Inspection Date** 6/27/2011  
**Current Surveillance Date** 4/21/2014  
**Current Assessment Rating** NA Not Applicable  
**Cause of Damage** No Damage  
**Accessible** Yes  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M

**Inspector**



---

Jeffrey P. Rehtin

**State** Indiana  
**Accreditation Number** 19A003594

# PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Parkwood Elementary School  
**HA#** 02-C  
**Type of Material** Miscellaneous Material  
**Quantity of Material** Unquantified SF  
**Material Location**  
Cafeteria + custodial room  
**Material Description**  
12" X 12" Floor tile (NEWER) White  
**Comments**  
This material was not in poor condition overall.  
**Does Material Contain Asbestos?** Assumed  
**Is it Friable?** No  
**Original Inspection Date** 6/27/2011  
**Current Surveillance Date** 4/21/2014  
**Current Assessment Rating** NA Not Applicable  
**Cause of Damage** No Damage  
**Accessible** Yes  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M

**Inspector**



---

Jeffrey P. Rechten

**State** Indiana  
**Accreditation Number** 19A003594



# PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Parkwood Elementary School  
**HA#** 02-D  
**Type of Material** Miscellaneous Material  
**Quantity of Material** Unquantified SF  
**Material Location**  
Cafeteria  
**Material Description**  
12" X 12" Floor tile (NEWER) Dark Blue  
**Comments**  
This material was not in poor condition overall.  
**Does Material Contain Asbestos?** Assumed  
**Is it Friable?** No  
**Original Inspection Date** 6/27/2011  
**Current Surveillance Date** 4/21/2014  
**Current Assessment Rating** NA Not Applicable  
**Cause of Damage** No Damage  
**Accessible** Yes  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M

**Inspector**



---

Jeffrey P. Rehtin

**State** Indiana  
**Accreditation Number** 19A003594

# PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Parkwood Elementary School  
**HA#** 02-E  
**Type of Material** Miscellaneous Material  
**Quantity of Material** Unquantified SF  
**Material Location**  
Stage  
**Material Description**  
12" X 12" Floor tile Light gray  
**Comments**  
This material was not in poor condition overall.  
**Does Material Contain Asbestos?** Assumed  
**Is it Friable?** No  
**Original Inspection Date** 6/27/2011  
**Current Surveillance Date** 4/21/2014  
**Current Assessment Rating** NA Not Applicable  
**Cause of Damage** No Damage  
**Accessible** Yes  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M

**Inspector**



---

Jeffrey P. Rechten

**State** Indiana  
**Accreditation Number** 19A003594

# PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools

**Building Name** Parkwood Elementary School

**HA#** A

**Type of Material** Miscellaneous Material

**Quantity of Material** Unquantified LF

**Material Location**

Throughout the building

**Material Description**

Cove base

**Comments**

There are minor signs of wear but this material was not in poor condition overall. Some has been replaced with new cove base.

**Does Material Contain Asbestos?** Assumed

**Is it Friable?** No

**Original Inspection Date** 5/31/1995

**Current Surveillance Date** 4/21/2014

**Current Assessment Rating** NR Not Rated

**Cause of Damage** No Damage

**Accessible** Yes

**Potential for Damage** Low

**Removed** No

**Planned Response Action** O & M

**Inspector**



---

Jeffrey P. Rechten

**State** Indiana

**Accreditation Number** 19A003594

# PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools

**Building Name** Parkwood Elementary School

**HA#** B

**Type of Material** Miscellaneous Material

**Quantity of Material** Approx 900 SF

**Material Location**  
Throughout the building

**Material Description**  
Cove base mastic

**Comments**  
Mastic was exposed to inspect in the library (By door) & gym and it was not in poor condition.

**Does Material Contain Asbestos?** No

**Is it Friable?** No

**Original Inspection Date** 5/31/1995

**Current Surveillance Date** 4/21/2014

**Current Assessment Rating** NR Not Rated

**Cause of Damage** No Damage

**Accessible** No

**Potential for Damage** Low

**Removed** No

**Planned Response Action** O & M

**Inspector**



---

Jeffrey P. Rechten

**State** Indiana

**Accreditation Number** 19A003594

# PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools

**Building Name** Parkwood Elementary School

**HA#** C

**Type of Material** Miscellaneous Material

**Quantity of Material** 2,114 SF

**Material Location**  
Outside building soffit

**Material Description**  
Transite soffit

**Comments**

This material is not in poor condition with some minor cracking around the edges. The first panel by the entrance has been replaced with grey material (possibly plywood). The 5th one from the left has a long crack in it but is still in place.

**Does Material Contain Asbestos?** Assumed  
**Is it Friable?** No  
**Original Inspection Date** 5/31/1995  
**Current Surveillance Date** 4/21/2014  
**Current Assessment Rating** NR Not Rated  
**Cause of Damage** No Damage  
**Accessible** Yes  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M

**Inspector**



---

Jeffrey P. Rechten

**State** Indiana

**Accreditation Number** 19A003594

# PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools

**Building Name** Parkwood Elementary School

**HA#** D

**Type of Material** Miscellaneous Material

**Quantity of Material** 0 SF

**Material Location**

Gymnasium and cafeteria

**Material Description**

Green shock joints on AHU

**Comments**

This material was not in poor condition. Four locations of material above gymnasium. This material was sampled by a licensed inspector and found to be a non-asbestos material by an accredited laboratory. Therefore, it is being removed from the management plan.

**Does Material Contain Asbestos?** No

**Is it Friable?** No

**Original Inspection Date** 5/31/1995

**Current Surveillance Date** 4/21/2014

**Current Assessment Rating** NR Not Rated

**Cause of Damage** No Damage

**Accessible** Yes

**Potential for Damage** Low

**Removed** Yes

**Planned Response Action** Remove

**Inspector**



---

Jeffrey P. Rechten

**State** Indiana

**Accreditation Number** 19A003594

# PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Parkwood Elementary School  
**HA#** 01  
**Type of Material** Thermal Material  
**Quantity of Material** Unquantified LF

**Material Location**

Above ceiling from boiler room to kitchen area. (halls, classrooms, storage room, restrooms) Behind refrigerator in custodial room.

**Material Description**


Fittings

**Comments**

This material was not in poor condition. It is seen above ceiling in the main hallway.

**Does Material Contain Asbestos?** Yes  
**Is it Friable?** No  
**Original Inspection Date** 6/1/1992  
**Current Surveillance Date** 10/24/2013  
**Current Assessment Rating** NR Not Rated  
**Cause of Damage** No Damage  
**Accessible** Yes  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M

**Inspector**



---

Jeffrey P. Rehtin

**State** Indiana  
**Accreditation Number** 19A003594

# PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Parkwood Elementary School  
**HA#** 02-A  
**Type of Material** Miscellaneous Material  
**Quantity of Material** Unquantified SF


**Material Location**  
Custodial Room & Classrooms

**Material Description**  
9"X9" tan floor tile (OLD)

**Comments**  
Most of this material is under carpet. This material shows normal wear, but was not in poor condition overall.

**Does Material Contain Asbestos?** Assumed  
**Is it Friable?** No  
**Original Inspection Date** 6/1/1992  
**Current Surveillance Date** 10/24/2013  
**Current Assessment Rating** NR Not Rated  
**Cause of Damage** No Damage  
**Accessible** Yes  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M

**Inspector**



Jeffrey P. Rehtin


**State** Indiana  
**Accreditation Number** 19A003594



# PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Parkwood Elementary School  
**HA#** 02-B  
**Type of Material** Miscellaneous Material  
**Quantity of Material** Unquantified SF  
**Material Location**  
Gym  
**Material Description**  
12"X12" Floor tile (NEWER) Light Blue  
**Comments**  
This material was not in poor condition overall.  
**Does Material Contain Asbestos?** Assumed  
**Is it Friable?** No  
**Original Inspection Date** 6/27/2011  
**Current Surveillance Date** 10/24/2013  
**Current Assessment Rating** NA Not Applicable  
**Cause of Damage** No Damage  
**Accessible** Yes  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M

**Inspector**



---


Jeffrey P. Rehtin

**State** Indiana  
**Accreditation Number** 19A003594

# PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Parkwood Elementary School  
**HA#** 02-C  
**Type of Material** Miscellaneous Material  
**Quantity of Material** Unquantified SF  
**Material Location**  
Cafeteria + custodial room  
**Material Description**  
12" X 12" Floor tile (NEWER) White  
**Comments**  
This material was not in poor condition overall.  
**Does Material Contain Asbestos?** Assumed  
**Is it Friable?** No  
**Original Inspection Date** 6/27/2011  
**Current Surveillance Date** 10/24/2013  
**Current Assessment Rating** NA Not Applicable  
**Cause of Damage** No Damage  
**Accessible** Yes  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M

**Inspector**




Jeffrey P. Rehtin

**State** Indiana  
**Accreditation Number** 19A003594

# PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Parkwood Elementary School  
**HA#** 02-D  
**Type of Material** Miscellaneous Material  
**Quantity of Material** Unquantified SF  
**Material Location**  
Cafeteria  
**Material Description**  
12" X 12" Floor tile (NEWER) Dark Blue  
**Comments**  
This material was not in poor condition overall.  
**Does Material Contain Asbestos?** Assumed  
**Is it Friable?** No  
**Original Inspection Date** 6/27/2011  
**Current Surveillance Date** 10/24/2013  
**Current Assessment Rating** NA Not Applicable  
**Cause of Damage** No Damage  
**Accessible** Yes  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M

**Inspector**



Jeffrey P. Rechten

**State** Indiana  
**Accreditation Number** 19A003594

# PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Parkwood Elementary School  
**HA#** 02-E  
**Type of Material** Miscellaneous Material  
**Quantity of Material** Unquantified SF  
**Material Location**  
Stage  
**Material Description**  
12" X 12" Floor tile Light gray  
**Comments**  
This material was not in poor condition overall.  
**Does Material Contain Asbestos?** Assumed  
**Is it Friable?** No  
**Original Inspection Date** 6/27/2011  
**Current Surveillance Date** 10/24/2013  
**Current Assessment Rating** NA Not Applicable  
**Cause of Damage** No Damage  
**Accessible** Yes  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M

**Inspector**



Jeffrey P. Rehtin

**State** Indiana  
**Accreditation Number** 19A003594

# PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools

**Building Name** Parkwood Elementary School

**HA#** A

**Type of Material** Miscellaneous Material

**Quantity of Material** Unquantified LF

**Material Location**

Throughout the building

**Material Description**

Cove base

**Comments**

There are minor signs of wear but this material was not in poor condition overall. Some has been replaced with new cove base.

**Does Material Contain Asbestos?** Assumed

**Is it Friable?** No

**Original Inspection Date** 5/31/1995

**Current Surveillance Date** 10/24/2013

**Current Assessment Rating** NR Not Rated

**Cause of Damage** No Damage


**Accessible** Yes

**Potential for Damage** Low

**Removed** No

**Planned Response Action** O & M

**Inspector**



---

Jeffrey P. Rehtin

**State** Indiana

**Accreditation Number** 19A003594

# PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools

**Building Name** Parkwood Elementary School

**HA#** B

**Type of Material** Miscellaneous Material

**Quantity of Material** Approx 900 SF

**Material Location**  
Throughout the building

**Material Description**  
Cove base mastic

**Comments**  
Mastic was exposed to inspect in the library (By door) & gym and it was not in poor condition.

**Does Material Contain Asbestos?** No

**Is it Friable?** No

**Original Inspection Date** 5/31/1995

**Current Surveillance Date** 10/24/2013

**Current Assessment Rating** NR Not Rated


**Cause of Damage** No Damage

**Accessible** No

**Potential for Damage** Low

**Removed** No

**Planned Response Action** O & M



**Inspector**

---

Jeffrey P. Rehtin

**State** Indiana

**Accreditation Number** 19A003594

# PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Parkwood Elementary School  
**HA#** C  
**Type of Material** Miscellaneous Material  
**Quantity of Material** 2,114 SF  
**Material Location**  
Outside building soffit


**Material Description**  
Transite soffit

**Comments**

This material is not in poor condition with some minor cracking around the edges. The first panel by the entrance has been replaced with grey material (possibly plywood). The 5th one from the left has a long crack in it but is still in place.

**Does Material Contain Asbestos?** Assumed  
**Is it Friable?** No  
**Original Inspection Date** 5/31/1995  
**Current Surveillance Date** 10/24/2013  
**Current Assessment Rating** NR Not Rated  
**Cause of Damage** No Damage  
**Accessible** Yes  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M

**Inspector**



---

Jeffrey P. Rehtin

**State** Indiana  
**Accreditation Number** 19A003594

# PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Parkwood Elementary School  
**HA#** D  
**Type of Material** Miscellaneous Material  
**Quantity of Material** 0 SF


**Material Location**  
Gymnasium and cafeteria

**Material Description**  
Green shock joints on AHU

**Comments**  
This material was not in poor condition. Four locations of material above gymnasium. This material was sampled by a licensed inspector and found to be a non-asbestos material by an accredited laboratory. Therefore, it is being removed from the management plan.

**Does Material Contain Asbestos?** No  
**Is it Friable?** No  
**Original Inspection Date** 5/31/1995  
**Current Surveillance Date** 10/24/2013  
**Current Assessment Rating** NR Not Rated  
**Cause of Damage** No Damage  
**Accessible** Yes  
**Potential for Damage** Low  
**Removed** Yes  
**Planned Response Action** Remove

**Inspector**



---

Jeffrey P. Rehtin

**State** Indiana  
**Accreditation Number** 19A003594



## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Parkwood Elementary School  
**HA#** 01  
**Type of Material** Thermal Material  
**Quantity of Material** Unquantified LF

**Material Location**

Above ceiling from boiler room to kitchen area. (halls, classrooms, storage room, restrooms) Behind refrigerator in custodial room.

**Material Description**

Fittings

**Comments**

This material was not in poor condition. It is seen above ceiling in the main hallway.

**Does Material Contain Asbestos?** Yes  
**Is it Friable?** No  
**Original Inspection Date** 6/1/1992  
**Current Surveillance Date** 10/24/2012  
**Current Assessment Rating** NR Not Rated  
**Cause of Damage** No Damage  
**Accessible** Yes  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M

**Inspector**



---

Jeffrey P. Rehtin

**State** Indiana  
**Accreditation Number** 19A003594

## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Parkwood Elementary School  
**HA#** 02-A  
**Type of Material** Miscellaneous Material  
**Quantity of Material** Unquantified SF

**Material Location**  
Custodial Room & Classrooms

**Material Description**  
9"X9" tan floor tile (OLD)

**Comments**

Most of this material is under carpet. This material shows normal wear, but was not in poor condition overall.

<b>Does Material Contain Asbestos?</b>	Assumed	
<b>Is it Friable?</b>	No	
<b>Original Inspection Date</b>	6/1/1992	
<b>Current Surveillance Date</b>	10/24/2012	
<b>Current Assessment Rating</b>	NR	Not Rated
<b>Cause of Damage</b>	No Damage	
<b>Accessible</b>	Yes	
<b>Potential for Damage</b>	Low	
<b>Removed</b>	No	
<b>Planned Response Action</b>	O & M	

**Inspector**



---

Jeffrey P. Rehtin

**State** Indiana  
**Accreditation Number** 19A003594

## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Parkwood Elementary School  
**HA#** 02-B  
**Type of Material** Miscellaneous Material  
**Quantity of Material** Unquantified SF  
**Material Location**  
Gym

**Material Description**

12"X12" Floor tile (NEWER) Light Blue

**Comments**

This material was not in poor condition overall.

**Does Material Contain Asbestos?** Assumed  
**Is it Friable?** No  
**Original Inspection Date** 6/27/2011  
**Current Surveillance Date** 10/24/2012  
**Current Assessment Rating** NA Not Applicable  
**Cause of Damage** No Damage  
**Accessible** Yes  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M

**Inspector**

  
\_\_\_\_\_  
Jeffrey P. Rehtin

**State** Indiana  
**Accreditation Number** 19A003594

## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools

**Building Name** Parkwood Elementary School

**HA#** 02-C

**Type of Material** Miscellaneous Material

**Quantity of Material** Unquantified SF

**Material Location**

Cafeteria + custodial room

**Material Description**

12" X 12" Floor tile (NEWER) White

**Comments**

This material was not in poor condition overall.

**Does Material Contain Asbestos?** Assumed

**Is it Friable?** No

**Original Inspection Date** 6/27/2011

**Current Surveillance Date** 10/24/2012

**Current Assessment Rating** NA Not Applicable

**Cause of Damage** No Damage

**Accessible** Yes

**Potential for Damage** Low

**Removed** No

**Planned Response Action** O & M

**Inspector**



---

Jeffrey P. Rechten

**State** Indiana

**Accreditation Number** 19A003594

## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Parkwood Elementary School  
**HA#** 02-D  
**Type of Material** Miscellaneous Material  
**Quantity of Material** Unquantified SF  
**Material Location**  
Cafeteria  
**Material Description**

12" X 12" Floor tile (NEWER) Dark Blue

**Comments**

This material was not in poor condition overall.

**Does Material Contain Asbestos?** Assumed  
**Is it Friable?** No  
**Original Inspection Date** 6/27/2011  
**Current Surveillance Date** 10/24/2012  
**Current Assessment Rating** NA Not Applicable  
**Cause of Damage** No Damage  
**Accessible** Yes  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M

**Inspector**



---

Jeffrey P. Rehtin

**State** Indiana  
**Accreditation Number** 19A003594

## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Parkwood Elementary School  
**HA#** 02-E  
**Type of Material** Miscellaneous Material  
**Quantity of Material** Unquantified SF  
**Material Location**  
**Stage**  
**Material Description**

12" X 12" Floor tile Light gray

**Comments**

This material was not in poor condition overall.

<b>Does Material Contain Asbestos?</b>	Assumed	
<b>Is it Friable?</b>	No	
<b>Original Inspection Date</b>	6/27/2011	
<b>Current Surveillance Date</b>	10/24/2012	
<b>Current Assessment Rating</b>	NA	Not Applicable
<b>Cause of Damage</b>	No Damage	
<b>Accessible</b>	Yes	
<b>Potential for Damage</b>	Low	
<b>Removed</b>	No	
<b>Planned Response Action</b>	O & M	

**Inspector**

  
\_\_\_\_\_  
Jeffrey P. Rehtin

**State** Indiana  
**Accreditation Number** 19A003594

## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Parkwood Elementary School  
**HA#** A  
**Type of Material** Miscellaneous Material  
**Quantity of Material** Unquantified LF

**Material Location**  
Throughout the building

**Material Description**  
Cove base

**Comments**

There are minor signs of wear but this material was not in poor condition overall. Some has been replaced with new cove base.

**Does Material Contain Asbestos?** Assumed  
**Is it Friable?** No  
**Original Inspection Date** 5/31/1995  
**Current Surveillance Date** 10/24/2012  
**Current Assessment Rating** NR Not Rated  
**Cause of Damage** No Damage  
**Accessible** Yes  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M

**Inspector**



---

Jeffrey P. Rechten

**State** Indiana  
**Accreditation Number** 19A003594

## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Parkwood Elementary School  
**HA#** B  
**Type of Material** Miscellaneous Material  
**Quantity of Material** Approx 900 SF

**Material Location**  
Throughout the building

**Material Description**  
Cove base mastic

**Comments**  
Mastic was exposed to inspect in the library (By door) & gym and it was not in poor condition.

**Does Material Contain Asbestos?** No  
**Is it Friable?** No  
**Original Inspection Date** 5/31/1995  
**Current Surveillance Date** 10/24/2012  
**Current Assessment Rating** NR Not Rated  
**Cause of Damage** No Damage  
**Accessible** No  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M

**Inspector**



---

Jeffrey P. Rehtin

**State** Indiana  
**Accreditation Number** 19A003594



## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Parkwood Elementary School  
**HA#** C  
**Type of Material** Miscellaneous Material  
**Quantity of Material** 2,114 SF

**Material Location**  
Outside building soffit

**Material Description**  
Transite soffit

**Comments**

This material is not in poor condition with some minor cracking around the edges. The first panel by the entrance has been replaced with grey material (possibly plywood). The 5th one from the left has a long crack in it but is still in place.

**Does Material Contain Asbestos?** Assumed  
**Is it Friable?** No  
**Original Inspection Date** 5/31/1995  
**Current Surveillance Date** 10/24/2012  
**Current Assessment Rating** NR Not Rated  
**Cause of Damage** No Damage  
**Accessible** Yes  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M

**Inspector**

  
\_\_\_\_\_  
Jeffrey P. Rehtin

**State** Indiana  
**Accreditation Number** 19A003594

## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Parkwood Elementary School  
**HA#** D  
**Type of Material** Miscellaneous Material  
**Quantity of Material** 0 SF

**Material Location**  
Gymnasium and cafeteria

**Material Description**  
Green shock joints on AHU

**Comments**

This material was not in poor condition. Four locations of material above gymnasium. This material was sampled by a licensed inspector and found to be a non-asbestos material by an accredited laboratory. Therefore, it is being removed from the management plan.

**Does Material Contain Asbestos?** No  
**Is it Friable?** No  
**Original Inspection Date** 5/31/1995  
**Current Surveillance Date** 10/24/2012  
**Current Assessment Rating** NR Not Rated  
**Cause of Damage** No Damage  
**Accessible** Yes  
**Potential for Damage** Low  
**Removed** Yes  
**Planned Response Action** Remove

**Inspector**

  
\_\_\_\_\_  
Jeffrey P. Rehtin

**State** Indiana  
**Accreditation Number** 19A003594

## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Parkwood Elementary School  
**HA#** 01  
**Type of Material** Thermal Material  
**Quantity of Material** Unquantified LF

**Material Location**

Above ceiling from boiler room to kitchen area. (halls, classrooms, storage room, restrooms) Behind refrigerator in custodial room.

**Material Description**

Fittings

**Comments**

This material was not in poor condition. It is seen above ceiling in the main hallway.

**Does Material Contain Asbestos?** Yes  
**Is it Friable?** No  
**Original Inspection Date** 6/1/1992  
**Current Surveillance Date** 6/25/2012  
**Current Assessment Rating** NR Not Rated  
**Cause of Damage** No Damage  
**Accessible** Yes  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M

**Inspector**

  
\_\_\_\_\_  
Jeffery P. Rehtin

**State** Indiana  
**Accreditation Number** 19A003594

## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Parkwood Elementary School  
**HA#** 02-A  
**Type of Material** Miscellaneous Material  
**Quantity of Material** Unquantified SF

**Material Location**  
Custodial Room & Classrooms

**Material Description**  
9"X9" tan floor tile (OLD)

**Comments**

Most of this material is under carpet. This material shows normal wear, but was not in poor condition overall.

**Does Material Contain Asbestos?** Assumed  
**Is it Friable?** No  
**Original Inspection Date** 6/1/1992  
**Current Surveillance Date** 6/25/2012  
**Current Assessment Rating** NR Not Rated  
**Cause of Damage** No Damage  
**Accessible** Yes  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M

**Inspector**

  
\_\_\_\_\_  
Jeffrey P. Reecht

**State** Indiana  
**Accreditation Number** 19A003594

## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Parkwood Elementary School  
**HA#** 02-B  
**Type of Material** Miscellaneous Material  
**Quantity of Material** Unquantified SF  
**Material Location**  
Gym  
**Material Description**

12"X12" Floor tile (NEWER) Light Blue

**Comments**

This material was not in poor condition overall.

**Does Material Contain Asbestos?** Assumed  
**Is it Friable?** No  
**Original Inspection Date** 6/27/2011  
**Current Surveillance Date** 6/25/2012  
**Current Assessment Rating** NA Not Applicable  
**Cause of Damage** No Damage  
**Accessible** Yes  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M

**Inspector**

  
\_\_\_\_\_  
Jeffery P. Rechin

**State** Indiana  
**Accreditation Number** 19A003594

## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Parkwood Elementary School  
**HA#** 02-C  
**Type of Material** Miscellaneous Material  
**Quantity of Material** Unquantified SF


**Material Location**  
Cafeteria + custodial room

**Material Description**  
12" X 12" Floor tile (NEWER) White

**Comments**  
This material was not in poor condition overall.

**Does Material Contain Asbestos?** Assumed  
**Is it Friable?** No  
**Original Inspection Date** 6/27/2011  
**Current Surveillance Date** 6/25/2012  
**Current Assessment Rating** NA Not Applicable  
**Cause of Damage** No Damage  
**Accessible** Yes  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M

**Inspector**

  
\_\_\_\_\_  
Jeffrey P. Rehtin

**State** Indiana  
**Accreditation Number** 19A003594

## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Parkwood Elementary School  
**HA#** 02-D  
**Type of Material** Miscellaneous Material  
**Quantity of Material** Unquantified SF  
**Material Location**  
Cafeteria  
**Material Description**

12" X 12" Floor tile (NEWER) Dark Blue

**Comments**

This material was not in poor condition overall.

**Does Material Contain Asbestos?** Assumed  
**Is it Friable?** No  
**Original Inspection Date** 6/27/2011  
**Current Surveillance Date** 6/25/2012  
**Current Assessment Rating** NA Not Applicable  
**Cause of Damage** No Damage  
**Accessible** Yes  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M

**Inspector**

  
Jeffrey P. Rehtin

**State** Indiana  
**Accreditation Number** 19A003594

## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Parkwood Elementary School  
**HA#** 02-E  
**Type of Material** Miscellaneous Material  
**Quantity of Material** Unquantified SF  
**Material Location**  
**Stage**  
**Material Description**


12" X 12" Floor tile Light gray

**Comments**

This material was not in poor condition overall.

**Does Material Contain Asbestos?** Assumed  
**Is it Friable?** No  
**Original Inspection Date** 6/27/2011  
**Current Surveillance Date** 6/25/2012  
**Current Assessment Rating** NA Not Applicable  
**Cause of Damage** No Damage  
**Accessible** Yes  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M

**Inspector**

  
\_\_\_\_\_  
Jeffery P. Rechin

**State** Indiana  
**Accreditation Number** 19A003594



## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Parkwood Elementary School  
**HA#** A  
**Type of Material** Miscellaneous Material  
**Quantity of Material** Unquantified LF

**Material Location**  
Throughout the building

**Material Description**  
Cove base

**Comments**

There are minor signs of wear but this material was not in poor condition overall. Some has been replaced with new cove base.

**Does Material Contain Asbestos?** Assumed  
**Is it Friable?** No  
**Original Inspection Date** 5/31/1995  
**Current Surveillance Date** 6/25/2012  
**Current Assessment Rating** NR Not Rated  
**Cause of Damage** No Damage  
**Accessible** Yes  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M

**Inspector**

  
\_\_\_\_\_  
Jeffery P. Rechin

**State** Indiana  
**Accreditation Number** 19A003594

## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Parkwood Elementary School  
**HA#** B  
**Type of Material** Miscellaneous Material  
**Quantity of Material** Approx 900 SF

**Material Location**  
Throughout the building

**Material Description**  
Cove base mastic

**Comments**

Mastic was exposed to inspect in the library (By door) & gym and it was not in poor condition.

**Does Material Contain Asbestos?** No  
**Is it Friable?** No  
**Original Inspection Date** 5/31/1995  
**Current Surveillance Date** 6/25/2012  
**Current Assessment Rating** NR Not Rated  
**Cause of Damage** No Damage  
**Accessible** No  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M

**Inspector**

  
\_\_\_\_\_  
Jeffery P. Rehtin

**State** Indiana  
**Accreditation Number** 19A003594

## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Parkwood Elementary School  
**HA#** C  
**Type of Material** Miscellaneous Material  
**Quantity of Material** 2,114 SF

**Material Location**  
Outside building soffit

**Material Description**  
Transite soffit

**Comments**

This material is not in poor condition with some minor cracking around the edges. The first panel by the entrance has been replaced with grey material (possibly plywood). The 5th one from the left has a long crack in it but is still in place.

**Does Material Contain Asbestos?** Assumed  
**Is it Friable?** No  
**Original Inspection Date** 5/31/1995  
**Current Surveillance Date** 6/25/2012  
**Current Assessment Rating** NR Not Rated  
**Cause of Damage** No Damage  
**Accessible** Yes  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M

**Inspector**

  
\_\_\_\_\_  
Jeffery P. Rehtin

**State** Indiana  
**Accreditation Number** 19A003594

## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Parkwood Elementary School  
**HA#** D  
**Type of Material** Miscellaneous Material  
**Quantity of Material** 0 SF

**Material Location**  
Gymnasium and cafeteria

**Material Description**  
Green shock joints on AHU

**Comments**

This material was not in poor condition. Four locations of material above gymnasium. This material was sampled by a licensed inspector and found to be a non-asbestos material by an accredited laboratory. Therefore, it is being removed from the management plan.

**Does Material Contain Asbestos?** No  
**Is it Friable?** No  
**Original Inspection Date** 5/31/1995  
**Current Surveillance Date** 6/25/2012  
**Current Assessment Rating** NR Not Rated  
**Cause of Damage** No Damage  
**Accessible** Yes  
**Potential for Damage** Low  
**Removed** Yes  
**Planned Response Action** Remove

**Inspector**

  
Jeffery P. Rehtin

**State** Indiana  
**Accreditation Number** 19A003594

## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Parkwood Elementary School  
**HA#** 01  
**Type of Material** Thermal Material  
**Quantity of Material** Unquantified LF

**Material Location**

Above ceiling from boiler room to kitchen area. (halls, classrooms, storage room, restrooms) Behind refrigerator in custodial room.

**Material Description**


Fittings

**Comments**

This material was not in poor condition. It is easily seen above ceiling in the main hallway. The boiler/mechanical room fittings and the air handler room fittings (30) were abated by a licensed contractor in the summer of 2011 HVAC renovation.


**Does Material Contain Asbestos?** Yes  
**Is it Friable?** No  
**Original Inspection Date** 6/1/1992  
**Current Surveillance Date** 6/27/2011  
**Current Assessment Rating** NR Not Required  
**Cause of Damage** No Damage  
**Accessible** Yes  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M

**Inspector**

  
Sandra Shadley

**State** Indiana  
**Accreditation Number** 19A002323

## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Parkwood Elementary School  
**HA#** 02-A  
**Type of Material** Miscellaneous Material  
**Quantity of Material** Unquantified SF  
**Material Location**  
Custodial Room & Classrooms  
**Material Description**  
9"X9" Floor tile (OLD)  
**Comments**  
This material was not in poor condition overall.  
**Does Material Contain Asbestos?** Assumed  
**Is it Friable?** No  
**Original Inspection Date** 6/1/1992  
**Current Surveillance Date** 6/27/2011  
**Current Assessment Rating** NR Not Required  
**Cause of Damage** No Damage  
**Accessible** Yes  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M  
**Inspector**  
  
Sandra Shadley  
**State** Indiana  
**Accreditation Number** 19A002323

## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Parkwood Elementary School  
**HA#** 02-B  
**Type of Material** Miscellaneous Material  
**Quantity of Material** Unquantified SF

**Material Location**  
Gym


**Material Description**  
12"X12" Floor tile (NEWER) Light Blue

**Comments**

This material was not in poor condition overall.

**Does Material Contain Asbestos?** Assumed  
**Is it Friable?** No  
**Original Inspection Date** 6/27/2011  
**Current Surveillance Date** 6/27/2011  
**Current Assessment Rating** NA Not Applicable  
**Cause of Damage** No Damage  
**Accessible** Yes  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M

**Inspector**

  
Sandra Shadley

**State** Indiana  
**Accreditation Number** 19A002323

## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools

**Building Name** Parkwood Elementary School

**HA#** 02-C

**Type of Material** Miscellaneous Material

**Quantity of Material** Unquantified SF

**Material Location**

Cafeteria + custodial room

**Material Description**

12" X 12" Floor tile (NEWER) White

**Comments**

This material was not in poor condition overall.

**Does Material Contain Asbestos?** Assumed

**Is it Friable?** No

**Original Inspection Date** 6/27/2011

**Current Surveillance Date** 6/27/2011

**Current Assessment Rating** NA Not Applicable

**Cause of Damage** No Damage


**Accessible** Yes

**Potential for Damage** Low

**Removed** No

**Planned Response Action** O & M

**Inspector**

  
Sandra Shadley

**State** Indiana

**Accreditation Number** 19A002323



## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Parkwood Elementary School  
**HA#** 02-D  
**Type of Material** Miscellaneous Material  
**Quantity of Material** Unquantified SF

**Material Location**  
Cafeteria

**Material Description**

12" X 12" Floor tile (NEWER) Dark Blue

**Comments**

This material was not in poor condition overall.

**Does Material Contain Asbestos?** Assumed  
**Is it Friable?** No  
**Original Inspection Date** 6/27/2011  
**Current Surveillance Date** 6/27/2011  
**Current Assessment Rating** NA Not Applicable  
**Cause of Damage** No Damage  
**Accessible** Yes  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M

**Inspector**

  
Sandra Shadley

**State** Indiana  
**Accreditation Number** 19A002323

## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Parkwood Elementary School  
**HA#** 02-E  
**Type of Material** Miscellaneous Material  
**Quantity of Material** Unquantified SF

**Material Location**  
Stage

**Material Description**


12" X 12" Floor tile Light gray

**Comments**

This material was not in poor condition overall.

**Does Material Contain Asbestos?** Assumed  
**Is it Friable?** No  
**Original Inspection Date** 6/27/2011  
**Current Surveillance Date** 6/27/2011  
**Current Assessment Rating** NA Not Applicable  
**Cause of Damage** No Damage  
**Accessible** Yes  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M

**Inspector**

  
Sandra Shadley

**State** Indiana  
**Accreditation Number** 19A002323

## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Parkwood Elementary School  
**HA#** A  
**Type of Material** Miscellaneous Material  
**Quantity of Material** Unquantified LF

**Material Location**  
Throughout the building


**Material Description**  
Cove base

**Comments**

There are minor signs of wear but this material was not in poor condition overall. Some has been replaced with new cove base.

**Does Material Contain Asbestos?** Assumed  
**Is it Friable?** No  
**Original Inspection Date** 5/31/1995  
**Current Surveillance Date** 6/27/2011  
**Current Assessment Rating** NR Not Required  
**Cause of Damage** No Damage  
**Accessible** Yes  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M

**Inspector**

  
Sandra Shadley

**State** Indiana  
**Accreditation Number** 19A002323

## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Parkwood Elementary School  
**HA#** B  
**Type of Material** Miscellaneous Material  
**Quantity of Material** Approx 900 SF


**Material Location**  
Throughout the building

**Material Description**  
Cove base mastic

**Comments**  
Mastic was exposed to inspect in the library (By door) & gym and it was not in poor condition.

**Does Material Contain Asbestos?** No  
**Is it Friable?** No  
**Original Inspection Date** 5/31/1995  
**Current Surveillance Date** 6/27/2011  
**Current Assessment Rating** NR Not Required  
**Cause of Damage** No Damage  
**Accessible** No  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M

**Inspector**

  
Sandra Shadley

**State** Indiana  
**Accreditation Number** 19A002323

## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Parkwood Elementary School  
**HA#** C  
**Type of Material** Miscellaneous Material  
**Quantity of Material** 2,114 SF

**Material Location**  
Outside building soffit

**Material Description**  
Transite soffit

**Comments**

This material is not in poor condition with some minor cracking around the edges. The first panel by the entrance has been replaced with grey material (possibly plywood). The 5th one from the left has a long crack in it but is still in place.

**Does Material Contain Asbestos?** Assumed  
**Is it Friable?** No  
**Original Inspection Date** 5/31/1995  
**Current Surveillance Date** 6/27/2011  
**Current Assessment Rating** NR Not Required  
**Cause of Damage** No Damage  
**Accessible** Yes  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M

**Inspector**

  
Sandra Shadley

**State** Indiana  
**Accreditation Number** 19A002323

## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Parkwood Elementary School  
**HA#** D  
**Type of Material** Miscellaneous Material  
**Quantity of Material** 0 SF

**Material Location**  
Gymnasium and cafeteria


**Material Description**  
Green shock joints on AHU

**Comments**

This material was not in poor condition. Four locations of material above gymnasium. This material was sampled by a licensed inspector and found to be a non-asbestos material by an accredited laboratory. Therefore, it is being removed from the management plan.

**Does Material Contain Asbestos?** No  
**Is it Friable?** No  
**Original Inspection Date** 5/31/1995  
**Current Surveillance Date** 6/27/2011  
**Current Assessment Rating** NR Not Required  
**Cause of Damage** No Damage  
**Accessible** Yes  
**Potential for Damage** Low  
**Removed** Yes  
**Planned Response Action** Remove

**Inspector**

  
Sandra Shadley

**State** Indiana  
**Accreditation Number** 19A002323

## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Parkwood Elementary School  
**HA#** 01  
**Type of Material** Thermal Material  
**Quantity of Material** Unquantified LF

**Material Location**

Above ceiling from boiler room to kitchen area. (halls, classrooms, boiler room/mechanical room, storage room, restrooms) Behind refrigerator in custodial room.

**Material Description**

Fittings

**Comments**

This material was not in poor condition. It is easily seen in the boiler room/mechanical room in the main hallway and in the air handler room above the gymnasium. These fittings are painted yellow, blue, gray and red.

**Does Material Contain Asbestos?** Yes  
**Is it Friable?** No  
**Original Inspection Date** 6/1/1992  
**Current Surveillance Date** 12/6/2010  
**Current Assessment Rating** NR Not Required  
**Cause of Damage** No Damage  
**Accessible** Yes  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M

**Inspector**



Paul W. Krick

**State** Indiana  
**Accreditation Number** 197812124

## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Parkwood Elementary School  
**HA#** 02  
**Type of Material** Miscellaneous Material  
**Quantity of Material** Unquantified SF

**Material Location**  
Throughout the building

**Material Description**  
Floor tile

**Comments**

There is newer floor tile in the gymnasium and cafeteria. The custodial room is mostly old 9 X 9 light brown floor tile. This material was not in poor condition overall. Classrooms have a combination of 9 X 9 floor tile and carpet.

**Does Material Contain Asbestos?** Assumed  
**Is it Friable?** No  
**Original Inspection Date** 6/1/1992  
**Current Surveillance Date** 12/6/2010  
**Current Assessment Rating** NR Not Required  
**Cause of Damage** No Damage  
**Accessible** Yes  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M

**Inspector**

  
\_\_\_\_\_  
Paul W. Krick

**State** Indiana  
**Accreditation Number** 197812124



## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Parkwood Elementary School  
**HA#** A  
**Type of Material** Miscellaneous Material  
**Quantity of Material** Unquantified LF

**Material Location**  
Throughout the building


**Material Description**  
Cove base

**Comments**

There are minor signs of wear but this material was not in poor condition overall. Some has been replaced with new cove base.

**Does Material Contain Asbestos?** Assumed  
**Is it Friable?** No  
**Original Inspection Date** 5/31/1995  
**Current Surveillance Date** 12/6/2010  
**Current Assessment Rating** NR Not Required  
**Cause of Damage** No Damage  
**Accessible** Yes  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M

**Inspector**




Paul W. Krick

**State** Indiana  
**Accreditation Number** 197812124

## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Parkwood Elementary School  
**HA#** B  
**Type of Material** Miscellaneous Material  
**Quantity of Material** Approx. 900 SF  
**Material Location**  
Throughout the building  
**Material Description**  
Cove base mastic  
**Comments**  
No mastic was exposed to inspect.  
**Does Material Contain Asbestos?** Assumed  
**Is it Friable?** No  
**Original Inspection Date** 5/31/1995  
**Current Surveillance Date** 12/6/2010  
**Current Assessment Rating** NR Not Required  
**Cause of Damage** No Damage  
**Accessible** No  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M

**Inspector**



Paul W. Krick

**State** Indiana  
**Accreditation Number** 197812124

# PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Parkwood Elementary School  
**HA#** C  
**Type of Material** Miscellaneous Material  
**Quantity of Material** 2,114 SF

**Material Location**  
Outside building soffit


**Material Description**  
Transite soffit

**Comments**

This material is not in poor condition with some minor cracking around the edges. The first panel by the entrance has been replaced with grey material (possibly plywood). The 5th one from the left has a long crack in it but is still in place.

**Does Material Contain Asbestos?** Assumed  
**Is it Friable?** No  
**Original Inspection Date** 5/31/1995  
**Current Surveillance Date** 12/6/2010  
**Current Assessment Rating** NR Not Required  
**Cause of Damage** No Damage  
**Accessible** Yes  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M

**Inspector**



Paul W. Krick

**State** Indiana  
**Accreditation Number** 197812124

## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Parkwood Elementary School  
**HA#** D  
**Type of Material** Miscellaneous Material  
**Quantity of Material** 120 SF

**Material Location**  
Gymnasium and cafeteria

**Material Description**


Green shock joints on AHU

**Comments**

This material was not in poor condition. Four locations of material above gymnasium. No shock joint was visible on the unit in the kitchen stockroom. Could not locate during this inspection.

**Does Material Contain Asbestos?** Assumed  
**Is it Friable?** No  
**Original Inspection Date** 5/31/1995  
**Current Surveillance Date** 12/6/2010  
**Current Assessment Rating** NR Not Required  
**Cause of Damage** No Damage  
**Accessible** Yes  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M

**Inspector**

  
\_\_\_\_\_  
Paul W. Krick

**State** Indiana  
**Accreditation Number** 197812124

## PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools

Building Name Parkwood Elementary School

HA# 01

Type of Material Thermal Material

Quantity of Material Unquantified LF

**Material Location**

Above ceiling from boiler room to kitchen area. (halls, classrooms, boiler room/mechanical room, storage room, restrooms)

**Material Description**

Fittings

**Comments**

This material was not in poor condition. It is easily seen in the boiler room/mechanical room in the main hallway and in the air handler room above the gymnasium.

Does Material Contain Asbestos? Yes

Is it Friable? No

Original Inspection Date 6/1/1992

Current Surveillance Date 12/4/2009

Current Assessment Rating NR Not Required

Cause of Damage No Damage


Accessible Yes

Potential for Damage Low

Removed No

Planned Response Action O & M

Inspector

  
George William Ogle

State Indiana

Accreditation Number 191003027

## PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools  
Building Name Parkwood Elementary School  
HA# 02  
Type of Material Miscellaneous Material  
Quantity of Material Unquantified SF

### Material Location

Throughout the building

### Material Description

Floor tile

### Comments

There is newer floor tile in the gymnasium. Floor tile is under carpet in cafeteria. There are some chipped edges around the sink in the custodial room. The custodial room has been divided by a wall. The other side has carpet over the floor tile. This material was not in poor condition overall.

Does Material Contain Asbestos? Assumed  
Is it Friable? No  
Original Inspection Date 6/1/1992  
Current Surveillance Date 12/4/2009  
Current Assessment Rating NR Not Required  
Cause of Damage No Damage  
Accessible Yes  
Potential for Damage Low  
Removed No  
Planned Response Action O & M

Inspector

  
George William Ogle

State

Indiana

Accreditation Number

191003027

## PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools

Building Name Parkwood Elementary School

HA# A

Type of Material Miscellaneous Material

Quantity of Material Approx. 2,800 LF

Material Location  
Throughout the building

Material Description

Cove base

Comments

There are minor signs of wear but this material was not in poor condition overall.

Does Material Contain Asbestos? Assumed

Is it Friable? No

Original Inspection Date 5/31/1995

Current Surveillance Date 12/4/2009

Current Assessment Rating NR Not Required

Cause of Damage No Damage

Accessible Yes

Potential for Damage Low

Removed No

Planned Response Action O & M

Inspector

  
George William Ogle

State Indiana

Accreditation Number 191003027

# PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools  
Building Name Parkwood Elementary School  
HA# B  
Type of Material Miscellaneous Material  
Quantity of Material Approx. 900 SF  
Material Location Throughout the building  
Material Description Cove base mastic  
Comments No mastic was exposed to inspect.  
Does Material Contain Asbestos? Assumed  
Is it Friable? No  
Original Inspection Date 5/31/1995  
Current Surveillance Date 12/4/2009  
Current Assessment Rating NR Not Required  
Cause of Damage No Damage  
Accessible No  
Potential for Damage Low  
Removed No  
Planned Response Action O & M

Inspector

  
George William Ogle

State

Indiana

Accreditation Number

191003027



## PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools  
Building Name Parkwood Elementary School  
HA# C  
Type of Material Miscellaneous Material  
Quantity of Material 2,114 SF  
Material Location

Outside building soffit

### Material Description

Transite soffit

### Comments

This material is not in poor condition with some minor cracking around the edges. The first panel by the entrance has been replaced with grey material (possibly plywood). The 5th one from the left has a long crack in it but is still in place.

Does Material Contain Asbestos? Assumed  
Is it Friable? No  
Original Inspection Date 5/31/1995  
Current Surveillance Date 12/4/2009  
Current Assessment Rating NR Not Required  
Cause of Damage No Damage  
Accessible Yes  
Potential for Damage Low  
Removed No  
Planned Response Action O & M

Inspector

  
George William Ogle

State

Indiana

Accreditation Number

191003027

# PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools

Building Name Parkwood Elementary School

HA# D

Type of Material Miscellaneous Material

Quantity of Material 120 SF

Material Location  
Gymnasium and cafeteria

Material Description  
Green shock joints on AHU

Comments  
This material was not in poor condition. Four locations of material above gymnasium.  
No shock joint was visible on the unit in the kitchen stockroom.

Does Material Contain Asbestos?	Assumed
Is it Friable?	No
Original Inspection Date	5/31/1995
Current Surveillance Date	12/4/2009
Current Assessment Rating	NR Not Required
Cause of Damage	No Damage
Accessible	Yes
Potential for Damage	Low
Removed	No
Planned Response Action	O & M

Inspector

  
George William Ogle

State

Indiana

Accreditation Number

191003027

## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Parkwood Elementary School  
**HA#** 01  
**Type of Material** Thermal Material  
**Quantity of Material** Unquantified LF

**Material Location**

Above ceiling from boiler room to kitchen area. (halls, classrooms, boiler room/mechanical room, storage room, restrooms)

**Material Description**

Fittings

**Comments**

This material was not in poor condition. It is easily seen in the boiler room/mechanical room in the main hallway and in the air handler room above the gymnasium.

**Does Material Contain Asbestos?** Yes  
**Is it Friable?** No  
**Original Inspection Date** 6/1/1992  
**Current Surveillance Date** 6/10/2009  
**Current Assessment Rating** NR Not Required  
**Cause of Damage** No Damage  
**Accessible** Yes  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M

**Inspector**

  
George William Ogle

**State** IN  
**Accreditation Number** 191003027

## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Parkwood Elementary School  
**HA#** 02  
**Type of Material** Miscellaneous Material  
**Quantity of Material** Unquantified SF

**Material Location**  
Throughout the building

**Material Description**

Floor tile

**Comments**

There is newer floor tile in the gymnasium. Floor tile is under carpet in cafeteria. There are some chipped edges around the sink in the custodial room. The custodial room has been divided by a wall. The other side has carpet over the floor tile. This material was not in poor condition overall.

**Does Material Contain Asbestos?** Assumed  
**Is it Friable?** No  
**Original Inspection Date** 6/1/1992  
**Current Surveillance Date** 6/10/2009  
**Current Assessment Rating** NR Not Required  
**Cause of Damage** No Damage  
**Accessible** Yes  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M

**Inspector**

  
George William Ogle

**State** IN  
**Accreditation Number** 191003027

## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Parkwood Elementary School  
**HA#** A  
**Type of Material** Miscellaneous Material  
**Quantity of Material** Approx. 2,800 LF

**Material Location**  
Throughout the building

**Material Description**  
Cove base

**Comments**

There are minor signs of wear but this material was not in poor condition overall. (The missing piece by Room 26 has been replaced.)

**Does Material Contain Asbestos?** Assumed  
**Is it Friable?** No  
**Original Inspection Date** 5/31/1995  
**Current Surveillance Date** 6/10/2009  
**Current Assessment Rating** NR Not Required  
**Cause of Damage** No Damage  
**Accessible** Yes  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M

**Inspector**

  
George William Ogle

**State** IN  
**Accreditation Number** 191003027

# PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Parkwood Elementary School  
**HA#** B  
**Type of Material** Miscellaneous Material  
**Quantity of Material** Approx. 900 SF  
**Material Location**  
Throughout the building  
**Material Description**  
Cove base mastic  
**Comments**  
No mastic was exposed to inspect.  
**Does Material Contain Asbestos?** Assumed  
**Is it Friable?** No  
**Original Inspection Date** 5/31/1995  
**Current Surveillance Date** 6/10/2009  
**Current Assessment Rating** NR Not Required  
**Cause of Damage** No Damage  
**Accessible** No  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M

**Inspector**

  
George William Ogle

**State**

IN

**Accreditation Number**

191003027

## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Parkwood Elementary School  
**HA#** C  
**Type of Material** Miscellaneous Material  
**Quantity of Material** 2,114 SF

**Material Location**  
Outside building soffit

**Material Description**  
Transite soffit

**Comments**

This material is not in poor condition with some minor cracking around the edges. The first panel by the entrance has been replaced with grey material (possibly plywood). The 5th one from the left has a long crack in it but is still in place.

**Does Material Contain Asbestos?** Assumed  
**Is it Friable?** No  
**Original Inspection Date** 5/31/1995  
**Current Surveillance Date** 6/10/2009  
**Current Assessment Rating** NR Not Required  
**Cause of Damage** No Damage  
**Accessible** Yes  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M

**Inspector**

  
George William Ogle

**State** IN  
**Accreditation Number** 191003027

# PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools

**Building Name** Parkwood Elementary School

**HA#** D

**Type of Material** Miscellaneous Material

**Quantity of Material** 120 SF

**Material Location**  
Gymnasium and cafeteria

**Material Description**  
Green shock joints on AHU

**Comments**

This material was not in poor condition. Four locations of material above gymnasium. No shock joint was visible on the unit in the kitchen stockroom.

<b>Does Material Contain Asbestos?</b>	Assumed
<b>Is it Friable?</b>	No
<b>Original Inspection Date</b>	5/31/1995
<b>Current Surveillance Date</b>	6/10/2009
<b>Current Assessment Rating</b>	NR Not Required
<b>Cause of Damage</b>	No Damage
<b>Accessible</b>	Yes
<b>Potential for Damage</b>	Low
<b>Removed</b>	No
<b>Planned Response Action</b>	O & M

**Inspector**

  
George William Ogle

**State**

IN

**Accreditation Number**

191003027



## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Parkwood Elementary School  
**HA#** 01  
**Type of Material** Thermal Material  
**Quantity of Material** Unquantified LF

**Material Location**

Above ceiling from boiler room to kitchen area. (halls, classrooms, boiler room/mechanical room, storage room, restrooms)

**Material Description**

Fittings

**Comments**

This material was not in poor condition. It is easily seen in the boiler room/mechanical room in the main hallway and in the air handler room above the gymnasium.

**Does Material Contain Asbestos?** Yes  
**Is it Friable?** No  
**Original Inspection Date** 6/1/1992  
**Current Surveillance Date** 12/10/2008  
**Current Assessment Rating** NR Not Required  
**Cause of Damage** No Damage  
**Accessible** Yes  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M

**Inspector**

  
George William Ogle

**State**

Indiana

**Accreditation Number**

191003027

## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Parkwood Elementary School  
**HA#** 02  
**Type of Material** Miscellaneous Material  
**Quantity of Material** Unquantified SF

**Material Location**

Throughout the building

**Material Description**

Floor tile

**Comments**

There is newer floor tile in the gymnasium. Floor tile is under carpet in cafeteria. There are some chipped edges around the sink in the custodial room. The custodial room has been divided by a wall. The other side has carpet over the floor tile. This material was not in poor condition overall.

**Does Material Contain Asbestos?** Assumed  
**Is it Friable?** No  
**Original Inspection Date** 6/1/1992  
**Current Surveillance Date** 12/10/2008  
**Current Assessment Rating** NR Not Required  
**Cause of Damage** No Damage  
**Accessible** Yes  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M

**Inspector**

  
George William Ogle

**State** Indiana  
**Accreditation Number** 191003027

## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Parkwood Elementary School  
**HA#** A  
**Type of Material** Miscellaneous Material  
**Quantity of Material** Approx. 2,800 LF

**Material Location**  
Throughout the building

**Material Description**  
Cove base

**Comments**  
There are minor signs of wear but this material was not in poor condition overall. (The missing piece by Room 26 has been replaced.)

**Does Material Contain Asbestos?** Assumed  
**Is it Friable?** No  
**Original Inspection Date** 5/31/1995  
**Current Surveillance Date** 12/10/2008  
**Current Assessment Rating** NR Not Required  
**Cause of Damage** No Damage  
**Accessible** Yes  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M

**Inspector**

  
George William Ogle

**State** Indiana  
**Accreditation Number** 191003027

## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Parkwood Elementary School  
**HA#** B  
**Type of Material** Miscellaneous Material  
**Quantity of Material** Approx. 900 SF  
**Material Location**  
Throughout the building  
**Material Description**  
Cove base mastic  
**Comments**  
No mastic was exposed to inspect.  
**Does Material Contain Asbestos?** Assumed  
**Is it Friable?** No  
**Original Inspection Date** 5/31/1995  
**Current Surveillance Date** 12/10/2008  
**Current Assessment Rating** NR Not Required  
**Cause of Damage** No Damage  
**Accessible** No  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M

**Inspector**

  
George William Ogle

**State**

Indiana

**Accreditation Number**

191003027

## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Parkwood Elementary School  
**HA#** C  
**Type of Material** Miscellaneous Material  
**Quantity of Material** 2,114 SF

**Material Location**  
Outside building soffit


**Material Description**  
Transite soffit

**Comments**

This material is not in poor condition with some minor cracking around the edges. The first panel by the entrance has been replaced with grey material (possibly plywood). The 5th one from the left has a long crack in it but is still in place.

**Does Material Contain Asbestos?** Assumed  
**Is it Friable?** No  
**Original Inspection Date** 5/31/1995  
**Current Surveillance Date** 12/10/2008  
**Current Assessment Rating** NR Not Required  
**Cause of Damage** No Damage  
**Accessible** Yes  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M

**Inspector**

  
George William Ogle

**State** Indiana  
**Accreditation Number** 191003027

## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Parkwood Elementary School  
**HA#** D  
**Type of Material** Miscellaneous Material  
**Quantity of Material** 120 SF

**Material Location**  
Gymnasium and cafeteria

**Material Description**  
Green shock joints on AHU

**Comments**

This material was not in poor condition. Four locations of material above gymnasium.  
No shock joint was visible on the unit in the kitchen stockroom.

**Does Material Contain Asbestos?** Assumed  
**Is it Friable?** No  
**Original Inspection Date** 5/31/1995  
**Current Surveillance Date** 12/10/2008  
**Current Assessment Rating** NR Not Required  
**Cause of Damage** No Damage  
**Accessible** Yes  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M

**Inspector**

  
George William Ogle

**State** Indiana  
**Accreditation Number** 191003027

## PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools  
Building Name Parkwood Elementary School  
HA# 01  
Type of Material Thermal Material  
Quantity of Material Unquantified LF

### Material Location

Above ceiling from boiler room to kitchen area. (halls, classrooms, boiler room/mechanical room, storage room, restrooms)

### Material Description


Fittings

### Comments

This material was not in poor condition. It is easily seen in the boiler room/mechanical room in the main hallway and in the air handler room above the gymnasium.

Does Material Contain Asbestos? Yes  
Is it Friable? No  
Original Inspection Date 6/1/1992  
Current Surveillance Date 6/30/2008  
Current Assessment Rating NR Not Required  
Cause of Damage No Damage  
Accessible Yes  
Potential for Damage Low  
Removed No  
Planned Response Action O & M

Inspector

  
George William Ogle

State

Indiana

Accreditation Number

191003027

## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Parkwood Elementary School  
**HA#** 02  
**Type of Material** Miscellaneous Material  
**Quantity of Material** Unquantified SF

**Material Location**  
Throughout the building


**Material Description**  
Floor tile

**Comments**

There is newer floor tile in the gymnasium. Floor tile is under carpet in cafeteria. There are some chipped edges around the sink in the custodial room. The custodial room has been divided by a new wall. The other side will get carpet over the floor tile. This material was not in poor condition overall.

**Does Material Contain Asbestos?** Assumed  
**Is it Friable?** No  
**Original Inspection Date** 6/1/1992  
**Current Surveillance Date** 6/30/2008  
**Current Assessment Rating** NR Not Required  
**Cause of Damage** No Damage  
**Accessible** Yes  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M

**Inspector**

  
George William Ogle

**State** Indiana  
**Accreditation Number** 191003027



## PERIODIC SURVEILLANCE REPORT

**.EA Name** Greater Clark County Schools  
**Building Name** Parkwood Elementary School  
**HA#** A  
**Type of Material** Miscellaneous Material  
**Quantity of Material** Approx. 2,800 LF  
**Material Location**

Throughout the building

**Material Description**

Cove base

**Comments**

There are minor signs of wear with a missing piece (no mastic visible) by room 26 (formerly C6). This material was not in poor condition overall.

**Does Material Contain Asbestos?** Assumed  
**Is it Friable?** No  
**Original Inspection Date** 5/31/1995  
**Current Surveillance Date** 6/30/2008  
**Current Assessment Rating** NR Not Required  
**Cause of Damage** No Damage  
**Accessible** Yes  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M

**Inspector**

  
George William Ogle

**State**

Indiana

**Accreditation Number**

191003027

## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Parkwood Elementary School  
**HA#** B  
**Type of Material** Miscellaneous Material  
**Quantity of Material** Approx. 900 SF  
**Material Location**  
Throughout the building  
**Material Description**  
Cove base mastic  
**Comments**  
No mastic was exposed to inspect.  
**Does Material Contain Asbestos?** Assumed  
**Is it Friable?** No  
**Original Inspection Date** 5/31/1995  
**Current Surveillance Date** 6/30/2008  
**Current Assessment Rating** NR Not Required  
**Cause of Damage** No Damage  
**Accessible** No  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M

**Inspector**

  
George William Ogle

**State** Indiana  
**Accreditation Number** 191003027

## PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools  
Building Name Parkwood Elementary School  
HA# C  
Type of Material Miscellaneous Material  
Quantity of Material 2,114 SF  
Material Location

Outside building soffit

**Material Description**

Transite soffit

**Comments**

This material is not in poor condition with some minor cracking around the edges. The first panel by the entrance has been replaced with grey material (possibly plywood). The 5th one from the left has a long crack in it but is still in place.

Does Material Contain Asbestos? Assumed  
Is it Friable? No  
Original Inspection Date 5/31/1995  
Current Surveillance Date 6/30/2008  
Current Assessment Rating NR Not Required  
Cause of Damage No Damage  
Accessible Yes  
Potential for Damage Low  
Removed No  
Planned Response Action O & M

Inspector

  
George William Ogle

State Indiana  
Accreditation Number 191003027

## PERIODIC SURVEILLANCE REPORT

**EA Name** Greater Clark County Schools  
**Building Name** Parkwood Elementary School  
**HA#** D  
**Type of Material** Miscellaneous Material  
**Quantity of Material** 120 SF  
**Material Location**

Gymnasium and cafeteria

**Material Description**


Green shock joints on AHU

**Comments**

This material was not in poor condition. Four locations of material above gymnasium. No shock joint was visible on the unit in the kitchen stockroom.

**Does Material Contain Asbestos?** Assumed  
**Is it Friable?** No  
**Original Inspection Date** 5/31/1995  
**Current Surveillance Date** 6/30/2008  
**Current Assessment Rating** NR Not Required  
**Cause of Damage** No Damage  
**Accessible** Yes  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M

**Inspector**

  
George William Ogle

**State**

Indiana

**Accreditation Number**

191003027

## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools

**Building Name** Parkwood Elementary School

**HA#** 01

**Type of Material** Thermal Material

**Quantity of Material** Unquantified LF

**Material Location**

Above ceiling from boiler room to kitchen area. (halls, classrooms, boiler room/mechanical room, storage room, restrooms)

**Material Description**

Fittings

**Comments**

This material was not in poor condition. It is easily seen in the boiler room/mechanical room in the main hallway and in the air handler room above the gymnasium.

**Does Material Contain Asbestos?** Yes

**Is it Friable?** No

**Original Inspection Date** 6/1/1992

**Current Surveillance Date** 12/6/2007

**Current Assessment Rating** NR Not Required

**Cause of Damage** No Damage

**Accessible** Yes

**Potential for Damage** Low

**Removed** No

**Planned Response Action** O & M

**Inspector**

  
George William Ogle

**State** Indiana

**Accreditation Number** 191003027

## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Parkwood Elementary School  
**HA#** 02  
**Type of Material** Miscellaneous Material  
**Quantity of Material** Unquantified SF  
**Material Location**

Throughout the building

**Material Description**


Floor tile

**Comments**

There is newer floor tile in the gymnasium. Floor tile is under carpet in cafeteria. There are some chipped edges around the sink in the custodial room. The custodial room has been divided by a new wall. The other side will get carpet over the floor tile. This material was not in poor condition overall.

**Does Material Contain Asbestos?** Assumed  
**Is it Friable?** No  
**Original Inspection Date** 6/1/1992  
**Current Surveillance Date** 12/6/2007  
**Current Assessment Rating** NR Not Required  
**Cause of Damage** No Damage  
**Accessible** Yes  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M

**Inspector**

  
George William Ogle

**State**

Indiana

**Accreditation Number**

191003027

## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Parkwood Elementary School  
**HA#** A  
**Type of Material** Miscellaneous Material  
**Quantity of Material** Approx. 2,800 LF  
**Material Location**

Throughout the building

**Material Description**

Cove base

**Comments**

There are minor signs of wear with a missing piece (no mastic visible) by room 26 (formerly C6). This material was not in poor condition overall.

**Does Material Contain Asbestos?** Assumed  
**Is it Friable?** No  
**Original Inspection Date** 5/31/1995  
**Current Surveillance Date** 12/6/2007  
**Current Assessment Rating** NR Not Required  
**Cause of Damage** No Damage  
**Accessible** Yes  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M

**Inspector**

  
George William Ogle

**State**

Indiana

**Accreditation Number**

191003027

## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Parkwood Elementary School  
**HA#** B  
**Type of Material** Miscellaneous Material  
**Quantity of Material** Approx. 900 SF  
**Material Location**  
Throughout the building  
**Material Description**  
Cove base mastic  
**Comments**  
No mastic was exposed to inspect.  
**Does Material Contain Asbestos?** Assumed  
**Is it Friable?** No  
**Original Inspection Date** 5/31/1995  
**Current Surveillance Date** 12/6/2007  
**Current Assessment Rating** NR Not Required  
**Cause of Damage** No Damage  
**Accessible** No  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M

**Inspector**

  
George William Ogle

**State**

Indiana

**Accreditation Number**

191003027



## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Parkwood Elementary School  
**HA#** C  
**Type of Material** Miscellaneous Material  
**Quantity of Material** 2,114 SF  
**Material Location**

Outside building soffit

**Material Description**

Transite soffit

**Comments**

Material is not in poor condition with some minor cracking around the edges. The first panel by the entrance has been replaced with grey material (possibly plywood).

**Does Material Contain Asbestos?** Assumed  
**Is it Friable?** No  
**Original Inspection Date** 5/31/1995  
**Current Surveillance Date** 12/6/2007  
**Current Assessment Rating** NR Not Required  
**Cause of Damage** No Damage  
**Accessible** Yes  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M

**Inspector**

  
George William Ogle

**State** Indiana  
**Accreditation Number** 191003027

## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Parkwood Elementary School  
**HA#** D  
**Type of Material** Miscellaneous Material  
**Quantity of Material** 120 SF  
**Material Location**

Gymnasium and cafeteria

**Material Description**

Green shock joints on AHU

**Comments**

This material was not in poor condition. Four locations of material above gymnasium.  
No shock joint was visible on the unit in the kitchen stockroom.

**Does Material Contain Asbestos?** Assumed  
**Is it Friable?** No  
**Original Inspection Date** 5/31/1995  
**Current Surveillance Date** 12/6/2007  
**Current Assessment Rating** NR Not Required  
**Cause of Damage** No Damage  
**Accessible** Yes  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M

**Inspector**

  
George William Ogle

**State** Indiana  
**Accreditation Number** 191003027

## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Parkwood Elementary School  
**HA#** 01  
**Type of Material** Thermal Material  
**Quantity of Material** Unquantified LF

**Material Location**

Above ceiling from boiler room to kitchen area. (halls, classrooms, boiler room/mechanical room, storage room, restrooms)

**Material Description**

Fittings

**Comments**

This material was not in poor condition. It is easily seen in the boiler room/mechanical room in the main hallway and in the air handler room above the gymnasium.

**Does Material Contain Asbestos?** Yes  
**Is it Friable?** No  
**Original Inspection Date** 6/1/1992  
**Current Surveillance Date** 12/18/2006  
**Current Assessment Rating** NR Not Required  
**Cause of Damage** No Damage  
**Accessible** Yes  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M

**Inspector**

  
George William Ogle

**State** Indiana  
**Accreditation Number** 191003027

## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Parkwood Elementary School  
**HA#** 02  
**Type of Material** Miscellaneous Material  
**Quantity of Material** Unquantified SF

**Material Location**  
Throughout the building

**Material Description**  
Floor tile

**Comments**

There is newer floor tile in the gymnasium. Floor tile is under carpet in cafeteria. There are some chipped edges around the sink in the custodial room. This material was not in poor condition overall.

**Does Material Contain Asbestos?** Assumed  
**Is it Friable?** No  
**Original Inspection Date** 6/1/1992  
**Current Surveillance Date** 12/18/2006  
**Current Assessment Rating** NR Not Required  
**Cause of Damage** No Damage  
**Accessible** Yes  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M

**Inspector**

  
George William Ogle

**State** Indiana  
**Accreditation Number** 191003027

## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Parkwood Elementary School  
**HA#** A  
**Type of Material** Miscellaneous Material  
**Quantity of Material** Approx. 2,800 LF

**Material Location**  
Throughout the building


**Material Description**  
Cove base

**Comments**

There are minor signs of wear with a missing piece (no mastic visible) by room 26 (formerly C6). This material was not in poor condition overall.

**Does Material Contain Asbestos?** Assumed  
**Is it Friable?** No  
**Original Inspection Date** 5/31/1995  
**Current Surveillance Date** 12/18/2006  
**Current Assessment Rating** NR Not Required  
**Cause of Damage** No Damage  
**Accessible** Yes  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M


**Inspector**

  
George William Ogle

**State** Indiana  
**Accreditation Number** 191003027

## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Parkwood Elementary School  
**HA#** B  
**Type of Material** Miscellaneous Material  
**Quantity of Material** Approx. 900 SF  
**Material Location**  
Throughout the building  
**Material Description**  
Cove base mastic  
**Comments**  
No mastic was exposed to inspect.  
**Does Material Contain Asbestos?** Assumed  
**Is it Friable?** No  
**Original Inspection Date** 5/31/1995  
**Current Surveillance Date** 12/18/2006  
**Current Assessment Rating** NR Not Required  
**Cause of Damage** No Damage  
**Accessible** No  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M

**Inspector** \_\_\_\_\_  
  
George William Ogle

**State** Indiana  
**Accreditation Number** 191003027

## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Parkwood Elementary School  
**HA#** C  
**Type of Material** Miscellaneous Material  
**Quantity of Material** 2,114 SF

**Material Location**  
Outside building soffit

**Material Description**  
Transite soffit

**Comments**

Material is not in poor condition with some minor cracking around the edges. The first panel by the entrance has been replaced with grey material (possibly plywood).

**Does Material Contain Asbestos?** Assumed  
**Is it Friable?** No  
**Original Inspection Date** 5/31/1995  
**Current Surveillance Date** 12/18/2006  
**Current Assessment Rating** NR Not Required  
**Cause of Damage** No Damage  
**Accessible** Yes  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M

**Inspector**

  
George William Ogle

**State** Indiana  
**Accreditation Number** 191003027

## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Parkwood Elementary School  
**HA#** D  
**Type of Material** Miscellaneous Material  
**Quantity of Material** 120 SF

**Material Location**  
Gymnasium and cafeteria

**Material Description**  
Green shock joints on AHU

**Comments**

This material was not in poor condition. Four locations of material above gymnasium.  
No shock joint was visible on the unit in the kitchen stockroom.

**Does Material Contain Asbestos?** Assumed  
**Is it Friable?** No  
**Original Inspection Date** 5/31/1995  
**Current Surveillance Date** 12/18/2006  
**Current Assessment Rating** NR Not Required  
**Cause of Damage** No Damage  
**Accessible** Yes  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M

**Inspector**

  
George William Ogle

**State** Indiana  
**Accreditation Number** 191003027



## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Parkwood Elementary School  
**HA#** 01  
**Type of Material** Thermal Material  
**Quantity of Material** Unquantified LF  
**Material Location**

Above ceiling from boiler room to kitchen area. (halls, classrooms, boiler room/mechanical room, storage room, restrooms)

**Material Description**


Fittings

**Comments**

This material was not in poor condition. It is easily seen in the boiler room/mechanical room in the main hallway and in the air handler room above the gymnasium.

**Does Material Contain Asbestos?** Yes  
**Is it Friable?** No  
**Original Inspection Date** 6/1/1992  
**Current Surveillance Date** 6/28/2006  
**Current Assessment Rating** NR Not Required  
**Cause of Damage** No Damage  
**Accessible** Yes  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M

**Inspector**



Christopher Ames

**State**

Indiana

**Accreditation Number**

198612124

## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Parkwood Elementary School  
**HA#** 02  
**Type of Material** Miscellaneous Material  
**Quantity of Material** Unquantified SF

**Material Location**  
Throughout the building

**Material Description**  
Floor tile

**Comments**

There is newer floor tile in the gymnasium. Floor tile is under carpet in cafeteria. There are some chipped edges around the sink in the custodial room. This material was not in poor condition overall.

**Does Material Contain Asbestos?** Assumed  
**Is it Friable?** No  
**Original Inspection Date** 6/1/1992  
**Current Surveillance Date** 6/28/2006  
**Current Assessment Rating** NR Not Required  
**Cause of Damage** No Damage  
**Accessible** Yes  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M

**Inspector**

  
\_\_\_\_\_  
Christopher Ames

**State** Indiana  
**Accreditation Number** 198612124

## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Parkwood Elementary School  
**HA#** A  
**Type of Material** Miscellaneous Material  
**Quantity of Material** Approx. 2,800 LF  
**Material Location**

Throughout the building

**Material Description**

Cove base

**Comments**

There are minor signs of wear with a missing piece (no mastic visible) by room 26 (formerly C6). This material was not in poor condition overall.

**Does Material Contain Asbestos?** Assumed  
**Is it Friable?** No  
**Original Inspection Date** 5/31/1995  
**Current Surveillance Date** 6/28/2006  
**Current Assessment Rating** NR Not Required  
**Cause of Damage** No Damage  
**Accessible** Yes  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M


**Inspector**

  
\_\_\_\_\_  
Christopher Ames

**State** Indiana  
**Accreditation Number** 198612124

## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Parkwood Elementary School  
**HA#** B  
**Type of Material** Miscellaneous Material  
**Quantity of Material** Approx. 900 SF  
**Material Location**  
Throughout the building  
**Material Description**  
Cove base mastic  
**Comments**  
No mastic was exposed to inspect.  
**Does Material Contain Asbestos?** Assumed  
**Is it Friable?** No  
**Original Inspection Date** 5/31/1995  
**Current Surveillance Date** 6/28/2006  
**Current Assessment Rating** NR Not Required  
**Cause of Damage** No Damage  
**Accessible** No  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M

**Inspector**   
\_\_\_\_\_  
Christopher Ames

**State** Indiana  
**Accreditation Number** 198612124

## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Parkwood Elementary School  
**HA#** C  
**Type of Material** Miscellaneous Material  
**Quantity of Material** 2,114 SF

**Material Location**  
Outside building soffit

**Material Description**  
Transite soffit

**Comments**

Material is not in poor condition with some minor cracking around the edges. The first panel by the entrance has been replaced with grey material (possibly plywood).

**Does Material Contain Asbestos?** Assumed  
**Is it Friable?** No  
**Original Inspection Date** 5/31/1995  
**Current Surveillance Date** 6/28/2006  
**Current Assessment Rating** NR Not Required  
**Cause of Damage** No Damage  
**Accessible** Yes  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M

**Inspector**

  
\_\_\_\_\_  
Christopher Ames

**State** Indiana  
**Accreditation Number** 198612124

## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Parkwood Elementary School  
**HA#** D  
**Type of Material** Miscellaneous Material  
**Quantity of Material** 120 SF

**Material Location**  
Gymnasium and cafeteria

**Material Description**  
Green shock joints on AHU

**Comments**

This material was not in poor condition. Four locations of material above gymnasium.  
No shock joint was visible on the unit in the kitchen stockroom.

**Does Material Contain Asbestos?** Assumed  
**Is it Friable?** No  
**Original Inspection Date** 5/31/1995  
**Current Surveillance Date** 6/28/2006  
**Current Assessment Rating** NR Not Required  
**Cause of Damage** No Damage  
**Accessible** Yes  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M

**Inspector**

  
\_\_\_\_\_  
Christopher Ames

**State** Indiana  
**Accreditation Number** 198612124

## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools

**Building Name** Parkwood Elementary School

**HA#** 01

**Type of Material** Thermal Material

**Quantity of Material** Unquantified LF

**Material Location**

Above ceiling from boiler room to kitchen area. (halls, classrooms, boiler room/mechanical room, storage room, restrooms)

**Material Description**

Fittings

**Comments**

This material was not in poor condition. It is easily seen in the boiler room/mechanical room in the main hallway and in the air handler room above the gymnasium.

**Does Material Contain Asbestos?** Yes

**Is it Friable?** No

**Original Inspection Date** 6/1/1992

**Current Surveillance Date** 1/23/2006

**Current Assessment Rating** NR Not Required

**Cause of Damage** No Damage

**Accessible** Yes

**Potential for Damage** Low

**Removed** No

**Planned Response Action** O & M

**Inspector**

  
George William Ogle

**State** Indiana

**Accreditation Number** 191523030

## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Parkwood Elementary School  
**HA#** 02  
**Type of Material** Miscellaneous Material  
**Quantity of Material** Unquantified SF

**Material Location**  
Throughout the building

**Material Description**

Floor tile

**Comments**

There is newer floor tile in the gymnasium. Floor tile is under carpet in cafeteria. There are some chipped edges around the sink in the custodial room. This material was not in poor condition overall.

**Does Material Contain Asbestos?** Assumed  
**Is it Friable?** No  
**Original Inspection Date** 6/1/1992  
**Current Surveillance Date** 1/23/2006  
**Current Assessment Rating** NR Not Required  
**Cause of Damage** No Damage  
**Accessible** Yes  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M

**Inspector**

  
George William Ogle

**State** Indiana  
**Accreditation Number** 191523030



## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Parkwood Elementary School  
**HA#** A  
**Type of Material** Miscellaneous Material  
**Quantity of Material** Approx. 2,800 LF  
**Material Location**

Throughout the building

**Material Description**


Cove base

**Comments**

There are minor signs of wear with a missing piece (no mastic visible) by room 26 (formerly C6). This material was not in poor condition overall.

**Does Material Contain Asbestos?** Assumed  
**Is it Friable?** No  
**Original Inspection Date** 5/31/1995  
**Current Surveillance Date** 1/23/2006  
**Current Assessment Rating** NR Not Required  
**Cause of Damage** No Damage  
**Accessible** Yes  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M

**Inspector**

  
George William Ogle

**State** Indiana  
**Accreditation Number** 191523030

## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Parkwood Elementary School  
**HA#** B  
**Type of Material** Miscellaneous Material  
**Quantity of Material** Approx. 900 SF  
**Material Location**  
Throughout the building  
**Material Description**  
Cove base mastic  
**Comments**  
No mastic was exposed to inspect.  
**Does Material Contain Asbestos?** Assumed  
**Is it Friable?** No  
**Original Inspection Date** 5/31/1995  
**Current Surveillance Date** 1/23/2006  
**Current Assessment Rating** NR Not Required  
**Cause of Damage** No Damage  
**Accessible** No  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M

**Inspector** \_\_\_\_\_  
*George W. Ogle*  
George William Ogle

**State** Indiana  
**Accreditation Number** 191523030

## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Parkwood Elementary School  
**HA#** C  
**Type of Material** Miscellaneous Material  
**Quantity of Material** 2,114 SF

**Material Location**  
Outside building soffit

**Material Description**


Transite soffit

**Comments**

Material is not in poor condition with some minor cracking around the edges. The first panel by the entrance has been replaced with grey material (possibly plywood).

**Does Material Contain Asbestos?** Assumed  
**Is it Friable?** No  
**Original Inspection Date** 5/31/1995  
**Current Surveillance Date** 1/23/2006  
**Current Assessment Rating** NR Not Required  
**Cause of Damage** No Damage  
**Accessible** Yes  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M

**Inspector**

  
George William Ogle

**State** Indiana  
**Accreditation Number** 191523030

## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Parkwood Elementary School  
**HA#** D  
**Type of Material** Miscellaneous Material  
**Quantity of Material** 120 SF

**Material Location**

Gymnasium and cafeteria

**Material Description**

Green shock joints on AHU

**Comments**

This material was not in poor condition. Four locations of material above gymnasium. No shock joint was visible on the unit in the kitchen stockroom.

**Does Material Contain Asbestos?** Assumed  
**Is it Friable?** No  
**Original Inspection Date** 5/31/1995  
**Current Surveillance Date** 1/23/2006  
**Current Assessment Rating** NR Not Required  
**Cause of Damage** No Damage  
**Accessible** Yes  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M

**Inspector**


  
George William Ogle

**State**

Indiana

**Accreditation Number**

191523030



## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools

**Building Name** Parkwood Elementary School

**HA#** 01

**Type of Material** Thermal Material

**Quantity of Material** Unquantified LF

**Material Location**

Above ceiling from boiler room to kitchen area. (halls, classrooms, boiler room/mechanical room, storage room, restrooms)

**Material Description**

Fittings

**Comments**

This material was not in poor condition. It is easily seen in the boiler room/mechanical room in the main hallway and in the air handler room above the gymnasium.

**Does Material Contain Asbestos?** Yes

**Is it Friable?** No

**Original Inspection Date** 6/1/1992

**Current Surveillance Date** 7/19/2005

**Current Assessment Rating** NR Not Required

**Cause of Damage** No Damage

**Accessible** Yes

**Potential for Damage** Low

**Removed** No

**Planned Response Action** O & M

**Inspector**

  
George William Ogle

**State** Indiana

**Accreditation Number** 191523030

## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Parkwood Elementary School  
**HA#** 02  
**Type of Material** Miscellaneous Material  
**Quantity of Material** Unquantified SF

**Material Location**  
Throughout the building

**Material Description**  
Floor tile

**Comments**

There is newer floor tile in the gymnasium. Floor tile is under carpet in cafeteria. There are some chipped edges around the sink in the custodial room. This material was not in poor condition overall.

**Does Material Contain Asbestos?** Assumed  
**Is it Friable?** No  
**Original Inspection Date** 6/1/1992  
**Current Surveillance Date** 7/19/2005  
**Current Assessment Rating** NR Not Required  
**Cause of Damage** No Damage  
**Accessible** Yes  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M

**Inspector**

  
George William Ogles

**State** Indiana  
**Accreditation Number** 191523030

## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools

**Building Name** Parkwood Elementary School

**HA#** A

**Type of Material** Miscellaneous Material

**Quantity of Material** Approx. 2,800 LF

**Material Location**  
Throughout the building

**Material Description**  
Cove base

**Comments**  
There are minor signs of wear with a missing piece (no mastic visible) by room 26 (formerly C6). This material was not in poor condition overall.

**Does Material Contain Asbestos?** Assumed

**Is it Friable?** No

**Original Inspection Date** 5/31/1995

**Current Surveillance Date** 7/19/2005

**Current Assessment Rating** NR Not Required

**Cause of Damage** No Damage


**Accessible** Yes

**Potential for Damage** Low

**Removed** No

**Planned Response Action** O & M

**Inspector**

  
George William Ogle

**State** Indiana

**Accreditation Number** 191523030



## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Parkwood Elementary School  
**HA#** B  
**Type of Material** Miscellaneous Material  
**Quantity of Material** Approx. 900 SF  
**Material Location**  
Throughout the building  
**Material Description**  
Cove base mastic  
**Comments**  
No mastic was exposed to inspect.  
**Does Material Contain Asbestos?** Assumed  
**Is it Friable?** No  
**Original Inspection Date** 5/31/1995  
**Current Surveillance Date** 7/19/2005  
**Current Assessment Rating** NR Not Required  
**Cause of Damage** No Damage  
**Accessible** No  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M

**Inspector**

  
George William Ogle

**State** Indiana  
**Accreditation Number** 191523030

## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Parkwood Elementary School  
**HA#** C  
**Type of Material** Miscellaneous Material  
**Quantity of Material** 2,114 SF  
**Material Location**  
Outside building soffit


**Material Description**  
Transite soffit

**Comments**

Material is not in poor condition with some minor cracking around the edges. The first panel by the entrance has been replaced with grey material (possibly plywood).

**Does Material Contain Asbestos?** Assumed  
**Is it Friable?** No  
**Original Inspection Date** 5/31/1995  
**Current Surveillance Date** 7/19/2005  
**Current Assessment Rating** NR Not Required  
**Cause of Damage** No Damage  
**Accessible** Yes  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M

**Inspector**

  
George William Ogle

**State** Indiana  
**Accreditation Number** 191523030

## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools

**Building Name** Parkwood Elementary School

**HA#** D

**Type of Material** Miscellaneous Material

**Quantity of Material** 120 SF

**Material Location**  
Gymnasium and cafeteria

**Material Description**  
Green shock joints on AHU

**Comments**  
This material was not in poor condition. Four locations of material above gymnasium. No one had a key to get to the unit behind the kitchen stockroom.

**Does Material Contain Asbestos?** Assumed

**Is it Friable?** No

**Original Inspection Date** 5/31/1995

**Current Surveillance Date** 7/19/2005

**Current Assessment Rating** NR Not Required

**Cause of Damage** No Damage

**Accessible** Yes

**Potential for Damage** Low

**Removed** No


**Planned Response Action** O & M

**Inspector**

  
George William Ogge

**State** Indiana

**Accreditation Number** 191523030



## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools

**Building Name** Parkwood Elementary School

**HA#** 01

**Type of Material** Thermal Material

**Quantity of Material** Unquantified LF

**Material Location**

Above ceiling from boiler room to kitchen area. (halls, classrooms, boiler room/mechanical room, storage room, restrooms)

**Material Description**

Fittings

**Comments**

This material was not in poor condition. It is easily seen in the boiler room/mechanical room in the main hallway and in the air handler room above the gymnasium.

**Does Material Contain Asbestos?** Yes

**Is it Friable?** No

**Original Inspection Date** 6/1/1992

**Current Surveillance Date** 12/9/2004

**Current Assessment Rating** NR Not Required

**Cause of Damage** No Damage

**Accessible** Yes

**Potential for Damage** Low

**Removed** No

**Planned Response Action** O & M

**Inspector**

  
\_\_\_\_\_  
Christiaan Sparks

**State** Indiana

**Accreditation Number** 190804103

## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Parkwood Elementary School  
**HA#** 02  
**Type of Material** Miscellaneous Material  
**Quantity of Material** Unquantified SF

**Material Location**  
Throughout the building

**Material Description**  
Floor tile

**Comments**

There is newer floor tile in the gymnasium. Floor tile is under carpet in cafeteria. There are some chipped edges around the sink in the custodial room. There was no tile beneath new tile on the stage. Wood material is present. This material was not in poor condition overall.

**Does Material Contain Asbestos?** Assumed  
**Is it Friable?** No  
**Original Inspection Date** 6/1/1992  
**Current Surveillance Date** 12/9/2004  
**Current Assessment Rating** NR Not Required  
**Cause of Damage** No Damage  
**Accessible** Yes  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M

**Inspector**

  
\_\_\_\_\_  
Christiaan Sparks

**State** Indiana  
**Accreditation Number** 190804103

## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Parkwood Elementary School  
**HA#** A  
**Type of Material** Miscellaneous Material  
**Quantity of Material** Approx. 2,800 LF

**Material Location**  
Throughout the building


**Material Description**  
Cove base

**Comments**

There are minor signs of wear with a missing piece by room 26 (formerly C6). This material was not in poor condition overall.

**Does Material Contain Asbestos?** Assumed  
**Is it Friable?** No  
**Original Inspection Date** 5/31/1995  
**Current Surveillance Date** 12/9/2004  
**Current Assessment Rating** NR Not Required  
**Cause of Damage** No Damage  
**Accessible** Yes  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M

**Inspector**

  
\_\_\_\_\_  
Christiaan Sparks

**State** Indiana  
**Accreditation Number** 190804103

## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools

**Building Name** Parkwood Elementary School

**HA#** B

**Type of Material** Miscellaneous Material

**Quantity of Material** Approx. 900 SF

**Material Location**  
Throughout the building

**Material Description**  
Cove base mastic

**Comments**  
Where exposed, this material was not in poor condition.

**Does Material Contain Asbestos?** Assumed

**Is it Friable?** No

**Original Inspection Date** 5/31/1995

**Current Surveillance Date** 12/9/2004

**Current Assessment Rating** NR Not Required

**Cause of Damage** No Damage

**Accessible** No

**Potential for Damage** Low

**Removed** No

**Planned Response Action** O & M

**Inspector**

  
\_\_\_\_\_  
Christiaan Sparks

**State** Indiana

**Accreditation Number** 190804103



## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Parkwood Elementary School  
**HA#** C  
**Type of Material** Miscellaneous Material  
**Quantity of Material** 2,114 SF

**Material Location**  
Outside building soffit

**Material Description**  
Transite soffit

**Comments**

Material is not in poor condition with some minor cracking around the edges. The first panel by the entrance has been replaced with grey material (possibly plywood).

**Does Material Contain Asbestos?** Assumed  
**Is it Friable?** No  
**Original Inspection Date** 5/31/1995  
**Current Surveillance Date** 12/9/2004  
**Current Assessment Rating** NR Not Required  
**Cause of Damage** No Damage  
**Accessible** Yes  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M

**Inspector**

  
\_\_\_\_\_  
Christiaan Sparks

**State** Indiana  
**Accreditation Number** 190804103

## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools

**Building Name** Parkwood Elementary School

**HA#** D

**Type of Material** Miscellaneous Material

**Quantity of Material** 120 SF

**Material Location**  
Gymnasium and cafeteria

**Material Description**  
Green shock joints on AHU

**Comments**  
This material was not in poor condition.

**Does Material Contain Asbestos?** Assumed

**Is it Friable?** No

**Original Inspection Date** 5/31/1995

**Current Surveillance Date** 12/9/2004

**Current Assessment Rating** NR Not Required

**Cause of Damage** No Damage


**Accessible** Yes

**Potential for Damage** Low

**Removed** No


**Planned Response Action** O & M

**Inspector**

  
\_\_\_\_\_  
Christiaan Sparks

**State** Indiana

**Accreditation Number** 190804103



## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools

**Building Name** Parkwood Elementary School

**HA#** 01

**Type of Material** Thermal Material

**Quantity of Material** Unquantified LF

**Material Location**

Above ceiling from boiler room to kitchen area. (halls, classrooms, boiler room/mechanical room, storage room, restrooms)

**Material Description**

Fittings

**Comments**

This material was not in poor condition. It is easily seen in the boiler room/mechanical room in the main hallway and in the air handler room above the gymnasium.

**Does Material Contain Asbestos?** Yes

**Is it Friable?** No

**Original Inspection Date** 06/01/1992

**Current Surveillance Date** 12/08/2003

**Current Assessment Rating** NR Not Required

**Cause of Damage** No Damage

**Accessible** Yes

**Potential for Damage** Low

**Removed** No

**Planned Response Action** O & M

**Inspector**

  
\_\_\_\_\_  
Christiaan Sparks

**State** Indiana

**Accreditation Number** 190804103

## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Parkwood Elementary School  
**HA#** 02  
**Type of Material** Miscellaneous Material  
**Quantity of Material** Unquantified SF

**Material Location**  
Throughout the building


**Material Description**  
Floor tile

**Comments**

There is newer floor tile in the gymnasium. Floor tile is under carpet in cafeteria. There are some chipped edges around the sink in the custodial room. There was no tile beneath new tile on the stage. Wood material is present. This material was not in poor condition overall.

**Does Material Contain Asbestos?** Assumed  
**Is it Friable?** No  
**Original Inspection Date** 06/01/1992  
**Current Surveillance Date** 12/08/2003  
**Current Assessment Rating** NR Not Required  
**Cause of Damage** No Damage  
**Accessible** Yes  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M

**Inspector**

  
\_\_\_\_\_  
Christiaan Sparks

**State** Indiana  
**Accreditation Number** 190804103

## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools

**Building Name** Parkwood Elementary School

**HA#** A

**Type of Material** Miscellaneous Material

**Quantity of Material** Approx. 2,800 LF

**Material Location**  
Throughout the building

**Material Description**  
Cove base

**Comments**

There are minor signs of wear with a missing piece by room 26 (formerly C6). This material was not in poor condition overall.

**Does Material Contain Asbestos?** Assumed

**Is it Friable?** No

**Original Inspection Date** 05/31/1995

**Current Surveillance Date** 12/08/2003

**Current Assessment Rating** NR Not Required

**Cause of Damage** No Damage

**Accessible** Yes

**Potential for Damage** Low

**Removed** No

**Planned Response Action** O & M

**Inspector**

  
\_\_\_\_\_  
Christiaan Sparks

**State** Indiana

**Accreditation Number** 190804103

## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools

**Building Name** Parkwood Elementary School

**HA#** B

**Type of Material** Miscellaneous Material

**Quantity of Material** Approx. 900 SF

**Material Location**  
Throughout the building

**Material Description**  
Cove base mastic

**Comments**  
Where exposed, this material was not in poor condition.

**Does Material Contain Asbestos?** Assumed

**Is it Friable?** No

**Original Inspection Date** 05/31/1995

**Current Surveillance Date** 12/08/2003

**Current Assessment Rating** NR Not Required

**Cause of Damage** No Damage

**Accessible** No

**Potential for Damage** Low

**Removed** No

**Planned Response Action** O & M

**Inspector**

  
\_\_\_\_\_  
Christiaan Sparks

**State** Indiana

**Accreditation Number** 190804103

## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Parkwood Elementary School  
**HA#** C  
**Type of Material** Miscellaneous Material  
**Quantity of Material** 2,114 SF

**Material Location**  
Outside building soffit


**Material Description**  
Transite soffit

**Comments**

Material is not in poor condition with some minor cracking around the edges. The first panel by the entrance has been replaced with grey material (possibly plywood).

**Does Material Contain Asbestos?** Assumed  
**Is it Friable?** No  
**Original Inspection Date** 05/31/1995  
**Current Surveillance Date** 12/08/2003  
**Current Assessment Rating** NR Not Required  
**Cause of Damage** No Damage  
**Accessible** Yes  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M

**Inspector**

  
\_\_\_\_\_  
Christiaan Sparks

**State** Indiana  
**Accreditation Number** 190804103



## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Parkwood Elementary School  
**HA#** D  
**Type of Material** Miscellaneous Material  
**Quantity of Material** 120 SF  
**Material Location**  
Gymnasium and cafeteria  
**Material Description**  
Green shock joints on AHU  
**Comments**  
This material was not in poor condition.  
**Does Material Contain Asbestos?** Assumed  
**Is it Friable?** No  
**Original Inspection Date** 05/31/1995  
**Current Surveillance Date** 12/08/2003  
**Current Assessment Rating** NR Not Required  
**Cause of Damage** No Damage  
**Accessible** Yes  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M

**Inspector**

  
\_\_\_\_\_  
Christiaan Sparks

**State** Indiana  
**Accreditation Number** 190804103



## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools

**Building Name** Parkwood Elementary School

**HA#** 01

**Type of Material** Thermal Material

**Quantity of Material** Unquantified LF

**Material Location**

Above ceiling from boiler room to kitchen area. (halls, classrooms, boiler room, storage room, restrooms)

**Material Description**

Fittings

**Comments**

This material was not in poor condition. It is easily seen in the mechanical room in the main hallway and in the air handler room above the gymnasium.

**Does Material Contain Asbestos?** Yes

**Is it Friable?** No

**Original Inspection Date** 06/01/1992

**Current Surveillance Date** 06/12/2003

**Current Assessment Rating** NR Not Required

**Cause of Damage** No Damage

**Accessible** Yes

**Potential for Damage** Low

**Removed** No

**Planned Response Action** O & M

**Inspector**



---

Christiaan Sparks

**State** Indiana

**Accreditation Number** 190804103

## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Parkwood Elementary School  
**HA#** 02  
**Type of Material** Miscellaneous Material  
**Quantity of Material** Unquantified SF

**Material Location**  
Throughout the building

**Material Description**  
Floor tile

**Comments**

There is newer floor tile in the gymnasium. Floor tile is under carpet in cafeteria and on stage. There are some chipped edges around the sink in the custodial room, but overall this material was not in poor condition.

**Does Material Contain Asbestos?** Assumed  
**Is it Friable?** No  
**Original Inspection Date** 06/01/1992  
**Current Surveillance Date** 06/12/2003  
**Current Assessment Rating** NR Not Required  
**Cause of Damage** No Damage  
**Accessible** Yes  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M

**Inspector**



---

Christiaan Sparks

**State** Indiana  
**Accreditation Number** 190804103

## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Parkwood Elementary School  
**HA#** A  
**Type of Material** Miscellaneous Material  
**Quantity of Material** Approx. 2,800 LF

**Material Location**  
Throughout the building

**Material Description**  
Cove base

**Comments**

There are minor signs of wear with a missing piece by room 26 (formerly C6). This material was not in poor condition overall.

**Does Material Contain Asbestos?** Assumed  
**Is it Friable?** No  
**Original Inspection Date** 05/31/1995  
**Current Surveillance Date** 06/12/2003  
**Current Assessment Rating** NR Not Required  
**Cause of Damage** No Damage  
**Accessible** Yes  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M

**Inspector**



Christiaan Sparks

**State** Indiana  
**Accreditation Number** 190804103

## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Parkwood Elementary School  
**HA#** B  
**Type of Material** Miscellaneous Material  
**Quantity of Material** Approx. 900 SF

**Material Location**  
Throughout the building

**Material Description**  
Cove base mastic

**Comments**  
Where exposed, this material was not in poor condition.

**Does Material Contain Asbestos?** Assumed  
**Is it Friable?** No  
**Original Inspection Date** 05/31/1995  
**Current Surveillance Date** 06/12/2003  
**Current Assessment Rating** NR Not Required  
**Cause of Damage** No Damage  
**Accessible** No  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M

**Inspector**



---

Christiaan Sparks

**State** Indiana  
**Accreditation Number** 190804103

## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools

**Building Name** Parkwood Elementary School

**HA#** C

**Type of Material** Miscellaneous Material

**Quantity of Material** 2,114 SF

**Material Location**  
Outside building soffit

**Material Description**  
Transite soffit

**Comments**

Material is not in poor condition with some minor cracking around the edges. The first panel by the entrance has been replaced with grey material (possibly plywood).

**Does Material Contain Asbestos?** Assumed

**Is it Friable?** No

**Original Inspection Date** 05/31/1995

**Current Surveillance Date** 06/12/2003

**Current Assessment Rating** NR Not Required

**Cause of Damage** No Damage

**Accessible** Yes

**Potential for Damage** Low

**Removed** No

**Planned Response Action** O & M

**Inspector**



Christiaan Sparks

**State** Indiana

**Accreditation Number** 190804103

## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Parkwood Elementary School  
**HA#** D  
**Type of Material** Miscellaneous Material  
**Quantity of Material** 120 SF  
**Material Location**  
Gymnasium and cafeteria  
**Material Description**  
Green shock joints on AHU  
**Comments**  
This material was not in poor condition.  
**Does Material Contain Asbestos?** Assumed  
**Is it Friable?** No  
**Original Inspection Date** 05/31/1995  
**Current Surveillance Date** 06/12/2003  
**Current Assessment Rating** NR Not Required  
**Cause of Damage** No Damage  
**Accessible** Yes  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M

**Inspector**   
\_\_\_\_\_  
Christiaan Sparks

**State** Indiana  
**Accreditation Number** 190804103





## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools

**Building Name** Parkwood Elementary School

**HA#** 01

**Type of Material** Thermal Material

**Quantity of Material** Unquantified LF

**Material Location**

Above ceiling from boiler room to kitchen area. (halls, classrooms, boiler room, storage room, restrooms)

**Material Description**

Fittings

**Comments**

This material was not in poor condition.

**Does Material Contain Asbestos?** Yes

**Is it Friable?** No

**Original Inspection Date** 06/01/1992

**Current Surveillance Date** 12/17/2002

**Current Assessment Rating** NR Not Required

**Cause of Damage** No Damage


**Accessible** Yes

**Potential for Damage** Low

**Removed** No

**Planned Response Action** O & M

**Inspector**



Christiaan Sparks

**State** Indiana

**Accreditation Number** 190804103

## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools

**Building Name** Parkwood Elementary School

**HA#** 02

**Type of Material** Miscellaneous Material

**Quantity of Material** Unquantified SF

**Material Location**  
Throughout the building

**Material Description**  
Floor tile

**Comments**

There is newer floor tile in the gymnasium. Floor tile is under carpet in cafeteria and on stage. There are some chipped edges around the sink in the custodial room, but overall this material was not in poor condition.

**Does Material Contain Asbestos?** Assumed

**Is it Friable?** No

**Original Inspection Date** 06/01/1992

**Current Surveillance Date** 12/17/2002

**Current Assessment Rating** NR Not Required

**Cause of Damage** No Damage


**Accessible** Yes

**Potential for Damage** Low

**Removed** No

**Planned Response Action** O & M

**Inspector**



---

Christiaan Sparks

**State** Indiana

**Accreditation Number** 190804103

## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Parkwood Elementary School  
**HA#** A  
**Type of Material** Miscellaneous Material  
**Quantity of Material** Approx. 2,800 LF

**Material Location**  
Throughout the building

**Material Description**  
Cove base

**Comments**

There are minor signs of wear with a missing piece by room C6. This material was not in poor condition overall.

**Does Material Contain Asbestos?** Assumed  
**Is it Friable?** No  
**Original Inspection Date** 05/31/1995  
**Current Surveillance Date** 12/17/2002  
**Current Assessment Rating** NR Not Required  
**Cause of Damage** No Damage  
**Accessible** Yes  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M

**Inspector**

  
\_\_\_\_\_  
Christiaan Sparks

**State** Indiana  
**Accreditation Number** 190804103

## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Parkwood Elementary School  
**HA#** B  
**Type of Material** Miscellaneous Material  
**Quantity of Material** Approx. 900 SF


**Material Location**  
Throughout the building

**Material Description**  
Cove base mastic

**Comments**  
Where exposed, this material was not in poor condition.

**Does Material Contain Asbestos?** Assumed  
**Is it Friable?** No  
**Original Inspection Date** 05/31/1995  
**Current Surveillance Date** 12/17/2002  
**Current Assessment Rating** NR Not Required  
**Cause of Damage** No Damage  
**Accessible** No  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M

**Inspector**



Christiaan Sparks

**State** Indiana  
**Accreditation Number** 190804103

## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools

**Building Name** Parkwood Elementary School

**HA#** C

**Type of Material** Miscellaneous Material

**Quantity of Material** 2,114 SF

**Material Location**  
Outside building soffit

**Material Description**  
Transite soffit

**Comments**

Material is not in poor condition with some minor cracking around the edges. The first panel by the entrance has been replaced with grey material (possibly plywood).

**Does Material Contain Asbestos?** Assumed

**Is it Friable?** No

**Original Inspection Date** 05/31/1995

**Current Surveillance Date** 12/17/2002

**Current Assessment Rating** NR Not Required

**Cause of Damage** No Damage

**Accessible** Yes

**Potential for Damage** Low

**Removed** No

**Planned Response Action** O & M

**Inspector**

  
\_\_\_\_\_  
Christiaan Sparks

**State** Indiana

**Accreditation Number** 190804103

## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Parkwood Elementary School  
**HA#** D  
**Type of Material** Miscellaneous Material  
**Quantity of Material** 120 SF  
**Material Location**  
Gymnasium and cafeteria  
**Material Description**  
Green shock joints on AHU  
**Comments**  
This material was not in poor condition.  
**Does Material Contain Asbestos?** Assumed  
**Is it Friable?** No  
**Original Inspection Date** 05/31/1995  
**Current Surveillance Date** 12/17/2002  
**Current Assessment Rating** NR Not Required  
**Cause of Damage** No Damage  
**Accessible** Yes  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M

**Inspector**

  
\_\_\_\_\_  
Christiaan Sparks

**State** Indiana  
**Accreditation Number** 190804103





## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools

**Building Name** Parkwood Elementary School

**HA#** 01

**Type of Material** Thermal Material

**Quantity of Material** Unquantified LF

**Material Location**

Above ceiling from boiler room to kitchen area. (halls, classrooms, boiler room, storage room, restrooms)

**Material Description**

Fittings

**Comments**

All fittings observed were not in poor condition.

**Does Material Contain Asbestos?** Yes

**Is it Friable?** No

**Original Inspection Date** 06/01/1992

**Current Surveillance Date** 06/19/2002

**Current Assessment Rating** NR Not Required

**Cause of Damage** No Damage


**Accessible** Yes

**Potential for Damage** Low

**Removed** No

**Planned Response Action** O & M

**Inspector**

  
Richard D. Calvert

**State** Indiana

**Accreditation Number** 315989970

## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Parkwood Elementary School  
**HA#** 02  
**Type of Material** Miscellaneous Material  
**Quantity of Material** Unquantified SF

**Material Location**  
Throughout the building


**Material Description**  
Floor tile

**Comments**

There is newer floor tile in the gymnasium. Floor tile is under carpet in cafeteria and on stage. There are some chipped edges around the sink in the custodial room, but overall the material is not in poor condition.

**Does Material Contain Asbestos?** Assumed  
**Is it Friable?** No  
**Original Inspection Date** 06/01/1992  
**Current Surveillance Date** 06/19/2002  
**Current Assessment Rating** NR Not Required  
**Cause of Damage** No Damage  
**Accessible** Yes  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M

**Inspector**

  
Richard D. Calvert

**State** Indiana  
**Accreditation Number** 315989970

## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Parkwood Elementary School  
**HA#** A  
**Type of Material** Miscellaneous Material  
**Quantity of Material** Approx. 2,800 LF

**Material Location**  
Throughout the building


**Material Description**  
Cove base

**Comments**

This material is not in poor condition overall. There are minor signs of wear and a missing piece by the west entrance.

**Does Material Contain Asbestos?** Assumed  
**Is it Friable?** No  
**Original Inspection Date** 05/31/1995  
**Current Surveillance Date** 06/19/2002  
**Current Assessment Rating** NR Not Required  
**Cause of Damage** No Damage  
**Accessible** Yes  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M

**Inspector**

  
Richard D. Calvert

**State** Indiana  
**Accreditation Number** 315989970

## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Parkwood Elementary School  
**HA#** B  
**Type of Material** Miscellaneous Material  
**Quantity of Material** Approx. 900 SF  
**Material Location**  
Throughout the building  
**Material Description**  
Cove base mastic  
**Comments**  
Where exposed, this material is not in poor condition.  
**Does Material Contain Asbestos?** Assumed  
**Is it Friable?** No  
**Original Inspection Date** 05/31/1995  
**Current Surveillance Date** 06/19/2002  
**Current Assessment Rating** NR Not Required  
**Cause of Damage** No Damage  
**Accessible** No  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M  
**Inspector**  
  
Richard D. Calvert  
**State** Indiana  
**Accreditation Number** 315989970

## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Parkwood Elementary School  
**HA#** C  
**Type of Material** Miscellaneous Material  
**Quantity of Material** 2,114 SF

**Material Location**  
Outside building soffit


**Material Description**  
Transite soffit

**Comments**

Material is not in poor condition with some minor cracking around the edges. The first panel by the entrance has been replaced with grey material (possibly plywood).

**Does Material Contain Asbestos?** Assumed  
**Is it Friable?** No  
**Original Inspection Date** 05/31/1995  
**Current Surveillance Date** 06/19/2002  
**Current Assessment Rating** NR Not Required  
**Cause of Damage** No Damage  
**Accessible** Yes  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M


**Inspector**

  
Richard D. Calvert

**State** Indiana  
**Accreditation Number** 315989970

## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Parkwood Elementary School  
**HA#** D  
**Type of Material** Miscellaneous Material  
**Quantity of Material** 120 SF  
**Material Location**  
Gymnasium and cafeteria  
**Material Description**  
Green shock joints on AHU  
**Comments**  
Material is not in poor condition.  
**Does Material Contain Asbestos?** Assumed  
**Is it Friable?** No  
**Original Inspection Date** 05/31/1995  
**Current Surveillance Date** 06/19/2002  
**Current Assessment Rating** NR Not Required  
**Cause of Damage** No Damage  
**Accessible** Yes  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M  
**Inspector**  
  
Richard D. Calvert  
**State** Indiana  
**Accreditation Number** 315989970



## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools

**Building Name** Parkwood Elementary School

**HA#** 01

**Type of Material** Thermal Material

**Quantity of Material** Unquantified LF

**Material Location**

Above ceiling from boiler room to kitchen area. (halls, classrooms, boiler room, storage room, restrooms)

**Material Description**

Fittings

**Comments**

All fittings observed were not in poor condition.

**Does Material Contain Asbestos?** Yes

**Is it Friable?** No

**Original Inspection Date** 06/01/1992

**Current Surveillance Date** 12/12/2001

**Current Assessment Rating** NR Not Required

**Cause of Damage** No Damage


**Accessible** Yes

**Potential for Damage** Low

**Removed** No

**Planned Response Action** O & M

**Inspector**

  
\_\_\_\_\_  
Stephen Kimbrough

**State** Indiana

**Accreditation Number** 191914122



## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Parkwood Elementary School  
**HA#** 02  
**Type of Material** Miscellaneous Material  
**Quantity of Material** Unquantified SF

**Material Location**  
Throughout the building


**Material Description**  
Floor tile

**Comments**

There is newer floor tile in the gymnasium. Floor tile is under carpet in cafeteria and on stage. There are some chipped edges around the sink in the custodial room, but overall the material is not in poor condition.

**Does Material Contain Asbestos?** Assumed  
**Is it Friable?** No  
**Original Inspection Date** 06/01/1992  
**Current Surveillance Date** 12/12/2001  
**Current Assessment Rating** NR Not Required  
**Cause of Damage** No Damage  
**Accessible** Yes  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M

**Inspector**

  
\_\_\_\_\_  
Stephen Kimbrough

**State** Indiana  
**Accreditation Number** 191914122

## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools

**Building Name** Parkwood Elementary School

**HA#** A

**Type of Material** Miscellaneous Material

**Quantity of Material** Approx. 2,800 LF

**Material Location**  
Throughout the building

**Material Description**  
Cove base

**Comments**

This material is not in poor condition overall. There are minor signs of wear and a missing piece by the west entrance.

**Does Material Contain Asbestos?** Assumed

**Is it Friable?** No

**Original Inspection Date** 05/31/1995

**Current Surveillance Date** 12/12/2001

**Current Assessment Rating** NR Not Required

**Cause of Damage** No Damage

**Accessible** Yes

**Potential for Damage** Low

**Removed** No

**Planned Response Action** O & M

**Inspector**

  
Stephen Kimbrough

**State** Indiana

**Accreditation Number** 191914122

## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Parkwood Elementary School  
**HA#** B  
**Type of Material** Miscellaneous Material  
**Quantity of Material** Approx. 900 SF  
**Material Location**  
Throughout the building  
**Material Description**  
Cove base mastic  
**Comments**  
Where exposed, this material is not in poor condition.  
**Does Material Contain Asbestos?** Assumed  
**Is it Friable?** No  
**Original Inspection Date** 05/31/1995  
**Current Surveillance Date** 12/12/2001  
**Current Assessment Rating** NR Not Required  
**Cause of Damage** No Damage  
**Accessible** No  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M  
**Inspector**  
  
Stephen Kimbrough  
**State** Indiana  
**Accreditation Number** 191914122

## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools

**Building Name** Parkwood Elementary School

**HA#** C

**Type of Material** Miscellaneous Material

**Quantity of Material** 2,114 SF

**Material Location**  
Outside building soffit

**Material Description**  
Transite soffit

**Comments**

Material is not in poor condition with some minor cracking around the edges.

**Does Material Contain Asbestos?** Assumed

**Is it Friable?** No

**Original Inspection Date** 05/31/1995

**Current Surveillance Date** 12/12/2001

**Current Assessment Rating** NR Not Required

**Cause of Damage** No Damage


**Accessible** Yes

**Potential for Damage** Low

**Removed** No

**Planned Response Action** O & M

**Inspector**

  
\_\_\_\_\_  
Stephen Kimbrough

**State** Indiana

**Accreditation Number** 191914122

## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Parkwood Elementary School  
**HA#** D  
**Type of Material** Miscellaneous Material  
**Quantity of Material** 120 SF  
**Material Location**  
Gymnasium and cafeteria  
**Material Description**  
Green shock joints on AHU  
**Comments**  
Material is not in poor condition.  
**Does Material Contain Asbestos?** Assumed  
**Is it Friable?** No  
**Original Inspection Date** 05/31/1995  
**Current Surveillance Date** 12/12/2001  
**Current Assessment Rating** NR Not Required  
**Cause of Damage** No Damage  
**Accessible** Yes  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M  
**Inspector**  
  
Stephen Kimbrough  
**State** Indiana  
**Accreditation Number** 191914122



## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools

**Building Name** Parkwood Elementary School

**HA#** 01

**Type of Material** Thermal Material

**Quantity of Material** Unquantified LF

**Material Location**

Above ceiling from boiler room to kitchen area. (halls, classrooms, boiler room, storage room, restrooms)

**Material Description**

Fittings

**Comments**

All fittings observed were in good condition.

**Does Material Contain Asbestos?** Yes

**Is it Friable?** No

**Original Inspection Date** 06/01/1992

**Current Surveillance Date** 01/10/2001

**Current Assessment Rating** NR Not Required

**Cause of Damage** No Damage

**Accessible** Yes

**Potential for Damage** Low

**Removed** No

**Planned Response Action** O & M

**Inspector**



Patrick E. Wilson

**State** Indiana

**Accreditation Number** 190824065

## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools

**Building Name** Parkwood Elementary School

**HA#** 02

**Type of Material** Miscellaneous Material

**Quantity of Material** Unquantified SF

**Material Location**  
Throughout the building

**Material Description**  
Floor tile

**Comments**

There is newer floor tile in the gymnasium. Floor tile is under carpet in cafeteria and on stage. Small amount of chipped edges around sink in custodial room, but tile is in overall good condition.

**Does Material Contain Asbestos?** Assumed

**Is it Friable?** No

**Original Inspection Date** 06/01/1992

**Current Surveillance Date** 01/10/2001

**Current Assessment Rating** NR Not Required

**Cause of Damage** No Damage

**Accessible** Yes

**Potential for Damage** Low

**Removed** No

**Planned Response Action** O & M

**Inspector**



Patrick E. Wilson

**State** Indiana

**Accreditation Number** 190824065



## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Parkwood Elementary School  
**HA#** A  
**Type of Material** Miscellaneous Material  
**Quantity of Material** Approx. 2,800 LF

**Material Location**  
Throughout the building

**Material Description**  
Cove base

**Comments**  
This material is in good condition overall with minor signs of wear.

**Does Material Contain Asbestos?** Assumed  
**Is it Friable?** No  
**Original Inspection Date** 05/31/1995  
**Current Surveillance Date** 01/10/2001  
**Current Assessment Rating** NR Not Required  
**Cause of Damage** Deterioration & Age  
**Accessible** Yes  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M

**Inspector**



Patrick E. Wilson

**State** Indiana  
**Accreditation Number** 190824065


## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Parkwood Elementary School  
**HA#** B  
**Type of Material** Miscellaneous Material  
**Quantity of Material** Approx. 900 SF  
**Material Location**  
Throughout the building  
**Material Description**  
Cove base mastic  
**Comments**  
No mastic was exposed to inspect.  
**Does Material Contain Asbestos?** Assumed  
**Is it Friable?** No  
**Original Inspection Date** 05/31/1995  
**Current Surveillance Date** 01/10/2001  
**Current Assessment Rating** NR Not Required  
**Cause of Damage** No Damage  
**Accessible** No  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M  
**Inspector**  
  
\_\_\_\_\_  
Patrick E. Wilson  
**State** Indiana  
**Accreditation Number** 190824065

## PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools  
Building Name Parkwood Elementary School  
HA# C  
Type of Material Miscellaneous Material  
Quantity of Material 2,114 SF  
Material Location  
Outside building soffit  
Material Description  
Transite soffit  
Comments  
Material is in good condition.  
Does Material Contain Asbestos? Assumed  
Is it Friable? No  
Original Inspection Date 05/31/1995  
Current Surveillance Date 01/10/2001  
Current Assessment Rating NR Not Required  
Cause of Damage No Damage  
Accessible Yes  
Potential for Damage Low  
Removed No  
Planned Response Action O & M

Inspector



Patrick E. Wilson

State Indiana  
Accreditation Number 190824065

## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Parkwood Elementary School  
**HA#** D  
**Type of Material** Miscellaneous Material  
**Quantity of Material** 120 SF  
**Material Location**  
Gymnasium and cafeteria  
**Material Description**  
Green shock joints on AHU  
**Comments**  
Material is in good condition.  
**Does Material Contain Asbestos?** Assumed  
**Is it Friable?** No  
**Original Inspection Date** 05/31/1995  
**Current Surveillance Date** 01/10/2001  
**Current Assessment Rating** NR Not Required  
**Cause of Damage** No Damage  
**Accessible** Yes  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M

**Inspector**



Patrick E. Wilson

**State** Indiana  
**Accreditation Number** 190824065



## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools

**Building Name** Parkwood Elementary School

**HA#** 01

**Type of Material** Thermal Material

**Quantity of Material** Unquantified SF

**Material Location**

Above Ceiling from Boiler Room to Kitchen Area. (Halls, Classrooms, Boiler Room, Storage Room, Restrooms)

**Material Description**

Fittings

**Comments**

Fittings are in good condition.

**Does Material Contain Asbestos?** Yes

**Is it Friable?** No

**Original Inspection Date** 06/01/1992

**Current Surveillance Date** 06/29/2000

**Current Assessment Rating** NR Not Required

**Cause of Damage** No Damage

**Accessible** Yes

**Potential for Damage** Low

**Removed** No

**Planned Response Action** O & M

**Inspector**

  
George William Ogle

**State** Indiana

**Accreditation Number** 191523030

## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Parkwood Elementary School  
**HA#** 02  
**Type of Material** Miscellaneous Material  
**Quantity of Material** Unquantified SF

**Material Location**  
Throughout the building


**Material Description**  
Floor Tile

**Comments**

There is newer floor tile in the gymnasium. Floor tile is under carpet in cafeteria and on stage. Small amount of chipped edges around sink in custodial room, but tile is in overall good condition.

**Does Material Contain Asbestos?** Assumed  
**Is it Friable?** No  
**Original Inspection Date** 06/01/1992  
**Current Surveillance Date** 06/29/2000  
**Current Assessment Rating** NR Not Required  
**Cause of Damage** No Damage  
**Accessible** Yes  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M

**Inspector**

  
George William Ogle

**State** Indiana  
**Accreditation Number** 191523030

## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Parkwood Elementary School  
**HA#** A  
**Type of Material** Miscellaneous Material  
**Quantity of Material** Unquantified LF  
**Material Location**  
Throughout the building  
**Material Description**  
Cove Base  
**Comments**  
This material is in good condition overall.  
**Does Material Contain Asbestos?** Assumed  
**Is it Friable?** No  
**Original Inspection Date** 05/31/1995  
**Current Surveillance Date** 06/29/2000  
**Current Assessment Rating** NR Not Required  
**Cause of Damage** No Damage  
**Accessible** Yes  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M

**Inspector**

  
George William Ogle

**State** Indiana  
**Accreditation Number** 191523030



## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools

**Building Name** Parkwood Elementary School

**HA#** B

**Type of Material** Miscellaneous Material

**Quantity of Material** Unquantified LF

**Material Location**  
Throughout the building

**Material Description**  
Cove Base Mastic

**Comments**  
No mastic was exposed to inspect.

**Does Material Contain Asbestos?** Assumed

**Is it Friable?** No

**Original Inspection Date** 05/31/1995

**Current Surveillance Date** 06/29/2000

**Current Assessment Rating** NR Not Required

**Cause of Damage** No Damage


**Accessible** No

**Potential for Damage** Low

**Removed** No

**Planned Response Action** O & M

**Inspector**

  
George William Ogle

**State** Indiana

**Accreditation Number** 191523030

## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Parkwood Elementary School  
**HA#** C  
**Type of Material** Miscellaneous Material  
**Quantity of Material** 2,114 SF  
**Material Location**  
Outside building soffit  
**Material Description**  
Transite Soffit  
**Comments**  
Material is in good condition.  
**Does Material Contain Asbestos?** Assumed  
**Is it Friable?** No  
**Original Inspection Date** 05/31/1995  
**Current Surveillance Date** 06/29/2000  
**Current Assessment Rating** NR Not Required  
**Cause of Damage** No Damage  
**Accessible** Yes  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M

**Inspector**

  
George William Ogile

**State**

Indiana

**Accreditation Number**

191523030


## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Parkwood Elementary School  
**HA#** D  
**Type of Material** Miscellaneous Material  
**Quantity of Material** Unquantified SF  
**Material Location**  
Gymnasium and Cafeteria  
**Material Description**  
Green Shock Joints on AHU  
**Comments**  
Material is in good condition.  
**Does Material Contain Asbestos?** Assumed  
**Is it Friable?** No  
**Original Inspection Date** 05/31/1995  
**Current Surveillance Date** 06/29/2000  
**Current Assessment Rating** NR Not Required  
**Cause of Damage** No Damage  
**Accessible** Yes  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M

**Inspector**

  
George William Ogilvie

**State** Indiana  
**Accreditation Number** 191523030



## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools

**Building Name** Parkwood Elementary School

**HA#** 01

**Type of Material** Thermal Material

**Quantity of Material** Unquantified SF

**Material Location**

Above Ceiling from Boiler Room to Kitchen Area. (Halls, Classrooms, Boiler Room, Storage Room, Restrooms)

**Material Description**

Fittings

**Comments**

Damaged fitting near water heater in boiler room has been removed. Two damaged fittings across the hall from the gymnasium have been repaired.

**Does Material Contain Asbestos?** Yes

**Is it Friable?** No

**Original Inspection Date** 06/01/1992

**Current Surveillance Date** 12/08/1999

**Current Assessment Rating** NR Not Required

**Cause of Damage** No Damage


**Accessible** Yes

**Potential for Damage** Low

**Removed** No

**Planned Response Action** O & M

**Inspector**



Matthew Wallace

**State** Indiana

**Accreditation Number** 191219020

## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Parkwood Elementary School  
**HA#** 02  
**Type of Material** Miscellaneous Material  
**Quantity of Material** Unquantified SF

**Material Location**  
Throughout the building

**Material Description**  
Floor Tile

**Comments**

New non-ACM floor tile in gymnasium. Floor tile is under carpet in cafeteria and on stage. Material is worn at entrances to classrooms, but is in overall good condition.

**Does Material Contain Asbestos?** Assumed  
**Is it Friable?** No  
**Original Inspection Date** 06/01/1992  
**Current Surveillance Date** 12/08/1999  
**Current Assessment Rating** NR Not Required  
**Cause of Damage** No Damage  
**Accessible** Yes  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M

**Inspector**

  
Matthew Wallace

**State** Indiana  
**Accreditation Number** 191219020

## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Parkwood Elementary School  
**HA#** A  
**Type of Material** Miscellaneous Material  
**Quantity of Material** Unquantified LF

**Material Location**  
Throughout the building

**Material Description**  
Cove Base

**Comments**

Material is in good condition. The art room has new cove base. The loose pieces in the cafeteria have been reapplied.

**Does Material Contain Asbestos?** Assumed  
**Is it Friable?** No  
**Original Inspection Date** 05/31/1995  
**Current Surveillance Date** 12/08/1999  
**Current Assessment Rating** NR Not Required  
**Cause of Damage** No Damage  
**Accessible** Yes  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M


**Inspector**

  
Matthew Wallace

**State** Indiana  
**Accreditation Number** 191219020

## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Parkwood Elementary School  
**HA#** B  
**Type of Material** Miscellaneous Material  
**Quantity of Material** Unquantified LF  
**Material Location**  
Throughout the building  
**Material Description**  
Cove Base Mastic  
**Comments**  
Material not exposed to inspect.  
**Does Material Contain Asbestos?** Assumed  
**Is it Friable?** No  
**Original Inspection Date** 05/31/1995  
**Current Surveillance Date** 12/08/1999  
**Current Assessment Rating** NR Not Required  
**Cause of Damage** No Damage  
**Accessible** No  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M

**Inspector**   
Matthew Wallace

**State** Indiana  
**Accreditation Number** 191219020



## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Parkwood Elementary School  
**HA#** C  
**Type of Material** Miscellaneous Material  
**Quantity of Material** Unquantified SF  
**Material Location**  
Throughout the building  
**Material Description**  
Transite Soffit  
**Comments**  
Material is in good condition.  
**Does Material Contain Asbestos?** Assumed  
**Is it Friable?** No  
**Original Inspection Date** 05/31/1995  
**Current Surveillance Date** 12/08/1999  
**Current Assessment Rating** NR Not Required  
**Cause of Damage** No Damage  
**Accessible** Yes  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M


**Inspector**   
Matthew Wallace

**State** Indiana  
**Accreditation Number** 191219020

## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Parkwood Elementary School  
**HA#** D  
**Type of Material** Miscellaneous Material  
**Quantity of Material** Unquantified SF  
**Material Location**  
Gymnasium and Cafeteria  
**Material Description**  
Shock Joints on AHV  
**Comments**  
Material is in good condition.  
**Does Material Contain Asbestos?** Assumed  
**Is it Friable?** No  
**Original Inspection Date** 05/31/1995  
**Current Surveillance Date** 12/08/1999  
**Current Assessment Rating** NR Not Required  
**Cause of Damage** No Damage  
**Accessible** Yes  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M


**Inspector**

  
Matthew Wallace

**State** Indiana  
**Accreditation Number** 191219020



## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Parkwood Elementary School  
**HA#** 01  
**Type of Material** Thermal Material  
**Quantity of Material** Unquantified SF  
**Material Location**  
Above Ceiling from Boiler Room to Kitchen Area. (Halls, Classrooms, Boiler Room, Storage Room, Restrooms)  
**Material Description**  
Fittings  
**Comments**  
Damaged fitting near water heater in boiler room has been removed. Two damaged fittings across the hall from the gymnasium have been repaired.  
**Does Material Contain Asbestos?** Yes  
**Is it Friable?** No  
**Original Inspection Date** 06/01/1992  
**Current Surveillance Date** 06/24/1999  
**Current Assessment Rating** NR Not Required  
**Cause of Damage** No Damage  
**Accessible** Yes  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M  
**Inspector**  
  
Matthew Wallace  
**State** Indiana  
**Accreditation Number** 191219020

## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools

**Building Name** Parkwood Elementary School

**HA#** 02

**Type of Material** Miscellaneous Material

**Quantity of Material** Unquantified SF

**Material Location**  
Throughout the building

**Material Description**  
Floor Tile

**Comments**

New non-ACM floor tile in gymnasium. Floor tile is under carpet in cafeteria and on stage.  
Material is worn at entrances to classrooms.

**Does Material Contain Asbestos?** Assumed

**Is it Friable?** No

**Original Inspection Date** 06/01/1992

**Current Surveillance Date** 06/24/1999

**Current Assessment Rating** NR Not Required

**Cause of Damage** No Damage


**Accessible** Yes

**Potential for Damage** Low

**Removed** No

**Planned Response Action** O & M

**Inspector**

  
Matthew Wallace

**State** Indiana

**Accreditation Number** 191219020

## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools

**Building Name** Parkwood Elementary School

**HA#** A

**Type of Material** Miscellaneous Material

**Quantity of Material** Unquantified LF

**Material Location**  
Throughout the building

**Material Description**  
Cove Base

**Comments**  
Material is in good condition. There are loose pieces in the art room and cafeteria.

**Does Material Contain Asbestos?** Assumed

**Is it Friable?** No

**Original Inspection Date** 05/31/1995

**Current Surveillance Date** 06/24/1999

**Current Assessment Rating** NR Not Required

**Cause of Damage** No Damage


**Accessible** Yes

**Potential for Damage** Low

**Removed** No

**Planned Response Action** O & M


**Inspector**

  
Matthew Wallace

**State** Indiana

**Accreditation Number** 191219020

## PERIODIC SURVEILLANCE REPORT


**LEA Name** Greater Clark County Schools  
**Building Name** Parkwood Elementary School  
**HA#** B  
**Type of Material** Miscellaneous Material  
**Quantity of Material** Unquantified LF  
**Material Location** Throughout the building  
**Material Description** Cove Base Mastic  
**Comments** Where exposed, material is in good condition.  
**Does Material Contain Asbestos?** Assumed  
**Is it Friable?** No  
**Original Inspection Date** 05/31/1995  
**Current Surveillance Date** 06/24/1999  
**Current Assessment Rating** NR Not Required  
**Cause of Damage** No Damage  
**Accessible** No  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M  
**Inspector**   
Matthew Wallace  
**State** Indiana  
**Accreditation Number** 191219020

## PERIODIC SURVEILLANCE REPORT

<b>LEA Name</b>	Greater Clark County Schools	
<b>Building Name</b>	Parkwood Elementary School	
<b>HA#</b>	C	
<b>Type of Material</b>	Miscellaneous Material	
<b>Quantity of Material</b>	Unquantified SF	
<b>Material Location</b>	Throughout the building	
<b>Material Description</b>	Transite Soffit	
<b>Comments</b>	Material is in good condition.	
<b>Does Material Contain Asbestos?</b>	Assumed	
<b>Is it Friable?</b>	No	
<b>Original Inspection Date</b>	05/31/1995	
<b>Current Surveillance Date</b>	06/24/1999	
<b>Current Assessment Rating</b>	NR	Not Required
<b>Cause of Damage</b>	No Damage	
<b>Accessible</b>	Yes	
<b>Potential for Damage</b>	Low	
<b>Removed</b>	No	
<b>Planned Response Action</b>	O & M	
<b>Inspector</b>	 Matthew Wallace	
<b>State</b>	Indiana	
<b>Accreditation Number</b>	191219020	



## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Parkwood Elementary School  
**HA#** D  
**Type of Material** Miscellaneous Material  
**Quantity of Material** Unquantified SF  
**Material Location** Gymnasium and Cafeteria  
**Material Description** Shock Joints on AHV  
**Comments** Material is in good condition.  
**Does Material Contain Asbestos?** Assumed  
**Is it Friable?** No  
**Original Inspection Date** 05/31/1995  
**Current Surveillance Date** 06/24/1999  
**Current Assessment Rating** NR Not Required  
**Cause of Damage** No Damage  
**Accessible** Yes  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M  
**Inspector**   
Matthew Wallace  
**State** Indiana  
**Accreditation Number** 191219020



## PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools  
Building Name Parkwood Elementary School  
HA# 01  
Type of Material Thermal Material  
Quantity of Material Unquantified SF  
Material Location Above Ceiling from Boiler Room to Kitchen Area. (Halls, Classrooms, Boiler Room, Storage Room, Restrooms)

Material Description  
Fittings

### Comments

Damaged fitting near water heater in boiler room has been removed. Two damaged fittings across the hall from the gymnasium have been repaired.

Does Material Contain Asbestos? Yes  
Is it Friable? No  
Original Inspection Date 06/01/1992  
Current Surveillance Date 12/29/1998  
Current Assessment Rating NR Not Required  
Cause of Damage No Damage  
Accessible Yes  
Potential for Damage Low  
Removed No  
Planned Response Action O & M

Inspector



Clint Yates

State

Indiana

Accreditation Number

193804035

## PERIODIC SURVEILLANCE REPORT


LEA Name Greater Clark County Schools  
Building Name Parkwood Elementary School  
HA# 02  
Type of Material Miscellaneous Material  
Quantity of Material Unquantified SF  
Material Location Throughout the building  
Material Description Floor Tile

### Comments

New non-ACM floor tile in gymnasium. Floor tile is under carpet in cafeteria and on stage. Material is worn at entrances to classrooms.

Does Material Contain Asbestos? Assumed  
Is it Friable? No  
Original Inspection Date 06/01/1992  
Current Surveillance Date 12/29/1998  
Current Assessment Rating NR Not Required  
Cause of Damage No Damage  
Accessible Yes  
Potential for Damage Low  
Removed No  
Planned Response Action O & M

Inspector



Clint Yates

State Indiana  
Accreditation Number 193804035

## PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools  
Building Name Parkwood Elementary School  
HA# A  
Type of Material Miscellaneous Material  
Quantity of Material Unquantified LF  
Material Location Throughout the building


Material Description  
Cove Base

### Comments

Material is in good condition. There are loose pieces in the art room.

Does Material Contain Asbestos? Assumed  
Is it Friable? No  
Original Inspection Date 05/31/1995  
Current Surveillance Date 12/29/1998  
Current Assessment Rating NR Not Required  
Cause of Damage No Damage  
Accessible Yes  
Potential for Damage Low  
Removed No  
Planned Response Action O & M

Inspector




Clint Yates

State Indiana  
Accreditation Number 193804035

## PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools  
Building Name Parkwood Elementary School  
HA# B  
Type of Material Miscellaneous Material  
Quantity of Material Unquantified LF  
Material Location Throughout the building  
Material Description Cove Base Mastic  
Comments Where exposed, material is in good condition.  
Does Material Contain Asbestos? Assumed  
Is it Friable? No  
Original Inspection Date 05/31/1995  
Current Surveillance Date 12/29/1998  
Current Assessment Rating NR Not Required  
Cause of Damage No Damage  
Accessible No  
Potential for Damage Low  
Removed No  
Planned Response Action O & M

Inspector



Clint Yates

State

Indiana


Accreditation Number

193804035

## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Parkwood Elementary School  
**HA#** C  
**Type of Material** Miscellaneous Material  
**Quantity of Material** Unquantified SF  
**Material Location**  
Throughout the building  
**Material Description**  
Transite Soffit  
**Comments**  
Material is in good condition.  
**Does Material Contain Asbestos?** Assumed  
**Is it Friable?** No  
**Original Inspection Date** 05/31/1995  
**Current Surveillance Date** 12/29/1998  
**Current Assessment Rating** NR Not Required  
**Cause of Damage** No Damage  
**Accessible** Yes  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M

**Inspector**




Clint Yates

**State** Indiana  
**Accreditation Number** 193804035

## PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools  
Building Name Parkwood Elementary School  
HA# D  
Type of Material Miscellaneous Material  
Quantity of Material Unquantified SF  
Material Location  
Gymnasium and Cafeteria  
Material Description  
Shock Joints on AHV  
Comments  
Material is in good condition.  
Does Material Contain Asbestos? Assumed  
Is it Friable? No  
Original Inspection Date 05/31/1995  
Current Surveillance Date 12/29/1998  
Current Assessment Rating NR Not Required  
Cause of Damage No Damage  
Accessible Yes  
Potential for Damage Low  
Removed No  
Planned Response Action O & M

Inspector



Clint Yates

State

Indiana

Accreditation Number

193804035






## PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools  
Building Name Parkwood Elementary School  
HA# 01  
Type of Material Thermal Material  
Quantity of Material Each  
Material Location  
Above Ceiling from Boiler Room to Kitchen Area. (Halls, Classrooms, Boiler Room, Storage Room, Restrooms)  
Material Description  
Fittings  
Comments  
Damaged fitting found near water heater in boiler room. Two damaged fittings across the hall from the gymnasium. O & M needed.  
Does Material Contain Asbestos? Assumed  
Is it Friable? No  
Original Inspection Date 6/ 1/92  
Current Surveillance Date 1/14/98  
Current Assessment Rating NR Not Required  
Cause of Damage Water Damage  
Accessible Yes  
Potential for Damage Low  
Removed No  
Planned Response Action O & M

Inspector



---

Karen Foxx

State Indiana  
Accreditation Number 191129014

## PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools  
Building Name Parkwood Elementary School  
HA# 02  
Type of Material Miscellaneous Material  
Quantity of Material SF

Material Location  
Throughout the building

Material Description  
Floor Tile

### Comments

New non-ACM floor tile in gymnasium. Floor tile is under carpet in cafeteria and on stage. Material is worn at entrances to classrooms.

Does Material Contain Asbestos? Assumed  
Is it Friable? No  
Original Inspection Date 6/ 1/92  
Current Surveillance Date 1/14/98  
Current Assessment Rating NR Not Required  
Cause of Damage No Damage  
Accessible Yes  
Potential for Damage Low  
Removed No  
Planned Response Action O & M

Inspector



Karen Foxx

State Indiana  
Accreditation Number 191129014

## PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools

Building Name Parkwood Elementary School

HA# A

Type of Material Miscellaneous Material

Quantity of Material LF

Material Location  
Throughout the building

Material Description  
Cove Base

Comments  
Material is in good condition. There are loose pieces in the art room.

Does Material Contain Asbestos? Assumed

Is it Friable? No

Original Inspection Date 5/31/95

Current Surveillance Date 1/14/98

Current Assessment Rating NR Not Required

Cause of Damage No Damage

Accessible Yes

Potential for Damage Low

Removed No

Planned Response Action O & M

Inspector



Karen Foxx

State Indiana

Accreditation Number 191129014

## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Parkwood Elementary School  
**HA#** B  
**Type of Material** Miscellaneous Material  
**Quantity of Material** LF  
**Material Location**  
Throughout the building  
**Material Description**  
Cove Base Mastic  
**Comments**  
Where exposed, material is in good condition.  
**Does Material Contain Asbestos?** Assumed  
**Is it Friable?** No  
**Original Inspection Date** 5/31/95  
**Current Surveillance Date** 1/14/98  
**Current Assessment Rating** NR Not Required  
**Cause of Damage** No Damage  
**Accessible** No  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M

**Inspector**



Karen Foxx

**State** Indiana  
**Accreditation Number** 191129014

## PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools  
Building Name Parkwood Elementary School  
HA# C  
Type of Material Miscellaneous Material  
Quantity of Material SF  
Material Location Throughout the building  
Material Description Transite Soffit  
Comments Material is in good condition.  
Does Material Contain Asbestos? Assumed  
Is it Friable? No  
Original Inspection Date 5/31/95  
Current Surveillance Date 1/14/98  
Current Assessment Rating NR Not Required  
Cause of Damage No Damage  
Accessible Yes  
Potential for Damage Low  
Removed No  
Planned Response Action O & M

Inspector



Karen Foxx

State Indiana  
Accreditation Number 191129014

## PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools  
Building Name Parkwood Elementary School  
HA# D  
Type of Material Miscellaneous Material  
Quantity of Material SF  
Material Location  
Gymnasium and Cafeteria  
Material Description  
Shock Joints on AHV  
Comments  
Material is in good condition.  
Does Material Contain Asbestos? Assumed  
Is it Friable? No  
Original Inspection Date 5/31/95  
Current Surveillance Date 1/14/98  
Current Assessment Rating NR Not Required  
Cause of Damage No Damage  
Accessible Yes  
Potential for Damage Low  
Removed No  
Planned Response Action O & M

Inspector



Karen Foxx

State Indiana  
Accreditation Number 191129014

## PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools  
Building Name Parkwood Elementary School  
HA# E  
Type of Material Miscellaneous Material  
Quantity of Material SF  
Material Location  
Boiler Room  
Material Description  
Incinerator

### Comments

Material was sampled in March '96 and found to be negative for asbestos.  
Incinerator has been removed.

Does Material Contain Asbestos? No  
Is it Friable? No  
Original Inspection Date 5/31/95  
Current Surveillance Date 1/14/98  
Current Assessment Rating NA Not Applicable  
Cause of Damage Not Applicable  
Accessible No  
Potential for Damage NA  
Removed Yes  
Planned Response Action None


Inspector



Karen Foxx

State Indiana  
Accreditation Number 191129014






## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Parkwood Elementary School  
**HA#** 1  
**Type of Material** Thermal Material  
**Quantity of Material** Each  
**Material Location**  
Above Ceiling from Boiler Room to Kitchen Area. (Halls, Classrooms, Boiler Room, Storage Room, Restrooms)  
**Material Description**  
Fittings  
**Comments**  
Damaged fitting found near water heater. Two damaged fittings across the hall from the gymnasium. O & M needed.  
**Does Material Contain Asbestos?** Assumed  
**Is it Friable?** No  
**Original Inspection Date** 6/ 1/92  
**Current Surveillance Date** 7/ 3/97  
**Current Assessment Rating** NR Not Required  
**Cause of Damage** No Damage  
**Accessible** Yes  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M

**Inspector**



Karen Foxx

**State** Indiana  
**Accreditation Number** 191129014

## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Parkwood Elementary School  
**HA#** 2  
**Type of Material** Miscellaneous Material  
**Quantity of Material** SF

**Material Location**  
Throughout the building

**Material Description**  
Floor Tile

**Comments**

New non-ACM floor tile in gymnasium. Floor tile is under carpet in cafeteria and on stage. Material is worn at entrances to classrooms.

**Does Material Contain Asbestos?** Assumed  
**Is it Friable?** No  
**Original Inspection Date** 6/ 1/92  
**Current Surveillance Date** 7/ 3/97  
**Current Assessment Rating** NR Not Required  
**Cause of Damage** No Damage  
**Accessible** Yes  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M

**Inspector**

  
\_\_\_\_\_  
Karen Foxx

**State** Indiana  
**Accreditation Number** 191129014

## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Parkwood Elementary School  
**HA#** A  
**Type of Material** Miscellaneous Material  
**Quantity of Material** LF

**Material Location**  
Throughout the building

**Material Description**  
Cove Base

**Comments**

Material is in good condition. There are loose pieces in the art room.

**Does Material Contain Asbestos?** Assumed  
**Is it Friable?** No  
**Original Inspection Date** 5/31/95  
**Current Surveillance Date** 7/ 3/97  
**Current Assessment Rating** NR Not Required  
**Cause of Damage** No Damage  
**Accessible** Yes  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M

**Inspector**

  
\_\_\_\_\_  
Karen Foxx

**State** Indiana  
**Accreditation Number** 191129014

## PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools  
Building Name Parkwood Elementary School  
HA# B  
Type of Material Miscellaneous Material  
Quantity of Material LF


Material Location  
Throughout the building

Material Description  
Cove Base Mastic

Comments  
Where exposed, material is in good condition.

Does Material Contain Asbestos? Assumed  
Is it Friable? No  
Original Inspection Date 5/31/95  
Current Surveillance Date 7/ 3/97  
Current Assessment Rating NR Not Required  
Cause of Damage No Damage  
Accessible No  
Potential for Damage Low  
Removed No  
Planned Response Action O & M

Inspector



---

Karen Foxx

State Indiana  
Accreditation Number 191129014

## PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools  
Building Name Parkwood Elementary School  
HA# C  
Type of Material Miscellaneous Material  
Quantity of Material SF  
Material Location Throughout the building  
Material Description Transite Soffit  
Comments Material is in good condition.  
Does Material Contain Asbestos? Assumed  
Is it Friable? No  
Original Inspection Date 5/31/95  
Current Surveillance Date 7/ 3/97  
Current Assessment Rating NR Not Required  
Cause of Damage No Damage  
Accessible Yes  
Potential for Damage Low  
Removed No  
Planned Response Action O & M

Inspector



Karen Foxx

State Indiana  
Accreditation Number 191129014

## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Parkwood Elementary School  
**HA#** D  
**Type of Material** Miscellaneous Material  
**Quantity of Material** SF  
**Material Location**  
Gymnasium and Cafeteria  
**Material Description**  
Shock Joints on AHV  
**Comments**  
Material is in good condition.  
**Does Material Contain Asbestos?** Assumed  
**Is it Friable?** No  
**Original Inspection Date** 5/31/95  
**Current Surveillance Date** 7/ 3/97  
**Current Assessment Rating** NR Not Required  
**Cause of Damage** No Damage  
**Accessible** Yes  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M

**Inspector**



---

Karen Foxx

**State** Indiana  
**Accreditation Number** 191129014

## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Parkwood Elementary School  
**HA#** E  
**Type of Material** Miscellaneous Material  
**Quantity of Material** SF  
**Material Location**  
Boiler Room  
**Material Description**  
Incinerator

**Comments**

Material was sampled in March '96 and found to be negative for asbestos. Incinerator has been removed.

**Does Material Contain Asbestos?** No  
**Is it Friable?** No  
**Original Inspection Date** 5/31/95  
**Current Surveillance Date** 7/ 3/97  
**Current Assessment Rating** NA Not Applicable  
**Cause of Damage** Not Applicable  
**Accessible** No  
**Potential for Damage** NA  
**Removed** Yes  
**Planned Response Action** None


**Inspector**



Karen Foxx

**State** Indiana  
**Accreditation Number** 191129014





## PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools

Building Name Parkwood Elementary School

HA# 1

Type of Material Thermal Material

Quantity of Material Each

**Material Location**

Above Ceiling from Boiler Room to Kitchen Area. (Halls, Classrooms, Boiler Room, Storage Room, Restrooms)

**Material Description**

Fittings

**Comments**

Damaged fitting found near water heater. Two damaged fittings across the hall from the gymnasium. O & M needed.

Does Material Contain Asbestos? Assumed

Is it Friable? No

Original Inspection Date 6/ 1/92

Current Surveillance Date 12/16/96

Current Assessment Rating NR Not Required

Cause of Damage No Damage


Accessible Yes

Potential for Damage Low

Removed No

Planned Response Action O & M

Inspector



Clint Yates

State Indiana


Accreditation Number 193804035

## PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools  
Building Name Parkwood Elementary School  
HA# 2  
Type of Material Miscellaneous Material  
Quantity of Material SF  
Material Location  
Throughout the building  
Material Description  
Floor Tile  
Comments  
New non-ACM floor tile in gymnasium. Floor tile is under carpet in cafeteria and stage.

Does Material Contain Asbestos? Assumed  
Is it Friable? No  
Original Inspection Date 6/ 1/92  
Current Surveillance Date 12/16/96  
Current Assessment Rating NR Not Required  
Cause of Damage No Damage  
Accessible Yes  
Potential for Damage Low  
Removed No  
Planned Response Action O & M

Inspector



Clint Yates

State

Indiana

Accreditation Number

193804035

## PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools

Building Name Parkwood Elementary School

HA# A

Type of Material Miscellaneous Material

Quantity of Material LF

Material Location  
Throughout the building

Material Description  
Cove Base

### Comments

Material is assumed to be positive and will be treated as ACM until it is sampled.  
Material is in good condition.

Does Material Contain Asbestos? Assumed

Is it Friable? No

Original Inspection Date 5/31/95

Current Surveillance Date 12/16/96

Current Assessment Rating NR Not Required

Cause of Damage No Damage


Accessible Yes

Potential for Damage Low

Removed No

Planned Response Action O & M

Inspector



Clint Yates

State Indiana

Accreditation Number 193804035

## PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools

Building Name Parkwood Elementary School

HA# B

Type of Material Miscellaneous Material

Quantity of Material LF


Material Location  
Throughout the building

Material Description  
Cove Base Mastic

Comments  
Material is assumed to be positive and will be treated as ACM until it is sampled.  
Material is in good condition.

Does Material Contain Asbestos? Assumed  
Is it Friable? No  
Original Inspection Date 5/31/95  
Current Surveillance Date 12/16/96  
Current Assessment Rating NR Not Required  
Cause of Damage No Damage  
Accessible No  
Potential for Damage Low  
Removed No  
Planned Response Action O & M

Inspector

  
Clint Yates

State Indiana

Accreditation Number 193804035

## PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools  
Building Name Parkwood Elementary School  
HA# C  
Type of Material Miscellaneous Material  
Quantity of Material SF

Material Location  
Throughout the building


Material Description  
Transite Soffit

### Comments

Material is assumed to be positive and will be treated as ACM until it is sampled.  
Material is in good condition.

Does Material Contain Asbestos? Assumed  
Is it Friable? No  
Original Inspection Date 5/31/95  
Current Surveillance Date 12/16/96  
Current Assessment Rating NR Not Required  
Cause of Damage No Damage  
Accessible Yes  
Potential for Damage Low  
Removed No  
Planned Response Action O & M

Inspector



Clint Yates

State Indiana  
Accreditation Number 193804035

## PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools  
Building Name Parkwood Elementary School  
HA# D  
Type of Material Miscellaneous Material  
Quantity of Material SF

Material Location  
Gymnasium and Cafeteria

Material Description  
Shock Joints on AHV

**Comments**

Material is assumed to be positive and will be treated as ACM until it is sampled.  
Material is in good condition.

Does Material Contain Asbestos? Assumed  
Is it Friable? No  
Original Inspection Date 5/31/95  
Current Surveillance Date 12/16/96  
Current Assessment Rating NR Not Required  
Cause of Damage No Damage  
Accessible Yes  
Potential for Damage Low  
Removed No  
Planned Response Action O & M

Inspector



Clint Yates

State

Indiana

Accreditation Number

193804035

## PERIODIC SURVEILLANCE REPORT


**LEA Name** Greater Clark County Schools  
**Building Name** Parkwood Elementary School  
**HA#** E  
**Type of Material** Miscellaneous Material  
**Quantity of Material** SF  
**Material Location**  
Boiler Room  
**Material Description**  
Incinerator

**Comments**

Material is assumed to be positive and will be treated as ACM until it is sampled.  
Material is in good condition.


**Does Material Contain Asbestos?** Assumed  
**Is it Friable?** No  
**Original Inspection Date** 5/31/95  
**Current Surveillance Date** 12/16/96  
**Current Assessment Rating** NR Not Required  
**Cause of Damage** No Damage  
**Accessible** Yes  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M

**Inspector**

  
Clint Yates

**State** Indiana  
**Accreditation Number** 193804035





## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools

**Building Name** Parkwood Elementary School

**HA#** 1

**Type of Material** Thermal Material

**Quantity of Material** Each

**Material Location**

Above Ceiling from Boiler Room to Kitchen Area. (Halls, Classrooms, Boiler Room, Storage Room, Restrooms)

**Material Description**

Fittings

**Comments**

Damaged fitting found near water heater. It is assumed to be ACM.

**Does Material Contain Asbestos?** Assumed

**Is it Friable?** No

**Original Inspection Date** 6/ 1/92

**Current Surveillance Date** 6/20/96

**Current Assessment Rating** NR Not Required

**Cause of Damage** No Damage

**Accessible** Yes

**Potential for Damage** Low

**Removed** No

**Planned Response Action** O & M

**Inspector**



Rex Gaddis

**State** Indiana

**Accreditation Number** 190908032

## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools

**Building Name** Parkwood Elementary School

**HA#** 2

**Type of Material** Miscellaneous Material

**Quantity of Material** SF

**Material Location**  
Throughout the building

**Material Description**  
Floor Tile

**Comments**

New non-ACM floor tile in gymnasium. Floor tile is under carpet in cafeteria and stage.

**Does Material Contain Asbestos?** Assumed

**Is it Friable?** No

**Original Inspection Date** 6/ 1/92

**Current Surveillance Date** 6/20/96

**Current Assessment Rating** NR Not Required

**Cause of Damage** No Damage


**Accessible** Yes

**Potential for Damage** Low

**Removed** No

**Planned Response Action** O & M

**Inspector**



Rex Gaddis

**State** Indiana

**Accreditation Number** 190908032

## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Parkwood Elementary School  
**HA#** A  
**Type of Material** Miscellaneous Material  
**Quantity of Material** LF

**Material Location**  
Throughout the building


**Material Description**  
Cove Base

**Comments**

Material is assumed to be positive and will be treated as ACM until it is sampled.  
Material is in good condition.

**Does Material Contain Asbestos?** Assumed  
**Is it Friable?** No  
**Original Inspection Date** 5/31/95  
**Current Surveillance Date** 6/20/96  
**Current Assessment Rating** NR Not Required  
**Cause of Damage** No Damage  
**Accessible** Yes  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M

**Inspector**



Rex Gaddis

**State** Indiana  
**Accreditation Number** 190908032

## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Parkwood Elementary School  
**HA#** B  
**Type of Material** Miscellaneous Material  
**Quantity of Material** LF

**Material Location**  
Throughout the building


**Material Description**  
Cove Base Mastic

**Comments**

Material is assumed to be positive and will be treated as ACM until it is sampled.  
Material is in good condition.

**Does Material Contain Asbestos?** Assumed  
**Is it Friable?** No  
**Original Inspection Date** 5/31/95  
**Current Surveillance Date** 6/20/96  
**Current Assessment Rating** NR Not Required  
**Cause of Damage** No Damage  
**Accessible** No  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M

**Inspector**



Rex Gaddis

**State** Indiana  
**Accreditation Number** 190908032

## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools

**Building Name** Parkwood Elementary School

**HA#** C

**Type of Material** Miscellaneous Material

**Quantity of Material** SF

**Material Location**  
Throughout the building


**Material Description**  
Transite Soffit

**Comments**

Material is assumed to be positive and will be treated as ACM until it is sampled.  
Material is in good condition.

**Does Material Contain Asbestos?** Assumed  
**Is it Friable?** No  
**Original Inspection Date** 5/31/95  
**Current Surveillance Date** 6/20/96  
**Current Assessment Rating** NR Not Required  
**Cause of Damage** No Damage  
**Accessible** Yes  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M

**Inspector**



Rex Gaddis

**State** Indiana

**Accreditation Number** 190908032

## PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools  
Building Name Parkwood Elementary School  
HA# D  
Type of Material Miscellaneous Material  
Quantity of Material SF

Material Location  
Gymnasium and Cafeteria


Material Description  
Shock Joints on AHV

### Comments

Material is assumed to be positive and will be treated as ACM until it is sampled.  
Material is in good condition.

Does Material Contain Asbestos? Assumed  
Is it Friable? No  
Original Inspection Date 5/31/95  
Current Surveillance Date 6/20/96  
Current Assessment Rating NR Not Required  
Cause of Damage No Damage  
Accessible Yes  
Potential for Damage Low  
Removed No  
Planned Response Action O & M

Inspector



Rex Gaddis

State Indiana  
Accreditation Number 190908032

## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Parkwood Elementary School  
**HA#** E  
**Type of Material** Miscellaneous Material  
**Quantity of Material** SF

**Material Location**  
Boiler Room


**Material Description**  
Incinerator

**Comments**

Material is assumed to be positive and will be treated as ACM until it is sampled.  
Material is in good condition.

**Does Material Contain Asbestos?** Assumed  
**Is it Friable?** No  
**Original Inspection Date** 5/31/95  
**Current Surveillance Date** 6/20/96  
**Current Assessment Rating** NR Not Required  
**Cause of Damage** No Damage  
**Accessible** Yes  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M


**Inspector**



Rex Gaddis

**State** Indiana  
**Accreditation Number** 190908032





PERIODIC SURVEILLANCE REPORT

LEA NAME: Greater Clark County Schools

BUILDING NAME: Parkwood Elementary School

HA#: 1

TYPE OF MATERIAL: Thermal Material

QUANTITY OF MATERIAL:

MATERIAL LOCATION:

Above Ceiling from Boiler Room to Kitchen Area. (Halls, Classrooms, Boiler Room, Storage Room, Restrooms)

MATERIAL DESCRIPTION:


Fittings

COMMENTS:

Damaged fitting found near water heater. It is assumed to be ACM.

IS MATERIAL FRIABLE? NO  
ORIGINAL INSPECTION DATE: 06/01/92  
CURRENT SURVEILLANCE DATE: 12/07/95  
CURRENT ASSESSMENT RATING: NR Not Required  
CAUSE OF DAMAGE: No Damage  
ACCESSIBLE: YES  
POTENTIAL FOR DAMAGE: Low  
REMOVED: NO  
STATE: Indiana

INSPECTOR NAME:



Clint Yates

PERIODIC SURVEILLANCE REPORT

LEA NAME: Greater Clark County Schools

BUILDING NAME: Parkwood Elementary School

HA#: 2

TYPE OF MATERIAL: Miscellaneous Material

QUANTITY OF MATERIAL:

MATERIAL LOCATION:

Throughout Building

MATERIAL DESCRIPTION:

Floor Tile

COMMENTS:

New non-ACM floor tile in gymnasium. Floor tile is under carpet in cafeteria and stage.

IS MATERIAL FRIABLE? NO  
ORIGINAL INSPECTION DATE: 06/01/92  
CURRENT SURVEILLANCE DATE: 12/07/95  
CURRENT ASSESSMENT RATING: NR Not Required  
CAUSE OF DAMAGE: No Damage  
ACCESSIBLE: YES  
POTENTIAL FOR DAMAGE: Low  
REMOVED: NO  
STATE: Indiana

INSPECTOR NAME:



Clint Yates

PERIODIC SURVEILLANCE REPORT

LEA NAME: Greater Clark County Schools

BUILDING NAME: Parkwood Elementary School

HA#: A

TYPE OF MATERIAL: Miscellaneous Material

QUANTITY OF MATERIAL:

MATERIAL LOCATION:

Throughout Building

MATERIAL DESCRIPTION:

Cove Base

COMMENTS:

This material was not addressed in the original inspection. It is assumed to be positive and will be treated as ACM until it is sampled. Material is in good condition and is non-friable and does not need an assessment rating at this time.

IS MATERIAL FRIABLE? NO

ORIGINAL INSPECTION DATE:

CURRENT SURVEILLANCE DATE: 12/07/95

CURRENT ASSESSMENT RATING: NR Not Required

CAUSE OF DAMAGE: No Damage


ACCESSIBLE: YES

POTENTIAL FOR DAMAGE: Low

REMOVED: NO

STATE: Indiana

INSPECTOR NAME:



Clint Yates

PERIODIC SURVEILLANCE REPORT

LEA NAME: Greater Clark County Schools

BUILDING NAME: Parkwood Elementary School

HA#: B

TYPE OF MATERIAL: Miscellaneous Material

QUANTITY OF MATERIAL:

MATERIAL LOCATION:

Throughout Building

MATERIAL DESCRIPTION:

Cove Base Mastic

COMMENTS:

This material was not addressed in the original inspection. It is assumed to be positive and will be treated as ACM until it is sampled. Material is in good condition and is non-friable and does not need an assessment rating at this time.

IS MATERIAL FRIABLE? NO

ORIGINAL INSPECTION DATE:

CURRENT SURVEILLANCE DATE: 12/07/95

CURRENT ASSESSMENT RATING: NR Not Required

CAUSE OF DAMAGE: No Damage

ACCESSIBLE: NO

POTENTIAL FOR DAMAGE: Low

REMOVED: NO

STATE: Indiana

INSPECTOR NAME:



Clint Yates

PERIODIC SURVEILLANCE REPORT

LEA NAME: Greater Clark County Schools

BUILDING NAME: Parkwood Elementary School

HA#: C

TYPE OF MATERIAL: Miscellaneous Material

QUANTITY OF MATERIAL:

MATERIAL LOCATION:

Throughout Building

MATERIAL DESCRIPTION:

Transite Soffit

COMMENTS:

This material was not addressed in the original inspection. It is assumed to be positive and will be treated as ACM until it is sampled. Material is in good conditon and is non-friable and does not need an assessment rating at this time.

IS MATERIAL FRIABLE? NO

ORIGINAL INSPECTION DATE:

CURRENT SURVEILLANCE DATE: 12/07/95

CURRENT ASSESSMENT RATING: NR Not Required

CAUSE OF DAMAGE: No Damage


ACCESSIBLE: YES

POTENTIAL FOR DAMAGE: Low

REMOVED: NO

STATE: Indiana

INSPECTOR NAME:



Clint Yates

PERIODIC SURVEILLANCE REPORT

LEA NAME: Greater Clark County Schools

BUILDING NAME: Parkwood Elementary School

HA#: D

TYPE OF MATERIAL: Miscellaneous Material

QUANTITY OF MATERIAL:

MATERIAL LOCATION:

Gymnasium and Cafeteria

MATERIAL DESCRIPTION:

Shock Joints on AHV

COMMENTS:

This material was not addressed in the original inspection. It is assumed to be positive and will be treated as ACM until it is sampled. Material is in good condition and is non-friable and does not need an assessment rating at this time.

IS MATERIAL FRIABLE? NO

ORIGINAL INSPECTION DATE:

CURRENT SURVEILLANCE DATE: 12/07/95

CURRENT ASSESSMENT RATING: NR Not Required

CAUSE OF DAMAGE: No Damage

ACCESSIBLE: YES

POTENTIAL FOR DAMAGE: Low

REMOVED: NO

STATE: Indiana

INSPECTOR NAME:



Clint Yates

PERIODIC SURVEILLANCE REPORT

LEA NAME: Greater Clark County Schools  
BUILDING NAME: Parkwood Elementary School  
HA#: E  
TYPE OF MATERIAL: Miscellaneous Material  
QUANTITY OF MATERIAL:  
MATERIAL LOCATION:

Boiler Room

MATERIAL DESCRIPTION:

Incinerator

COMMENTS:

This material was not addressed in the original inspection. It is assumed to be positive and will be treated as ACM until it is sampled. Material is in good condition and is non-friable and does not need an assessment rating at this time.

IS MATERIAL FRIABLE? NO  
ORIGINAL INSPECTION DATE:  
CURRENT SURVEILLANCE DATE: 12/07/95  
CURRENT ASSESSMENT RATING: NR Not Required  
CAUSE OF DAMAGE: No Damage  
ACCESSIBLE: YES  
POTENTIAL FOR DAMAGE: Low  
REMOVED: NO  
STATE: Indiana

INSPECTOR NAME:

  
Clint Yates



*THIRD YEAR REINSPECTIONS*

**REINSPECTION PLAN**

**GREATER CLARK COUNTY SCHOOLS**

Reinspection by an accredited building inspector will be scheduled to be performed not more than three years from the date of the original inspection. The reinspection report will then be made a permanent part of this Management Plan. Reinspections will be performed every three years for as long as the building contains ACBM, and will be reinspected once within three years from the date that all ACBM has been removed.

Records of each reinspection should be maintained in this binder.

<u>DATE PLANNED</u>	<u>DATE COMPLETED</u>	<u>COMPLETED BY</u>
<u>JUNE 2007</u>	<u>July 2007</u>	<u>Bill Cole</u>
<u>JUNE 2010</u>	<u>June 2010</u>	<u>Sandy Shadley</u>
<u>JUNE 2013</u>	<u>June 2013</u>	<u>Jeff Hechtin</u>
<u>JUNE 2016</u>	<u>April 2016</u>	<u>Benjamin [Signature]</u>
<u>JUNE 2019</u>	<u>May 2019</u>	<u>[Signature]</u>
<u>JUNE 2022</u>	_____	_____
<u>JUNE 2025</u>	_____	_____

REINSPECTION PLAN

## GREATER CLARK COUNTY SCHOOLS

## PARKWOOD ELEMENTARY SCHOOL

The ACBM in this building shall be reinspected every three years to determine any change in the condition of the materials for as long they remain in the building. This reinspection will be conducted tri-annually by an accredited inspector.

The following table outlines the dates on which these inspections should take place in this school building.

REINSPECTION SCHEDULE

<u>DATE PLANNED</u>	<u>DATE COMPLETED</u>	<u>COMPLETED BY</u>
<u>JUNE 1992</u>	<u>JUNE 1992</u>	<u>ASBESTECH</u>
<u>JUNE 1995</u>	<u>June '95</u>	<u>Alliance</u>
<u>JUNE 1998</u>	<u>June '98</u>	<u>Alliance</u>
<u>JUNE 2001</u>	<u>July '01</u>	<u>P. Wilson</u>
<u>JUNE 2004</u>	<u>July '04</u>	<u>C. Sparks</u>

# Triennial Reinspection

**LEA Name** Greater Clark County School Corporation  
**Building Name** Parkwood Elementary School  
**Building Number** 19  
**HA ID** 01  
**HA Description** Fittings  
**HA Type** Thermal System Insulation (TSI)  
**HA Location** Above ceiling from boiler room to kitchen area. (halls, classrooms, storage room, restrooms) Behind refrigerator in custodial room.

**Quantity** Unquantified LF  
**Comments** This material was not in poor condition. It is seen above ceiling in the main hallway.  
**Asbestos** Known  
**Friable** No

**Original Inspection** 6/1/1992  
**Current Inspection** 5/16/2019

## Material Assessment

**Assessment Rating** 5 ACBM with potential for damage

## Damage Assessment and Potential for Damage

<b><u>Percent Damaged</u></b>	%	Good Condition		
<b><u>Physical Contact</u></b>		<b><u>Vibration</u></b>		<b><u>Air</u></b>
Low/None		Low/None		Low/None

**Planned Response Action** O&M

**Inspector**



Sean Stults

**State** IN

**Accreditation Number** 19A007184

# Triennial Reinspection

**LEA Name** Greater Clark County School Corporation  
**Building Name** Parkwood Elementary School  
**Building Number** 19  
**HA ID** 02-A  
**HA Description** 9"X9" tan floor tile (OLD)  
**HA Type** Miscellaneous Material  
**HA Location** Custodial Room & Classrooms

**Quantity** Unquantified SF  
**Comments** 9"X9" floor tile was removed and replaced by 12"X12" floor tile in the custodial closet.  
Most of this material is under carpet. This material shows normal wear, but was not in poor condition overall.

**Asbestos** Assumed  
**Friable** No

**Original Inspection** 6/1/1992  
**Current Inspection** 5/16/2019

## Material Assessment

**Assessment Rating** 5 ACBM with potential for damage

## Damage Assessment and Potential for Damage

<b>Percent Damaged</b>	%	Good Condition	
<b>Physical Contact</b>		<b>Vibration</b>	<b>Air</b>
Low/None		Low/None	Low/None

**Planned Response Action** O&M

**Inspector**



Sean Stults

**State** IN

**Accreditation Number** 19A007184

# Triennial Reinspection

**LEA Name** Greater Clark County School Corporation  
**Building Name** Parkwood Elementary School  
**Building Number** 19  
**HA ID** 02-B  
**HA Description** 12"X12" Floor tile (NEWER) Light Blue  
**HA Type** Miscellaneous Material  
**HA Location** Gym

**Quantity** Unquantified SF  
**Comments** This material was not in poor condition overall.  
**Asbestos** Assumed  
**Friable** No

**Original Inspection** 6/27/2011  
**Current Inspection** 5/16/2019

## Material Assessment

**Assessment Rating** 5 ACBM with potential for damage

## Damage Assessment and Potential for Damage

<b>Percent Damaged</b>	%	Good Condition	
<b>Physical Contact</b>		<b>Vibration</b>	<b>Air</b>
Low/None		Low/None	Low/None

**Planned Response Action** O&M

**Inspector**



Sean Stults

**State** IN

**Accreditation Number** 19A007184

# Triennial Reinspection

**LEA Name** Greater Clark County School Corporation  
**Building Name** Parkwood Elementary School  
**Building Number** 19  
**HA ID** 02-C  
**HA Description** 12" X 12" Floor tile (NEWER) White  
**HA Type** Miscellaneous Material  
**HA Location** Cafeteria + custodial room

**Quantity** Unquantified SF  
**Comments** This material was not in poor condition overall.  
**Asbestos** Assumed  
**Friable** No

**Original Inspection** 6/27/2011  
**Current Inspection** 5/16/2019

## Material Assessment

**Assessment Rating** 5 ACBM with potential for damage

## Damage Assessment and Potential for Damage

<b>Percent Damaged</b>	%	Good Condition	
<b>Physical Contact</b>		<b>Vibration</b>	<b>Air</b>
Low/None		Low/None	Low/None

**Planned Response Action** O&M

**Inspector**



Sean Stults

**State** IN

**Accreditation Number** 19A007184



# Triennial Reinspection

**LEA Name** Greater Clark County School Corporation  
**Building Name** Parkwood Elementary School  
**Building Number** 19  
**HA ID** 02-D  
**HA Description** 12" X 12" Floor tile (NEWER) Dark Blue  
**HA Type** Miscellaneous Material  
**HA Location** Cafeteria

**Quantity** Unquantified SF  
**Comments** This material was not in poor condition overall.  
**Asbestos** Assumed  
**Friable** No

**Original Inspection** 6/27/2011  
**Current Inspection** 5/16/2019

## Material Assessment

**Assessment Rating** 5 ACBM with potential for damage

## Damage Assessment and Potential for Damage

<b>Percent Damaged</b>	%	Good Condition	
<b>Physical Contact</b>		<b>Vibration</b>	<b>Air</b>
Low/None		Low/None	Low/None

**Planned Response Action** O&M

**Inspector**



Sean Stults

**State** IN

**Accreditation Number** 19A007184

# Triennial Reinspection

**LEA Name** Greater Clark County School Corporation  
**Building Name** Parkwood Elementary School  
**Building Number** 19  
**HA ID** 02-E  
**HA Description** 12" X 12" Floor tile Light gray  
**HA Type** Miscellaneous Material  
**HA Location** Stage

**Quantity** Unquantified SF  
**Comments** This material was not in poor condition overall.  
**Asbestos** Assumed  
**Friable** No

**Original Inspection** 6/27/2011  
**Current Inspection** 5/16/2019

## Material Assessment

**Assessment Rating** 5 ACBM with potential for damage

## Damage Assessment and Potential for Damage

<b>Percent Damaged</b>	%	Good Condition	
<b>Physical Contact</b>		<b>Vibration</b>	<b>Air</b>
Low/None		Low/None	Low/None

**Planned Response Action** O&M

**Inspector**



Sean Stults

**State** IN

**Accreditation Number** 19A007184

# Triennial Reinspection

**LEA Name** Greater Clark County School Corporation  
**Building Name** Parkwood Elementary School  
**Building Number** 19  
**HA ID** A  
**HA Description** Cove Base  
**HA Type** Miscellaneous Material  
**HA Location** Throughout building

**Quantity** Unquantified LF  
**Comments** There are minor signs of wear but this material was not in poor condition overall. Some has been replaced with new cove base.  
**Asbestos** Assumed  
**Friable** No  
**Original Inspection** 5/31/1995  
**Current Inspection** 5/16/2019

## Material Assessment

**Assessment Rating** 5 ACBM with potential for damage

## Damage Assessment and Potential for Damage

**Percent Damaged** % Good Condition

<b><u>Physical Contact</u></b>	<b><u>Vibration</u></b>	<b><u>Air</u></b>
Low/None	Low/None	Low/None

**Planned Response Action** O&M

**Inspector**



Sean Stults

**State** IN

**Accreditation Number** 19A007184

# Triennial Reinspection

**LEA Name** Greater Clark County School Corporation  
**Building Name** Parkwood Elementary School  
**Building Number** 19  
**HA ID** B  
**HA Description** Cove Base Mastic  
**HA Type** Miscellaneous Material  
**HA Location** Throughout building

**Quantity** Approx 900 SF  
**Comments** Mastic was exposed to inspect in the library (By door) & gym and it was not in poor condition.  
**Asbestos** No  
**Friable** No

**Original Inspection** 5/31/1995  
**Current Inspection** 5/16/2019

## Material Assessment

**Assessment Rating** 5 ACBM with potential for damage

## Damage Assessment and Potential for Damage

<b><u>Percent Damaged</u></b>	%	Good Condition
<b><u>Physical Contact</u></b>	<b><u>Vibration</u></b>	<b><u>Air</u></b>
Low/None	Low/None	Low/None

**Planned Response Action** O&M

**Inspector**



Sean Stults

**State** IN

**Accreditation Number** 19A007184

# Triennial Reinspection

**LEA Name** Greater Clark County School Corporation  
**Building Name** Parkwood Elementary School  
**Building Number** 19  
**HA ID** C  
**HA Description** Transite Soffite  
**HA Type** Miscellaneous Material  
**HA Location** Outside building soffit

**Quantity** 2114 SF

**Comments** This material is not in poor condition with some minor cracking around the edges. The first panel by the entrance has been replaced with grey material (possibly plywood). The 5th one from the left has a long crack in it but is still in place.

**Asbestos** Assumed  
**Friable** No

**Original Inspection** 5/31/1995  
**Current Inspection** 5/16/2019

## Material Assessment

**Assessment Rating** 5 ACBM with potential for damage

## Damage Assessment and Potential for Damage

**Percent Damaged** % Good Condition

<u>Physical Contact</u>	<u>Vibration</u>	<u>Air</u>
Low/None	Low/None	Low/None

**Planned Response Action** O&M

**Inspector**



Sean Stults

**State** IN

**Accreditation Number** 19A007184

# Triennial Reinspection

**LEA Name** Greater Clark County School Corporation  
**Building Name** Parkwood Elementary School  
**Building Number** 19  
**HA ID** D  
**HA Description** Green shock joints on AHU  
**HA Type** Miscellaneous Material  
**HA Location** Gymnasium and cafeteria

**Quantity** 0 SF

**Comments** This material was not in poor condition. Four locations of material above gymnasium.  
This material was sampled by a licensed inspector and found to be a non-asbestos material by an accredited laboratory. Therefore, it is being removed from the management plan.

**Asbestos** No  
**Friable** No

**Original Inspection** 5/31/1995  
**Current Inspection** 5/16/2019

## Material Assessment

**Assessment Rating** 5 ACBM with potential for damage

## Damage Assessment and Potential for Damage

<b><u>Percent Damaged</u></b>	%	Good Condition	
<b><u>Physical Contact</u></b>		<b><u>Vibration</u></b>	<b><u>Air</u></b>
Low/None		Low/None	Low/None

**Planned Response Action** O&M

**Inspector**



Sean Stults

**State** IN

**Accreditation Number** 19A007184



# Triennial Reinspection

**LEA Name** Greater Clark County School Corporation  
**Building Name** Parkwood Elementary School  
**Building Number** 19  
**HA ID** 01  
**HA Description** Fittings  
**HA Type** Thermal System Insulation (TSI)  
**HA Location** Above ceiling from boiler room to kitchen area. (halls, classrooms, storage room, restrooms) Behind refrigerator in custodial room.

**Quantity** Unquantified LF  
**Comments** This material was not in poor condition. It is seen above ceiling in the main hallway.  
**Asbestos** Known  
**Friable** No

**Original Inspection** 6/1/1992  
**Current Inspection** 4/27/2016

## Material Assessment

**Assessment Rating** 5 ACBM with potential for damage

## Damage Assessment and Potential for Damage

<b><u>Percent Damaged</u></b>	%	Good Condition	
<b><u>Physical Contact</u></b>		<b><u>Vibration</u></b>	<b><u>Air</u></b>
Low/None		Low/None	Low/None

**Planned Response Action** O&M

**Inspector**



Benjamin S. Hood

**State** IN

**Accreditation Number** 19A001039

# Triennial Reinspection

**LEA Name** Greater Clark County School Corporation  
**Building Name** Parkwood Elementary School  
**Building Number** 19  
**HA ID** 02-A  
**HA Description** 9"X9" tan floor tile (OLD)  
**HA Type** Miscellaneous Material  
**HA Location** Custodial Room & Classrooms

**Quantity** Unquantified SF  
**Comments** 9"X9" floor tile was removed and replaced by 12"X12" floor tile in the custodial closet.  
Most of this material is under carpet. This material shows normal wear, but was not in poor condition overall.  
**Asbestos** Assumed  
**Friable** No  
**Original Inspection** 6/1/1992  
**Current Inspection** 4/27/2016

## Material Assessment

**Assessment Rating** 5 ACBM with potential for damage


## Damage Assessment and Potential for Damage

**Percent Damaged** % Good Condition

<u>Physical Contact</u>	<u>Vibration</u>	<u>Air</u>
Low/None	Low/None	Low/None

**Planned Response Action** O&M

**Inspector**



Benjamin S. Hood

**State IN**

**Accreditation Number 19A001039**

# Triennial Reinspection

**LEA Name** Greater Clark County School Corporation  
**Building Name** Parkwood Elementary School  
**Building Number** 19  
**HA ID** 02-B  
**HA Description** 12"X12" Floor tile (NEWER) Light Blue  
**HA Type** Miscellaneous Material  
**HA Location** Gym

**Quantity** Unquantified SF  
**Comments** This material was not in poor condition overall.  
**Asbestos** Assumed  
**Friable** No

**Original Inspection** 6/27/2011  
**Current Inspection** 4/27/2016

## Material Assessment


**Assessment Rating** 5 ACBM with potential for damage

## Damage Assessment and Potential for Damage

<b>Percent Damaged</b>	%	Good Condition	
<b>Physical Contact</b>		<b>Vibration</b>	<b>Air</b>
Low/None		Low/None	Low/None

**Planned Response Action** O&M

**Inspector**



Benjamin S. Hood

**State** IN

**Accreditation Number** 19A001039

# Triennial Reinspection

**LEA Name** Greater Clark County School Corporation  
**Building Name** Parkwood Elementary School  
**Building Number** 19  
**HA ID** 02-C  
**HA Description** 12" X 12" Floor tile (NEWER) White  
**HA Type** Miscellaneous Material  
**HA Location** Cafeteria + custodial room

**Quantity** Unquantified SF  
**Comments** This material was not in poor condition overall.  
**Asbestos** Assumed  
**Friable** No

**Original Inspection** 6/27/2011  
**Current Inspection** 4/27/2016

## Material Assessment

**Assessment Rating** 5 ACBM with potential for damage

## Damage Assessment and Potential for Damage

<b><u>Percent Damaged</u></b>	%	Good Condition	
<b><u>Physical Contact</u></b>		<b><u>Vibration</u></b>	<b><u>Air</u></b>
Low/None		Low/None	Low/None

**Planned Response Action** O&M

**Inspector**



Benjamin S. Hood

**State** IN

**Accreditation Number** 19A001039

# Triennial Reinspection

**LEA Name** Greater Clark County School Corporation  
**Building Name** Parkwood Elementary School  
**Building Number** 19  
**HA ID** 02-D  
**HA Description** 12" X 12" Floor tile (NEWER) Dark Blue  
**HA Type** Miscellaneous Material  
**HA Location** Cafeteria

**Quantity** Unquantified SF  
**Comments** This material was not in poor condition overall.  
**Asbestos** Assumed  
**Friable** No

**Original Inspection** 6/27/2011  
**Current Inspection** 4/27/2016

## Material Assessment

**Assessment Rating** 5 ACBM with potential for damage

## Damage Assessment and Potential for Damage

<b>Percent Damaged</b>	%	Good Condition	
<b>Physical Contact</b>		<b>Vibration</b>	<b>Air</b>
Low/None		Low/None	Low/None

**Planned Response Action** O&M

**Inspector**



Benjamin S. Hood

**State** IN

**Accreditation Number** 19A001039

# Triennial Reinspection

**LEA Name** Greater Clark County School Corporation  
**Building Name** Parkwood Elementary School  
**Building Number** 19  
**HA ID** 02-E  
**HA Description** 12" X 12" Floor tile Light gray  
**HA Type** Miscellaneous Material  
**HA Location** Stage

**Quantity** Unquantified SF  
**Comments** This material was not in poor condition overall.  
**Asbestos** Assumed  
**Friable** No

**Original Inspection** 6/27/2011  
**Current Inspection** 4/27/2016

## Material Assessment

**Assessment Rating** 5 ACBM with potential for damage

## Damage Assessment and Potential for Damage

<b><u>Percent Damaged</u></b>	%	Good Condition
<b><u>Physical Contact</u></b>	<b><u>Vibration</u></b>	<b><u>Air</u></b>
Low/None	Low/None	Low/None

**Planned Response Action** O&M

**Inspector**



Benjamin S. Hood

**State** IN

**Accreditation Number** 19A001039

# Triennial Reinspection

**LEA Name** Greater Clark County School Corporation  
**Building Name** Parkwood Elementary School  
**Building Number** 19  
**HA ID** A  
**HA Description** Cove Base  
**HA Type** Miscellaneous Material  
**HA Location** Throughout building

**Quantity** Unquantified LF  
**Comments** There are minor signs of wear but this material was not in poor condition overall. Some has been replaced with new cove base.  
**Asbestos** Assumed  
**Friable** No  
**Original Inspection** 5/31/1995  
**Current Inspection** 4/27/2016

## Material Assessment

**Assessment Rating** 5 ACBM with potential for damage

## Damage Assessment and Potential for Damage

**Percent Damaged** % Good Condition

<u>Physical Contact</u>	<u>Vibration</u>	<u>Air</u>
Low/None	Low/None	Low/None

**Planned Response Action** O&M

**Inspector**



Benjamin S. Hood

**State** IN

**Accreditation Number** 19A001039



# Triennial Reinspection

**LEA Name** Greater Clark County School Corporation  
**Building Name** Parkwood Elementary School  
**Building Number** 19  
**HA ID** B  
**HA Description** Cove Base Mastic  
**HA Type** Miscellaneous Material  
**HA Location** Throughout building

**Quantity** Approx 900 SF  
**Comments** Mastic was exposed to inspect in the library (By door) & gym and it was not in poor condition.  
**Asbestos** No  
**Friable** No  
**Original Inspection** 5/31/1995  
**Current Inspection** 4/27/2016

## Material Assessment

**Assessment Rating** 5 ACBM with potential for damage

## Damage Assessment and Potential for Damage

**Percent Damaged** % Good Condition

<b><u>Physical Contact</u></b>	<b><u>Vibration</u></b>	<b><u>Air</u></b>
Low/None	Low/None	Low/None

**Planned Response Action** O&M

**Inspector**



Benjamin S. Hood

**State** IN

**Accreditation Number** 19A001039

# Triennial Reinspection

**LEA Name** Greater Clark County School Corporation  
**Building Name** Parkwood Elementary School  
**Building Number** 19  
**HA ID** C  
**HA Description** Transite Soffite  
**HA Type** Miscellaneous Material  
**HA Location** Outside building soffit

**Quantity** 2114 SF

**Comments** This material is not in poor condition with some minor cracking around the edges. The first panel by the entrance has been replaced with grey material (possibly plywood). The 5th one from the left has a long crack in it but is still in place.

**Asbestos** Assumed  
**Friable** No

**Original Inspection** 5/31/1995  
**Current Inspection** 4/27/2016

## Material Assessment

**Assessment Rating** 5 ACBM with potential for damage


## Damage Assessment and Potential for Damage

**Percent Damaged** % Good Condition

<u>Physical Contact</u>	<u>Vibration</u>	<u>Air</u>
Low/None	Low/None	Low/None

**Planned Response Action** O&M

**Inspector**



Benjamin S. Hood

**State IN**

**Accreditation Number 19A001039**

# Triennial Reinspection

**LEA Name** Greater Clark County School Corporation  
**Building Name** Parkwood Elementary School  
**Building Number** 19  
**HA ID** D  
**HA Description** Green shock joints on AHU  
**HA Type** Miscellaneous Material  
**HA Location** Gymnasium and cafeteria

**Quantity** 0 SF  
**Comments** This material was not in poor condition. Four locations of material above gymnasium.  
This material was sampled by a licensed inspector and found to be a non-asbestos material by an accredited laboratory. Therefore, it is being removed from the management plan.

**Asbestos** No  
**Friable** No

**Original Inspection** 5/31/1995  
**Current Inspection** 4/27/2016

## Material Assessment

**Assessment Rating** 5 ACBM with potential for damage

## Damage Assessment and Potential for Damage

<b><u>Percent Damaged</u></b>	%	Good Condition	
<b><u>Physical Contact</u></b>		<b><u>Vibration</u></b>	<b><u>Air</u></b>
Low/None		Low/None	Low/None

**Planned Response Action** O&M


**Inspector**



Benjamin S. Hood

**State IN**

**Accreditation Number 19A001039**



## THIRD YEAR REINSPECTION REPORT

**LEA Name** Greater Clark County Schools

**Building Name** Parkwood Elementary School

**HA#** 01

**Type of Material** Thermal Material

**Quantity of Material** Unquantified LF

**Material Location**

Above ceiling from boiler room to kitchen area. (halls, classrooms, storage room, restrooms) Behind refrigerator in custodial room.

**Material Description**

Fittings

**Comments**

This material was not in poor condition. It is seen above ceiling in the main hallway.

**Does Material Contain Asbestos?** Yes

**Is it Friable?** No

**Original Inspection Date** 6/1/1992

**Current Reinspection Date** 4/24/2013

**Current Assessment Rating** NR Not Rated

**Cause of Damage** No Damage

**Accessible** Yes

**Potential for Damage** Low

**Removed** No

**Planned Response Action** O & M

**Inspector**

  
\_\_\_\_\_  
Jeffrey P. Rehtin

**State** Indiana

**Accreditation Number** 19A003594

## THIRD YEAR REINSPECTION REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Parkwood Elementary School  
**HA#** 02-A  
**Type of Material** Miscellaneous Material  
**Quantity of Material** Unquantified SF

**Material Location**  
Custodial Room & Classrooms

**Material Description**  
9"X9" tan floor tile (OLD)

**Comments**

Most of this material is under carpet. This material shows normal wear, but was not in poor condition overall.

**Does Material Contain Asbestos?** Assumed  
**Is it Friable?** No  
**Original Inspection Date** 6/1/1992  
**Current Reinspection Date** 4/24/2013  
**Current Assessment Rating** NR Not Rated  
**Cause of Damage** No Damage  
**Accessible** Yes  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M

**Inspector**



---

Jeffrey P. Rechten

**State** Indiana  
**Accreditation Number** 19A003594



## THIRD YEAR REINSPECTION REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Parkwood Elementary School  
**HA#** 02-B  
**Type of Material** Miscellaneous Material  
**Quantity of Material** Unquantified SF

**Material Location**  
Gym

**Material Description**

12"X12" Floor tile (NEWER) Light Blue

**Comments**

This material was not in poor condition overall.

**Does Material Contain Asbestos?** Assumed  
**Is it Friable?** No  
**Original Inspection Date** 6/27/2011  
**Current Reinspection Date** 4/24/2013  
**Current Assessment Rating** NA Not Applicable  
**Cause of Damage** No Damage  
**Accessible** Yes  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M

**Inspector**



---

Jeffrey P. Rehtin

**State** Indiana  
**Accreditation Number** 19A003594

## THIRD YEAR REINSPECTION REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Parkwood Elementary School  
**HA#** 02-C  
**Type of Material** Miscellaneous Material  
**Quantity of Material** Unquantified SF

**Material Location**  
Cafeteria + custodial room

**Material Description**  
12" X 12" Floor tile (NEWER) White

**Comments**

This material was not in poor condition overall.

**Does Material Contain Asbestos?** Assumed  
**Is it Friable?** No  
**Original Inspection Date** 6/27/2011  
**Current Reinspection Date** 4/24/2013  
**Current Assessment Rating** NA Not Applicable  
**Cause of Damage** No Damage  
**Accessible** Yes  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M

**Inspector**



---

Jeffrey P. Rechten

**State** Indiana  
**Accreditation Number** 19A003594

## THIRD YEAR REINSPECTION REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Parkwood Elementary School  
**HA#** 02-D  
**Type of Material** Miscellaneous Material  
**Quantity of Material** Unquantified SF  
**Material Location**  
Cafeteria

**Material Description**


12" X 12" Floor tile (NEWER) Dark Blue

**Comments**

This material was not in poor condition overall.

**Does Material Contain Asbestos?** Assumed  
**Is it Friable?** No  
**Original Inspection Date** 6/27/2011  
**Current Reinspection Date** 4/24/2013  
**Current Assessment Rating** NA Not Applicable  
**Cause of Damage** No Damage  
**Accessible** Yes  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M

**Inspector**



---

Jeffrey P. Rechten

**State** Indiana  
**Accreditation Number** 19A003594

## THIRD YEAR REINSPECTION REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Parkwood Elementary School  
**HA#** 02-E  
**Type of Material** Miscellaneous Material  
**Quantity of Material** Unquantified SF

**Material Location**  
Stage

**Material Description**

12" X 12" Floor tile Light gray

**Comments**

This material was not in poor condition overall.

**Does Material Contain Asbestos?** Assumed  
**Is it Friable?** No  
**Original Inspection Date** 6/27/2011  
**Current Reinspection Date** 4/24/2013  
**Current Assessment Rating** NA Not Applicable  
**Cause of Damage** No Damage  
**Accessible** Yes  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M

**Inspector**



---

Jeffrey P. Rechten

**State** Indiana  
**Accreditation Number** 19A003594

## THIRD YEAR REINSPECTION REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Parkwood Elementary School  
**HA#** A  
**Type of Material** Miscellaneous Material  
**Quantity of Material** Unquantified LF

**Material Location**  
Throughout the building

**Material Description**  
Cove base

**Comments**

There are minor signs of wear but this material was not in poor condition overall. Some has been replaced with new cove base.

**Does Material Contain Asbestos?** Assumed  
**Is it Friable?** No  
**Original Inspection Date** 5/31/1995  
**Current Reinspection Date** 4/24/2013  
**Current Assessment Rating** NR Not Rated  
**Cause of Damage** No Damage  
**Accessible** Yes  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M

**Inspector**



---

Jeffrey P. Rehtin

**State** Indiana  
**Accreditation Number** 19A003594

## THIRD YEAR REINSPECTION REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Parkwood Elementary School  
**HA#** B  
**Type of Material** Miscellaneous Material  
**Quantity of Material** Approx 900 SF

**Material Location**  
Throughout the building

**Material Description**  
Cove base mastic

**Comments**

Mastic was exposed to inspect in the library (By door) & gym and it was not in poor condition.

**Does Material Contain Asbestos?** No  
**Is it Friable?** No  
**Original Inspection Date** 5/31/1995  
**Current Reinspection Date** 4/24/2013  
**Current Assessment Rating** NR Not Rated  
**Cause of Damage** No Damage  
**Accessible** No  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M

**Inspector**

  
\_\_\_\_\_  
Jeffrey P. Rehtin

**State** Indiana  
**Accreditation Number** 19A003594

## THIRD YEAR REINSPECTION REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Parkwood Elementary School  
**HA#** C  
**Type of Material** Miscellaneous Material  
**Quantity of Material** 2,114 SF

**Material Location**  
Outside building soffit

**Material Description**  
Transite soffit

**Comments**

This material is not in poor condition with some minor cracking around the edges. The first panel by the entrance has been replaced with grey material (possibly plywood). The 5th one from the left has a long crack in it but is still in place.

**Does Material Contain Asbestos?** Assumed  
**Is it Friable?** No  
**Original Inspection Date** 5/31/1995  
**Current Reinspection Date** 4/24/2013  
**Current Assessment Rating** NR Not Rated  
**Cause of Damage** No Damage  
**Accessible** Yes  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M

**Inspector**

  
\_\_\_\_\_  
Jeffrey P. Rehtin

**State** Indiana  
**Accreditation Number** 19A003594

## THIRD YEAR REINSPECTION REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Parkwood Elementary School  
**HA#** D  
**Type of Material** Miscellaneous Material  
**Quantity of Material** 0 SF

**Material Location**  
Gymnasium and cafeteria

**Material Description**  
Green shock joints on AHU

**Comments**

This material was not in poor condition. Four locations of material above gymnasium. This material was sampled by a licensed inspector and found to be a non-asbestos material by an accredited laboratory. Therefore, it is being removed from the management plan.

**Does Material Contain Asbestos?** No  
**Is it Friable?** No  
**Original Inspection Date** 5/31/1995  
**Current Reinspection Date** 4/24/2013  
**Current Assessment Rating** NR Not Rated  
**Cause of Damage** No Damage  
**Accessible** Yes  
**Potential for Damage** Low  
**Removed** Yes  
**Planned Response Action** Remove

**Inspector**



---

Jeffrey P. Rechten

**State** Indiana  
**Accreditation Number** 19A003594



## THIRD YEAR REINSPECTION REPORT

**LEA Name** Greater Clark County Schools

**Building Name** Parkwood Elementary School

**HA#** 01

**Type of Material** Thermal Material

**Quantity of Material** Unquantified LF

**Material Location**

Above ceiling from boiler room to kitchen area. (halls, classrooms, boiler room/mechanical room, storage room, restrooms) Behind refrigerator in custodial room.

**Material Description**

Fittings

**Comments**

This material was not in poor condition. It is easily seen in the boiler room/mechanical room in the main hallway and in the air handler room above the gymnasium. These fittings are painted yellow, blue, gray and red.

**Does Material Contain Asbestos?** Yes

**Is it Friable?** No

**Original Inspection Date** 6/1/1992

**Current Reinspection Date** 6/30/2010

**Current Assessment Rating** NR Not Required

**Cause of Damage** No Damage

**Accessible** Yes

**Potential for Damage** Low

**Removed** No

**Planned Response Action** O & M

**Inspector**



Sandra Shadley

**State** IN

**Accreditation Number** 19A002323

## THIRD YEAR REINSPECTION REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Parkwood Elementary School  
**HA#** 02  
**Type of Material** Miscellaneous Material  
**Quantity of Material** Unquantified SF

**Material Location**  
Throughout the building

**Material Description**

Floor tile

**Comments**

There is newer floor tile in the gymnasium and cafeteria. The custodial room is mostly old 9 X 9 light brown floor tile. This material was not in poor condition overall. Classrooms have a combination of 9 X 9 floor tile and carpet.

**Does Material Contain Asbestos?** Assumed  
**Is it Friable?** No  
**Original Inspection Date** 6/1/1992  
**Current Reinspection Date** 6/30/2010  
**Current Assessment Rating** NR Not Required  
**Cause of Damage** No Damage  
**Accessible** Yes  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M

**Inspector**

  
Sandra Shadley

**State** IN  
**Accreditation Number** 19A002323

## THIRD YEAR REINSPECTION REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Parkwood Elementary School  
**HA#** A  
**Type of Material** Miscellaneous Material  
**Quantity of Material** Unquantified LF

**Material Location**  
Throughout the building


**Material Description**  
Cove base

**Comments**

There are minor signs of wear but this material was not in poor condition overall. Some has been replaced with new cove base.

**Does Material Contain Asbestos?** Assumed  
**Is it Friable?** No  
**Original Inspection Date** 5/31/1995  
**Current Reinspection Date** 6/30/2010  
**Current Assessment Rating** NR Not Required  
**Cause of Damage** No Damage  
**Accessible** Yes  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M

**Inspector**

  
Sandra Shadley

**State** IN  
**Accreditation Number** 19A002323

## THIRD YEAR REINSPECTION REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Parkwood Elementary School  
**HA#** B  
**Type of Material** Miscellaneous Material  
**Quantity of Material** Approx. 900 SF

**Material Location**  
Throughout the building

**Material Description**  
Cove base mastic

**Comments**  
No mastic was exposed to inspect.

**Does Material Contain Asbestos?** Assumed  
**Is it Friable?** No  
**Original Inspection Date** 5/31/1995  
**Current Reinspection Date** 6/30/2010  
**Current Assessment Rating** NR Not Required  
**Cause of Damage** No Damage  
**Accessible** No  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M

**Inspector**

  
Sandra Shadley

**State** IN  
**Accreditation Number** 19A002323

## THIRD YEAR REINSPECTION REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Parkwood Elementary School  
**HA#** C  
**Type of Material** Miscellaneous Material  
**Quantity of Material** 2,114 SF

**Material Location**  
Outside building soffit

**Material Description**  
Transite soffit

**Comments**

This material is not in poor condition with some minor cracking around the edges. The first panel by the entrance has been replaced with grey material (possibly plywood). The 5th one from the left has a long crack in it but is still in place.

**Does Material Contain Asbestos?** Assumed  
**Is it Friable?** No  
**Original Inspection Date** 5/31/1995  
**Current Reinspection Date** 6/30/2010  
**Current Assessment Rating** NR Not Required  
**Cause of Damage** No Damage  
**Accessible** Yes  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M

**Inspector**

  
Sandra Shadley

**State** IN  
**Accreditation Number** 19A002323

## THIRD YEAR REINSPECTION REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Parkwood Elementary School  
**HA#** D  
**Type of Material** Miscellaneous Material  
**Quantity of Material** 120 SF

**Material Location**  
Gymnasium and cafeteria

**Material Description**  
Green shock joints on AHU

**Comments**

This material was not in poor condition. Four locations of material above gymnasium. No shock joint was visible on the unit in the kitchen stockroom. Could not locate during this inspection.

**Does Material Contain Asbestos?** Assumed  
**Is it Friable?** No  
**Original Inspection Date** 5/31/1995  
**Current Reinspection Date** 6/30/2010  
**Current Assessment Rating** NR Not Required  
**Cause of Damage** No Damage  
**Accessible** Yes  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M

**Inspector**

  
Sandra Shadley

**State** IN  
**Accreditation Number** 19A002323

# THIRD YEAR REINSPECTION REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Parkwood Elementary School  
**HA#** 01  
**Type of Material** Thermal Material  
**Quantity of Material** Unquantified LF

**Material Location**

Above ceiling from boiler room to kitchen area. (halls, classrooms, boiler room/mechanical room, storage room, restrooms)

**Material Description**


Fittings

**Comments**

This material was not in poor condition. It is easily seen in the boiler room/mechanical room in the main hallway and in the air handler room above the gymnasium.

**Does Material Contain Asbestos?** Yes  
**Is it Friable?** No  
**Original Inspection Date** 6/1/1992  
**Current Reinspection Date** 7/9/2007  
**Current Assessment Rating** NR Not Required  
**Cause of Damage** No Damage  
**Accessible** Yes  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M

**Inspector**

  
George William Ogle

**State** Indiana  
**Accreditation Number** 191003027

## THIRD YEAR REINSPECTION REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Parkwood Elementary School  
**HA#** 02  
**Type of Material** Miscellaneous Material  
**Quantity of Material** Unquantified SF

**Material Location**  
Throughout the building

**Material Description**  
Floor tile

**Comments**

There is newer floor tile in the gymnasium. Floor tile is under carpet in cafeteria. There are some chipped edges around the sink in the custodial room. The custodial room has been divided by a new wall. The other side will get carpet over the floor tile. This material was not in poor condition overall.

**Does Material Contain Asbestos?** Assumed  
**Is it Friable?** No  
**Original Inspection Date** 6/1/1992  
**Current Reinspection Date** 7/9/2007  
**Current Assessment Rating** NR Not Required  
**Cause of Damage** No Damage  
**Accessible** Yes  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M

**Inspector**

  
George William Ogle

**State** Indiana  
**Accreditation Number** 191003027



# THIRD YEAR REINSPECTION REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Parkwood Elementary School  
**HA#** A  
**Type of Material** Miscellaneous Material  
**Quantity of Material** Approx. 2,800 LF

**Material Location**  
Throughout the building


**Material Description**  
Cove base

**Comments**

There are minor signs of wear with a missing piece (no mastic visible) by room 26 (formerly C6). This material was not in poor condition overall.

**Does Material Contain Asbestos?** Assumed  
**Is it Friable?** No  
**Original Inspection Date** 5/31/1995  
**Current Reinspection Date** 7/9/2007  
**Current Assessment Rating** NR Not Required  
**Cause of Damage** No Damage  
**Accessible** Yes  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M

**Inspector**

  
George William Ogle

**State** Indiana  
**Accreditation Number** 191003027

# THIRD YEAR REINSPECTION REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Parkwood Elementary School  
**HA#** B  
**Type of Material** Miscellaneous Material  
**Quantity of Material** Approx. 900 SF  
**Material Location**  
Throughout the building  
**Material Description**  
Cove base mastic  
**Comments**  
No mastic was exposed to inspect.  
**Does Material Contain Asbestos?** Assumed  
**Is It Friable?** No  
**Original Inspection Date** 5/31/1995  
**Current Reinspection Date** 7/9/2007  
**Current Assessment Rating** NR Not Required  
**Cause of Damage** No Damage  
**Accessible** No  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M

**Inspector**

  
George William Ogle

**State** Indiana  
**Accreditation Number** 191003027

# THIRD YEAR REINSPECTION REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Parkwood Elementary School  
**HA#** C  
**Type of Material** Miscellaneous Material  
**Quantity of Material** 2,114 SF

**Material Location**  
Outside building soffit

**Material Description**  
Transite soffit

**Comments**

Material is not in poor condition with some minor cracking around the edges. The first panel by the entrance has been replaced with grey material (possibly plywood).

**Does Material Contain Asbestos?** Assumed  
**Is it Friable?** No  
**Original Inspection Date** 5/31/1995  
**Current Reinspection Date** 7/9/2007  
**Current Assessment Rating** NR Not Required  
**Cause of Damage** No Damage  
**Accessible** Yes  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M

**Inspector**

  
George William Ogle

**State** Indiana  
**Accreditation Number** 191003027

# THIRD YEAR REINSPECTION REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Parkwood Elementary School  
**HA#** D  
**Type of Material** Miscellaneous Material  
**Quantity of Material** 120 SF

**Material Location**  
Gymnasium and cafeteria

**Material Description**  
Green shock joints on AHU

**Comments**

This material was not in poor condition. Four locations of material above gymnasium.  
No shock joint was visible on the unit in the kitchen stockroom.

**Does Material Contain Asbestos?** Assumed  
**Is it Friable?** No  
**Original Inspection Date** 5/31/1995  
**Current Reinspection Date** 7/9/2007  
**Current Assessment Rating** NR Not Required  
**Cause of Damage** No Damage  
**Accessible** Yes  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M

**Inspector**

  
George William Oggle

**State** Indiana  
**Accreditation Number** 191003027

## THIRD YEAR REINSPECTION REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Parkwood Elementary School  
**HA#** 01  
**Type of Material** Thermal Material  
**Quantity of Material** Unquantified LF

**Material Location**

Above ceiling from boiler room to kitchen area. (halls, classrooms, boiler room/mechanical room, storage room, restrooms)

**Material Description**

Fittings

**Comments**

This material was not in poor condition. It is easily seen in the boiler room/mechanical room in the main hallway and in the air handler room above the gymnasium.

**Does Material Contain Asbestos?** Yes  
**Is it Friable?** No  
**Original Inspection Date** 6/1/1992  
**Current Reinspection Date** 7/2/2004  
**Current Assessment Rating** NR Not Required  
**Cause of Damage** No Damage  
**Accessible** Yes  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M

**Inspector**

  
\_\_\_\_\_  
Christian Sparks

**State** Indiana  
**Accreditation Number** 190804103

## THIRD YEAR REINSPECTION REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Parkwood Elementary School  
**HA#** 02  
**Type of Material** Miscellaneous Material  
**Quantity of Material** Unquantified SF

**Material Location**  
Throughout the building


**Material Description**  
Floor tile

**Comments**

There is newer floor tile in the gymnasium. Floor tile is under carpet in cafeteria. There are some chipped edges around the sink in the custodial room. There was no tile beneath new tile on the stage. Wood material is present. This material was not in poor condition overall.

**Does Material Contain Asbestos?** Assumed  
**Is it Friable?** No  
**Original Inspection Date** 6/1/1992  
**Current Reinspection Date** 7/2/2004  
**Current Assessment Rating** NR Not Required  
**Cause of Damage** No Damage  
**Accessible** Yes  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M

**Inspector**

  
\_\_\_\_\_  
Christian Sparks

**State** Indiana  
**Accreditation Number** 190804103

## THIRD YEAR REINSPECTION REPORT


**LEA Name** Greater Clark County Schools  
**Building Name** Parkwood Elementary School  
**HA#** A  
**Type of Material** Miscellaneous Material  
**Quantity of Material** Approx. 2,800 LF  
**Material Location**  
Throughout the building  
**Material Description**  
Cove base

**Comments**

There are minor signs of wear with a missing piece by room 26 (formerly C6). This material was not in poor condition overall.

**Does Material Contain Asbestos?** Assumed  
**Is it Friable?** No  
**Original Inspection Date** 5/31/1995  
**Current Reinspection Date** 7/2/2004  
**Current Assessment Rating** NR Not Required  
**Cause of Damage** No Damage  
**Accessible** Yes  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M

**Inspector**

  
\_\_\_\_\_  
Christian Sparks

**State** Indiana  
**Accreditation Number** 190804103

## THIRD YEAR REINSPECTION REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Parkwood Elementary School  
**HA#** B  
**Type of Material** Miscellaneous Material  
**Quantity of Material** Approx. 900 SF  
**Material Location**  
Throughout the building  
**Material Description**  
Cove base mastic  
**Comments**  
Where exposed, this material was not in poor condition.  
**Does Material Contain Asbestos?** Assumed  
**Is it Friable?** No  
**Original Inspection Date** 5/31/1995  
**Current Reinspection Date** 7/2/2004  
**Current Assessment Rating** NR Not Required  
**Cause of Damage** No Damage  
**Accessible** No  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M

**Inspector**

  
\_\_\_\_\_  
Christiaan Sparks

**State** Indiana  
**Accreditation Number** 190804103



## THIRD YEAR REINSPECTION REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Parkwood Elementary School  
**HA#** C  
**Type of Material** Miscellaneous Material  
**Quantity of Material** 2,114 SF

**Material Location**  
Outside building soffit


**Material Description**  
Transite soffit

**Comments**

Material is not in poor condition with some minor cracking around the edges. The first panel by the entrance has been replaced with grey material (possibly plywood).

**Does Material Contain Asbestos?** Assumed  
**Is it Friable?** No  
**Original Inspection Date** 5/31/1995  
**Current Reinspection Date** 7/2/2004  
**Current Assessment Rating** NR Not Required  
**Cause of Damage** No Damage  
**Accessible** Yes  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M

**Inspector**

  
\_\_\_\_\_  
Christiaan Sparks

**State** Indiana  
**Accreditation Number** 190804103


# THIRD YEAR REINSPECTION REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Parkwood Elementary School  
**HA#** D  
**Type of Material** Miscellaneous Material  
**Quantity of Material** 120 SF  
**Material Location**  
Gymnasium and cafeteria  
**Material Description**  
Green shock joints on AHU  
**Comments**  
This material was not in poor condition.  
**Does Material Contain Asbestos?** Assumed  
**Is it Friable?** No  
**Original Inspection Date** 5/31/1995  
**Current Reinspection Date** 7/2/2004  
**Current Assessment Rating** NR Not Required  
**Cause of Damage** No Damage  
**Accessible** Yes  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M

**Inspector**

  
\_\_\_\_\_  
Christiaan Sparks

**State** Indiana  
**Accreditation Number** 190804103



# THIRD YEAR REINSPECTION REPORT

**LEA Name** Greater Clark County Schools

**Building Name** Parkwood Elementary School

**HA#** 01

**Type of Material** Thermal Material

**Quantity of Material** Unquantified LF

**Material Location**

Above ceiling from boiler room to kitchen area. (halls, classrooms, boiler room, storage room, restrooms)

**Material Description**

Fittings

**Comments**

All fittings observed were in good condition.

**Does Material Contain Asbestos?** Yes

**Is it Friable?** No

**Original Inspection Date** 06/01/1992

**Current Reinspection Date** 07/10/2001

**Current Assessment Rating** NR Not Required

**Cause of Damage** No Damage

**Accessible** Yes

**Potential for Damage** Low

**Removed** No

**Planned Response Action** O & M

**Inspector**



Patrick E. Wilson

**State** Indiana

**Accreditation Number** 190824065

## THIRD YEAR REINSPECTION REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Parkwood Elementary School  
**HA#** 02  
**Type of Material** Miscellaneous Material  
**Quantity of Material** Unquantified SF

**Material Location**  
Throughout the building

**Material Description**  
Floor tile

**Comments**

There is newer floor tile in the gymnasium. Floor tile is under carpet in cafeteria and on stage. Small amount of chipped edges around sink in custodial room, but tile is in overall good condition.

**Does Material Contain Asbestos?** Assumed  
**Is it Friable?** No  
**Original Inspection Date** 06/01/1992  
**Current Reinspection Date** 07/10/2001  
**Current Assessment Rating** NR Not Required  
**Cause of Damage** No Damage  
**Accessible** Yes  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M

**Inspector**

  
Patrick E. Wilson

**State** Indiana  
**Accreditation Number** 190824065

## THIRD YEAR REINSPECTION REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Parkwood Elementary School  
**HA#** A  
**Type of Material** Miscellaneous Material  
**Quantity of Material** Approx. 2,800 LF

**Material Location**  
Throughout the building

**Material Description**  
Cove base

**Comments**

This material is in good condition overall. There are minor signs of wear and a missing piece by the west entrance.

**Does Material Contain Asbestos?** Assumed  
**Is it Friable?** No  
**Original Inspection Date** 05/31/1995  
**Current Reinspection Date** 07/10/2001  
**Current Assessment Rating** NR Not Required  
**Cause of Damage** Deterioration & Age  
**Accessible** Yes  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M

**Inspector**

*Patrick Wilson* *KW*

Patrick E. Wilson

**State** Indiana  
**Accreditation Number** 190824065

# THIRD YEAR REINSPECTION REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Parkwood Elementary School  
**HA#** B  
**Type of Material** Miscellaneous Material  
**Quantity of Material** Approx. 900 SF  
**Material Location**  
Throughout the building  
**Material Description**  
Cove base mastic  
**Comments**  
Where exposed, this material is in good condition.  
**Does Material Contain Asbestos?** Assumed  
**Is it Friable?** No  
**Original Inspection Date** 05/31/1995  
**Current Reinspection Date** 07/10/2001  
**Current Assessment Rating** NR Not Required  
**Cause of Damage** No Damage  
**Accessible** No  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M

**Inspector**

  
\_\_\_\_\_  
Patrick E. Wilson

**State** Indiana  
**Accreditation Number** 190824065

## THIRD YEAR REINSPECTION REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Parkwood Elementary School  
**HA#** C  
**Type of Material** Miscellaneous Material  
**Quantity of Material** 2,114 SF

**Material Location**  
Outside building soffit

**Material Description**  
Transite soffit

**Comments**  
Material is in good condition with some minor cracking around the edges.

**Does Material Contain Asbestos?** Assumed  
**Is it Friable?** No  
**Original Inspection Date** 05/31/1995  
**Current Reinspection Date** 07/10/2001  
**Current Assessment Rating** NR Not Required  
**Cause of Damage** Deterioration & Age  
**Accessible** Yes  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M

**Inspector**

*Patrick Wilson kw*

Patrick E. Wilson

**State** Indiana  
**Accreditation Number** 190824065



# THIRD YEAR REINSPECTION REPORT


**LEA Name** Greater Clark County Schools  
**Building Name** Parkwood Elementary School  
**HA#** D  
**Type of Material** Miscellaneous Material  
**Quantity of Material** 120 SF  
**Material Location**  
Gymnasium and cafeteria  
**Material Description**  
Green shock joints on AHU  
**Comments**  
Material is in good condition.  
**Does Material Contain Asbestos?** Assumed  
**Is it Friable?** No  
**Original Inspection Date** 05/31/1995  
**Current Reinspection Date** 07/10/2001  
**Current Assessment Rating** NR Not Required  
**Cause of Damage** No Damage  
**Accessible** Yes  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M

**Inspector**

*Patrick Wilson kw*

Patrick E. Wilson

**State** Indiana  
**Accreditation Number** 190824065



## THIRD YEAR REINSPECTION REPORT

**LEA Name** Greater Clark County Schools

**Building Name** Parkwood Elementary School

**HA#** 01

**Type of Material** Thermal Material

**Quantity of Material** Each

**Material Location**

Above Ceiling from Boiler Room to Kitchen Area. (Halls, Classrooms, Boiler Room, Storage Room, Restrooms)

**Material Description**

Fittings

**Comments**

Damaged fitting near water heater in boiler room has been removed. Two damaged fittings across the hall from the gymnasium have been repaired.

**Does Material Contain Asbestos?** Yes

**Is it Friable?** No

**Original Inspection Date** 6/ 1/92

**Current Reinspection Date** 6/ 1/98

**Current Assessment Rating** NR Not Required

**Cause of Damage** No Damage


**Accessible** Yes

**Potential for Damage** Low

**Removed** No

**Planned Response Action** O & M

**Inspector**

  
\_\_\_\_\_  
Clint Yates

**State** Indiana

**Accreditation Number** 193804035

## THIRD YEAR REINSPECTION REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Parkwood Elementary School  
**HA#** 02  
**Type of Material** Miscellaneous Material  
**Quantity of Material** SF

**Material Location**  
Throughout the building


**Material Description**  
Floor Tile

**Comments**

New non-ACM floor tile in gymnasium. Floor tile is under carpet in cafeteria and on stage. Material is worn at entrances to classrooms.

**Does Material Contain Asbestos?** Assumed  
**Is it Friable?** No  
**Original Inspection Date** 6/ 1/92  
**Current Reinspection Date** 6/ 1/98  
**Current Assessment Rating** NR Not Required  
**Cause of Damage** No Damage  
**Accessible** Yes  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M

**Inspector**

  
Clint Yates

**State** Indiana  
**Accreditation Number** 193804035

## THIRD YEAR REINSPECTION REPORT

**LEA Name** Greater Clark County Schools

**Building Name** Parkwood Elementary School

**HA#** A

**Type of Material** Miscellaneous Material

**Quantity of Material** LF

**Material Location**  
Throughout the building

**Material Description**  
Cove Base

**Comments**

Material is in good condition. There are loose pieces in the art room.

**Does Material Contain Asbestos?** Assumed

**Is it Friable?** No

**Original Inspection Date** 5/31/95

**Current Reinspection Date** 6/ 1/98

**Current Assessment Rating** NR Not Required

**Cause of Damage** No Damage


**Accessible** Yes

**Potential for Damage** Low

**Removed** No

**Planned Response Action** O & M

**Inspector**

  
Clint Yates

**State** Indiana

**Accreditation Number** 193804035

## THIRD YEAR REINSPECTION REPORT

**LEA Name** Greater Clark County Schools

**Building Name** Parkwood Elementary School

**HA#** B

**Type of Material** Miscellaneous Material

**Quantity of Material** LF

**Material Location**  
Throughout the building

**Material Description**  
Cove Base Mastic

**Comments**  
Where exposed, material is in good condition.

**Does Material Contain Asbestos?** Assumed

**Is it Friable?** No

**Original Inspection Date** 5/31/95

**Current Reinspection Date** 6/ 1/98

**Current Assessment Rating** NR Not Required

**Cause of Damage** No Damage


**Accessible** No

**Potential for Damage** Low

**Removed** No

**Planned Response Action** O & M

**Inspector**



Clint Yates

**State** Indiana

**Accreditation Number** 193804035

## THIRD YEAR REINSPECTION REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Parkwood Elementary School  
**HA#** C  
**Type of Material** Miscellaneous Material  
**Quantity of Material** SF


**Material Location**  
Throughout the building

**Material Description**  
Transite Soffit

**Comments**  
Material is in good condition.

**Does Material Contain Asbestos?** Assumed  
**Is it Friable?** No  
**Original Inspection Date** 5/31/95  
**Current Reinspection Date** 6/ 1/98  
**Current Assessment Rating** NR Not Required  
**Cause of Damage** No Damage  
**Accessible** Yes  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M

**Inspector**

  
Clint Yates

**State** Indiana  
**Accreditation Number** 193804035

# THIRD YEAR REINSPECTION REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Parkwood Elementary School  
**HA#** D  
**Type of Material** Miscellaneous Material  
**Quantity of Material** SF


**Material Location**  
Gymnasium and Cafeteria

**Material Description**  
Shock Joints on AHV

**Comments**  
Material is in good condition.

**Does Material Contain Asbestos?** Assumed  
**Is it Friable?** No  
**Original Inspection Date** 5/31/95  
**Current Reinspection Date** 6/ 1/98  
**Current Assessment Rating** NR Not Required  
**Cause of Damage** No Damage  
**Accessible** Yes  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M


**Inspector**



Clint Yates

**State** Indiana  
**Accreditation Number** 193804035





THIRD YEAR REINSPECTION REPORT

LEA NAME: Greater Clark County School Corp.

BUILDING NAME: Parkwood Elementary School

HA#: 1

TYPE OF MATERIAL: Thermal Material

QUANTITY OF MATERIAL:

MATERIAL LOCATION:

Above Ceiling from Boiler Room to Kitchen Area. (Halls, Classrooms, Boiler Room, Storage Room, Restrooms)

MATERIAL DESCRIPTION:

Fittings

COMMENTS:

Material is in good condition. It is assumed to be ACM.

IS MATERIAL FRIABLE?

NO

ORIGINAL INSPECTION DATE:

06/01/92

CURRENT REINSPECTION DATE:

06/28/95

CURRENT ASSESSMENT RATING:

NR Not Required

CAUSE OF DAMAGE:

No Damage

ACCESSIBLE:

NO

POTENTIAL FOR DAMAGE:

Low

REMOVED:

NO

CURRENT VIDEO TAPE:  
(TAPE NO/FOOTAGE)

/

INSPECTOR NAME:

  
\_\_\_\_\_  
Rex Gaddis

STATE:

Indiana

ACCREDITATION NO.:

190908032

THIRD YEAR REINSPECTION REPORT

LEA NAME: Greater Clark County School Corp.

BUILDING NAME: Parkwood Elementary School

HA#: 2

TYPE OF MATERIAL: Miscellaneous Material

QUANTITY OF MATERIAL:

MATERIAL LOCATION:

Throughout Building

MATERIAL DESCRIPTION:

Floor Tile

COMMENTS:

New non-ACM floor tile in gymnasium. Floor tile is under carpet in cafeteria and stage.

IS MATERIAL FRIABLE? NO

ORIGINAL INSPECTION DATE: 06/01/92

CURRENT REINSPECTION DATE: 06/28/95

CURRENT ASSESSMENT RATING: NR Not Required


CAUSE OF DAMAGE: No Damage

ACCESSIBLE: NO

POTENTIAL FOR DAMAGE: Low

REMOVED: NO

CURRENT VIDEO TAPE:  
(TAPE NO/FOOTAGE) /

INSPECTOR NAME:   
Rex Gaddis

STATE: Indiana

ACCREDITATION NO.: 190908032

THIRD YEAR REINSPECTION REPORT

LEA NAME: Greater Clark County School Corp.

BUILDING NAME: Parkwood Elementary School

HA#: A

TYPE OF MATERIAL: Miscellaneous Material

QUANTITY OF MATERIAL:

MATERIAL LOCATION:

Throughout Building

MATERIAL DESCRIPTION:

Cove Base

COMMENTS:

This material was not addressed in the original inspection. It is assumed to be positive and will be treated as ACM until it is sampled. Material is in good condition and is non-friable and does not need an assessment rating at this time.

IS MATERIAL FRIABLE? NO

ORIGINAL INSPECTION DATE:

CURRENT REINSPECTION DATE: 06/28/95

CURRENT ASSESSMENT RATING: NR Not Required

CAUSE OF DAMAGE: No Damage

ACCESSIBLE: NO

POTENTIAL FOR DAMAGE: Low

REMOVED: NO

CURRENT VIDEO TAPE: /  
(TAPE NO/FOOTAGE)

INSPECTOR NAME:

  
\_\_\_\_\_  
Rex Gaddis

STATE: Indiana

ACCREDITATION NO.: 190908032

THIRD YEAR REINSPECTION REPORT

LEA NAME: Greater Clark County School Corp.

BUILDING NAME: Parkwood Elementary School

HA#: B

TYPE OF MATERIAL: Miscellaneous Material

QUANTITY OF MATERIAL:

MATERIAL LOCATION:

Throughout Building

MATERIAL DESCRIPTION:

Cove Base Mastic

COMMENTS:

This material was not addressed in the original inspection. It is assumed to be positive and will be treated as ACM until it is sampled. Material is in good condition and is non-friable and does not need an assessment rating at this time.

IS MATERIAL FRIABLE? NO

ORIGINAL INSPECTION DATE:

CURRENT REINSPECTION DATE: 06/28/95

CURRENT ASSESSMENT RATING: NR Not Required

CAUSE OF DAMAGE: No Damage

ACCESSIBLE: NO

POTENTIAL FOR DAMAGE: Low

REMOVED: NO

CURRENT VIDEO TAPE: /  
(TAPE NO/FOOTAGE)

INSPECTOR NAME:

  
\_\_\_\_\_  
Rex Gaddis

STATE: Indiana

ACCREDITATION NO.: 190908032

THIRD YEAR REINSPECTION REPORT

LEA NAME: Greater Clark County School Corp.

BUILDING NAME: Parkwood Elementary School

HA#: C

TYPE OF MATERIAL: Miscellaneous Material

QUANTITY OF MATERIAL:

MATERIAL LOCATION:

Throughout Building

MATERIAL DESCRIPTION:

Transite Soffit

COMMENTS:

This material was not addressed in the original inspection. It is assumed to be positive and will be treated as ACM until it is sampled. Material is in good condition and is non-friable and does not need an assessment rating at this time.

IS MATERIAL FRIABLE? NO

ORIGINAL INSPECTION DATE:

CURRENT REINSPECTION DATE: 06/28/95

CURRENT ASSESSMENT RATING: NR Not Required

CAUSE OF DAMAGE: No Damage

ACCESSIBLE: NO

POTENTIAL FOR DAMAGE: Low

REMOVED: NO

CURRENT VIDEO TAPE: /  
(TAPE NO/FOOTAGE)

INSPECTOR NAME:

  
\_\_\_\_\_  
Rex Gaddis

STATE: Indiana

ACCREDITATION NO.: 190908032

THIRD YEAR REINSPECTION REPORT

LEA NAME: Greater Clark County School Corp.

BUILDING NAME: Parkwood Elementary School

HA#: D

TYPE OF MATERIAL: Miscellaneous Material

QUANTITY OF MATERIAL:

MATERIAL LOCATION:

Gymnasium and Cafeteria

MATERIAL DESCRIPTION:

Shock Joints on AHV

COMMENTS:

This material was not addressed in the original inspection. It is assumed to be positive and will be treated as ACM until it is sampled. Material is in good condition and is non-friable and does not need an assessment rating at this time.

IS MATERIAL FRIABLE? NO

ORIGINAL INSPECTION DATE:

CURRENT REINSPECTION DATE: 06/28/95

CURRENT ASSESSMENT RATING: NR Not Required

CAUSE OF DAMAGE: No Damage

ACCESSIBLE: NO

POTENTIAL FOR DAMAGE: Low

REMOVED: NO

CURRENT VIDEO TAPE: /  
(TAPE NO/FOOTAGE)

INSPECTOR NAME:

  
\_\_\_\_\_  
Rex Gaddis

STATE: Indiana

ACCREDITATION NO.: 190908032

THIRD YEAR REINSPECTION REPORT

LEA NAME: Greater Clark County School Corp.

BUILDING NAME: Parkwood Elementary School

HA#: E

TYPE OF MATERIAL: Miscellaneous Material

QUANTITY OF MATERIAL:

MATERIAL LOCATION:

Boiler Room

MATERIAL DESCRIPTION:

Incinerator

COMMENTS:

This material was not addressed in the original inspection. It is assumed to be positive and will be treated as ACM until it is sampled. Material is in good condition and is non-friable and does not need an assessment rating at this time.

IS MATERIAL FRIABLE? NO

ORIGINAL INSPECTION DATE:

CURRENT REINSPECTION DATE: 06/28/95

CURRENT ASSESSMENT RATING: NR Not Required

CAUSE OF DAMAGE: No Damage

ACCESSIBLE: NO

POTENTIAL FOR DAMAGE: Low

REMOVED: NO

CURRENT VIDEO TAPE: /  
(TAPE NO/FOOTAGE)

INSPECTOR NAME:

  
\_\_\_\_\_  
Rex Gaddis

STATE: Indiana

ACCREDITATION NO.: 190908032



*ADDITIONAL BULK SAMPLES*

**ALLIANCE INDIANA, INC.**  
1433 Sadlier Circle West Dr.  
Indianapolis, IN 46239  
317/351-5600 Fax 317/351-5610

A-960363  
3/6

Project Name- Greater Clark Cty.  
Project Location- Parkwood / Springhill / Riverside  
City/State- Duboisville Indiana  
Project Number- NGR00A02 Date- 3/6/96  
Samples Collected By- Danny Anderson

SAMPLE I.D. NUMBER	LOCATION OF SAMPLE	DESCRIPTION OF SAMPLE MATERIAL
PE-01	Innervator	Rusty Scale NAD
SE-01	Innervator	Rusty Scale NAD
RE-01	Innervator	Rusty Scale NAD
		(32)

**CHAIN OF CUSTODY**

Sample By: MAREN FOX Received By: \_\_\_\_\_ Recorded By: \_\_\_\_\_  
Date: 3/6/96 Date: \_\_\_\_\_ Date: \_\_\_\_\_ Log#: \_\_\_\_\_  
Signature: [Signature] Signature: \_\_\_\_\_ Signature: [Signature]  
Date Shipped: 3/6/96 Shipped Via: \_\_\_\_\_ Shipped To: 3/6/96

March 19, 1998

**Alliance Indiana, Inc.**

Attention: Rex Gaddis  
1433 Sadlier Circle, West Dr.  
Indianapolis, IN 46239

**RE: 3 PLM Analyses**

Client Project Name:	Greater Clark County
Client Project Number:	NGR-00A02
Results Faxed to:	Rex Gaddis
Date:	March 18, 1998
Time:	11:45 am
Laboratory Batch Number:	980460
ATC Project Number:	70424.9701


Dear Mr. Gaddis:

Enclosed are the results from the bulk asbestos analyses for the 3 samples submitted to the ATC Asbestos Laboratory on March 17, 1998. Percentages were determined by visually estimating the area percentage for each type of fibrous material. Samples estimated to contain less than ten percent asbestos fibers may require quantification by point counting. These samples may be resubmitted at your discretion.

ATC will hold your samples for thirty days after the completion of the analysis. At the end of the thirty day period, it will be our policy to dispose of the samples unless prior arrangements are made.

It has been a pleasure serving you. If there are any questions, please contact me at (317) 849-4990.

Respectfully submitted,  
ATC Associates Inc.



---

Scott Lindsay  
Group Leader


**ATC ASSOCIATES INC.**  
**BULK SAMPLE ANALYSIS REPORT**  
 NVLAP Accredited  
 NVLAP Code Number 101265-00

Date: March 19, 1998

Client: Alliance Indiana, Inc.

Project Identification: NGR-00A02 - Greater Clark County  
 Date Sample Received: March 17, 1998  
 ATC Lab Batch Number: 980460

Lab ID	Client ID	Color / Description	Layer(s)	Asbestos Type	%	Other Fibrous Material	%	Non-Fibrous Material
001	P1	Tan Insulation	1	Chrysotile	10-15	Cellulose Glass	3-5 10-20	Binder
002	P2	Tan Insulation	1	Chrysotile	10-20	Cellulose Glass	2-3 10-20	Binder
003	P3	Tan Insulation	1	Amosite	20-30	None Detected		Binder

  
 Jennifer Winders, Analyst

  
 Scott Lindsay, Group Leader

- Analytical Methods: EPA 600/M4-82-020, December 82, EPA 600/R-93/116, July 1993
- Enclosed test results relates only to items tested.
- This report shall not be reproduced, except in full without written approval of the laboratory.
- This report can not be used to claim product endorsement by NVLAP or any agency of the U.S. Government.
- Method limitations: Analysis of floor tile and other resinously bound materials by Polarized Light Microscopy (PLM) may yield false negative results due to method limitations. In these cases ATC recommends alternative methods of analysis.
- For all heterogeneous samples easily separated into sub-samples each component will be analyzed separately. When layers cannot be separated without compromising the layer they will be analyzed as one sample. When a heterogeneous sample contains no asbestos in any layer reported results will be combined in one. When asbestos is detected in a layer or layers of a heterogeneous sample each individual layer will be reported separately.

980460

**ALLIANCE INDIANA, INC.**  
1433 Sadlier Circle West Dr.  
Indianapolis, IN 46239  
317/351-5600 Fax 317/351-5610

Project Name- Greater Clark County

Project Location- Parkwood Elem

City/State- Clarksville, In

Project Number- NGR00ACZ Date- 3/17/98

Samples Collected By- Gaddis

SAMPLE I.D. NUMBER	LOCATION OF SAMPLE	DESCRIPTION OF SAMPLE MATERIAL
P1	Boiler Room	Fitting Red Chry. 10-15;
P2	Boiler Room	Fitting Blue Chry. 10-20;
P3	Boiler Room	Breeching Ano. 20-30;
Need results 3/18/98.		

**CHAIN OF CUSTODY**

Sample By: Gaddis

Date: 3/17/98

Signature: [Signature]

Date Shipped: 3/17/98

Received By: \_\_\_\_\_

Date: \_\_\_\_\_

Signature: [Signature]

Shipped Via: 3/17/98

Recorded By: \_\_\_\_\_

Date: \_\_\_\_\_ Log#: \_\_\_\_\_

Signature: \_\_\_\_\_

Shipped To: \_\_\_\_\_

*NOTICES*



NOTIFICATION LOG

LEA Name - Greater Clark County Schools

<u>Date of Notification</u>	<u>Copy of Notification in Supplemental Book?</u>
1989	
1990	
1991	
1992	
1993	
1994	
1995	✓
1996	✓
1997	✓
1998	✓
1999	✓
2000	✓
2001	✓
2002	✓
2003	✓
2004	✓
2005	✓
2006	✓
2007	✓
2008	✓



March 2015

AHERA ANNUAL NOTICE  
GREATER CLARK COUNTY SCHOOLS

This information is being published to comply with the requirements of 40 CFR 763, Subpart E, Asbestos Containing Materials in Schools. This regulation, commonly known as the "AHERA" rule, requires local education agencies, such as this one, to perform certain tasks in regards to the presence and control of asbestos containing materials in the buildings under the jurisdiction of the local education agency.

These include but are not limited to:

1. Developing an asbestos management plan which is designed to outline procedures and guidelines for the initial inspection, triennial reinspections, and 6 month periodic surveillance of asbestos-containing materials that are present in the buildings.
2. Provide awareness training and additional training to selected school employees.
3. Periodically notify all workers and occupants, or their local guardians, parent teacher organizations, and collective bargaining organizations of the availability of asbestos management plans, the location of same and the times that the plans may be reviewed.

This notification is to advise all patrons, occupants, or their legal guardians, collective bargaining organizations, and parent-teachers organizations, that the asbestos management plans required under this act are available for review upon request. The plans can be viewed by any person during normal business hours of the particular school. Interested parties wishing to inquire about the plans should contact the individual school office. Master copies of the plans for all buildings under the jurisdiction of this local education agency are available in the Auxiliary Services at River Valley Middle School, which is located at 2220 Veteran's Parkway, Jeffersonville, Indiana 47130; telephone number (812) 288-4821. Inquiries regarding any facet of the regulation or the management plans should be directed to Mr. Steve Hobgood at the above telephone number during regular business hours.

Greater Clark County Schools, school facilities, and buildings which contain asbestos-containing materials (ACMs) and must comply with the 40 CFR 763, Subpart E (AHERA) regulations include:

**Jeffersonville, Charlestown and New Washington High Schools; Parkview, River Valley and Charlestown Middle Schools; Wilson, Thomas Jefferson, Northaven, New Washington, Jonathan Jennings, Bridgepoint, Maple, Spring Hill, and Parkwood Elementary Schools, Service Center, Corden Porter Storage, Auto Tech Program- Witten Property, and Corden Porter Center with Gym.**

Listed is a brief description of asbestos projects currently ongoing and completed at our facilities this past school year, as well as activities currently scheduled for the 2015/2016 school year. Detailed reports of each activity will become a part of each school's asbestos management plan and may be reviewed in the school office.

\* The required triennial re-inspection will be performed in April 2016.

\* The required six month periodic surveillance was performed in October 2014.

\* The required six month periodic surveillance activities are scheduled for April and October each year.

School facilities and buildings that are asbestos free and require no surveillance or reinspection are:

**Pleasant Ridge Elementary School, Utica Elementary School, Corden Porter former Options Building and the Administration Building**

March 2014

AHERA ANNUAL NOTICE  
GREATER CLARK COUNTY SCHOOLS

This information is being published to comply with the requirements of 40 CFR 763, Subpart E, Asbestos Containing Materials in Schools. This regulation, commonly known as the "AHERA" rule, requires local education agencies, such as this one, to perform certain tasks in regards to the presence and control of asbestos containing materials in the buildings under the jurisdiction of the local education agency.

These include but are not limited to:

1. Developing an asbestos management plan which is designed to outline procedures and guidelines for the initial inspection, triennial reinspections, and 6 month periodic surveillance of asbestos-containing materials that are present in the buildings.
2. Provide awareness training and additional training to selected school employees.
3. Periodically notify all workers and occupants, or their local guardians, parent teacher organizations, and collective bargaining organizations of the availability of asbestos management plans, the location of same and the times that the plans may be reviewed.

This notification is to advise all patrons, occupants, or their legal guardians, collective bargaining organizations, and parent-teachers organizations, that the asbestos management plans required under this act are available for review upon request. The plans can be viewed by any person during normal business hours of the particular school. Interested parties wishing to inquire about the plans should contact the individual school office. Master copies of the plans for all buildings under the jurisdiction of this local education agency are available in the Auxiliary Services building, which is located at 2220 Veteran's Parkway, Jeffersonville, Indiana 47130; telephone number (812) 288-4821. Inquiries regarding any facet of the regulation or the management plans should be directed to Mr. Steve Hobgood at the above telephone number during regular business hours.

Greater Clark County Schools, school facilities, and buildings which contain asbestos-containing materials (ACMs) and must comply with the 40 CFR 763, Subpart E (AHERA) regulations include:

**Jeffersonville, Charlestown and New Washington High Schools; Parkview, River Valley and Charlestown Middle Schools; Wilson, Thomas Jefferson, Northaven, New Washington, Jonathan Jennings, Bridgepoint, Maple, Spring Hill, and Parkwood Elementary Schools, the Auxiliary Services Building, Service Center, Corden Porter Storage, and Corden Porter Center with Gym.**

Listed is a brief description of asbestos projects currently ongoing and completed at our facilities this past school year, as well as activities currently scheduled for the 2014/2015 school year. Detailed reports of each activity will become a part of each school's asbestos management plan and may be reviewed in the school office.

\* The required triennial re-inspection will be performed in April 2013.

\* The required six month periodic surveillance was performed in October 2013.

\* The required six month periodic surveillance activities are scheduled for April and October each year.

School facilities and buildings that are asbestos free and require no surveillance or reinspection are:

**Pleasant Ridge Elementary School, Utica Elementary School, Cordon Porter former Options Building and the Administration Building**

March 2013

AHERA ANNUAL NOTICE  
GREATER CLARK COUNTY SCHOOLS

This information is being published to comply with the requirements of 40 CFR 763, Subpart E, Asbestos Containing Materials in Schools. This regulation, commonly known as the "AHERA" rule, requires local education agencies, such as this one, to perform certain tasks in regards to the presence and control of asbestos containing materials in the buildings under the jurisdiction of the local education agency.

These include but are not limited to:

1. Developing an asbestos management plan which is designed to outline procedures and guidelines for the initial inspection, triennial reinspections, and 6 month periodic surveillance of asbestos-containing materials that are present in the buildings.
2. Provide awareness training and additional training to selected school employees.
3. Periodically notify all workers and occupants, or their local guardians, parent teacher organizations, and collective bargaining organizations of the availability of asbestos management plans, the location of same and the times that the plans may be reviewed.

This notification is to advise all patrons, occupants, or their legal guardians, collective bargaining organizations, and parent-teachers organizations, that the asbestos management plans required under this act are available for review upon request. The plans can be viewed by any person during normal business hours of the particular school. Interested parties wishing to inquire about the plans should contact the individual school office. Master copies of the plans for all buildings under the jurisdiction of this local education agency are available in the Auxiliary Services building, which is located at 2710 E 10<sup>th</sup> Street, Jeffersonville, Indiana 47130; telephone number (812) 288-4821. Inquiries regarding any facet of the regulation or the management plans should be directed to Mr. Steve Hobgood at the above telephone number during regular business hours.

Greater Clark County Schools, school facilities, and buildings which contain asbestos-containing materials (ACMs) and must comply with the 40 CFR 763, Subpart E (AHERA) regulations include:

**Jeffersonville, Charlestown and New Washington High Schools; Parkview, River Valley and Charlestown Middle Schools; Wilson, Thomas Jefferson, Northaven, New Washington, Jonathan Jennings, Bridgepoint, Maple, Spring Hill, and Parkwood Elementary Schools, the Auxiliary Services Building, Service Center, Corden Porter Storage, and Corden Porter Center with Gym.**

Listed is a brief description of asbestos projects currently ongoing and completed at our facilities this past school year, as well as activities currently scheduled for the 2013/2014 school year. Detailed reports of each activity will become a part of each school's asbestos management plan and may be reviewed in the school office.

- \* The required triennial re-inspection will be performed in April 2013.
- \* The required six month periodic surveillance was performed in October 2012.
- \* The required six month periodic surveillance activities are scheduled for April and October each year.
- \* Projects completed in 2012: Parkview Middle School.

School facilities and buildings that are asbestos free and require no surveillance or reinspection are:

**Pleasant Ridge Elementary School, Utica Elementary School, Cordon Porter former Options Building and the Administration Building**

March 2012

**AHERA ANNUAL NOTICE  
GREATER CLARK COUNTY SCHOOLS**

This information is being published to comply with the requirements of 40 CFR 763, Subpart E, Asbestos Containing Materials in Schools. This regulation, commonly known as the "AHERA" rule, requires local education agencies, such as this one, to perform certain tasks in regards to the presence and control of asbestos containing materials in the buildings under the jurisdiction of the local education agency.

These include but are not limited to:

1. Developing an asbestos management plan which is designed to outline procedures and guidelines for the initial inspection, triennial reinspections, and 6 month periodic surveillance of asbestos-containing materials that are present in the buildings.
2. Provide awareness training and additional training to selected school employees.
3. Periodically notify all workers and occupants, or their local guardians, parent teacher organizations, and collective bargaining organizations of the availability of asbestos management plans, the location of same and the times that the plans may be reviewed.

This notification is to advise all patrons, occupants, or their legal guardians, collective bargaining organizations, and parent-teachers organizations, that the asbestos management plans required under this act are available for review upon request. The plans can be viewed by any person during normal business hours of the particular school. Interested parties wishing to inquire about the plans should contact the individual school office. Master copies of the plans for all buildings under the jurisdiction of this local education agency are available in the Auxiliary Services building, which is located at 2710 E 10<sup>th</sup> Street, Jeffersonville, Indiana 47130; telephone number (812) 288-4821. Inquiries regarding any facet of the regulation or the management plans should be directed to Mr. Steve Hobgood at the above telephone number during regular business hours.

Greater Clark County Schools, school facilities, and buildings which contain asbestos-containing materials (ACMs) and must comply with the 40 CFR 763, Subpart E (AHERA) regulations include:

**Jeffersonville, Charlestown and New Washington High Schools; Parkview, River Valley and Charlestown Middle Schools; Wilson, Thomas Jefferson, Northaven, New Washington, Jonathan Jennings, Bridgepoint, Maple, Spring Hill, and Parkwood Elementary Schools, the Auxiliary Services Building, Service Center, and Corden Porter Center with Gym.**

Listed is a brief description of asbestos projects currently ongoing and completed at our facilities this past school year, as well as activities currently scheduled for the 2012/2013 school year. Detailed reports of each activity will become a part of each school's asbestos management plan and may be reviewed in the school office.

- \* The required triennial re-inspection will be performed in June 2013.
- \* The required six month periodic surveillance was performed in December 2011.
- \* The required six month periodic surveillance activities are scheduled for June and December each year.
- \* Projects completed in 2011: Options building and Parkwood Elementary.
- \* Projects scheduled for 2012: Parkview Middle School and Bridgepoint Elementary.
- \* Cordon Porter storage building was sold in 2012.

School facilities and buildings that are asbestos free and require no surveillance or reinspection are:

**Pleasant Ridge Elementary School, Utica Elementary School, Cordon Porter former Options Building and the Administration Building**

**AHERA ANNUAL NOTICE  
GREATER CLARK COUNTY SCHOOLS**

This information is being published to comply with the requirements of 40 CFR 763 Subpart E Asbestos Containing Materials in Schools. This regulation, commonly known as the "AHERA" rule, requires local education agencies, such as this one, to perform certain tasks in regards to the presence and control of asbestos containing materials in the buildings under the jurisdiction of the local education agency.

These include but are not limited to:

1. Developing an asbestos management plan which is designed to outline procedures and guidelines for the inspection, reinspection and periodic surveillance of asbestos containing materials that are present in the buildings.
2. Provide awareness training and additional training to selected school employees.
3. Periodically notify all workers and occupants, or their local guardians, parent teacher organizations, and collective bargaining organizations of the availability of asbestos management plans, the location of same and the times that the plans may be reviewed.

This notification is to advise all patrons, occupants, or their legal guardians, collective bargaining organizations, and parent-teachers organizations, that the asbestos management plans required under this act are available for review upon request. A copy of the plans for all buildings under the jurisdiction of this local education agency are available in the Auxillary Services building, which is located at 2710 E 10<sup>th</sup> Street, Jeffersonville, Indiana 47130; telephone number (812) 288-4821. Plans for individual schools and other buildings are located in the administration office of each school. The plans can be viewed by any person during normal business hours of the particular school. Interested parties wishing to inquire about the hours and times that the plans are available should call the above number.

At this time, the management plans can provide information regarding inspections, response actions, and post-response action activities, including periodic reinspection and surveillance activities that are planned or in progress. Inquiries regarding any facet of the regulation or the management plans should be directed to Mr. Steve Hobgood at the above telephone number during regular business hours.

Listed is a brief description of asbestos work that has been completed in our schools this year. Detailed reports have become part of each school's asbestos management plan and may be reviewed in the school office.

**Jeffersonville, Charlestown and New Washington High Schools; Parkview, River Valley and Charlestown Middle Schools; Wilson, Thomas Jefferson, Northaven, New Washington, Jonathan Jennings, Bridgepoint, Maple, Spring Hill, and Parkwood Elementary Schools; the former Administration Building, Service Center, Options and Corden Porter Center Buildings and Alternative School-**

- \* The required triennial reinspection will be performed in June 2013.
- \* The required six month periodic surveillance was performed in December 2010.
- \* The next scheduled activity is the required six month periodic surveillance in June 2011.
- \* Charlestown High School asbestos removal project was completed in 2010.
- \* Options Building is under renovation in 2011.
- \* Parkwood Elementary is under renovation in 2011.

**Pleasant Ridge Elementary School, Utica Elementary School and the (New) Administration Building**  
– These buildings are asbestos free and **Riverside Elementary** was demolished in 2006.  
No surveillances or reinspections are required for these buildings.

March 2011

AHERA ANNUAL NOTICE  
GREATER CLARK COUNTY SCHOOLS

This information is being published to comply with the requirements of 40 CFR 763 Subpart E Asbestos Containing Materials in Schools. This regulation, commonly known as the "AHERA" rule, requires local education agencies, such as this one, to perform certain tasks in regards to the presence and control of asbestos containing materials in the buildings under the jurisdiction of the local education agency.

These include but are not limited to:

1. Developing an asbestos management plan which is designed to outline procedures and guidelines for the inspection, reinspection and periodic surveillance of asbestos containing materials that are present in the buildings.
2. Provide awareness training and additional training to selected school employees.
3. Periodically notify all workers and occupants, or their local guardians, parent teacher organizations, and collective bargaining organizations of the availability of asbestos management plans, the location of same and the times that the plans may be reviewed.

This notification is to advise all patrons, occupants, or their legal guardians, collective bargaining organizations, and parent-teachers organizations, that the asbestos management plans required under this act are available for review upon request. A copy of the plans for all buildings under the jurisdiction of this local education agency are available in the Auxillary Services building, which is located at 2710 E 10<sup>th</sup> Street, Jeffersonville, Indiana 47130; telephone number (812) 288-4821. Plans for individual schools and other buildings are located in the administration office of each school. The plans can be viewed by any person during normal business hours of the particular school. Interested parties wishing to inquire about the hours and times that the plans are available should call the above number.

At this time, the management plans can provide information regarding inspections, response actions, and post-response action activities, including periodic reinspection and surveillance activities that are planned or in progress. Inquiries regarding any facet of the regulation or the management plans should be directed to Mr. Steve Hobgood at the above telephone number during regular business hours.

Listed is a brief description of asbestos work that has been completed in our schools this year. Detailed reports have become part of each school's asbestos management plan and may be reviewed in the school office.

**Jeffersonville, Charlestown and New Washington High Schools; Parkview, River Valley and Charlestown Middle Schools; Wilson, Thomas Jefferson, Northaven, New Washington, Jonathan Jennings, Bridgepoint, Maple, Spring Hill, and Parkwood Elementary Schools; the former Administration Building, Service Center, and Corden Porter Center Buildings -**

\* The required triennial reinspection will be performed in June 2010.

\* The required six month periodic surveillance was performed in December 2009.

\* The next scheduled activity is the required six month periodic surveillance in December 2010.

Charlestown High School is an ongoing asbestos removal project which will be complete prior to partial demolition.

**Pleasant Ridge Elementary School, Utica Elementary School and the (New) Administration Building –** These buildings are asbestos free and **Riverside Elementary** was demolished in 2006. No surveillances or reinspections are required for these buildings.

March 2010

**AHERA ANNUAL NOTICE  
GREATER CLARK COUNTY SCHOOLS**

This information is being published to comply with the requirements of 40 CFR 763 Subpart E Asbestos Containing Materials in Schools. This regulation, commonly known as the "AHERA" rule, requires local education agencies, such as this one, to perform certain tasks in regards to the presence and control of asbestos containing materials in the buildings under the jurisdiction of the local education agency.

These include but are not limited to:

1. Developing an asbestos management plan which is designed to outline procedures and guidelines for the inspection, reinspection and periodic surveillance of asbestos containing materials that are present in the buildings.
2. Provide awareness training and additional training to selected school employees.
3. Periodically notify all workers and occupants, or their local guardians, parent teacher organizations, and collective bargaining organizations of the availability of asbestos management plans, the location of same and the times that the plans may be reviewed.

This notification is to advise all patrons, occupants, or their legal guardians, collective bargaining organizations, and parent-teachers organizations, that the asbestos management plans required under this act are available for review upon request. A copy of the plans for all buildings under the jurisdiction of this local education agency are available in the Service Center building, which is located at 301 E. 11th Street, Jeffersonville, Indiana 47130; telephone number (812) 288-4821. Plans for individual schools and other buildings are located in the administration office of each school. The plans can be viewed by any person during normal business hours of the particular school. Interested parties wishing to inquire about the hours and times that the plans are available should call the above number.

At this time, the management plans can provide information regarding inspections, response actions, and post-response action activities, including periodic reinspection and surveillance activities that are planned or in progress. Inquiries regarding any facet of the regulation or the management plans should be directed to Mr. Steve Hobgood at the above telephone number during regular business hours.

Listed is a brief description of asbestos work that has been completed in our schools this year. Detailed reports have become part of each school's asbestos management plan and may be reviewed in the school office.

**Jeffersonville, Charlestown and New Washington High Schools; Parkview, River Valley and Charlestown Middle Schools; Wilson, Thomas Jefferson, Northaven, New Washington, Jonathan Jennings, Bridgepoint, Maple, Spring Hill, and Parkwood Elementary Schools; the former Administration Building, Service Center, and Corden Porter Center Buildings -**

- \* The required triennial reinspection was performed in June 2007.
- \* The required six month periodic surveillance was performed in December 2008.
- \* The next scheduled activities are the required six month periodic surveillance in June 2009 and Dec 2009. Charlestown High School has undergone an asbestos removal project prior to partial demolition.

**Pleasant Ridge Elementary School, Utica Elementary School and the (New) Administration Building -**  
These buildings are asbestos free and Riverside Elementary was demolished in 2006.  
No surveillances or re-inspections are required for these buildings.

April 2009

AHERA ANNUAL NOTICE  
GREATER CLARK COUNTY SCHOOLS

This information is being published to comply with the requirements of 40 CFR 763 Subpart E asbestos containing materials in schools. This regulation, commonly known as the "AHERA" rule, requires local education agencies, such as this one, to perform certain tasks in regards to the presence and control of asbestos containing materials in the buildings under the jurisdiction of the local education agency.

These include but are not limited to:

1. Developing an asbestos management plan which is designed to outline procedures and guidelines for the inspection, reinspection and periodic surveillance of asbestos containing materials that are present in the buildings.
2. Provide awareness training and additional training to selected school employees.
3. Periodically notify all workers and occupants, or their local guardians, parent teacher organizations, and collective bargaining organizations of the availability of asbestos management plans, the location of same and the times that the plans may be reviewed.

This notification is to advise all patrons, occupants, or their legal guardians, collective bargaining organizations, and parent-teachers organizations, that the asbestos management plans required under this act are available for review upon request. A copy of the plans for all buildings under the jurisdiction of this local education agency are available in the Service Center building, which is located at 301 E. 11th Street, Jeffersonville, Indiana 47130; telephone number (812)288-4821. Plans for individual schools and other buildings are located in the administration office of each school. The plans can be viewed by any person during normal business hours of the particular school. Interested parties wishing to inquire about the hours and times that the plans are available should call the above number.

At this time, the management plans can provide information regarding inspections, response actions, and post-response action activities, including periodic reinspection and surveillance activities that are planned or in progress. Inquiries regarding any facet of the regulation or the management plans should be directed to Mr. Steve Hobgood at the above telephone number during regular business hours.

Listed is a brief description of asbestos work that has been completed in our schools this year. Detailed reports have become part of each school's asbestos management plan and may be reviewed in the school office.

**Jeffersonville, Charlestown, and New Washington High Schools; Parkview, Charlestown, and River Valley Middle Schools; Wilson, Thomas Jefferson, Northaven, New Washington, Jonathan Jennings, Bridgepoint, Maple, Spring Hill, and Parkwood Elementary Schools; the former Administration Building, Service Center, and Corden Porter Center Buildings -**

- \* The required triennial reinspection was performed in June 2007.
- \* The required six month periodic surveillance was performed in December 2007.
- \* The next scheduled activities are the required six month periodic surveillance in June 2008 and Dec 2008.

**Pleasant Ridge Elementary School, Utica Elementary School and the (New) Administration Building –** These buildings are asbestos free. **Riverside Elementary** was Demolition in 2006. No surveillances or reinspections are required.

April 2008



AHERA ANNUAL NOTICE  
GREATER CLARK COUNTY SCHOOLS

This information is being published to comply with the requirements of 40 CFR 763 Subpart E asbestos containing materials in schools. This regulation, commonly known as the "AHERA" rule, requires local education agencies, such as this one, to perform certain tasks in regards to the presence and control of asbestos containing materials in the buildings under the jurisdiction of the local education agency.

These include but are not limited to:

1. Developing an asbestos management plan which is designed to outline procedures and guidelines for the inspection, reinspection and periodic surveillance of asbestos containing materials that are present in the buildings.
2. Provide awareness training and additional training to selected school employees.
3. Periodically notify all workers and occupants, or their local guardians, parent teacher organizations, and collective bargaining organizations of the availability of asbestos management plans, the location of same and the times that the plans may be reviewed.

This notification is to advise all patrons, occupants, or their legal guardians, collective bargaining organizations, and parent-teachers organizations, that the asbestos management plans required under this act are available for review upon request. A copy of the plans for all buildings under the jurisdiction of this local education agency are available in the Service Center building, which is located at 301 E. 11th Street, Jeffersonville, Indiana 47130; telephone number 288-4821. Plans for individual schools and other buildings are located in the administration office of each school. The plans can be viewed by any person during normal business hours of the particular school. Interested parties wishing to inquire about the hours and times that the plans are available should call the above number.

At this time, the management plans can provide information regarding inspections, response actions, and post-response action activities, including periodic reinspection and surveillance activities that are planned or in progress. Inquiries regarding any facet of the regulation or the management plans should be directed to Mr. Chuck Graves at the above telephone number during regular business hours.

Listed is a brief description of asbestos work that has been completed in our schools this year. Detailed reports have become part of each school's asbestos management plan and may be reviewed in the school office.

**Jeffersonville, Charlestown, and New Washington High Schools; Parkview, Charlestown, and River Valley Middle Schools; Wilson, Thomas Jefferson, Northaven, New Washington, Jonathan Jennings, Bridgepoint, Maple, Spring Hill, and Parkwood Elementary Schools; the former Administration Building, Service Center, and Corden Porter Center Buildings -**

- \* The required six month periodic surveillance was performed in June 2006.
- \* The required six month periodic surveillance was performed in December 2006.
- \* The next scheduled activities are the required six month periodic surveillance in June 2007 and Dec 2007.

**Pleasant Ridge Elementary School, Utica Elementary School and the (New) Administration Building –** These buildings are asbestos free. **Riverside Elementary** was Demolition in 2006. No surveillances or reinspections are required.

March 2007

AHERA ANNUAL NOTICE  
GREATER CLARK COUNTY SCHOOLS

This information is being published to comply with the requirements of 40 CFR 763 Subpart E asbestos containing materials in schools. This regulation, commonly known as the "AHERA" rule, requires local education agencies, such as this one, to perform certain tasks in regards to the presence and control of asbestos containing materials in the buildings under the jurisdiction of the local education agency.

These include but are not limited to:

1. Developing an asbestos management plan which is designed to outline procedures and guidelines for the inspection, reinspection and periodic surveillance of asbestos containing materials that are present in the buildings.
2. Provide awareness training and additional training to selected school employees.
3. Periodically notify all workers and occupants, or their local guardians, parent teacher organizations, and collective bargaining organizations of the availability of asbestos management plans, the location of same and the times that the plans may be reviewed.

This notification is to advise all patrons, occupants, or their legal guardians, collective bargaining organizations, and parent-teachers organizations, that the asbestos management plans required under this act are available for review upon request. A copy of the plans for all buildings under the jurisdiction of this local education agency are available in the Service Center building, which is located at 301 E. 11th Street, Jeffersonville, Indiana 47130; telephone number 288-4821. Plans for individual schools and other buildings are located in the administration office of each school. The plans can be viewed by any person during normal business hours of the particular school. Interested parties wishing to inquire about the hours and times that the plans are available should call the above number.

At this time, the management plans can provide information regarding inspections, response actions, and post-response action activities, including periodic reinspection and surveillance activities that are planned or in progress. Inquiries regarding any facet of the regulation or the management plans should be directed to Mr. Chuck Graves at the above telephone number during regular business hours.

Listed is a brief description of asbestos work that has been completed in our schools this year. Detailed reports have become part of each school's asbestos management plan and may be reviewed in the school office.

**Jeffersonville, Charlestown, and New Washington High Schools; Parkview, Charlestown, and River Valley Middle Schools; Wilson, Thomas Jefferson, Northaven, New Washington, Jonathan Jennings, Bridgepoint, Maple, Riverside, Spring Hill, and Parkwood Elementary Schools; the former Administration Building, Service Center, and Corden Porter Center Buildings -**

\* The required triennial reinspection was performed in June 2005.

\* The required six month periodic surveillance was performed in December 2005.

\* The next scheduled activities are the required six month periodic surveillance in June 2006 and Dec 2006.

**Pleasant Ridge Elementary School, Utica Elementary School and the (New) Administration Building –**  
These buildings are asbestos free. No surveillances or reinspections are required.

March 2006

AHERA Annual Notice  
GREATER CLARK COUNTY SCHOOLS

This information is being published to comply with the requirements of 40 CFR 763 Subpart E asbestos containing materials in schools. This regulation, commonly known as the "AHERA" rule, requires local education agencies, such as this one, to perform certain tasks in regards to the presence and control of asbestos containing materials in the buildings under the jurisdiction of the local education agency.

These include but are not limited to:

1. Developing an asbestos management plan which is designed to outline procedures and guidelines for the inspection, reinspection and periodic surveillance of asbestos containing materials that are present in the buildings.
2. Provide awareness training and additional training to selected school employees.
3. Periodically notify all workers and occupants, or their local guardians, parent teacher organizations, and collective bargaining organizations of the availability of asbestos management plans, the location of same and the times that the plans may be reviewed.

This notification is to advise all patrons, occupants, or their legal guardians, collective bargaining organizations, and parent-teachers organizations, that the asbestos management plans required under this act are available for review upon request. A copy of the plans for all buildings under the jurisdiction of this local education agency are available in the Service Center building, which is located at 301 E. 11th Street, Jeffersonville, Indiana 47130; telephone number 288-4821. Plans for individual schools and other buildings are located in the administration office of each school. The plans can be viewed by any person during normal business hours of the particular school. Interested parties wishing to inquire about the hours and times that the plans are available should call the above number.

At this time, the management plans can provide information regarding inspections, response actions, and post-response action activities, including periodic reinspection and surveillance activities that are planned or in progress. Inquiries regarding any facet of the regulation or the management plans should be directed to Mr. Chuck Graves at the above telephone number during regular business hours.

Listed is a brief description of asbestos work that has been completed in our schools this year. Detailed reports have become part of each school's asbestos management plan and may be reviewed in the school office.

**Jeffersonville, Charlestown, and New Washington High Schools; Parkview, Charlestown, and River Valley Middle Schools; Wilson, Thomas Jefferson, Northaven, New Washington, Jonathan Jennings, Bridgepoint, Maple, Riverside, Spring Hill, and Parkwood Elementary Schools; the former Administration Building, Service Center, and Corden Porter Center Buildings -**

- \* The required triennial reinspection was performed in June 2004.
- \* The required six month periodic surveillance was performed in December 2004.
- \* The next scheduled activities are the required six month periodic surveillance in June 2005 and December 2005.

**Pleasant Ridge Elementary School, Utica Elementary School and the (New) Administration Building -**

- \* These buildings are asbestos free. No surveillances or reinspections are required.

AHERA Annual Notice  
GREATER CLARK COUNTY SCHOOLS

This information is being published to comply with the requirements of 40 CFR 763 Subpart E asbestos containing materials in schools. This regulation, commonly known as the "AHERA" rule, requires local education agencies, such as this one, to perform certain tasks in regards to the presence and control of asbestos containing materials in the buildings under the jurisdiction of the local education agency.

These include but are not limited to:

1. Developing an asbestos management plan which is designed to outline procedures and guidelines for the inspection, reinspection and periodic surveillance of asbestos containing materials that are present in the buildings.
2. Provide awareness training and additional training to selected school employees.
3. Periodically notify all workers and occupants, or their local guardians, parent teacher organizations, and collective bargaining organizations of the availability of asbestos management plans, the location of same and the times that the plans may be reviewed.

This notification is to advise all patrons, occupants, or their legal guardians, collective bargaining organizations, and parent-teachers organizations, that the asbestos management plans required under this act are available for review upon request. A copy of the plans for all buildings under the jurisdiction of this local education agency are available in the Service Center building, which is located at 301 E. 11th Street, Jeffersonville, Indiana 47130; telephone number 288-4821. Plans for individual schools and other buildings are located in the administration office of each school. The plans can be viewed by any person during normal business hours of the particular school. Interested parties wishing to inquire about the hours and times that the plans are available should call the above number.

At this time, the management plans can provide information regarding inspections, response actions, and post-response action activities, including periodic reinspection and surveillance activities that are planned or in progress. Inquiries regarding any facet of the regulation or the management plans should be directed to Mr. Tony Nauert at the above telephone number during regular business hours.

Listed is a brief description of asbestos work that has been completed in our schools this year. Detailed reports have become part of each school's asbestos management plan and may be reviewed in the school office.

**Jeffersonville, Charlestown, and New Washington High Schools; Parkview, Charlestown, and River Valley Middle Schools; Wilson, Thomas Jefferson, Northaven, New Washington, Jonathan Jennings, Bridgepoint, Maple, Riverside, Spring Hill, and Parkwood Elementary Schools; the former Administration Building, Service Center, and Corden Porter Center Buildings -**

- \* The required six month periodic surveillance was performed in June 2003.
- \* The required six month periodic surveillance was performed in December 2003.
- \* The next scheduled activities are the required triennial reinspection in June 2004 and a required six month periodic surveillance in December 2004.

**Pleasant Ridge Elementary School, Utica Elementary School and the (New) Administration Building -**

- \* These buildings are asbestos free. No surveillances or reinspections are required.

March 2004

AHERA Annual Notice  
GREATER CLARK COUNTY SCHOOLS

This information is being published to comply with the requirements of 40 CFR 763 Subpart E asbestos containing materials in schools. This regulation, commonly known as the "AHERA" rule, requires local education agencies, such as this one, to perform certain tasks in regards to the presence and control of asbestos containing materials in the buildings under the jurisdiction of the local education agency.

These include but are not limited to:

1. Developing an asbestos management plan which is designed to outline procedures and guidelines for the inspection, reinspection and periodic surveillance of asbestos containing materials that are present in the buildings.
2. Provide awareness training and additional training to selected school employees.
3. Periodically notify all workers and occupants, or their local guardians, parent teacher organizations, and collective bargaining organizations of the availability of asbestos management plans, the location of same and the times that the plans may be reviewed.

This notification is to advise all patrons, occupants, or their legal guardians, collective bargaining organizations, and parent-teachers organizations, that the asbestos management plans required under this act are available for review upon request. A copy of the plans for all buildings under the jurisdiction of this local education agency are available in the Service Center building, which is located at 301 E. 11th Street, Jeffersonville, Indiana 47130; telephone number 288-4821. Plans for individual schools and other buildings are located in the administration office of each school. The plans can be viewed by any person during normal business hours of the particular school. Interested parties wishing to inquire about the hours and times that the plans are available should call the above number.

At this time, the management plans can provide information regarding inspections, response actions, and post-response action activities, including periodic reinspection and surveillance activities that are planned or in progress. Inquiries regarding any facet of the regulation or the management plans should be directed to Mr. Tony Nauert at the above telephone number during regular business hours.

Listed is a brief description of asbestos work that has been completed in our schools this year. Detailed reports have become part of each school's asbestos management plan and may be reviewed in the school office.

**Jeffersonville, Charlestown, and New Washington High Schools; Parkview, Charlestown, and River Valley Middle Schools; Wilson, Thomas Jefferson, Northaven, New Washington, Jonathan Jennings, Bridgepoint, Maple, Riverside, Spring Hill, and Parkwood Elementary Schools; the former Administration Building, Service Center, and Corden Porter Center Buildings -**

- \* The required six month periodic surveillance was performed in June 2002.
- \* The required six month periodic surveillance was performed in December 2002.
- \* The next scheduled activity is the required periodic surveillance in June 2003.

**Pleasant Ridge Elementary School, Utica Elementary School and the (New) Administration Building -**

- \* These buildings are asbestos free. No surveillances or reinspections are required.

May 2003

AHERA Annual Notice  
GREATER CLARK COUNTY SCHOOLS

This information is being published to comply with the requirements of 40 CFR 763 Subpart E asbestos containing materials in schools. This regulation, commonly known as the "AHERA" rule, requires local education agencies, such as this one, to perform certain tasks in regards to the presence and control of asbestos containing materials in the buildings under the jurisdiction of the local education agency.

These include but are not limited to:

1. Developing an asbestos management plan which is designed to outline procedures and guidelines for the inspection, reinspection and periodic surveillance of asbestos containing materials that are present in the buildings.
2. Provide awareness training and additional training to selected school employees.
3. Periodically notify all workers and occupants, or their local guardians, parent teacher organizations, and collective bargaining organizations of the availability of asbestos management plans, the location of same and the times that the plans may be reviewed.

This notification is to advise all patrons, occupants, or their legal guardians, collective bargaining organizations, and parent-teachers organizations, that the asbestos management plans required under this act are available for review upon request. A copy of the plans for all buildings under the jurisdiction of this local education agency are available in the Service Center building, which is located at 301 E. 11th Street, Jeffersonville, Indiana 47130; telephone number 288-4821. Plans for individual schools and other buildings are located in the administration office of each school. The plans can be viewed by any person during normal business hours of the particular school. Interested parties wishing to inquire about the hours and times that the plans are available should call the above number.

At this time, the management plans can provide information regarding inspections, response actions, and post-response action activities, including periodic reinspection and surveillance activities that are planned or in progress. Inquiries regarding any facet of the regulation or the management plans should be directed to Mr. Tony Nauert at the above telephone number during regular business hours.

Listed is a brief description of asbestos work that has been completed in our schools this year. Detailed reports have become part of each school's asbestos management plan and may be reviewed in the school office.

**Jeffersonville, Charlestown, and New Washington High Schools; Parkview, Charlestown, and River Valley Middle Schools; Wilson, Thomas Jefferson, Northaven, New Washington, Jonathan Jennings, Bridgepoint, Maple, Riverside, Spring Hill, and Parkwood Elementary Schools; the Administration Building, Service Center, and Corden Porter Center Buildings -**

- \* The required triennial reinspection was performed in July 2001.
- \* The required six month periodic surveillance was performed in December 2001.
- \* The next scheduled activities are the required periodic surveillances in June 2002 and December 2002.

**Pleasant Ridge Elementary School and (New) Utica Elementary School -**

- \* These buildings are asbestos free. No surveillances or reinspections are required.

**(Old) Utica Elementary School -**

- \* In accordance with information collected from the GCCS this building has been deeded to the town of Utica. No further AHERA periodic surveillances or triennial reinspections will be conducted by the designated person.

AHERA Annual Notice  
GREATER CLARK COUNTY SCHOOLS

This information is being published to comply with the requirements of 40 CFR 763 Subpart E asbestos containing materials in schools. This regulation, commonly known as the "AHERA" rule, requires local education agencies, such as this one, to perform certain tasks in regards to the presence and control of asbestos containing materials in the buildings under the jurisdiction of the local education agency.

These include but are not limited to:

1. Developing an asbestos management plan which is designed to outline procedures and guidelines for the inspection, reinspection and periodic surveillance of asbestos containing materials that are present in the buildings.
2. Provide awareness training and additional training to selected school employees.
3. Periodically notify all workers and occupants, or their local guardians, parent teacher organizations, and collective bargaining organizations of the availability of asbestos management plans, the location of same and the times that the plans may be reviewed.

This notification is to advise all patrons, occupants, or their legal guardians, collective bargaining organizations, and parent-teachers organizations, that the asbestos management plans required under this act are available for review upon request. A copy of the plans for all buildings under the jurisdiction of this local education agency are available in the Service Center building, which is located at 301 E. 11th Street, Jeffersonville, Indiana 47130; telephone number 288-4821. Plans for individual schools and other buildings are located in the administration office of each school. The plans can be viewed by any person during normal business hours of the particular school. Interested parties wishing to inquire about the hours and times that the plans are available should call the above number.

At this time, the management plans can provide information regarding inspections, response actions, and post-response action activities, including periodic reinspection and surveillance activities that are planned or in progress. Inquiries regarding any facet of the regulation or the management plans should be directed to Mr. Tony Nauert at the above telephone number during regular business hours.

Listed is a brief description of asbestos work that has been completed in our schools this year. Detailed reports have become part of each school's asbestos management plan and may be reviewed in the school office.

**Jeffersonville, Charlestown, and New Washington High Schools; Parkview, Charlestown, and River Valley Middle Schools; Wilson, Thomas Jefferson, Northaven, (Old) Utica, New Washington, Jonathan Jennings, Bridgepoint, Maple, Riverside, Spring Hill, and Parkwood Elementary Schools; the Administration Building, Service Center, and Corden Porter Center -**

- \* The required six month periodic surveillance was performed in June 2000.
- \* The required six month periodic surveillance was performed in January 2001.
- \* The next scheduled activity is a required triennial reinspection in June 2001.

**Pleasant Ridge Elementary School and (New) Utica Elementary School -**

- \* This building is asbestos free. No surveillances or reinspections are required.

June 2001

AHERA Annual Notice  
GREATER CLARK COUNTY SCHOOLS

This information is being published to comply with the requirements of 40 CFR 763 Subpart E asbestos containing materials in schools. This regulation, commonly known as the "AHERA" rule, requires local education agencies, such as this one, to perform certain tasks in regards to the presence and control of asbestos containing materials in the buildings under the jurisdiction of the local education agency.

These include but are not limited to:

1. Developing an asbestos management plan which is designed to outline procedures and guidelines for the inspection, reinspection and periodic surveillance of asbestos containing materials that are present in the buildings.
2. Provide awareness training and additional training to selected school employees.
3. Periodically notify all workers and occupants, or their local guardians, parent teacher organizations, and collective bargaining organizations of the availability of asbestos management plans, the location of same and the times that the plans may be reviewed.

This notification is to advise all patrons, occupants, or their legal guardians, collective bargaining organizations, and parent-teachers organizations, that the asbestos management plans required under this act are available for review upon request. A copy of the plans for all buildings under the jurisdiction of this local education agency are available in the Service Center building, which is located at 301 E. 11th Street, Jeffersonville, Indiana 47130; telephone number 288-4821. Plans for individual schools and other buildings are located in the administration office of each school. The plans can be viewed by any person during normal business hours of the particular school. Interested parties wishing to inquire about the hours and times that the plans are available should call the above number.

At this time, the management plans can provide information regarding inspections, response actions, and post-response action activities, including periodic reinspection and surveillance activities that are planned or in progress. Inquiries regarding any facet of the regulation or the management plans should be directed to Mr. Tony Nauert at the above telephone number during regular business hours.

Listed is a brief description of asbestos work that has been completed in our schools this year. Detailed reports have become part of each school's asbestos management plan and may be reviewed in the school office.

**Jeffersonville, Charlestown, and New Washington High Schools; Parkview, Charlestown, and River Valley Middle Schools; Wilson, Thomas Jefferson, Northaven, Utica, New Washington, Jonathan Jennings, Bridgepoint, Maple, Riverside, Spring Hill, and Parkwood Elementary Schools; the Administration Building, Service Center, and Corden Porter Center -**

- \* The required six month periodic surveillance was performed in June 1999.
- \* The required six month periodic surveillance was performed in December 1999.
- \* The next scheduled activity is a required periodic surveillance in June 2000.

**Pleasant Ridge Elementary School -**

- \* This building is asbestos free. No surveillances or reinspections are required.

June 2000



## AHERA Annual Notice

This information is being published to comply with the requirements of 40 CFR 763 Subpart E asbestos containing materials in schools. This regulation, commonly known as the "AHERA" rule, requires local education agencies, such as this one, to perform certain tasks in regards to the presence and control of asbestos containing materials in the buildings under the jurisdiction of the local education agency.

These include but are not limited to:

1. Developing an asbestos management plan which is designed to outline procedures and guidelines for the inspection, reinspection and periodic surveillance of asbestos containing materials that are present in the buildings.
2. Provide awareness training and additional training to selected school employees.
3. Periodically notify all workers and occupants, or their local guardians, parent teacher organizations, and collective bargaining organizations of the availability of asbestos management plans, the location of same and the times that the plans may be reviewed.

This notification is to advise all patrons, occupants, or their legal guardians, collective bargaining organizations, and parent-teachers organizations, that the asbestos management plans required under this act are available for review upon request. A copy of the plans for all buildings under the jurisdiction of this local education agency are available in the Service Center building, which is located at 301 E. 11th Street, Jeffersonville, Indiana 47130; telephone number 288-4821. Plans for individual schools and other buildings are located in the administration office of each school. The plans can be viewed by any person during normal business hours of the particular school. Interested parties wishing to inquire about the hours and times that the plans are available should call the above number.

At this time, the management plans can provide information regarding inspections, response actions, and post-response action activities, including periodic reinspection and surveillance activities that are planned or in progress. Inquiries regarding any facet of the regulation or the management plans should be directed to Mr. Steve Meredith at the above telephone number during regular business hours.

Listed is a brief description of asbestos work that has been completed in our schools this year. Detailed reports have become part of each school's asbestos management plan and may be reviewed in the school office.

### **All school and support buildings where it is required -**

- \* The required six month periodic surveillance was performed in June 1998.
- \* The required six month periodic surveillance was performed in December 1998.
- \* The next scheduled activity is a required periodic surveillance in June 1999.

### **Parkwood Elementary School**

- \* O & M was performed in the boiler room in May 1998.

June 1999

## AHERA Annual Notice

This information is being published to comply with the requirements of 40 CFR 763 Subpart E asbestos containing materials in schools. This regulation, commonly known as the "AHERA" rule, requires local education agencies, such as this one, to perform certain tasks in regards to the presence and control of asbestos containing materials in the buildings under the jurisdiction of the local education agency.

These include but are not limited to:

1. Developing an asbestos management plan which is designed to outline procedures and guidelines for the inspection, reinspection and periodic surveillance of asbestos containing materials that are present in the buildings.
2. Provide awareness training and additional training to selected school employees.
3. Periodically notify all workers and occupants, or their local guardians, parent teacher organizations, and collective bargaining organizations of the availability of asbestos management plans, the location of same and the times that the plans may be reviewed.

This notification is to advise all patrons, occupants, or their legal guardians, collective bargaining organizations, and parent-teachers organizations, that the asbestos management plans required under this act are available for review upon request. A copy of the plans for all buildings under the jurisdiction of this local education agency are available in the Service Center building, which is located at 301 E. 11th Street, Jeffersonville, Indiana 47130; telephone number 288-4821. Plans for individual schools and other buildings are located in the administration office of each school. The plans can be viewed by any person during normal business hours of the particular school. Interested parties wishing to inquire about the hours and times that the plans are available should call the above number.

At this time, the management plans can provide information regarding inspections, response actions, and post-response action activities, including periodic reinspection and surveillance activities that are planned or in progress. Inquiries regarding any facet of the regulation or the management plans should be directed to Mr. Steve Meredith at the above telephone number during regular business hours.

Listed is a brief description of asbestos work that has been completed in our schools this year. Detailed reports have become part of each school's asbestos management plan and may be reviewed in the school office.

**All school and support buildings where it is required -**

- \* The required periodic surveillance was performed in June 1997 and December 1997.
- \* Next activity scheduled activity is a required third year reinspection in June 1998.

June 98

## AHERA Annual Notice

This information is being published to comply with the requirements of 40 CFR 763 Subpart E asbestos containing materials in schools. This regulation, commonly known as the "AHERA" rule, requires local education agencies, such as this one, to perform certain tasks in regards to the presence and control of asbestos containing materials in the buildings under the jurisdiction of the local education agency.

These include but are not limited to:

1. Developing an asbestos management plan which is designed to outline procedures and guidelines for the inspection, reinspection and periodic surveillance of asbestos containing materials that are present in the buildings.
2. Provide awareness training and additional training to selected school employees.
3. Periodically notify all workers and occupants, or their local guardians, parent teacher organizations, and collective bargaining organizations of the availability of asbestos management plans, the location of same and the times that the plans may be reviewed.

This notification is to advise all patrons, occupants, or their legal guardians, collective bargaining organizations, and parent-teachers organizations, that the asbestos management plans required under this act are available for review upon request. A copy of the plans for all buildings under the jurisdiction of this local education agency are available in the Service Center building, which is located at 301 E. 11th Street, Jeffersonville, Indiana 47130; telephone number 288-4821. Plans for individual schools and other buildings are located in the administration office of each school. The plans can be viewed by any person during normal business hours of the particular school. Interested parties wishing to inquire about the hours and times that the plans are available, should call the above number.

At this time, the management plans can provide information regarding inspections, response actions, and post-response action activities, including periodic reinspection and surveillance activities that are planned or in progress. Inquiries regarding any facet of the regulation or the management plans should be directed to Mr. Steve Meredith at the above telephone number during regular business hours.

Listed is a brief description of asbestos work that has been completed in our schools this year. Detailed reports have become part of each school's asbestos management plan and may be reviewed in the school office.

**All school and support buildings where it is required -**

- \* The required periodic surveillance was performed in June 1996 and December 1996.
- \* The next required periodic surveillance will be performed in June 1997 and December 1997.

June 97

This information is being published to comply with the requirements of 40 CFR 763 Subpart E asbestos containing materials in schools. This regulation, commonly known as the "ASHERA" rule, requires local education agencies, such as this one, to perform certain tasks in regards to the presence and control of asbestos containing materials in the buildings under the jurisdiction of the local education agency.

These include but are not limited to:

1. Developing an asbestos management plan which is designed to outline procedures and guidelines for the inspection, reinspection and periodic surveillance of asbestos containing materials that are present in the buildings.
2. Provide awareness training and additional training to selected school employees.
3. Periodically notify all workers and occupants, or their local guardians, parent teacher organizations, and collective bargaining organizations of the availability of asbestos management plans, the location of same and the times that the plans may be reviewed.

This notification is to advise all patrons, occupants, or their legal guardians, collective bargaining organizations, and parent-teachers organizations, that the asbestos management plans required under this act are available for review upon request. A copy of the plans for all buildings under the jurisdiction of this local education agency are available in the Service Center building, which is located at 301 E. 11th Street, Jeffersonville, Indiana 47130; telephone number 288-4821. Plans for individual schools and other buildings are located in the administration office of each school. The plans can be viewed by any person during normal business hours of the particular school. Interested parties wishing to inquire about the hours and times that the plans are available should call the above number.

At this time, the management plans can provide information regarding inspections, response actions, and post-response action activities, including periodic reinspection and surveillance activities that are planned or in progress. Inquiries regarding any facet of the regulation or the management plans should be directed to Mr. Denny Johanson at the above telephone number during regular business hours.

Listed is a brief description of asbestos work that has been completed in our schools this year. Detailed reports have become part of each school's asbestos management plan and may be reviewed in the school office.

**All buildings where it is required -**

- \* The required third year reinspection was performed in June 1995.
- \* The required periodic surveillance was performed in December 1995.
- \* Next activity scheduled is a periodic surveillance in June 1996.

**Charlestown High School -**

- \* Transite panels were compliantly removed from the exterior of the building.

**Corden Porter Building #3 -**

- \* TSI was compliantly removed from the boiler room.

June 96

This information is being published to comply with the requirements of 40 CFR 763 Subpart E asbestos containing materials in schools. This regulation, commonly known as the "AHERA" rule, requires local education agencies, such as this one, to perform certain tasks in regards to the presence and control of asbestos containing materials in the buildings under the jurisdiction of the local education agency.

These include but are not limited to:

1. Developing an asbestos management plan which is designed to outline procedures and guidelines for the inspection, reinspection and periodic surveillance of asbestos containing materials that are present in the buildings.
2. Provide awareness training and additional training to selected school employees.
3. Periodically notify all workers and occupants, or their local guardians, parent teacher organizations, and collective bargaining organizations of the availability of asbestos management plans, the location of same and the times that the plans may be reviewed.

This notification is to advise all patrons, occupants, or their legal guardians, collective bargaining organizations, and parent-teachers organizations, that the asbestos management plans required under this act are available for review upon request. A copy of the plans for all buildings under the jurisdiction of this local education agency are available in the Service Center building, which is located at 301 E. 11th Street, Jeffersonville, Indiana 47130; telephone number 288-4821. Plans for individual schools and other buildings are located in the administration office of each school. The plans can be viewed by any person during normal business hours of the particular school. Interested parties wishing to inquire about the hours and times that the plans are available, should call the above number.

At this time, the management plans can provide information regarding inspections, response actions, and post-response action activities, including periodic reinspection and surveillance activities that are planned or in progress. Inquiries regarding any facet of the regulation or the management plans should be directed to Mr. Dennis Johanson at the above telephone number during regular business hours.

Listed is a brief description of asbestos work that has been completed in our schools this year. Detailed reports have become part of each school's asbestos management plan and may be reviewed in the school office.

**All school and support buildings where it is required -**

- \* The required periodic surveillance was performed in June 1995 and December 1995.
- \* The required triennial reinspection was performed in June 1995.
- \* The next required periodic surveillance will be performed in June 1996 and December 1996.

June 95

*ACCREDITATIONS*

**ENVIRONMENTAL SAFETY ASSURANCE INSTITUTE**  
**1435 Sadler Circle West Drive**  
**Indianapolis, Indiana 46239**  
**(317) 352 -1270 / (317) 352 - 0669**

**CHRISTIAAN SPARKS**  
**306 - 04 - 2616**

Has Successfully Completed The Course  
Required Under TSCA Title II  
And Passed The Written Examination  
With a Score of 70% or Better

For  
**ASBESTOS BUILDING INSPECTOR REFRESHER**

Accredited by the  
Indiana Department of Environmental Management.

**Certificate # ES03/BIR755**

Course Dates: 09/26/2003  
Test Date: 09/26/ 2003 Expires: 09/26/2004



*Sharyn Reyes*  
Sharyn Reyes  
Instructor / Manager

**ENVIRONMENTAL SAFETY ASSURANCE INSTITUTE**  
1435 Sadlier Circle West Drive  
Indianapolis, Indiana 46239  
(317) 352-1270 / (317) 352-06

**GEORGE Wm. (BILL) OGLE**

Has Successfully Completed The Course  
Required Under TSCA Title II  
And Passed The Written Examination  
With a Score of 70% or Better  
For

**ASBESTOS MANAGEMENT PLANNER  
REFRESHER**

Accredited by the  
Indiana Department of Environmental Management.

**Certificate # ES03/MPR045**

Course Dates: 09/05/2003  
Test Date: 09/05/2003      Expires: 09/05/2004



*Sharyn Reyes*  
Sharyn Reyes  
Instructor



**ENVIRONMENTAL SAFETY ASSURANCE INSTITUTE**

**1435 Sadlier Circle West Drive  
Indianapolis, Indiana 46236  
(317) 352-1270 / (317) 352 - 0669**

**PATRICK E. WILSON**

**309 - 90 - 6909**

**Has Successfully Completed The Course  
Required Under TSCA Title II  
And Passed The Written Examination  
With a Score of 70% or Better  
For**

**ASBESTOS BUILDING INSPECTOR REFRESHER**

**Accredited by the  
Indiana Department of Environmental Management.**

**Certificate # ES00/BIR482**

**Course Dates: 11/29/2000  
Test Date: 11/29/2000 Expires: 11/29/2001**

*Sharyn Reyes*

**Sharyn Reyes**

**Instructor**



# Environmental Management Institute

5610 Crawfordsville Road, Suite 15, Indianapolis, Indiana 46224-3714

317/248-4848 • 800/488-8842 • FAX 317/248-4846  
www.spea.iupui.edu/Envtl\_mgmt

This confirms that

**George Wm. (Bill) Ogle**



Completed the Requisite Initial Training for  
Asbestos Accreditation Under TSCA Title II  
and has  
Passed with a Score of 70 or Greater the Examination for  
**Asbestos Management Planner**

Course date  
March 2 - 3, 2000

Examination Date  
March 3, 2000

Jack E. Leonard, President

Certificate: MP(I) 2157  
Expires March 3, 2001

Approved by: Illinois Department of Public Health  
Indiana Department of Environmental Management



ENVIRONMENTAL SAFETY ASSURANCE INSTITUTE  
1435 Sadlier Circle West Drive  
Indianapolis, Indiana 46239  
(317) 352-1270 / (317) 352-0669

**CLINT YATES**

316 - 92 - 7065


Has Successfully Completed The Course  
Required Under TSCA Title II  
And Passed The Written Examination  
With a Score of 70% or Better  
For

**ASBESTOS BUILDING INSPECTOR REFRESHER**

Accredited by the  
Indiana Department of Environmental Management.

Certificate # ES/BIR98/004.

Course Dates: 01/22/98 - 01/22/98  
Test Date: 01/22/98 Expires: 01/22/99



Sharyn Reyes  
Assistant / Instructor

# Environmental Management Institute

Environmental and Occupational Training Service

5610 Crawfordsville Road, Suite 15

Indianapolis, Indiana 46224-3714

317/248-4848

This confirms that

**Rex Gaddis**


Completed the Requisite Refresher Training for  
Asbestos Accreditation Under TSCA Title II  
and has

Passed with a Score of 70 or Greater the Examination for

**Asbestos Building Inspector**

Course date  
November 22, 1994

Examination Date  
November 22, 1994



Jack E. Leonard, President

Certificate: IN(R) 2713  
Expires November 22, 1995

Approved by: Illinois Department of Public Health  
Indiana Department of Environmental Management

INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT  
ASBESTOS CERTIFICATE OF ACCREDITATION  
CERTIFICATE # 102248026      EXPIRATION DATE 2/18/96  
**Rex Gaddis**  
IS CERTIFIED IN THE FOLLOWING DISCIPLINE(S)  
INSPECTOR     PLANNER     DESIGNER   
SUPERVISOR     WORKER   
WASTE DISPOSAL MANAGER   
BIRTHDATE: 3/24/52    SEX: M    EYES: BLU  
HEIGHT: 5-10    WEIGHT: 220    HAIR: BRO

INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT  
ASBESTOS CERTIFICATE OF ACCREDITATION  
CERTIFICATE # 190908032      EXPIRATION DATE 3/16/96  
**Rex Gaddis**  
IS CERTIFIED IN THE FOLLOWING DISCIPLINE(S)  
INSPECTOR     PLANNER     DESIGNER   
SUPERVISOR     WORKER   
WASTE DISPOSAL MANAGER   
BIRTHDATE: 3/24/52    SEX: M    EYES: BLU  
HEIGHT: 5-10    WEIGHT: 220    HAIR: BRO

*TRAINING*

**OPERATIONS AND MAINTENANCE  
INFORMATION**

### **MINOR FIBER RELEASE EPISODE**

The local education agency shall ensure that the procedures described below are followed in the event of a minor fiber release episode (i.e., the falling or dislodging of not more than 3 square or linear feet of friable ACM):

1. Thoroughly saturate the debris using wet methods.
2. Clean the area using wet methods, protective clothing, HEPA-vacuums, mini-enclosures, glove bags, as necessary to inhibit the spread of any released fibers. At a minimum, workers should use air-purifying respirators with HEPA filters.
3. Place the asbestos debris in a sealed, leak-tight container, preferably a 6 mil. labeled plastic bag.
4. Repair the area of damaged ACM with materials such as asbestos-free spackling, plaster, cement, or insulation, or seal with latex paint or an encapsulant, or immediately have the appropriate response action implemented.
5. Each fiber release episode should be documented.



### MAJOR FIBER RELEASE EPISODE

The local education agency shall ensure that the procedures described below are followed in the event of a major fiber release episode (i.e., the falling or dislodging of more than 3 square or linear feet of friable ACBM):

1. Restrict entry into the area and post signs to prevent entry into the area by persons other than those necessary to perform the response action.
2. Shut off or temporarily modify the air-handling system to prevent the distribution of fibers to other areas in the building.
3. AHERA requires that major fiber release episodes be designed by accredited Project Designers. However, the following response procedures should form the basis for response actions.
4. All the procedures recommended by EPA and required by OSHA for large-scale removal of ACM should be used. These include containment barrier, negative pressure ventilation, personal respiratory protection and protective clothing, decontamination facilities, and air testing.
5. Workers should wear "type C" respirators and protective clothing, including a body suit, hood, boots and gloves. Personal air monitoring may be conducted on representative workers, but is not required by OSHA when "type C" respirators are used.
6. Fallen debris should be sprayed with amended water and placed in plastic bags for disposal. Shovels are useful for collecting the debris. The floor should be thoroughly cleaned with a HEPA vacuum cleaner.
7. Walls, ceiling, pipes, boilers, or other surfaces where ACM was damaged or delaminated should be repaired temporarily. This might involve replastering with asbestos-free material, spraying with an encapsulant, or taping with duct tape. In some cases, ACM beyond the immediate area of damage may need to be removed to prevent additional episodes.
8. The air should be tested for asbestos fibers before the plastic barriers are removed and the area reoccupied. Testing should follow guidelines in Chapter 6 of the Purple Book and Chapter 4 of the Silver Book. That is, air should be sampled at the specified number of locations and analyzed by either phase contrast microscopy or transmission electron microscopy. However, sampling should not be done aggressively since the use of blowers and fans may dislodge fibers from the remaining ACM.

9. After the barriers have been taken down, a decontamination of the entire building or a portion of it should be considered. The need for this will depend on how rapidly the response team reacted to the episode and, in particular, how quickly the HVAC system was turned off. A thorough decontamination includes HEPA-vacuuming and/or wet wiping all carpets, furniture, and other surfaces. Decontamination of the HVAC system would involve disassembling and cleaning (HEPA-vacuuming or wet wiping) ducts, ventilators, registers, and other system parts. System filters should also be removed and replaced.

10. All equipment used in the cleanup operation should be washed or wiped with damp cloths. All disposable materials (e.g., cloths, mop heads, filters, coveralls) should be discarded as asbestos wastes.

11. Each fiber release episode should be documented.

**OPERATIONS AND MAINTENANCE REPORT**  
(Use only for O&M work less than 3 square or 3 linear feet)

L.E.A.: Greater Clark County Schools

BUILDING: Parkwood Elementary School

DATE: 19 May 1998

The following information is provided in accordance with 40 CFR 763.91 and 763.94.

1. Location: Boiler Room

Homogeneous Area/Material Description HA #1

2. Response: Clean XX          Repair XX          Encapsulation XX  
                  Enclosure                 Removal       

Reason: Perform clean-up of ACM debris.

3. Work Description: HEPA vacuum of loose debris on floor.

Wet wipe & rewettable canvas applied.

4. Date:            Start 19 May 1998                                  Stop 19 May 1998

Time:             Start 3:45 p.m.                                         Stop 9:00 p.m.

5. Material:       Surface N/A          SF                                  Thermal N/A          LF

Other:            debris < 3          SF          or                                  N/A          LF

6. Asbestos Control Method: Wet Methods XX                                  HEPA Vacuum XX

Glovebag           Mini-Enclosure       

7. Respiratory Protection: N.A.P.R. XX                                  P.A.P.R.       

Were all employees properly fit tested? YES          NO          NOT APPLICABLE

8. Equipment Used:

Low Vol. Pumps	<u>1</u>	High Vol. Pumps	<u>2</u>
FAM		AFD	
HEPA Vac	<u>1</u>		

Other: \_\_\_\_\_

9. Material Used:

6 Mil. Disposable Bags	_____	Poly	<u>XX</u>
Glovebags	_____	HEPA Filters	<u>XX</u>
Duct Tape	<u>XX</u>	Spray Glue	_____
Disposable Coveralls	<u>XX</u>	3M Pads	<u>XX</u>
Sponges	_____		

Encapsulants: Penetrating \_\_\_\_\_ Bridging XX

Other: \_\_\_\_\_

10. Work Personnel:

<u>NAME</u>	<u>16 HOUR TRAINED - IDEM ACCREDITED</u>			
Supervisor: Ed Staples	YES	NO	<u>YES</u>	NO
Worker(s): Ernis Holsfield	YES	NO	<u>YES</u>	NO
_____	YES	NO	YES	NO
_____	YES	NO	YES	NO
_____	YES	NO	YES	NO
_____	YES	NO	YES	NO

11. ACBM Disposal: Storage: YES NO, If yes, where stored: \_\_\_\_\_  
If no, where disposed: Landfill: Outer Loop Recycling and Disposal

12. Final Visual Inspection Approved: Clint Yates  
(LEA Designated Person - Printed Name)  
Clint Yates  
(LEA Designated Person - Signature)

**OPERATIONS AND MAINTENANCE REPORT**  
(Use only for O&M work less than 3 square or 3 linear feet)

L.E.A.: \_\_\_\_\_

BUILDING: \_\_\_\_\_

DATE: \_\_\_\_\_

The following information is provided in accordance with 40 CFR 763.91 and 763.94.

1. Location: \_\_\_\_\_  
Homogeneous Area/Material Description \_\_\_\_\_

2. Response: Clean \_\_\_\_\_ Repair \_\_\_\_\_ Encapsulation \_\_\_\_\_  
Enclosure \_\_\_\_\_ Removal \_\_\_\_\_

Reason: \_\_\_\_\_  
\_\_\_\_\_

3. Work Description: \_\_\_\_\_  
\_\_\_\_\_

4. Date: Start \_\_\_\_\_ Stop \_\_\_\_\_  
Time: Start \_\_\_\_\_ Stop \_\_\_\_\_

5. Material: Surface \_\_\_\_\_ SF Thermal \_\_\_\_\_ LF  
Other: \_\_\_\_\_ SF or \_\_\_\_\_ LF

6. Asbestos Control Method: Wet Methods \_\_\_\_\_ HEPA Vacuum \_\_\_\_\_  
Glovebag \_\_\_\_\_ Mini-Enclosure \_\_\_\_\_

7. Respiratory Protection: N.A.P.R. \_\_\_\_\_ P.A.P.R. \_\_\_\_\_

Were all employees properly fit tested? YES NO NOT APPLICABLE

8. Equipment Used:

Low Vol. Pumps  
FAM  
HEPA Vac

\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

High Vol. Pumps  
AFD

\_\_\_\_\_  
\_\_\_\_\_

Other: \_\_\_\_\_

9. Material Used:

6 Mil. Disposable Bags  
Glovebags  
Duct Tape  
Disposable Coveralls  
Sponges

\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

Poly  
HEPA Filters  
Spray Glue  
3M Pads

\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

Encapsulants: Penetrating \_\_\_\_\_ Bridging \_\_\_\_\_

Other: \_\_\_\_\_

10. Work Personnel:

NAME 16 HOUR TRAINED - IDEM ACCREDITED

Supervisor: \_\_\_\_\_ YES NO YES NO

Worker(s): \_\_\_\_\_ YES NO YES NO

\_\_\_\_\_ YES NO YES NO

\_\_\_\_\_ YES NO YES NO

\_\_\_\_\_ YES NO YES NO

\_\_\_\_\_ YES NO YES NO

11. ACBM Disposal: Storage: YES NO, If yes, where stored: \_\_\_\_\_

If no, where disposed: Landfill: \_\_\_\_\_

12. Final Visual Inspection Approved: \_\_\_\_\_

(LEA Designated Person - Printed Name)

\_\_\_\_\_  
(LEA Designated Person - Signature)

**OPERATIONS AND MAINTENANCE REPORT**  
(Use only for O&M work less than 3 square or 3 linear feet)

L.E.A.: \_\_\_\_\_

BUILDING: \_\_\_\_\_

DATE: \_\_\_\_\_

The following information is provided in accordance with 40 CFR 763.91 and 763.94.

1. Location: \_\_\_\_\_

Homogeneous Area/Material Description \_\_\_\_\_

2. Response: Clean \_\_\_\_\_ Repair \_\_\_\_\_ Encapsulation \_\_\_\_\_  
Enclosure \_\_\_\_\_ Removal \_\_\_\_\_

Reason: \_\_\_\_\_

\_\_\_\_\_

3. Work Description: \_\_\_\_\_

\_\_\_\_\_

4. Date: Start \_\_\_\_\_ Stop \_\_\_\_\_

Time: Start \_\_\_\_\_ Stop \_\_\_\_\_

5. Material: Surface \_\_\_\_\_ SF Thermal \_\_\_\_\_ LF

Other: \_\_\_\_\_ SF or \_\_\_\_\_ LF

6. Asbestos Control Method: Wet Methods \_\_\_\_\_ HEPA Vacuum \_\_\_\_\_

Glovebag \_\_\_\_\_ Mini-Enclosure \_\_\_\_\_

7. Respiratory Protection: N.A.P.R. \_\_\_\_\_ P.A.P.R. \_\_\_\_\_

Were all employees properly fit tested? YES NO NOT APPLICABLE

8. Equipment Used:

Low Vol. Pumps  
FAM  
HEPA Vac

\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

High Vol. Pumps  
AFD

\_\_\_\_\_  
\_\_\_\_\_

Other: \_\_\_\_\_

9. Material Used:

6 Mil. Disposable Bags  
Glovebags  
Duct Tape  
Disposable Coveralls  
Sponges

\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

Poly  
HEPA Filters  
Spray Glue  
3M Pads

\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

Encapsulants: Penetrating \_\_\_\_\_ Bridging \_\_\_\_\_

Other: \_\_\_\_\_

10. Work Personnel:

NAME 16 HOUR TRAINED - IDEM ACCREDITED

Supervisor: \_\_\_\_\_ YES NO YES NO

Worker(s): \_\_\_\_\_ YES NO YES NO

\_\_\_\_\_ YES NO YES NO

\_\_\_\_\_ YES NO YES NO

\_\_\_\_\_ YES NO YES NO

\_\_\_\_\_ YES NO YES NO

11. ACBM Disposal: Storage: YES NO, If yes, where stored: \_\_\_\_\_

If no, where disposed: Landfill: \_\_\_\_\_

12. Final Visual Inspection Approved: \_\_\_\_\_

(LEA Designated Person - Printed Name)

\_\_\_\_\_  
(LEA Designated Person - Signature)



**REMOVAL PROJECT  
INFORMATION**

*SHORT TERM WORKER PROGRAM*

**GREATER CLARK COUNTY SCHOOLS**

**SHORT-TERM WORKER SIGN OFF SHEET**

This form should be signed each and every time before a "short-term worker" (telephone repair worker, utility worker, etc.) performs work that may cause him to come in contact with ACBM or suspected ACBM assumed to be ACM. One copy of this form should then be forwarded to the LEA designated person, and one copy should be maintained in the school building's copy of the supplemental binder provided by Alliance Indiana, Inc., in order to fulfill the LEA's recordkeeping requirements. The third copy should be forwarded to Alliance Indiana, Inc. for placement in its copy of the supplemental binder.

School Building Name - Parkwood Elementary School Date \_\_\_\_\_

I certify that before performing any work which would possibly cause me to come in contact with Asbestos Containing Building Materials (ACBM), I was provided with adequate information regarding the locations of ACBM and suspected ACBM assumed to be ACM in the above-mentioned school building where I performed the work.

Signature - \_\_\_\_\_

Company - \_\_\_\_\_

Description of work (including number of days on site) - \_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

