

GREATER CLARK COUNTY SCHOOLS

JEFFERSONVILLE HIGH SCHOOL

AHERA

ASBESTOS MANAGEMENT PLAN

**DESIGNATED PERSON
TRUTH AND CORRECT STATEMENT**

Local Education Agency – Greater Clark County Schools
2112 Utica-Sellersburg Road
Jeffersonville, Indiana 47130


Designated Person - Alliance Environmental Group, Inc.
Sandra Shadley
5153 Commerce Square Drive, Suite E
Indianapolis, Indiana 46237

This Truth and Correct Statement, as outlined in 40 CFR 763.93(i), certifies that the general, local education agency responsibilities, as stipulated by 40 CFR 763.84, have been or will be met.

These responsibilities include:

1. Ensure that the activities of any persons who perform inspections, reinspections, and periodic surveillance, develop and update management plans, and develop and implement response actions, including operations and maintenance, are carried out in accordance with 40 CFR 763 Subpart E.
2. Ensure all custodial and maintenance employees are properly trained as required by 40 CFR 763 Subpart E and other applicable Federal and/or State regulations (e.g., the Occupational Safety and Health Administration Asbestos Standard for Construction, the EPA Worker Protection Rule, or applicable State regulations).
3. Ensure that workers and building occupants, or their legal guardians, are informed at least once each school year about inspections, response actions, and post-response action activities, including periodic reinspection and surveillance activities that are planned or in progress.
4. Ensure that short-term workers (e.g., telephone repair workers, utility workers, or exterminators) who may come in contact with asbestos in a school are provided information regarding the locations of ACBM and suspected ACBM assumed to be ACM.
5. Ensure that warning labels are posted in accordance with Section 763.95.
6. Ensure management plans are available for inspection and notification of such availability has been provided as specified in the management plan under Section 763.93(g).
7. The undersigned person designated by the LEA pursuant to Section 763.84(g) (1) has received adequate training as stipulated in Section 763.84(g) (2).
8. The LEA has and will consider whether any conflict of interest may arise from the interrelationship among accredited personnel and whether that should influence the selection of accredited personnel to perform activities under Part 763.

Signature: _____



Date: November 6, 2016

Sandra S. Shadley

ASBESTOS PROGRAM MASTER INDEX

The following volumes are part of the Asbestos Program for the **GREATER CLARK COUNTY SCHOOLS**:

- A. Original Asbestos Management Plan for each school building.
- B. Asbestos Management Plan Supplement for each school building.
 - 1. Amendments to Management Plan
 - 2. Remaining Materials Report
 - 3. Surveillance, Reinspection and Additional Bulk Sampling Information
 - 4. Annual Notifications, Accreditations and Training Records
 - 5. Operations and Maintenance Records
 - 6. Asbestos Removal Projects
 - 7. Short Term Worker Program

Copies of both volumes are found in the respective buildings. The Administration Building also contains duplicate copies of both volumes for each building in their entirety.

GREATER CLARK COUNTY SCHOOLS

JEFFERSONVILLE HIGH SCHOOL

TABLE OF CONTENTS

AMENDMENTS TO MANAGEMENT PLAN	1
REMAINING MATERIALS REPORT	2
SURVEILLANCE, REINSPECTION AND ADDITIONAL BULK SAMPLING INFORMATION	3
ANNUAL NOTIFICATIONS, ACCREDITATIONS, AND TRAINING	4
OPERATIONS AND MAINTENANCE RECORDS	5
ASBESTOS REMOVAL PROJECTS	6
SHORT TERM WORKER INFORMATION	7

AMENDMENTS TO THE MANAGEMENT PLAN

GREATER CLARK COUNTY SCHOOLS
JEFFERSONVILLE HIGH SCHOOL

LEA RESPONSIBILITY CERTIFICATION

LEA Designated Person - ALLIANCE INDIANA, INC.


Signature - Bruce Wallace, President/CEO

May 1, 1995
Date

ACCREDITATION STATEMENT

The Greater Clark County Schools ensures that the following items will be carried out:

Activities of any persons who perform inspections, reinspections, and periodic surveillance, develop and update management plans, and develop and implement response actions, including operations and maintenance, are carried out in accordance with Subpart E of this part.

All custodial and maintenance employees are properly trained as required by this Subpart E and other applicable Federal and/or State regulations (e.g., the OSHA asbestos standard for construction, the EPA worker protection rule, or applicable State regulations).

Workers and building occupants, or their legal guardians, are informed at least once each school year about inspections, response actions, and post response action activities, including periodic reinspection and surveillance activities that are planned or in progress.

Short-term workers (e.g., telephone repair workers, utility workers, or exterminators) who may come in contact with asbestos in a school are provided information regarding the locations of ACBM and suspected ACBM assumed to be ACM.

Warning labels are posted in accordance with 763.95.

Management plans are available for inspection and notification of such availability has been provided as specified in the management plan under 763.93(g).

Designate a person to ensure that requirements under this section are properly implemented.

Designated person receives adequate training to perform duties assigned under this section. Such training shall provide, as necessary, basic knowledge of:

Health effects of asbestos

Detection, identification, and assessment of ACM

Options for controlling ACBM

Asbestos management programs

Relevant Federal and State regulations concerning asbestos, including those in this Subpart E and those of the OSHA, U.S. Department of Labor, the U.S. Department of Transportation and the U.S. Environmental Protection Agency.

Consider whether any conflict of interest may arise from the interrelationship among accredited personnel and whether that should influence the selection of accredited personnel to perform activities under this subpart.

AMENDMENT TO MANAGEMENT PLAN


LEA Name - Greater Clark County Schools
Subject - LEA Designated Person Change
Amendment - Effective March 2005, the Designated Person for the Greater Clark County Schools is:

Alliance Environmental Group, Inc.
5340 Commerce Circle, Suite E
Indianapolis, Indiana 46237
(317) 865-3400

Personnel contributing to this Management Plan are licensed in according with 40 CFR 763.93(e)(12).

Management Planner: Sandra S. Shadley

Accreditation Number: 19A002720


Signature


Date

AMENDMENT TO THE MANAGEMENT PLAN

LEA Name - Greater Clark County Schools

Building - Jeffersonville High School

Subject - LEA Designated Person Change

Effective May 1, 1995 the Designated Person for the Greater Clark County Schools is:

Alliance Indiana, Inc.
1433 Sadlier Circle West Drive
Indianapolis, Indiana 46239
(317) 351-5600

Management Planner: Rex Gaddis

Accreditation No. 192218025



Signature

May 1, 1995
Date

**AMENDMENT TO THE
AHERA MANAGEMENT PLAN**

Building - Jeffersonville High School

Subject- New material

Reference - HA A Cove Base

Original Assessment - No assessment in original inspection.


Amended Assessment - The cove base in the building was not addressed in the original inspection. The material is considered to be suspect by EPA. The material will be assumed to contain asbestos and treated as such until a future renovation when it will be sampled.

Management Planner

Rex Gaddis

Indiana Department of Environmental Management Accreditation

192218025



Signature



Date

**AMENDMENT TO THE
AHERA MANAGEMENT PLAN**

Building - Jeffersonville High School

Subject- New material

Reference - HA B Cove Base Mastic

Original Assessment - No assessment in original inspection.


Amended Assessment - The cove base mastic in the building was not addressed in the original inspection. The material is considered to be suspect by EPA. The material will be assumed to contain asbestos and treated as such until a future renovation when it will be sampled.

Management Planner


Rex Gaddis

Indiana Department of Environmental Management Accreditation

192218025



Signature



Date

**AMENDMENT TO THE
AHERA MANAGEMENT PLAN**

Building - Jeffersonville High School

Subject- New material

Reference - HA C Transite Walls

Original Assessment - No assessment in original inspection.


Amended Assessment - Some walls in the gym/balcony area may be transite. This material often contains asbestos. This was not addressed in the original inspection. The material is considered to be suspect by EPA. The material will be assumed to contain asbestos and treated as such until a future renovation when it will be sampled.


Management Planner

Rex Gaddis

Indiana Department of Environmental Management Accreditation

192218025


Signature


Date

AMENDMENT TO MANAGEMENT PLAN

Building Name - Jeffersonville High School
Subject - Deletion of Material from Management Plan Supplement
Amendment - Homogeneous Area designation "C" covering transite walls on the second floor balcony and around the gymnasium will be removed from the Management Plan Supplement as the material was removed as non-friable in 1987.

Management Planner: Matthew S. Wallace

Accreditation Number: 192716070



Signature



Date

AMENDMENT TO MANAGEMENT PLAN

Building Name - (Now Former) Administration Building, W.E. Wilson Elementary School, Thomas Jefferson Elementary School, Jeffersonville High School, River Valley Middle School, Corden Porter Center, Corden Porter Building #3, Corden Porter Building #4, and the Service Center/Bus Garage

Subject - Typographical Error

Amendment - A typographical error was made on the paperwork for the Periodic Surveillance that was conducted in December 2001. The pages in the Management Plan Supplement which are dated 12/10/2002 should read 12/10/2001.

Management Planner: George Wm. Ogle

Accreditation Number: 191523030



Signature



Date

AMENDMENT TO MANAGEMENT PLAN

LEA Name - Greater Clark County Schools
Subject - LEA Designated Person Change
Amendment - Effective March 2005, the Designated Person for the Greater Clark County Schools is:

Alliance Environmental Group, Inc.
5340 Commerce Circle, Suite E
Indianapolis, Indiana 46237
(317) 865-3400

Personnel contributing to this Management Plan are licensed in according with 40 CFR 763.93(e)(12).

Management Planner: Sandra S. Shadley

Accreditation Number: 19A002720


Signature


Date


AMENDMENT TO MANAGEMENT PLAN

Building Name - Jefferson High School
Subject - Removal of Homogeneous Area A
Amendment - All of the cove base molding has been removed in a non-friable manner during various renovation activities since 1999. The elevator corridor area was removed during the summer of 2010. This homogeneous area is being removed from the management plan.

Management Planner: Sandra Shadley

Accreditation Number: 19A002720


Signature


Date

AMENDMENT TO MANAGEMENT PLAN


Building Name - Jefferson High School

Subject - Removal of Homogeneous Area 01

Amendment - Gaskets on boilers were removed by a licensed contractor in 2008; therefore; this material is being removed from the management plan.

Management Planner: Sandra Shadley

Accreditation Number: 19A002720


Signature


Date

AMENDMENT TO MANAGEMENT PLAN

Building Name - Jefferson High School
Subject - Removal of Homogeneous Area 02
Amendment - Boiler insulation on two boilers plus breeching was removed by a licensed contractor in 2008; therefore, this material is being removed from the management plan.

Management Planner: Sandra Shadley

Accreditation Number: 19A002720


Signature



Date


AMENDMENT TO MANAGEMENT PLAN

Building Name - Jefferson High School
Subject - Quantity update to Homogeneous Area 03
Amendment - Approximately 21 fittings in the boiler room area were removed non-friable during normal operations and maintenance activities. Most of the fittings were removed in 2008 by a licensed contractor. The quantity has been adjusted to 24.

Management Planner: Sandra Shadley

Accreditation Number: 19A002720


Signature


Date


AMENDMENT TO MANAGEMENT PLAN

Building Name - Jefferson High School
Subject - Quantity update to Homogeneous Area 05
Amendment - The first and second floor area floor tile was removed in a non-friable manner during the 2008 renovation. The only remaining material is in the elevator.

Management Planner: Sandra Shadley

Accreditation Number: 19A002720


Signature


Date

AMENDMENT TO MANAGEMENT PLAN

Building Name - Jeffersonville High School
Subject - Quantity Change of Homogeneous Area 05
Amendment - Floor tile was removed from the elevator during the course of the 2014 – 2015 renovations. The material was removed in a non-friable manner by a general contractor and disposed of in a general waste dumpster.

Management Planner: Sandra Shadley

Accreditation Number: 19A002720



Signature

May 7, 2015

Date

REMAINING MATERIALS

Greater Clark County School Corporation

Remaining Materials Report

4/23/2020

HA ID	HA Description	Quantity		Asbestos	HA Location	Planned Response Action
<u>Jeffersonville High School</u>						
03	3" Fittings (Domestic hot and cold)	26	Unit(s)	Known	Mechanical rooms (Basement off of elevator)	O&M
05	Floor Tile	40	SF	Known	Elevator	O&M
08	Floor tile mastic	3000	SF	Assumed	First and second floors	O&M
B	Cove base mastic	Unquantified	LF	Assumed	Throughout building	O&M

Greater Clark County School Corporation

Remaining Materials Report

1/14/2020

HA ID	HA Description	Quantity		Asbestos	HA Location	Planned Response Action
<u>Jeffersonville High School</u>						
03	3" Fittings (Domestic hot and cold)	26	Unit(s)	Known	Mechanical rooms (Basement off of elevator)	O&M
05	Floor Tile	40	SF	Known	Elevator	O&M
08	Floor tile mastic	3000	SF	Assumed	First and second floors	O&M
B	Cove base mastic	Unquantified	LF	Assumed	Throughout building	O&M

Greater Clark County School Corporation

Remaining Materials Report

5/16/2019

HA ID	HA Description	Quantity		Asbestos	HA Location	Planned Response Action
<u>Jeffersonville High School</u>						
03	3" Fittings (Domestic hot and cold)	26	Unit(s)	Known	Mechanical rooms (Basement off of elevator)	O&M
05	Floor Tile	40	SF	Known	Elevator	O&M
08	Floor tile mastic	3000	SF	Assumed	First and second floors	O&M
B	Cove base mastic	Unquantified	LF	Assumed	Throughout building	O&M

Greater Clark County School Corporation

Remaining Materials Report

11/13/2018

HA ID	HA Description	Quantity		Asbestos	HA Location	Planned Response Action
<u>Jeffersonville High School</u>						
03	3" Fittings (Domestic hot and cold)	26	Unit(s)	Known	Mechanical rooms (Basement off of elevator)	O&M
05	Floor Tile	40	SF	Known	Elevator	O&M
08	Floor tile mastic	3000	SF	Assumed	First and second floors	O&M
B	Cove base mastic	Unquantified	LF	Assumed	Throughout building	O&M

Greater Clark County School Corporation

Remaining Materials Report

5/2/2018

HA ID	HA Description	Quantity		Asbestos	HA Location	Planned Response Action
<u>Jeffersonville High School</u>						
03	3" Fittings (Domestic hot and cold)	26	Unit(s)	Known	Mechanical rooms (Basement off of elevator)	O&M
05	Floor Tile	40	SF	Known	Elevator	O&M
08	Floor tile mastic	3000	SF	Assumed	First and second floors	O&M
B	Cove base mastic	Unquantified	LF	Assumed	Throughout building	O&M

Greater Clark County School Corporation

Remaining Materials Report

10/18/2017

HA ID	HA Description	Quantity		Asbestos	HA Location	Planned Response Action
<u>Jeffersonville High School</u>						
03	3" Fittings (Domestic hot and cold)	26	Unit(s)	Known	Mechanical rooms (Basement off of elevator)	O&M
05	Floor Tile	40	SF	Known	Elevator	O&M
08	Floor tile mastic	3000	SF	Assumed	First and second floors	O&M
B	Cove base mastic	Unquantified	LF	Assumed	Throughout building	O&M

Greater Clark County School Corporation

Remaining Materials Report

4/13/2017

HA ID	HA Description	Quantity		Asbestos	HA Location	Planned Response Action
<u>Jeffersonville High School</u>						
03	3" Fittings (Domestic hot and cold)	26	Unit(s)	Known	Mechanical rooms (Basement off of elevator)	O&M
05	Floor Tile	40	SF	Known	Elevator	O&M
08	Floor tile mastic	3000	SF	Assumed	First and second floors	O&M
B	Cove base mastic	Unquantified	LF	Assumed	Throughout building	O&M

Greater Clark County School Corporation

Remaining Materials Report

11/3/2016

HA ID	HA Description	Quantity		Asbestos	HA Location	Planned Response Action
<u>Jeffersonville High School</u>						
03	3" Fittings (Domestic hot and cold)	26	Unit(s)	Known	Mechanical rooms (Basement off of elevator)	O&M
05	Floor Tile	40	SF	Known	Elevator	O&M
08	Floor tile mastic	3000	SF	Known	First and second floors	O&M
B	Cove base mastic	Unquantified	LF	Assumed	Throughout building	O&M

Greater Clark County School Corporation

Remaining Materials Report

4/28/2016

HA ID	HA Description	Quantity		Asbestos	HA Location	Planned Response Action
<u>Jeffersonville High School</u>						
03	3" Fittings (Domestic hot and cold)	26	Unit(s)	Known	Mechanical rooms (Basement off of elevator)	O&M
05	Floor Tile	40	SF	Known	Elevator	O&M
08	Floor tile mastic	3000	SF	Assumed	First and second floors	O&M
B	Cove base mastic	Unquantified	LF	Assumed	Throughout building	O&M

Greater Clark County School Corporation

Remaining Materials Report

10/20/2015

HA ID	HA Description	Quantity		Asbestos	HA Location	Planned Response Action
<u>Jeffersonville High School</u>						
03	3" Fittings (Domestic hot and cold)	26	Unit(s)	Known	Mechanical rooms (Basement off of elevator)	O&M
05	Floor Tile	40	SF	Known	Elevator	O&M
08	Floor tile mastic	3000	SF	Assumed	First and second floors	O&M
B	Cove base mastic	Unquantified	LF	Assumed	Throughout building	O&M

Greater Clark County Schools
Remaining Materials Report
April 22, 2015

HA#	Material	Quantity	ACBM Y/A	Location	Planned Activities
<u>Jeffersonville High School</u>					
03	3" Fittings (Domestic hot and cold)	26 EA	Y	Mechanical rooms (Basement off of elevator)	O & M
08	Floor tile mastic	3,000 SF	A	First and second floors	O & M
B	Cove base mastic	Unquantified LF	A	Throughout the building	O & M

**Greater Clark County Schools
Remaining Materials Report
October 22, 2014**

HA#	Material	Quantity	ACBM Y/A	Location	Planned Activities
<u>Jeffersonville High School</u>					
03	3" Fittings (Domestic hot and cold)	26 EA	Y	Boiler room area (Basement off of elevator)	O & M
05	Floor tile	40 SF	Y	Elevator	O & M
08	Floor tile mastic	3,000 SF	A	First and second floors	O & M
B	Cove base mastic	Unquantified LF	A	Throughout the building	O & M

**Greater Clark County Schools
Remaining Materials Report
April 21, 2014**

HA#	Material	Quantity	ACBM Y/A	Location	Planned Activities
<u>Jeffersonville High School</u>					
03	3" Fittings (Domestic hot and cold)	26 EA	Y	Boiler room area (Basement off of elevator)	O & M
05	Floor tile	40 SF	Y	Elevator	O & M
08	Floor tile mastic	3,000 SF	A	First and second floors	O & M
B	Cove base mastic	Unquantified LF	A	Throughout the building	O & M

**Greater Clark County Schools
Remaining Materials Report
October 24, 2013**

HA#	Material	Quantity	ACBM Y/A	Location	Planned Activities
<u>Jeffersonville High School</u>					
03	3" Fittings (Domestic hot and cold)	26 EA	Y	Boiler room area (Basement off of elevator)	O & M
05	Floor tile	40 SF	Y	Elevator	O & M
08	Floor tile mastic	3,000 SF	A	First and second floors	O & M
B	Cove base mastic	Unquantified LF	A	Throughout the building	O & M

**Greater Clark County Schools
Remaining Materials Report
April 24, 2013**

HA#	Material	Quantity	ACBM Y/A	Location	Planned Activities
<u>Jeffersonville High School</u>					
03	3" Fittings (Domestic hot and cold)	26 EA	Y	Boiler room area (Basement off of elevator)	O & M
05	Floor tile	40 SF	Y	Elevator	O & M
08	Floor tile mastic	3,000 SF	A	First and second floors	O & M
B	Cove base mastic	Unquantified LF	A	Throughout the building	O & M

**Greater Clark County Schools
Remaining Materials Report
October 24, 2012**

HA#	Material	Quantity	ACBM Y/A	Location	Planned Activities
<u>Jeffersonville High School</u>					
03	3" Fittings (Domestic hot and cold)	26 EA	Y	Boiler room area (Basement off of elevator)	O & M
05	Floor tile	40 SF	Y	Elevator	O & M
08	Floor tile mastic	3,000 SF	A	First and second floors	O & M
B	Cove base mastic	Unquantified LF	A	Throughout the building	O & M

**Greater Clark County Schools
Remaining Materials Report
June 25, 2012**

HA#	Material	Quantity	ACBM Y/A	Location	Planned Activities
<u>Jeffersonville High School</u>					
03	3" Fittings (Domestic hot and cold)	26 EA	Y	Boiler room area (Basement off of elevator)	O & M
05	Floor tile	40 SF	Y	Elevator	O & M
08	Floor tile mastic	3,000 SF	A	First and second floors	O & M
B	Cove base mastic	Unquantified LF	A	Throughout the building	O & M

**Greater Clark County Schools
Remaining Materials Report
December 15, 2011**

HA#	Material	Quantity	ACBM Y/A	Location	Planned Activities
<u>Jeffersonville High School</u>					
03	3" Fittings (Domestic hot and cold)	26 EA	Y	Boiler room area (Basement off of elevator)	O & M
05	Floor tile	40 SF	Y	Elevator	O & M
08	Floor tile mastic	3,000 SF	A	First and second floors	O & M
B	Cove base mastic	Unquantified LF	A	Throughout the building	O & M

**Greater Clark County Schools
Remaining Materials Report
June 27, 2011**

HA#	Material	Quantity	ACBM Y/A	Location	Planned Activities
<u>Jeffersonville High School</u>					
03	3" Fittings	24 EA	Y	Boiler room area (Basement off of elevator)	O & M
05	Floor tile	50 SF	Y	Elevator	O & M
08	Floor tile mastic	3,000 SF	A	First and second floors	O & M
B	Cove base mastic	Unquantified LF	A	Throughout the building	O & M

**Greater Clark County Schools
Remaining Materials Report
December 6, 2010**

HA#	Material	Quantity	ACBM Y/A	Location	Planned Activities
<u>Jeffersonville High School</u>					
03	3" Fittings	24 EA	Y	Boiler room area (Basement off of elevator)	O & M
05	Floor tile	50 SF	Y	Elevator	O & M
08	Floor tile mastic	3,000 SF	A	First and second floors	O & M
B	Cove base mastic	Unquantified LF	A	Throughout the building	O & M

Greater Clark County Schools
Remaining Materials Report
June 30, 2010

HA#	Material	Quantity	ACBM Y/A	Location	Planned Activities
<u>Jeffersonville High School</u>					
03	3" Fittings	24 EA	Y	Boiler room area (Basement off of elevator)	O & M
05	Floor tile	50 SF	Y	Elevator	O & M
08	Floor tile mastic	3,000 SF	A	First and second floors	O & M
B	Cove base mastic	Unquantified LF	A	Throughout the building	O & M

**Greater Clark County Schools
Remaining Materials Report
December 7, 2009**

HA#	Material	Quantity	ACBM Y/A	Location	Planned Activities
<u>Jeffersonville High School</u>					
03	3" and 12" fittings	45 EA	Y	Boiler room area	O & M
05	Floor tile	548 SF	Y	Second floor and elevator	O & M
08	Floor tile mastic	3,000 SF	A	First and second floors	O & M
A	Cove base molding	60 LF	A	Elevator corridor on second floor	O & M
B	Cove base mastic	Unquantified LF	A	Throughout the building	O & M

**Greater Clark County Schools
Remaining Materials Report
June 10, 2009**

HA#	Material	Quantity	ACBM Y/A	Location	Planned Activities
<u>Jeffersonville High School</u>					
03	3" and 12" fittings	45 EA	Y	Boiler room area	O & M
05	Floor tile	548 SF	Y	First and second floors	O & M
08	Floor tile mastic	3,000 SF	A	First and second floors	O & M
A	Cove base molding	60 LF	A	Elevator corridors	O & M
B	Cove base mastic	Unquantified LF	A	Throughout the building	O & M

**Greater Clark County Schools
Remaining Materials Report
December 10, 2008**

HA#	Material	Quantity	ACBM Y/A	Location	Planned Activities
<u>Jeffersonville High School</u>					
03	3" and 12" fittings	45 EA	Y	Boiler room area	O & M
05	Floor tile	548 SF	Y	First and second floors	O & M
08	Floor tile mastic	3,000 SF	A	First and second floors	O & M
A	Cove base molding	60 LF	A	Elevator corridors	O & M
B	Cove base mastic	Unquantified LF	A	Throughout the building	O & M

**Greater Clark County Schools
Remaining Materials Report
June 30, 2008**

HA#	Material	Quantity	ACBM Y/A	Location	Planned Activities
<u>Jeffersonville High School</u>					
01	Gaskets on boilers	LF	A	Boiler room	Remove
02	Boiler insulation on 2 boilers plus breach	SF	Y	Boiler room	Remove
03	3" and 12" 8 total fittings	45 EA	Y	Boiler room	O & M
05	Floor tile	548 SF	Y	First and second floors	O & M
08	Floor tile mastic	3,000 SF	A	First and second floors	O & M
A	Cove base molding	60 LF	A	Elevator corridors	O & M
B	Cove base mastic	Unquantified LF	A	Throughout the building	O & M

**Greater Clark County Schools
 Remaining Materials Report
 December 14, 2007**

HA#	Material	Quantity	ACBM Y/A	Location	Planned Activities
<u>Jeffersonville High School</u>					
01	Gaskets on boilers	52 LF	A	Boiler room	O & M
02	Boiler insulation on 2 boilers plus breach	1,800 SF	Y	Boiler room	O & M
03	3" and 12" fittings	222 LF	Y	Boiler room	O & M
05	Floor tile	548 SF	Y	First and second floors	O & M
08	Floor tile mastic	3,000 SF	A	First and second floors	O & M
A	Cove base molding	60 LF	A	Elevator corridors	O & M
B	Cove base mastic	Unquantified LF	A	Throughout the building	O & M

**Greater Clark County Schools
Remaining Materials Report
July 9, 2007**

HA#	Material	Quantity	ACBM Y/A	Location	Planned Activities
<u>Jeffersonville High School</u>					
01	Gaskets on boilers	52 LF	A	Boiler room	O & M
02	Boiler insulation on 2 boilers	1,800 SF	Y	Boiler room	O & M
03	3" and 12" fittings	222 LF	Y	Boiler room	O & M
05	Floor tile	548 SF	Y	First and second floors	O & M
08	Floor tile mastic	3,000 SF	A	First and second floors	O & M
A	Cove base molding	60 LF	A	Elevator corridors	O & M
B	Cove base mastic	Unquantified LF	A	Throughout the building	O & M

**Greater Clark County Schools
Remaining Materials Report
December 18, 2006**

HA#	Material	Quantity	ACBM Y/A	Location	Planned Activities
<u>Jeffersonville High School</u>					
01	Gaskets on boilers	52 LF	A	Boiler room	O & M
02	Boiler insulation on 2 boilers	1,800 SF	Y	Boiler room	O & M
03	3" and 12" fittings	222 LF	Y	Boiler room	O & M
05	Floor tile	548 SF	Y	First and second floors	O & M
08	Floor tile mastic	3,000 SF	A	First and second floors	O & M
A	Cove base molding	60 LF	A	Elevator corridors	O & M
B	Cove base mastic	Unquantified LF	A	Throughout the building	O & M

**Greater Clark County Schools
Remaining Materials Report
June 28, 2006**

HA#	Material	Quantity	ACBM Y/A	Location	Planned Activities
<u>Jeffersonville High School</u>					
01	Gaskets on boilers	52 LF	A	Boiler room	O & M
02	Boiler insulation on 2 boilers	1,800 SF	Y	Boiler room	O & M
03	3" and 12" fittings	222 LF	Y	Boiler room	O & M
05	Floor tile	548 SF	Y	First and second floors	O & M
08	Floor tile mastic	3,000 SF	A	First and second floors	O & M
A	Cove base molding	60 LF	A	Elevator corridors	O & M
B	Cove base mastic	Unquantified LF	A	Throughout the building	O & M

**Greater Clark County Schools
Remaining Materials Report
January 25, 2006**

HA#	Material	Quantity	ACBM Y/A	Location	Planned Activities
<u>Jeffersonville High School</u>					
01	Gaskets on boilers	52 LF	A	Boiler room	O & M
02	Boiler insulation on 2 boilers	1,800 SF	Y	Boiler room	O & M
03	3" and 12" fittings	222 LF	Y	Boiler room	O & M
05	Floor tile	548 SF	Y	First and second floors	O & M
08	Floor tile mastic	3,000 SF	A	First and second floors	O & M
A	Cove base molding	60 LF	A	Elevator corridors	O & M
B	Cove base mastic	Unquantified LF	A	Throughout the building	O & M

**Greater Clark County Schools
 Remaining Materials Report
 July 20, 2005**

HA#	Material	Quantity		ACBM Y/A	Location	Planned Activities
<u>Jeffersonville High School</u>						
01	Gaskets on boilers	52	LF	A	Boiler room	O & M
02	Boiler insulation on 2 boilers	1,800	SF	Y	Boiler room	O & M
03	3" and 12" fittings	222	LF	Y	Boiler room	O & M
05	Floor tile	548	SF	Y	First and second floors	O & M
08	Floor tile mastic	3,000	SF	A	First and second floors	O & M
A	Cove base molding	60	LF	A	Elevator corridors	O & M
B	Cove base mastic	Unquantified	LF	A	Throughout the building	O & M

Greater Clark County Schools
 Remaining Materials Report
 December 9, 2004

HA#	Material	Quantity	ACBM Y/A	Location	Planned Activities
<u>Jeffersonville High School</u>					
01	Gaskets on boilers	52 LF	A	Boiler room	O & M
02	Boiler insulation on 2 boilers	1,800 SF	Y	Boiler room	O & M
03	3" and 12" fittings	222 LF	Y	Boiler room	O & M
05	Floor tile	548 SF	Y	First and second floors	O & M
08	Floor tile mastic	3,000 SF	A	First and second floors	O & M
A	Cove base molding	60 LF	A	Elevator corridors	O & M
B	Cove base mastic	60 LF	A	Throughout the building	O & M

Greater Clark County Schools
 Remaining Materials Report
 July 2, 2004

HA#	Material	Quantity		ACBM Y/A	Location	Planned Activities
<u>Jeffersonville High School</u>						
01	Gaskets on boilers	52	LF	A	Boiler room	O & M
02	Boiler insulation on 2 boilers	1,800	SF	Y	Boiler room	O & M
03	3" and 12" fittings	222	LF	Y	Boiler room	O & M
05	Floor tile	548	SF	Y	First and second floors	O & M
08	Floor tile mastic	3,000	SF	A	First and second floors	O & M
A	Cove base molding	60	LF	A	Elevator corridors	O & M
B	Cove base mastic	60	LF	A	Throughout the building	O & M

Greater Clark County Schools
 Remaining Materials Report
 December 9, 2003

HA#	Material	Quantity		ACBM Y/A	Location	Planned Activities
<u>Jeffersonville High School</u>						
01	Gaskets on boilers	52	LF	A	Boiler room	O & M
02	Boiler insulation on 2 boilers	1,800	SF	Y	Boiler room	O & M
03	3" and 12" fittings	222	LF	Y	Boiler room	O & M
05	Floor tile	548	SF	Y	First and second floors	O & M
08	Floor tile mastic	3,000	SF	A	First and second floors	O & M
A	Cove base molding	60	LF	A	Elevator corridors	O & M
B	Cove base mastic	60	LF	A	Throughout the building	O & M

**Greater Clark County Schools
Remaining Materials Report
June 13, 2003**

HA#	Material	Quantity	ACBM Y/A	Location	Planned Activities
<u>Jeffersonville High School</u>					
01	Gaskets on boilers	52 LF	A	Boiler room	O & M
02	Boiler insulation on 2 boilers	1,800 SF	Y	Boiler room	O & M
03	3" and 12" fittings	222 LF	Y	Boiler room	O & M
05	Floor tile	548 SF	Y	First and second floors	O & M
08	Floor tile mastic	3,000 SF	A	First and second floors	O & M
A	Cove base molding	60 LF	A	Elevator corridors	O & M
B	Cove base mastic	60 LF	A	Throughout the building	O & M

Greater Clark County Schools
 Remaining Materials Report
 December 18, 2003

HA#	Material	Quantity	ACBM	Y/A	Location	Planned Activities
<u>Jeffersonville High School</u>						
01	Gaskets on boilers	52	LF	A	Boiler room	O & M
02	Boiler insulation on 2 boilers	1,800	SF	Y	Boiler room	O & M
03	3" and 12" fittings	222	LF	Y	Boiler room	O & M
05	Floor tile	548	SF	Y	First and second floors	O & M
08	Floor tile mastic	3,000	SF	A	First and second floors	O & M
A	Cove base molding	60	LF	A	Elevator corridors	O & M
B	Cove base mastic	60	LF	A	Throughout the building	O & M

Greater Clark County Schools
 Remaining Materials Report
 June 19, 2002

HA#	Material	Quantity		ACBM Y/A	Location	Planned Activities
<u>Jeffersonville High School</u>						
01	Gaskets on boilers	132	SF	A	Boiler room	O & M
02	Boiler insulation on 2 boilers	1,800	SF	Y	Boiler room	O & M
03	3" and 12" fittings	222	LF	Y	Boiler room	O & M
05	Floor tile	548	SF	Y	First and second floors	O & M
08	Floor tile mastic	3,000	SF	A	First and second floors	O & M
A	Cove base molding	Approx. 4,500	LF	A	Throughout the building	O & M
B	Cove base mastic	3,000	SF	A	Throughout the building	O & M

**Greater Clark County Schools
Remaining Materials Report
December 12, 2001**

HA#	Material	Quantity	ACBM Y/A	Location	Planned Activities
<u>Jeffersonville High School</u>					
01	Gaskets on boilers	132 SF	A	Boiler room	O & M
02	Boiler insulation on 2 boilers	1,800 SF	Y	Boiler room	O & M
03	3" and 12" fittings	222 LF	Y	Boiler room	O & M
05	Floor tile	548 SF	Y	First and second floors	O & M
08	Floor tile mastic	3,000 SF	A	First and second floors	O & M
A	Cove base molding	Approx. 4,500 LF	A	Throughout the building	O & M
B	Cove base mastic	3,000 SF	A	Throughout the building	O & M

**Greater Clark County Schools
Remaining Materials Report
July 12, 2001**

HA#	Material	Quantity	ACBM Y/A	Location	Planned Activities
<u>Jeffersonville High School</u>					
01	Gaskets on boilers	132 SF	A	Boiler room	O & M
02	Boiler insulation on 2 boilers	1,800 SF	Y	Boiler room	O & M
03	3" and 12" fittings	222 LF	Y	Boiler room	O & M
05	Floor tile	548 SF	Y	First and second floors	O & M
08	Floor tile mastic	3,000 SF	A	First and second floors	O & M
A	Cove base molding	Approx. 4,500 LF	A	Throughout the building	O & M
B	Cove base mastic	3,000 SF	A	Throughout the building	O & M

Greater Clark County Schools
 Remaining Materials Report
 January 11, 2001

HA#	Material	Quantity		ACBM	Y/A	Location	Planned Activities
<u>Jeffersonville High School</u>							
01	Gaskets on boilers	132	SF	A		Boiler room	O & M
02	Boiler insulation on 2 boilers	1,800	SF	Y		Boiler room	O & M
03	3" and 12" fittings	222	LF	Y		Boiler room	O & M
05	Floor tile	548	SF	Y		First and second floors	O & M
08	Floor tile mastic	3,000	SF	A		First and second floors	O & M
A	Cove base molding	Approx. 4,500	LF	A		Throughout the building	O & M
B	Cove base mastic	3,000	SF	A		Throughout the building	O & M

**Greater Clark County Schools
Remaining Materials Report
June 29, 2000**

HA#	Material	Quantity		ACBM Y/A	Location	Planned Activities
<u>Jeffersonville High School</u>						
01	Gaskets on Boilers	132	SF	A	Boiler Room	O & M
02	Boiler Insulation on 2 Boilers	1800	SF	Y	Boiler Room	O & M
03	3" and 12" Fittings	222	LF	Y	Boiler Room	O & M
05	Floor Tile	548	SF	Y	First and second floors	O & M
08	Floor Tile Mastic	3000	SF	A	First and second floors	O & M
A	Cove Base Molding	Unquantified	SF	A	Throughout the building	O & M
B	Cove Base Mastic	3000	SF	A	Throughout the building	O & M

Greater Clark County Schools
 Remaining Materials Report
 February 23, 2000

HA#	Material	Quantity	ACBM	Y/A	Location	Planned Activities
<u>Jeffersonville High School</u>						
01	Gaskets on Boilers	132	SF	A	Boiler Room	O & M
02	Boiler Insulation on 2 Boilers	1800	SF	Y	Boiler Room	O & M
03	3" and 12" Fittings	222	LF	Y	Boiler Room	O & M
08	Floor Tile Mastic	3000	SF	A	First and second floors	O & M
A	Cove Base Molding	3000	SF	A	Throughout the building	O & M
B	Cove Base Mastic	3000	SF	A	Throughout the building	O & M

**Greater Clark County Schools
Remaining Materials Report
July 6, 1999**

HA#	Material	Quantity	ACBM Y/A	Location	Planned Activities
<u>Jeffersonville High School</u>					
01	Gaskets on Boilers	132 SF	A	Boiler Room	O & M
02	Boiler Insulation on 2 Boilers	1800 SF	Y	Boiler Room	O & M
03	3" and 12" Fittings	222 LF	Y	Boiler Room	O & M
08	Floor Tile Mastic	3000 SF	A	First and second floors	O & M
A	Cove Base Molding	3000 SF	A	Throughout the building	O & M
B	Cove Base Mastic	3000 SF	A	Throughout the building	O & M

**PERIODIC SURVEILLANCE
REINSPECTION
ADDITIONAL BULK SAMPLING
INFORMATION**

ASSESSMENTS FOR AHERA

1. Damaged or significantly damaged thermal systems insulation.
2. Damaged friable surfacing ACM.
3. Significantly damaged friable surfacing ACM.
4. Damaged or significantly damaged friable miscellaneous ACM.
5. ACBM with potential for damage.
6. ACBM with potential for significant damage.
7. Any remaining friable ACBM or friable suspected ACBM.

If a material is non-friable, it does not require an assessment rating under AHERA.

Due to the differences in what is required of the LEA for damaged material compared to significantly damaged material, Alliance has modified the assessment scale to the following:

- 1A. Significantly damaged thermal systems insulation.
- 1B. Damaged thermal systems insulation.
- 4A. Significantly damaged friable miscellaneous ACM.
- 4B. Damaged friable miscellaneous ACM.

PERIODIC SURVEILLANCES

SURVEILLANCE INFORMATION
PERIODIC SURVEILLANCE PLAN
GREATER CLARK COUNTY SCHOOLS

The ACBM in this building will be periodically inspected to determine any change in the condition of the materials for as long as the material remain in the building, as required by the Asbestos Hazard Emergency Response Act (AHERA). This periodic surveillance shall be conducted on a semi-annual basis as required by law.

Records of each re-inspection will be maintained in this binder.

DATE PLANNED	DATE COMPLETED	COMPLETED BY
<u>October 2014</u>	October 22, 2014	
<u>April 2015</u>	April 22, 2015	
<u>October 2015</u>	October 20, 2016	
<u>April 2016</u>	RE-INSPECTION	
<u>October 2016</u>	November 3, 2016	
<u>April 2017</u>	April 13, 2017	
<u>October 2017</u>	October 18, 2017	
<u>April 2018</u>	May 2, 2018	
<u>October 2018</u>	November 13, 2018	
<u>April 2019</u>	RE-INSPECTION	
<u>October 2019</u>	January 14, 2020	
<u>April 2020</u>	April 23, 2020	
<u>October 2020</u>		

SURVEILLANCE INFORMATION

PERIODIC SURVEILLANCE PLAN

GREATER CLARK COUNTY SCHOOLS

The ACBM in this building will be periodically inspected to determine any change in the condition of the materials for as long as the material remain in the building, as required by the Asbestos Hazard Emergency Response Act (AHERA). This periodic surveillance shall be conducted on a semi-annual basis as required by law.

Records of each re-inspection will be maintained in this binder.

<u>April 2021</u>	_____	_____
<u>October 2021</u>	_____	_____
<u>April 2022</u>	RE-INSPECTION	_____
<u>October 2022</u>	_____	_____
<u>April 2023</u>	_____	_____
<u>October 2023</u>	_____	_____
<u>April 2024</u>	_____	_____
<u>October 2024</u>	_____	_____
<u>April 2025</u>	RE-INSPECTION	_____
<u>October 2025</u>	_____	_____
<u>April 2026</u>	_____	_____
<u>October 2026</u>	_____	_____

SURVEILLANCE INFORMATION

PERIODIC SURVEILLANCE PLAN SCHEDULE

GREATER CLARK COUNTY SCHOOLS

The ACBM in this building will be periodically inspected to determine any change in the condition of the materials for as long as the material remain in the building, as required by the Asbestos Hazard Emergency Response Act (AHERA). This periodic surveillance shall be conducted on a semi-annual basis as required by law.

Records of each re-inspection will be maintained in this binder.

<u>DATE PLANNED</u>	<u>DATE COMPLETED</u>	<u>COMPLETED BY</u>
<u>JUNE 2009</u>	<u>JUNE 2009</u>	<u>Bill Ogle</u>
<u>DECEMBER 2009</u>	<u>Dec 2009</u>	<u>Bill Ogle</u>
<u>JUNE 2010</u>	<u>Reinspection</u>	<u>Sandy Shadley</u>
<u>DECEMBER 2010</u>	<u>December 2010</u>	<u>Paul Kriek</u>
<u>JUNE 2011</u>	<u>June 2011</u>	<u>Sandy Shadley</u>
<u>DECEMBER 2011</u>	<u>December 2011</u>	<u>Sandy Shadley</u>
<u>JUNE 2012</u>	<u>June 2012</u>	<u>Jeff Hechtin</u>
<u>DECEMBER 2012</u>	<u>October 2012</u>	<u>Jeff Hechtin</u>
<u>JUNE 2013</u>	<u>Reinspection</u>	<u>Jeff Hechtin</u>
<u>DECEMBER 2013</u>	<u>_____</u>	<u>_____</u>

PERIODIC SURVEILLANCE PLAN

GREATER CLARK COUNTY SCHOOLS

The ACBM in this building will be periodically inspected to determine any change in the condition of the materials for as long as the material remain in the building, as required by the Asbestos Hazard Emergency Response Act (AHERA). This periodic surveillance shall be conducted on a semi-annual basis as required by law.

Records of each reinspection will be maintained in this binder.

<u>DATE PLANNED</u>	<u>DATE COMPLETED</u>	<u>COMPLETED BY</u>
<u>JUNE 2003</u>	<u>June '03</u>	<u>C. Sparks</u>
<u>DECEMBER 2003</u>	<u>Dec. '03</u>	<u>C. Sparks</u>
<u>JUNE 2004</u>	<u>REINSPECTION</u>	<u>C. Sparks</u>
<u>DECEMBER 2004</u>	<u>Dec. '04</u>	<u>C. Sparks</u>
<u>JUNE 2005</u>	<u>July '05</u>	<u>J. Ogle</u>
<u>DECEMBER 2005</u>	<u>Jan 06</u>	<u>Boyer</u>
<u>JUNE 2006</u>	<u>June 06</u>	<u>C. Amis</u>
<u>DECEMBER 2006</u>	<u>Dec 06</u>	<u>Boyer</u>
<u>JUNE 2007</u>	<u>REINSPECTION</u>	<u>Bill Ogle</u>
<u>DECEMBER 2007</u>	<u>December 2007</u>	<u>Bill Ogle</u>
<u>JUNE 2008</u>	<u>June 2008</u>	<u>Bill Ogle</u>
<u>DECEMBER 2008</u>	<u>December 2008</u>	<u>Bill Ogle</u>

PERIODIC SURVEILLANCE PLAN**GREATER CLARK COUNTY SCHOOLS****JEFFERSONVILLE HIGH SCHOOL**

The ACBM in this building will be periodically inspected to determine any change in the condition of the materials for as long they remain in the building. This inspection will be conducted semi-annually.

The following table outlines the dates on which these inspections should take place in this school building.

PERIODIC SURVEILLANCE SCHEDULE

<u>DATE PLANNED</u>	<u>DATE COMPLETED</u>	<u>COMPLETED BY</u>
<u>DECEMBER 1995</u>	<u>12-95</u>	<u>Alliance</u>
<u>JUNE 1996</u>	<u>6-96</u>	<u>Alliance</u>
<u>DECEMBER 1996</u>	<u>12-96</u>	<u>Alliance</u>
<u>JUNE 1997</u>	<u>7-97</u>	<u>Alliance</u>
<u>DECEMBER 1997</u>	<u>1-98</u>	<u>Alliance</u>
<u>JUNE 1998</u>	<u>REINSPECTION</u>	<u>Alliance</u>
<u>DECEMBER 1998</u>	<u>12-98</u>	<u>Alliance</u>
<u>JUNE 1999</u>	<u>June '99</u>	<u>Alliance</u>
<u>DECEMBER 1999</u>	<u>Dec. '99</u>	<u>Alliance</u>
<u>JUNE 2000</u>	<u>June 2000</u>	<u>Alliance</u>
<u>DECEMBER 2000</u>	<u>Jan. '01</u>	<u>Pat Wilson</u>
<u>JUNE 2001</u>	<u>REINSPECTION</u>	<u>P. Wilson</u>
<u>DECEMBER 2001</u>	<u>Dec. '01</u>	<u>A. Kimbrough</u>
<u>JUNE 2002</u>	<u>June. '02</u>	<u>R. Calvert</u>
<u>DECEMBER 2002</u>	<u>Dec. '02</u>	<u>C. Sparks</u>

Periodic Surveillance

LEA Name Greater Clark County School Corporation
Building Name Jeffersonville High School
Building Number 11
HA ID 03
HA Description 3" Fittings (Domestic hot and cold)
HA Type Thermal System Insulation (TSI)
HA Location Mechanical rooms (Basement off of elevator)

Quantity 26 Unit(s)
Comments The remaining fittings are in the custodial room (19), boiler room (3), chiller room (5) and electrical room (3). The remaining fittings are not in poor condition.
Asbestos Known
Friable Yes
Original Inspection 6/1/1988
Current Inspection 4/23/2020

Material Assessment

Assessment Rating 5 ACBM with potential for damage

Damage Assessment and Potential for Damage

<u>Percent Damaged</u>	%	Good Condition
<u>Physical Contact</u>	<u>Vibration</u>	<u>Air</u>
Low/None	Low/None	Low/None

Planned Response Action O&M

Inspector



Michael J. Ardis

State IN

Accreditation Number 19A007304

Periodic Surveillance

LEA Name Greater Clark County School Corporation
Building Name Jeffersonville High School
Building Number 11
HA ID 05
HA Description Floor Tile
HA Type Miscellaneous Material
HA Location Elevator

Quantity 40 SF
Comments This material was removed and replaced. It will be removed from the management plan.
Asbestos Known
Friable No
Original Inspection 6/1/1988
Current Inspection 4/23/2020

Material Assessment

Assessment Rating 5 ACBM with potential for damage

Damage Assessment and Potential for Damage

Percent Damaged % Good Condition

<u>Physical Contact</u>	<u>Vibration</u>	<u>Air</u>
Low/None	Low/None	Low/None

Planned Response Action O&M

Inspector



Michael J. Ardis

State IN

Accreditation Number 19A007304

Periodic Surveillance

LEA Name Greater Clark County School Corporation
Building Name Jeffersonville High School
Building Number 11
HA ID 08
HA Description Floor tile mastic
HA Type Miscellaneous Material
HA Location First and second floors

Quantity 3000 SF
Comments Where exposed on the elevator, this material was not in poor condition. The mastic was sealed and left in place under new floor tile.
Asbestos Assumed
Friable No
Original Inspection 6/1/1988
Current Inspection 4/23/2020

Material Assessment

Assessment Rating 5 ACBM with potential for damage

Damage Assessment and Potential for Damage

Percent Damaged % Good Condition

<u>Physical Contact</u>	<u>Vibration</u>	<u>Air</u>
Low/None	Low/None	Low/None

Planned Response Action O&M

Inspector



Michael J. Ardis

State IN

Accreditation Number 19A007304

Periodic Surveillance

LEA Name Greater Clark County School Corporation
Building Name Jeffersonville High School
Building Number 11
HA ID B
HA Description Cove base mastic
HA Type Miscellaneous Material
HA Location Throughout building

Quantity Unquantified LF
Comments Mastic was not visible to inspect newer cove base has been placed over older cove base mastic.
Asbestos Assumed
Friable No
Original Inspection 5/31/1995
Current Inspection 4/23/2020

Material Assessment

Assessment Rating 5 ACBM with potential for damage

Damage Assessment and Potential for Damage

Percent Damaged % Good Condition

<u>Physical Contact</u>	<u>Vibration</u>	<u>Air</u>
Low/None	Low/None	Low/None

Planned Response Action O&M

Inspector



Michael J. Ardis

State IN

Accreditation Number 19A007304

Periodic Surveillance

LEA Name Greater Clark County School Corporation
Building Name Jeffersonville High School
Building Number 11
HA ID 03
HA Description 3" Fittings (Domestic hot and cold)
HA Type Thermal System Insulation (TSI)
HA Location Mechanical rooms (Basement off of elevator)

Quantity 26 Unit(s)
Comments The remaining fittings are in the custodial room (19), boiler room (3), chiller room (5) and electrical room (3) and basement storage room. The remaining fittings are not in poor condition.
Asbestos Known
Friable Yes
Original Inspection 6/1/1988
Current Inspection 1/14/2020

Material Assessment

Assessment Rating 5 ACBM with potential for damage

Damage Assessment and Potential for Damage

<u>Percent Damaged</u>	%	Good Condition
<u>Physical Contact</u>	<u>Vibration</u>	<u>Air</u>
Low/None	Low/None	Low/None
<u>Planned Response Action</u>	O&M	

Inspector



Michael J. Ardis

State IN

Accreditation Number 19A007304

Periodic Surveillance

LEA Name Greater Clark County School Corporation
Building Name Jeffersonville High School
Building Number 11
HA ID 05
HA Description Floor Tile
HA Type Miscellaneous Material
HA Location Elevator

Quantity 40 SF
Comments This material was removed and replaced. It will be removed from the management plan.
Asbestos Known
Friable No
Original Inspection 6/1/1988
Current Inspection 1/14/2020

Material Assessment

Assessment Rating 5 ACBM with potential for damage

Damage Assessment and Potential for Damage

<u>Percent Damaged</u>	%	Good Condition
<u>Physical Contact</u>	<u>Vibration</u>	<u>Air</u>
Low/None	Low/None	Low/None

Planned Response Action O&M

Inspector



Michael J. Ardis

State IN

Accreditation Number 19A007304

Periodic Surveillance

LEA Name Greater Clark County School Corporation
Building Name Jeffersonville High School
Building Number 11
HA ID 08
HA Description Floor tile mastic
HA Type Miscellaneous Material
HA Location First and second floors

Quantity 3000 SF
Comments Where exposed on the elevator, this material was not in poor condition. The mastic was sealed and left in place under new floor tile.
Asbestos Assumed
Friable No
Original Inspection 6/1/1988
Current Inspection 1/14/2020

Material Assessment

Assessment Rating 5 ACBM with potential for damage

Damage Assessment and Potential for Damage

Percent Damaged % Good Condition

<u>Physical Contact</u>	<u>Vibration</u>	<u>Air</u>
Low/None	Low/None	Low/None

Planned Response Action O&M

Inspector



Michael J. Ardis

State IN

Accreditation Number 19A007304

Periodic Surveillance

LEA Name Greater Clark County School Corporation
Building Name Jeffersonville High School
Building Number 11
HA ID B
HA Description Cove base mastic
HA Type Miscellaneous Material
HA Location Throughout building

Quantity Unquantified LF
Comments Mastic was not visible to inspect newer cove base has been placed over older cove base mastic.
Asbestos Assumed
Friable No
Original Inspection 5/31/1995
Current Inspection 1/14/2020

Material Assessment

Assessment Rating 5 ACBM with potential for damage

Damage Assessment and Potential for Damage

Percent Damaged % Good Condition

<u>Physical Contact</u>	<u>Vibration</u>	<u>Air</u>
Low/None	Low/None	Low/None

Planned Response Action O&M

Inspector



Michael J. Ardis

State IN

Accreditation Number 19A007304

Periodic Surveillance

LEA Name Greater Clark County School Corporation
Building Name Jeffersonville High School
Building Number 11
HA ID 03
HA Description 3" Fittings (Domestic hot and cold)
HA Type Thermal System Insulation (TSI)
HA Location Mechanical rooms (Basement off of elevator)

Quantity 26 Unit(s)
Comments The remaining fittings are in the custodial room (19), boiler room (3), chiller room (5) and electrical room (3). The remaining fittings are not in poor condition.
Asbestos Known
Friable Yes
Original Inspection 6/1/1988
Current Inspection 11/13/2018

Material Assessment


Assessment Rating 5 ACBM with potential for damage

Damage Assessment and Potential for Damage

Percent Damaged	%	Good Condition	
Physical Contact	Low/None	Vibration Low/None	Air Low/None

Planned Response Action O&M

Inspector



Benjamin S. Hood

State IN

Accreditation Number 19A001039

Periodic Surveillance

LEA Name Greater Clark County School Corporation
Building Name Jeffersonville High School
Building Number 11
HA ID 05
HA Description Floor Tile
HA Type Miscellaneous Material
HA Location Elevator

Quantity 40 SF
Comments This material was removed and replaced. It will be removed from the management plan.
Asbestos Known
Friable No
Original Inspection 6/1/1988
Current Inspection 11/13/2018

Material Assessment

Assessment Rating 5 ACBM with potential for damage


Damage Assessment and Potential for Damage

Percent Damaged % Good Condition

<u>Physical Contact</u>	<u>Vibration</u>	<u>Air</u>
Low/None	Low/None	Low/None

Planned Response Action O&M

Inspector



Benjamin S. Hood

State IN

Accreditation Number 19A001039

Periodic Surveillance

LEA Name Greater Clark County School Corporation
Building Name Jeffersonville High School
Building Number 11
HA ID 08
HA Description Floor tile mastic
HA Type Miscellaneous Material
HA Location First and second floors

Quantity 3000 SF
Comments Where exposed on the elevator, this material was not in poor condition. The mastic was sealed and left in place under new floor tile.
Asbestos Assumed
Friable No
Original Inspection 6/1/1988
Current Inspection 11/13/2018


Material Assessment

Assessment Rating 5 ACBM with potential for damage

Damage Assessment and Potential for Damage

Percent Damaged	%	Good Condition	
Physical Contact	Low/None	Vibration Low/None	Air Low/None

Planned Response Action O&M

Inspector 

Benjamin S. Hood

State IN
Accreditation Number 19A001039

Periodic Surveillance

LEA Name Greater Clark County School Corporation
Building Name Jeffersonville High School
Building Number 11
HA ID B
HA Description Cove base mastic
HA Type Miscellaneous Material
HA Location Throughout building

Quantity Unquantified LF
Comments Mastic was not visible to inspect newer cove base has been placed over older cove base mastic.
Asbestos Assumed
Friable No
Original Inspection 5/31/1995
Current Inspection 11/13/2018

Material Assessment


Assessment Rating 5 ACBM with potential for damage

Damage Assessment and Potential for Damage

Percent Damaged % Good Condition

<u>Physical Contact</u>	<u>Vibration</u>	<u>Air</u>
Low/None	Low/None	Low/None

Planned Response Action O&M

Inspector 

Benjamin S. Hood

State IN
Accreditation Number 19A001039

Periodic Surveillance

LEA Name Greater Clark County School Corporation
Building Name Jeffersonville High School
Building Number 11
HA ID 03
HA Description 3" Fittings (Domestic hot and cold)
HA Type Thermal System Insulation (TSI)
HA Location Mechanical rooms (Basement off of elevator)

Quantity 26 Unit(s)
Comments The remaining fittings are in the custodial room (19), boiler room (3), chiller room (5) and electrical room (3). The remaining fittings are not in poor condition.
Asbestos Known
Friable Yes
Original Inspection 6/1/1988
Current Inspection 5/2/2018

Material Assessment


Assessment Rating 5 ACBM with potential for damage

Damage Assessment and Potential for Damage

Percent Damaged	%	Good Condition	
Physical Contact	Low/None	Vibration Low/None	Air Low/None

Planned Response Action O&M

Inspector



Benjamin S. Hood

State IN

Accreditation Number 19A001039

Periodic Surveillance

LEA Name Greater Clark County School Corporation
Building Name Jeffersonville High School
Building Number 11
HA ID 05
HA Description Floor Tile
HA Type Miscellaneous Material
HA Location Elevator

Quantity 40 SF
Comments This material was removed and replaced. It will be removed from the management plan.
Asbestos Known
Friable No
Original Inspection 6/1/1988
Current Inspection 5/2/2018

Material Assessment

Assessment Rating 5 ACBM with potential for damage

Damage Assessment and Potential for Damage

Percent Damaged % Good Condition

<u>Physical Contact</u>	<u>Vibration</u>	<u>Air</u>
Low/None	Low/None	Low/None

Planned Response Action O&M

Inspector



Benjamin S. Hood

State IN

Accreditation Number 19A001039

Periodic Surveillance

LEA Name Greater Clark County School Corporation
Building Name Jeffersonville High School
Building Number 11
HA ID 08
HA Description Floor tile mastic
HA Type Miscellaneous Material
HA Location First and second floors

Quantity 3000 SF
Comments Where exposed on the elevator, this material was not in poor condition. The mastic was sealed and left in place under new floor tile.
Asbestos Assumed
Friable No
Original Inspection 6/1/1988
Current Inspection 5/2/2018

Material Assessment

Assessment Rating 5 ACBM with potential for damage

Damage Assessment and Potential for Damage

Percent Damaged % Good Condition

<u>Physical Contact</u>	<u>Vibration</u>	<u>Air</u>
Low/None	Low/None	Low/None

Planned Response Action O&M

Inspector



Benjamin S. Hood

State IN

Accreditation Number 19A001039

Periodic Surveillance

LEA Name Greater Clark County School Corporation
Building Name Jeffersonville High School
Building Number 11
HA ID B
HA Description Cove base mastic
HA Type Miscellaneous Material
HA Location Throughout building

Quantity Unquantified LF
Comments Mastic was not visible to inspect newer cove base has been placed over older cove base mastic.
Asbestos Assumed
Friable No
Original Inspection 5/31/1995
Current Inspection 5/2/2018

Material Assessment

Assessment Rating 5 ACBM with potential for damage

Damage Assessment and Potential for Damage

Percent Damaged % Good Condition

<u>Physical Contact</u>	<u>Vibration</u>	<u>Air</u>
Low/None	Low/None	Low/None

Planned Response Action O&M

Inspector



Benjamin S. Hood

State IN

Accreditation Number 19A001039

Periodic Surveillance

LEA Name Greater Clark County School Corporation
Building Name Jeffersonville High School
Building Number 11
HA ID 03
HA Description 3" Fittings (Domestic hot and cold)
HA Type Thermal System Insulation (TSI)
HA Location Mechanical rooms (Basement off of elevator)

Quantity 26 Unit(s)
Comments The remaining fittings are in the custodial room (19), boiler room (3), chiller room (5) and electrical room (3). The remaining fittings are not in poor condition.
Asbestos Known
Friable Yes
Original Inspection 6/1/1988
Current Inspection 10/18/2017

Material Assessment

Assessment Rating 5 ACBM with potential for damage

Damage Assessment and Potential for Damage

Percent Damaged % Good Condition

Physical Contact	Vibration	Air
Low/None	Low/None	Low/None

Planned Response Action O&M



Inspector _____
Dustin Hawkins

State IN
Accreditation Number 19A007194

Periodic Surveillance

LEA Name Greater Clark County School Corporation
Building Name Jeffersonville High School
Building Number 11
HA ID 05
HA Description Floor Tile
HA Type Miscellaneous Material
HA Location Elevator

Quantity 40 SF
Comments This material was removed and replaced. It will be removed from the management plan.
Asbestos Known
Friable No
Original Inspection 6/1/1988
Current Inspection 10/18/2017

Material Assessment

Assessment Rating 5 ACBM with potential for damage

Damage Assessment and Potential for Damage

Percent Damaged % Good Condition

Physical Contact	Vibration	Air
Low/None	Low/None	Low/None

Planned Response Action O&M



Inspector _____
Dustin Hawkins

State IN
Accreditation Number 19A007194

Periodic Surveillance

LEA Name Greater Clark County School Corporation
Building Name Jeffersonville High School
Building Number 11
HA ID 08
HA Description Floor tile mastic
HA Type Miscellaneous Material
HA Location First and second floors

Quantity 3000 SF
Comments Where exposed on the elevator, this material was not in poor condition. The mastic was sealed and left in place under new floor tile.
Asbestos Assumed
Friable No
Original Inspection 6/1/1988
Current Inspection 10/18/2017

Material Assessment

Assessment Rating 5 ACBM with potential for damage

Damage Assessment and Potential for Damage

Percent Damaged % Good Condition

Physical Contact	Vibration	Air
Low/None	Low/None	Low/None

Planned Response Action O&M



Inspector _____
Dustin Hawkins

State IN
Accreditation Number 19A007194

Periodic Surveillance

LEA Name Greater Clark County School Corporation
Building Name Jeffersonville High School
Building Number 11
HA ID B
HA Description Cove base mastic
HA Type Miscellaneous Material
HA Location Throughout building

Quantity Unquantified LF
Comments Mastic was not visible to inspect newer cove base has been placed over older cove base mastic.
Asbestos Assumed
Friable No
Original Inspection 5/31/1995
Current Inspection 10/18/2017

Material Assessment

Assessment Rating 5 ACBM with potential for damage

Damage Assessment and Potential for Damage

Percent Damaged % Good Condition

<u>Physical Contact</u>	<u>Vibration</u>	<u>Air</u>
Low/None	Low/None	Low/None

Planned Response Action O&M



Inspector _____
Dustin Hawkins

State IN
Accreditation Number 19A007194

Periodic Surveillance

LEA Name Greater Clark County School Corporation
Building Name Jeffersonville High School
Building Number 11
HA ID B
HA Description Cove base mastic
HA Type Miscellaneous Material
HA Location Throughout building

Quantity Unquantified LF
Comments Mastic was not visible to inspect newer cove base has been placed over older cove base mastic.
Asbestos Assumed
Friable No
Original Inspection 5/31/1995
Current Inspection 4/13/2017

Material Assessment


Assessment Rating 5 ACBM with potential for damage

Damage Assessment and Potential for Damage

Percent Damaged % Good Condition

Physical Contact	Vibration	Air
Low/None	Low/None	Low/None

Planned Response Action O&M

Inspector 

Jamie Hosier

State Indiana
Accreditation Number 19A007179

Periodic Surveillance

LEA Name Greater Clark County School Corporation
Building Name Jeffersonville High School
Building Number 11
HA ID 03
HA Description 3" Fittings (Domestic hot and cold)
HA Type Thermal System Insulation (TSI)
HA Location Mechanical rooms (Basement off of elevator)

Quantity 26 Unit(s)
Comments The remaining fittings are in the custodial room (19), boiler room (3), chiller room (5) and electrical room (3). The remaining fittings are not in poor condition.
Asbestos Known
Friable Yes
Original Inspection 6/1/1988
Current Inspection 4/13/2017

Material Assessment

Assessment Rating 5 ACBM with potential for damage

Damage Assessment and Potential for Damage

Percent Damaged % Good Condition

<u>Physical Contact</u>	<u>Vibration</u>	<u>Air</u>
Low/None	Low/None	Low/None

Planned Response Action O&M

Inspector



Jamie Hosier

State Indiana

Accreditation Number 19A007179

Periodic Surveillance

LEA Name Greater Clark County School Corporation
Building Name Jeffersonville High School
Building Number 11
HA ID 05
HA Description Floor Tile
HA Type Miscellaneous Material
HA Location Elevator

Quantity 40 SF
Comments This material was removed and replaced. It will be removed from the management plan.
Asbestos Known
Friable No
Original Inspection 6/1/1988
Current Inspection 4/13/2017

Material Assessment

Assessment Rating 5 ACBM with potential for damage

Damage Assessment and Potential for Damage

Percent Damaged % Good Condition

<u>Physical Contact</u>	<u>Vibration</u>	<u>Air</u>
Low/None	Low/None	Low/None

Planned Response Action O&M

Inspector



Jamie Hosier

State Indiana

Accreditation Number 19A007179

Periodic Surveillance

LEA Name Greater Clark County School Corporation
Building Name Jeffersonville High School
Building Number 11
HA ID 08
HA Description Floor tile mastic
HA Type Miscellaneous Material
HA Location First and second floors

Quantity 3000 SF
Comments Where exposed on the elevator, this material was not in poor condition. The mastic was sealed and left in place under new floor tile.
Asbestos Assumed
Friable No
Original Inspection 6/1/1988
Current Inspection 4/13/2017

Material Assessment


Assessment Rating 5 ACBM with potential for damage

Damage Assessment and Potential for Damage

Percent Damaged % Good Condition

Physical Contact	Vibration	Air
Low/None	Low/None	Low/None

Planned Response Action O&M

Inspector 

Jamie Hosier

State Indiana
Accreditation Number 19A007179

Periodic Surveillance

LEA Name Greater Clark County School Corporation
Building Name Jeffersonville High School
Building Number 11
HA ID 03
HA Description 3" Fittings (Domestic hot and cold)
HA Type Thermal System Insulation (TSI)
HA Location Mechanical rooms (Basement off of elevator)

Quantity 26 Unit(s)
Comments The remaining fittings are in the custodial room (19), boiler room (3), chiller room (5) and electrical room (3). The remaining fittings are not in poor condition.
Asbestos Known
Friable Yes
Original Inspection 6/1/1988
Current Inspection 11/3/2016


Material Assessment

Assessment Rating 5 ACBM with potential for damage

Damage Assessment and Potential for Damage

Percent Damaged	%	Good Condition	
Physical Contact	Low/None	Vibration Low/None	Air Low/None

Planned Response Action O&M

Inspector 

Dustin Hawkins

State IN
Accreditation Number 19A007194

Periodic Surveillance

LEA Name Greater Clark County School Corporation
Building Name Jeffersonville High School
Building Number 11
HA ID 05
HA Description Floor Tile
HA Type Miscellaneous Material
HA Location Elevator

Quantity 40 SF
Comments This material was removed and replaced. It will be removed from the management plan.
Asbestos Known
Friable No
Original Inspection 6/1/1988
Current Inspection 11/3/2016

Material Assessment

Assessment Rating 5 ACBM with potential for damage

Damage Assessment and Potential for Damage

Percent Damaged % Good Condition

<u>Physical Contact</u>	<u>Vibration</u>	<u>Air</u>
Low/None	Low/None	Low/None

Planned Response Action O&M

Inspector



Dustin Hawkins

State IN

Accreditation Number 19A007194

Periodic Surveillance

LEA Name Greater Clark County School Corporation
Building Name Jeffersonville High School
Building Number 11
HA ID 08
HA Description Floor tile mastic
HA Type Miscellaneous Material
HA Location First and second floors

Quantity 3000 SF
Comments Where exposed on the elevator, this material was not in poor condition. The mastic was sealed and left in place under new floor tile. Black Mastic sampled in H124 and Boy's Dressing Room were found to be asbestos containing.
Asbestos Known
Friable No
Original Inspection 6/1/1988
Current Inspection 11/3/2016

Material Assessment

Assessment Rating 5 ACBM with potential for damage

Damage Assessment and Potential for Damage

Percent Damaged % Good Condition

Physical Contact

Low/None

Vibration

Low/None

Air

Low/None

Planned Response Action O&M



Inspector

Dustin Hawkins

State IN

Accreditation Number 19A007194

Periodic Surveillance

LEA Name Greater Clark County School Corporation
Building Name Jeffersonville High School
Building Number 11
HA ID B
HA Description Cove base mastic
HA Type Miscellaneous Material
HA Location Throughout building

Quantity Unquantified LF
Comments Mastic was not visible to inspect newer cove base has been placed over older cove base mastic.
Asbestos Assumed
Friable No
Original Inspection 5/31/1995
Current Inspection 11/3/2016

Material Assessment

Assessment Rating 5 ACBM with potential for damage

Damage Assessment and Potential for Damage

Percent Damaged	%	Good Condition	
Physical Contact		Vibration	Air
Low/None		Low/None	Low/None

Planned Response Action O&M



Inspector

Dustin Hawkins

State IN

Accreditation Number 19A007194

Periodic Surveillance

LEA Name Greater Clark County School Corporation
Building Name Jeffersonville High School
Building Number 11
HA ID 03
HA Description 3" Fittings (Domestic hot and cold)
HA Type Thermal System Insulation (TSI)
HA Location Mechanical rooms (Basement off of elevator)

Quantity 26 Unit(s)
Comments The remaining fittings are in the custodial room (19), boiler room (3), chiller room (5) and electrical room (3). The remaining fittings are not in poor condition.
Asbestos Known
Friable Yes
Original Inspection 6/1/1988
Current Inspection 10/20/2015

Material Assessment

Assessment Rating 5 ACBM with potential for damage

Damage Assessment and Potential for Damage

<u>Percent Damaged</u>	%	Good Condition	
<u>Physical Contact</u>		<u>Vibration</u>	<u>Air</u>
Low/None		Low/None	Low/None

Planned Response Action O&M

Inspector



Benjamin S. Hood

State IN

Accreditation Number 19A001039

Periodic Surveillance

LEA Name Greater Clark County School Corporation
Building Name Jeffersonville High School
Building Number 11
HA ID 05
HA Description Floor Tile
HA Type Miscellaneous Material
HA Location Elevator

Quantity 40 SF
Comments This material was removed and replaced. It will be removed from the management plan.
Asbestos Known
Friable No
Original Inspection 6/1/1988
Current Inspection 10/20/2015

Material Assessment

Assessment Rating 5 ACBM with potential for damage

Damage Assessment and Potential for Damage

Percent Damaged % Good Condition

<u>Physical Contact</u>	<u>Vibration</u>	<u>Air</u>
Low/None	Low/None	Low/None

Planned Response Action O&M

Inspector



Benjamin S. Hood

State IN

Accreditation Number 19A001039

Periodic Surveillance

LEA Name Greater Clark County School Corporation
Building Name Jeffersonville High School
Building Number 11
HA ID 08
HA Description Floor tile mastic
HA Type Miscellaneous Material
HA Location First and second floors

Quantity 3000 SF
Comments Where exposed on the elevator, this material was not in poor condition. The mastic was sealed and left in place under new floor tile.
Asbestos Assumed
Friable No
Original Inspection 6/1/1988
Current Inspection 10/20/2015

Material Assessment


Assessment Rating 5 ACBM with potential for damage

Damage Assessment and Potential for Damage

Percent Damaged % Good Condition

Physical Contact	Vibration	Air
Low/None	Low/None	Low/None

Planned Response Action O&M

Inspector 
Benjamin S. Hood

State IN
Accreditation Number 19A001039

Periodic Surveillance

LEA Name Greater Clark County School Corporation
Building Name Jeffersonville High School
Building Number 11
HA ID B
HA Description Cove base mastic
HA Type Miscellaneous Material
HA Location Throughout building

Quantity Unquantified LF
Comments Mastic was not visible to inspect newer cove base has been placed over older cove base mastic.
Asbestos Assumed
Friable No
Original Inspection 5/31/1995
Current Inspection 10/20/2015

Material Assessment

Assessment Rating 5 ACBM with potential for damage

Damage Assessment and Potential for Damage

Percent Damaged % Good Condition

<u>Physical Contact</u>	<u>Vibration</u>	<u>Air</u>
Low/None	Low/None	Low/None

Planned Response Action O&M

Inspector



Benjamin S. Hood

State IN

Accreditation Number 19A001039

PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools

Building Name Jeffersonville High School

HA# 03

Type of Material Thermal Material

Quantity of Material 26 EA

Material Location

Mechanical rooms (Basement off of elevator)

Material Description

3" Fittings (Domestic hot and cold)

Comments

The remaining fittings are in the custodial room (19), boiler room (3), chiller room (5) and electrical room (3). The remaining fittings are not in poor condition.

Does Material Contain Asbestos? Yes

Is it Friable? No

Original Inspection Date 6/1/1988

Current Surveillance Date 4/22/2015

Current Assessment Rating NR Not Rated


Cause of Damage No Damage

Accessible Yes

Potential for Damage Med

Removed No

Planned Response Action O & M



Inspector

Benjamin S. Hood

State Indiana

Accreditation Number 19A001039

PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools

Building Name Jeffersonville High School

HA# 05

Type of Material Miscellaneous Material

Quantity of Material 40 SF

Material Location
Elevator

Material Description
Floor tile

Comments

This material was removed and replaced. It will be removed from the management plan.

Does Material Contain Asbestos? Yes

Is it Friable? No

Original Inspection Date 6/1/1988

Current Surveillance Date 4/22/2015

Current Assessment Rating NR Not Rated


Cause of Damage Physical Damage

Accessible Yes

Potential for Damage Low

Removed Yes

Planned Response Action O & M



Inspector

Benjamin S. Hood

State Indiana

Accreditation Number 19A001039

PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools

Building Name Jeffersonville High School

HA# 08

Type of Material Miscellaneous Material

Quantity of Material 3,000 SF

Material Location

First and second floors

Material Description

Floor tile mastic

Comments

Where exposed on the elevator, this material was not in poor condition. The mastic was sealed and left in place under new floor tile.

Does Material Contain Asbestos? Assumed

Is it Friable? No

Original Inspection Date 6/1/1988

Current Surveillance Date 4/22/2015

Current Assessment Rating NR Not Rated


Cause of Damage No Damage

Accessible No

Potential for Damage Low

Removed No

Planned Response Action O & M



Inspector

Benjamin S. Hood

State Indiana

Accreditation Number 19A001039

PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools

Building Name Jeffersonville High School

HA# B

Type of Material Miscellaneous Material

Quantity of Material Unquantified LF

Material Location
Throughout the building

Material Description
Cove base mastic

Comments
Mastic was not visible to inspect newer cove base has been placed over older cove base mastic.

Does Material Contain Asbestos? Assumed

Is it Friable? No

Original Inspection Date 5/31/1995

Current Surveillance Date 4/22/2015

Current Assessment Rating NR Not Rated


Cause of Damage No Damage

Accessible No

Potential for Damage Low

Removed No

Planned Response Action O & M



Inspector

Benjamin S. Hood

State Indiana

Accreditation Number 19A001039

PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools

Building Name Jeffersonville High School

HA# 03

Type of Material Thermal Material

Quantity of Material 26 EA

Material Location

Boiler room area (Basement off of elevator)

Material Description

3" Fittings (Domestic hot and cold)

Comments

The remaining fittings are in the custodial room (19), boiler room (4), and electrical room (3). The remaining fittings are not in poor condition.

Does Material Contain Asbestos? Yes

Is it Friable? No

Original Inspection Date 6/1/1988

Current Surveillance Date 10/22/2014

Current Assessment Rating NR Not Rated


Cause of Damage No Damage

Accessible Yes

Potential for Damage Med

Removed No

Planned Response Action O & M



Inspector

Benjamin S. Hood

State Indiana

Accreditation Number 19A001039


PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools
Building Name Jeffersonville High School
HA# 05
Type of Material Miscellaneous Material
Quantity of Material 40 SF
Material Location
Elevator
Material Description
Floor tile

Comments

There are broken edges, however, this material was not in poor condition overall.

Does Material Contain Asbestos? Yes
Is it Friable? No
Original Inspection Date 6/1/1988
Current Surveillance Date 10/22/2014
Current Assessment Rating NR Not Rated
Cause of Damage Physical Damage
Accessible Yes
Potential for Damage Low
Removed No
Planned Response Action O & M



Inspector

Benjamin S. Hood

State Indiana
Accreditation Number 19A001039

PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools

Building Name Jeffersonville High School

HA# 08

Type of Material Miscellaneous Material

Quantity of Material 3,000 SF

Material Location
First and second floors

Material Description
Floor tile mastic

Comments
Where exposed on the elevator, this material was not in poor condition. The mastic was sealed and left in place under new floor tile.

Does Material Contain Asbestos? Assumed

Is it Friable? No

Original Inspection Date 6/1/1988

Current Surveillance Date 10/22/2014

Current Assessment Rating NR Not Rated


Cause of Damage No Damage

Accessible No

Potential for Damage Low

Removed No

Planned Response Action O & M



Inspector

Benjamin S. Hood

State Indiana

Accreditation Number 19A001039

PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools

Building Name Jeffersonville High School

HA# B

Type of Material Miscellaneous Material

Quantity of Material Unquantified LF

Material Location
Throughout the building

Material Description
Cove base mastic

Comments
Mastic was not visible to inspect newer cove base has been placed over older cove base mastic.

Does Material Contain Asbestos? Assumed

Is it Friable? No

Original Inspection Date 5/31/1995

Current Surveillance Date 10/22/2014

Current Assessment Rating NR Not Rated


Cause of Damage No Damage

Accessible No

Potential for Damage Low

Removed No

Planned Response Action O & M



Inspector

Benjamin S. Hood

State Indiana

Accreditation Number 19A001039

PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools

Building Name Jeffersonville High School

HA# 03

Type of Material Thermal Material

Quantity of Material 26 EA

Material Location

Boiler room area (Basement off of elevator)

Material Description

3" Fittings (Domestic hot and cold)

Comments

The remaining fittings are in the custodial room (19), boiler room (4), and electrical room (3). The remaining fittings are not in poor condition.

Does Material Contain Asbestos? Yes

Is it Friable? No

Original Inspection Date 6/1/1988

Current Surveillance Date 4/21/2014

Current Assessment Rating NR Not Rated

Cause of Damage No Damage

Accessible Yes

Potential for Damage Med

Removed No

Planned Response Action O & M

Inspector



Jeffrey P. Rehtin

State Indiana

Accreditation Number 19A003594

PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools

Building Name Jeffersonville High School

HA# 05

Type of Material Miscellaneous Material

Quantity of Material 40 SF

Material Location
Elevator

Material Description
Floor tile

Comments

There are broken edges, however, this material was not in poor condition overall.

Does Material Contain Asbestos? Yes

Is it Friable? No

Original Inspection Date 6/1/1988

Current Surveillance Date 4/21/2014

Current Assessment Rating NR Not Rated

Cause of Damage Physical Damage

Accessible Yes

Potential for Damage Low

Removed No

Planned Response Action O & M

Inspector



Jeffrey P. Rehtin

State Indiana

Accreditation Number 19A003594

PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools

Building Name Jeffersonville High School

HA# 08

Type of Material Miscellaneous Material

Quantity of Material 3,000 SF

Material Location
First and second floors

Material Description
Floor tile mastic

Comments
Where exposed on the elevator, this material was not in poor condition. The mastic was sealed and left in place under new floor tile.

Does Material Contain Asbestos? Assumed
Is it Friable? No
Original Inspection Date 6/1/1988
Current Surveillance Date 4/21/2014
Current Assessment Rating NR Not Rated
Cause of Damage No Damage
Accessible No
Potential for Damage Low
Removed No
Planned Response Action O & M

Inspector



Jeffrey P. Rechten

State Indiana

Accreditation Number 19A003594

PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools

Building Name Jeffersonville High School

HA# B

Type of Material Miscellaneous Material

Quantity of Material Unquantified LF

Material Location
Throughout the building

Material Description
Cove base mastic

Comments
Mastic was not visible to inspect newer cove base has been placed over older cove base mastic.

Does Material Contain Asbestos? Assumed

Is it Friable? No

Original Inspection Date 5/31/1995

Current Surveillance Date 4/21/2014

Current Assessment Rating NR Not Rated

Cause of Damage No Damage

Accessible No

Potential for Damage Low

Removed No

Planned Response Action O & M

Inspector



Jeffrey P. Rechten

State Indiana

Accreditation Number 19A003594

PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools
Building Name Jeffersonville High School
HA# 03
Type of Material Thermal Material
Quantity of Material 26 EA

Material Location
Boiler room area (Basement off of elevator)

Material Description
3" Fittings (Domestic hot and cold)

Comments
The remaining fittings are in the custodial room (19), boiler room (4), and electrical room (3). The remaining fittings are not in poor condition.

Does Material Contain Asbestos? Yes
Is it Friable? No
Original Inspection Date 6/1/1988
Current Surveillance Date 10/24/2013
Current Assessment Rating NR Not Rated
Cause of Damage No Damage
Accessible Yes
Potential for Damage Med
Removed No
Planned Response Action O & M

Inspector



Jeffrey P. Rehtin

State Indiana
Accreditation Number 19A003594


PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools
Building Name Jeffersonville High School
HA# 05
Type of Material Miscellaneous Material
Quantity of Material 40 SF
Material Location
Elevator
Material Description
Floor tile

Comments

There are broken edges, however, this material was not in poor condition overall.

Does Material Contain Asbestos? Yes
Is it Friable? No
Original Inspection Date 6/1/1988
Current Surveillance Date 10/24/2013
Current Assessment Rating NR Not Rated
Cause of Damage Physical Damage
Accessible Yes
Potential for Damage Low
Removed No
Planned Response Action O & M



Inspector

Jeffrey P. Rechten

State Indiana
Accreditation Number 19A003594

PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools

Building Name Jeffersonville High School

HA# 08

Type of Material Miscellaneous Material

Quantity of Material 3,000 SF

Material Location

First and second floors

Material Description

Floor tile mastic

Comments

Where exposed on the elevator, this material was not in poor condition. The mastic was sealed and left in place under new floor tile.

Does Material Contain Asbestos? Assumed

Is it Friable? No

Original Inspection Date 6/1/1988

Current Surveillance Date 10/24/2013

Current Assessment Rating NR Not Rated

Cause of Damage No Damage


Accessible No

Potential for Damage Low

Removed No

Planned Response Action O & M

Inspector



Jeffrey P. Rehtin

State Indiana

Accreditation Number 19A003594

PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools

Building Name Jeffersonville High School

HA# B

Type of Material Miscellaneous Material

Quantity of Material Unquantified LF

Material Location

Throughout the building

Material Description

Cove base mastic

Comments

Mastic was not visible to inspect newer cove base has been placed over older cove base mastic.

Does Material Contain Asbestos? Assumed

Is it Friable? No

Original Inspection Date 5/31/1995

Current Surveillance Date 10/24/2013

Current Assessment Rating NR Not Rated

Cause of Damage No Damage


Accessible No

Potential for Damage Low

Removed No

Planned Response Action O & M

Inspector



Jeffrey P. Rechtin

State Indiana

Accreditation Number 19A003594

PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools
Building Name Jeffersonville High School
HA# 03
Type of Material Thermal Material
Quantity of Material 26 EA

Material Location
Boiler room area (Basement off of elevator)

Material Description
3" Fittings (Domestic hot and cold)

Comments

The remaining fittings are in the custodial room (19), boiler room (4), and electrical room (3). The remaining fittings are not in poor condition.

Does Material Contain Asbestos? Yes
Is it Friable? No
Original Inspection Date 6/1/1988
Current Surveillance Date 10/24/2012
Current Assessment Rating NR Not Rated
Cause of Damage No Damage
Accessible Yes
Potential for Damage Med
Removed No
Planned Response Action O & M

Inspector



Jeffrey P. Rehtin

State Indiana
Accreditation Number 19A003594

PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools
Building Name Jeffersonville High School
HA# 05
Type of Material Miscellaneous Material
Quantity of Material 40 SF
Material Location
Elevator
Material Description
Floor tile
Comments

There are broken edges, however, this material was not in poor condition overall.

Does Material Contain Asbestos? Yes
Is it Friable? No
Original Inspection Date 6/1/1988
Current Surveillance Date 10/24/2012
Current Assessment Rating NR Not Rated
Cause of Damage Physical Damage
Accessible Yes
Potential for Damage Low
Removed No
Planned Response Action O & M

Inspector



Jeffrey P. Rehtin

State Indiana
Accreditation Number 19A003594

PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools
Building Name Jeffersonville High School
HA# 08
Type of Material Miscellaneous Material
Quantity of Material 3,000 SF

Material Location
First and second floors

Material Description
Floor tile mastic

Comments

Where exposed on the elevator, this material was not in poor condition. The mastic was sealed and left in place under new floor tile.

Does Material Contain Asbestos? Assumed
Is it Friable? No
Original Inspection Date 6/1/1988
Current Surveillance Date 10/24/2012
Current Assessment Rating NR Not Rated
Cause of Damage No Damage
Accessible No
Potential for Damage Low
Removed No
Planned Response Action O & M

Inspector



Jeffrey P. Rechten

State Indiana
Accreditation Number 19A003594

PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools

Building Name Jeffersonville High School

HA# B

Type of Material Miscellaneous Material

Quantity of Material Unquantified LF

Material Location

Throughout the building

Material Description

Cove base mastic

Comments

Mastic was not visible to inspect newer cove base has been placed over older cove base mastic.

Does Material Contain Asbestos? Assumed

Is it Friable? No

Original Inspection Date 5/31/1995

Current Surveillance Date 10/24/2012

Current Assessment Rating NR Not Rated

Cause of Damage No Damage


Accessible No

Potential for Damage Low

Removed No

Planned Response Action O & M

Inspector



Jeffrey P. Rehtin

State Indiana

Accreditation Number 19A003594

PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools
Building Name Jeffersonville High School
HA# 03
Type of Material Thermal Material
Quantity of Material 26 EA

Material Location
Boiler room area (Basement off of elevator)


Material Description
3" Fittings (Domestic hot and cold)

Comments

The remaining fittings are in the custodial room (19), boiler room (4), and electrical room (3). The remaining fittings are not in poor condition.

Does Material Contain Asbestos? Yes
Is it Friable? No
Original Inspection Date 6/1/1988
Current Surveillance Date 6/25/2012
Current Assessment Rating NR Not Rated
Cause of Damage No Damage
Accessible Yes
Potential for Damage Med
Removed No
Planned Response Action O & M

Inspector


Jeffery P. Rehtin

State Indiana
Accreditation Number 19A003594

PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools
Building Name Jeffersonville High School
HA# 05
Type of Material Miscellaneous Material
Quantity of Material 40 SF
Material Location
Elevator
Material Description
Floor tile
Comments

There are broken edges, however, this material was not in poor condition overall.

Does Material Contain Asbestos? Yes
Is it Friable? No
Original Inspection Date 6/1/1988
Current Surveillance Date 6/25/2012
Current Assessment Rating NR Not Rated
Cause of Damage Physical Damage
Accessible Yes
Potential for Damage Low
Removed No
Planned Response Action O & M

Inspector



Jeffery P. Rehtin

State

Indiana

Accreditation Number

19A003594

PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools
Building Name Jeffersonville High School
HA# 08
Type of Material Miscellaneous Material
Quantity of Material 3,000 SF

Material Location
First and second floors

Material Description
Floor tile mastic

Comments

Where exposed on the elevator, this material was not in poor condition. The mastic was sealed and left in place under new floor tile.

Does Material Contain Asbestos? Assumed
Is it Friable? No
Original Inspection Date 6/1/1988
Current Surveillance Date 6/25/2012
Current Assessment Rating NR Not Rated
Cause of Damage No Damage
Accessible No
Potential for Damage Low
Removed No
Planned Response Action O & M

Inspector



Jeffery P. Rechten

State Indiana
Accreditation Number 19A003594

PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools

Building Name Jeffersonville High School

HA# B

Type of Material Miscellaneous Material

Quantity of Material Unquantified LF

Material Location
Throughout the building

Material Description
Cove base mastic

Comments

Mastic was not visible to inspect newer cove base has been placed over older cove base mastic.

Does Material Contain Asbestos? Assumed

Is it Friable? No

Original Inspection Date 5/31/1995

Current Surveillance Date 6/25/2012

Current Assessment Rating NR Not Rated

Cause of Damage No Damage


Accessible No

Potential for Damage Low

Removed No

Planned Response Action O & M

Inspector



Jeffery P. Rehtin

State Indiana

Accreditation Number 19A003594

PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools

Building Name Jeffersonville High School

HA# 03

Type of Material Thermal Material

Quantity of Material 26 EA

Material Location

Boiler room area (Basement off of elevator)

Material Description

3" Fittings (Domestic hot and cold)

Comments

The remaining fittings are in the custodial room (19), boiler room (4), and electrical room (3). The remaining fittings are not in poor condition.

Does Material Contain Asbestos? Yes

Is it Friable? No

Original Inspection Date 6/1/1988

Current Surveillance Date 12/15/2011

Current Assessment Rating NR Not Required

Cause of Damage No Damage

Accessible Yes

Potential for Damage Med

Removed No

Planned Response Action O & M

Inspector


Sandra Shadley

State Indiana

Accreditation Number 19A002323

PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools

Building Name Jeffersonville High School

HA# 05

Type of Material Miscellaneous Material

Quantity of Material 40 SF

Material Location
Elevator

Material Description
Floor tile

Comments

There are broken edges, however, this material was not in poor condition overall.

Does Material Contain Asbestos? Yes

Is it Friable? No

Original Inspection Date 6/1/1988

Current Surveillance Date 12/15/2011

Current Assessment Rating NR Not Required

Cause of Damage Physical Damage


Accessible Yes

Potential for Damage Low

Removed No

Planned Response Action O & M

Inspector


Sandra Shadley

State Indiana

Accreditation Number 19A002323

PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools

Building Name Jeffersonville High School

HA# 08

Type of Material Miscellaneous Material

Quantity of Material 3,000 SF

Material Location

First and second floors

Material Description

Floor tile mastic

Comments

Where exposed on the elevator, this material was not in poor condition. The mastic was sealed and left in place under new floor tile.

Does Material Contain Asbestos? Assumed

Is it Friable? No

Original Inspection Date 6/1/1988

Current Surveillance Date 12/15/2011

Current Assessment Rating NR Not Required

Cause of Damage No Damage


Accessible No

Potential for Damage Low

Removed No

Planned Response Action O & M

Inspector


Sandra Shadley

State Indiana

Accreditation Number 19A002323

PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools

Building Name Jeffersonville High School

HA# B

Type of Material Miscellaneous Material

Quantity of Material Unquantified LF

Material Location

Throughout the building

Material Description

Cove base mastic

Comments

Mastic was not visible to inspect newer cove base has been placed over older cove base mastic.

Does Material Contain Asbestos? Assumed

Is it Friable? No

Original Inspection Date 5/31/1995

Current Surveillance Date 12/15/2011

Current Assessment Rating NR Not Required

Cause of Damage No Damage

Accessible No

Potential for Damage Low

Removed No

Planned Response Action O & M

Inspector


Sandra Shadley

State Indiana

Accreditation Number 19A002323

PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools
Building Name Jeffersonville High School
HA# 03
Type of Material Thermal Material
Quantity of Material 24 EA

Material Location
Boiler room area (Basement off of elevator)

Material Description
3" Fittings

Comments

Most of the fittings were removed by a licensed contractor in 2008. Some were also removed during routine O & M repairs. The remaining fittings are not in poor condition.

Does Material Contain Asbestos? Yes
Is it Friable? No
Original Inspection Date 6/1/1988
Current Surveillance Date 6/27/2011
Current Assessment Rating NR Not Required
Cause of Damage No Damage
Accessible Yes
Potential for Damage Med
Removed No
Planned Response Action O & M

Inspector


Sandra Shadley

State Indiana
Accreditation Number 19A002323

PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools
Building Name Jeffersonville High School
HA# 05
Type of Material Miscellaneous Material
Quantity of Material 50 SF

Material Location
Elevator

Material Description
Floor tile

Comments

There are a few broken edges in the elevator, however, this material was not in poor condition overall. The first and second floor corridor tile were removed in a non-friable manner as part of the renovation in 2008.

Does Material Contain Asbestos? Yes
Is it Friable? No
Original Inspection Date 6/1/1988
Current Surveillance Date 6/27/2011
Current Assessment Rating NR Not Required
Cause of Damage Physical Damage
Accessible Yes
Potential for Damage Low
Removed No
Planned Response Action O & M

Inspector


Sandra Shadley

State Indiana
Accreditation Number 19A002323

PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools

Building Name Jeffersonville High School

HA# 08

Type of Material Miscellaneous Material

Quantity of Material 3,000 SF

Material Location

First and second floors

Material Description

Floor tile mastic

Comments

Where exposed on the elevator, this material was not in poor condition. The mastic was sealed and left in place under new floor tile.

Does Material Contain Asbestos? Assumed

Is it Friable? No

Original Inspection Date 6/1/1988

Current Surveillance Date 6/27/2011

Current Assessment Rating NR Not Required

Cause of Damage No Damage

Accessible No

Potential for Damage Low

Removed No

Planned Response Action O & M

Inspector


Sandra Shadley

State Indiana

Accreditation Number 19A002323

PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools
Building Name Jeffersonville High School
HA# B
Type of Material Miscellaneous Material
Quantity of Material Unquantified LF
Material Location
Throughout the building
Material Description
Cove base mastic
Comments
Mastic was not visible to inspect newer cove base has been placed over older cove base mastic..
Does Material Contain Asbestos? Assumed
Is it Friable? No
Original Inspection Date 5/31/1995
Current Surveillance Date 6/27/2011
Current Assessment Rating NR Not Required
Cause of Damage No Damage
Accessible No
Potential for Damage Low
Removed No
Planned Response Action O & M
Inspector

Sandra Shadley
State Indiana
Accreditation Number 19A002323

PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools
Building Name Jeffersonville High School
HA# 03
Type of Material Thermal Material
Quantity of Material 24 EA

Material Location
Boiler room area (Basement off of elevator)

Material Description
3" Fittings

Comments

Most of the fittings were removed by a licensed contractor in 2008. Some were also removed during routine O & M repairs. The remaining fittings are not in poor condition.

Does Material Contain Asbestos? Yes
Is it Friable? No
Original Inspection Date 6/1/1988
Current Surveillance Date 12/6/2010
Current Assessment Rating NR Not Required
Cause of Damage No Damage
Accessible Yes
Potential for Damage Med
Removed No
Planned Response Action O & M

Inspector



Paul W. Krick

State Indiana
Accreditation Number 197812124

PERIODIC SURVEILLANCE REPORT


LEA Name Greater Clark County Schools
Building Name Jeffersonville High School
HA# 05
Type of Material Miscellaneous Material
Quantity of Material 50 SF
Material Location
Elevator
Material Description
Floor tile

Comments

There are a few broken edges in the elevator, however, this material was not in poor condition overall. The first and second floor corridor tile were removed in a non-friable manner as part of the renovation in 2008.

Does Material Contain Asbestos? Yes
Is it Friable? No
Original Inspection Date 6/1/1988
Current Surveillance Date 12/6/2010
Current Assessment Rating NR Not Required
Cause of Damage Physical Damage
Accessible Yes
Potential for Damage Low
Removed No
Planned Response Action O & M

Inspector



Paul W. Krick

State Indiana
Accreditation Number 197812124

PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools

Building Name Jeffersonville High School

HA# 08

Type of Material Miscellaneous Material

Quantity of Material 3,000 SF

Material Location

First and second floors

Material Description

Floor tile mastic

Comments

Where exposed on the elevator, this material was not in poor condition. The mastic was sealed and left in place under new floor tile.

Does Material Contain Asbestos? Assumed

Is it Friable? No

Original Inspection Date 6/1/1988

Current Surveillance Date 12/6/2010

Current Assessment Rating NR Not Required

Cause of Damage No Damage


Accessible No

Potential for Damage Low

Removed No

Planned Response Action O & M

Inspector



Paul W. Krick

State Indiana

Accreditation Number 197812124

PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools
Building Name Jeffersonville High School
HA# B
Type of Material Miscellaneous Material
Quantity of Material Unquantified LF


Material Location
Throughout the building

Material Description
Cove base mastic

Comments
Mastic was visible to inspect throughout most of the hallways where the newer cove base has been removed exposing the old cove base mastic..

Does Material Contain Asbestos? Assumed
Is it Friable? No
Original Inspection Date 5/31/1995
Current Surveillance Date 12/6/2010
Current Assessment Rating NR Not Required
Cause of Damage No Damage
Accessible No
Potential for Damage Low
Removed No
Planned Response Action O & M

Inspector



Paul W. Krick

State Indiana
Accreditation Number 197812124

PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools
Building Name Jeffersonville High School
HA# 03
Type of Material Thermal Material
Quantity of Material 45 EA
Material Location
Boiler room area
Material Description
3" and 12" fittings
Comments
The fittings are not in poor condition.
Does Material Contain Asbestos? Yes
Is it Friable? No
Original Inspection Date 6/1/1988
Current Surveillance Date 12/3/2009
Current Assessment Rating NR Not Required
Cause of Damage No Damage
Accessible Yes
Potential for Damage Med
Removed No
Planned Response Action O & M

Inspector


George William Ogle

State

Indiana

Accreditation Number

191003027

PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools

Building Name Jeffersonville High School

HA# 05

Type of Material Miscellaneous Material

Quantity of Material 548 SF

Material Location
Second floor and elevator

Material Description

Floor tile

Comments

There are a few broken edges in the elevator, however, this material was not in poor condition overall. The first floor corridor tile was removed non-friable as part of the renovation.

Does Material Contain Asbestos? Yes

Is it Friable? No

Original Inspection Date 6/1/1988

Current Surveillance Date 12/3/2009

Current Assessment Rating NR Not Required

Cause of Damage Physical Damage

Accessible Yes

Potential for Damage Low

Removed No

Planned Response Action O & M

Inspector


George William Ogle

State Indiana

Accreditation Number 191003027

PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools

Building Name Jeffersonville High School

HA# 08

Type of Material Miscellaneous Material

Quantity of Material 3,000 SF

Material Location

First and second floors

Material Description

Floor tile mastic

Comments

Where exposed on the first floor and on the elevator, this material was not in poor condition.

Does Material Contain Asbestos? Assumed

Is it Friable? No

Original Inspection Date 6/1/1988

Current Surveillance Date 12/3/2009

Current Assessment Rating NR Not Required

Cause of Damage No Damage

Accessible No

Potential for Damage Low

Removed No

Planned Response Action O & M

Inspector


George William Ogle

State Indiana

Accreditation Number 191003027

PERIODIC SURVEILLANCE REPORT

IEA Name Greater Clark County Schools

Building Name Jeffersonville High School

HA# A

Type of Material Miscellaneous Material

Quantity of Material 60 LF

Material Location
Elevator corridor on second floor

Material Description
Cove base molding

Comments
All cove base is new except for the elevator corridor on the 2nd floor and in the elevator. This material was not in poor condition. The molding in the first floor corridor was removed non-friable as part of the renovation.

Does Material Contain Asbestos? Assumed
Is it Friable? No
Original Inspection Date 5/31/1995
Current Surveillance Date 12/3/2009
Current Assessment Rating NR Not Required
Cause of Damage No Damage
Accessible Yes
Potential for Damage Low
Removed No
Planned Response Action O & M

Inspector


George William Ogle

State Indiana

Accreditation Number 191003027

PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools

Building Name Jeffersonville High School

HA# B

Type of Material Miscellaneous Material

Quantity of Material Unquantified LF

Material Location

Throughout the building

Material Description

Cove base mastic

Comments

Mastic was visible to inspect throughout most of the hallways where the newer cove base has been removed exposing the old cove base mastic..

Does Material Contain Asbestos? Assumed

Is it Friable? No

Original Inspection Date 5/31/1995

Current Surveillance Date 12/3/2009

Current Assessment Rating NR Not Required

Cause of Damage No Damage

Accessible No

Potential for Damage Low

Removed No

Planned Response Action O & M

Inspector


George William Ogle

State Indiana

Accreditation Number 191003027

PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools
Building Name Jeffersonville High School
HA# 03
Type of Material Thermal Material
Quantity of Material 45 EA

Material Location
Boiler room area

Material Description
3" and 12" fittings

Comments

All of the boiler room fittings were removed by an accredited contractor. The remaining 8 large and 37 small fittings are not in poor condition and all are located in the area around the boiler room.

Does Material Contain Asbestos? Yes
Is it Friable? No
Original Inspection Date 6/1/1988
Current Surveillance Date 6/10/2009
Current Assessment Rating NR Not Required
Cause of Damage No Damage
Accessible Yes
Potential for Damage Med
Removed No
Planned Response Action O & M

Inspector


George William Ogle

State IN
Accreditation Number 191003027

PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools
Building Name Jeffersonville High School
HA# 05
Type of Material Miscellaneous Material
Quantity of Material 548 SF

Material Location
First and second floors

Material Description
Floor tile

Comments

There are a few broken edges in the elevator and part of a tile missing in the first floor elevator corridor. However, this material was not in poor condition overall.

Does Material Contain Asbestos? Yes
Is it Friable? No
Original Inspection Date 6/1/1988
Current Surveillance Date 6/10/2009
Current Assessment Rating NR Not Required
Cause of Damage Physical Damage
Accessible Yes
Potential for Damage Low
Removed No
Planned Response Action O & M

Inspector


George William Ogle

State IN
Accreditation Number 191003027

PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools

Building Name Jeffersonville High School

HA# 08

Type of Material Miscellaneous Material

Quantity of Material 3,000 SF

Material Location

First and second floors

Material Description

Floor tile mastic

Comments

Where exposed on the first floor and on the elevator, this material was not in poor condition.

Does Material Contain Asbestos? Assumed

Is it Friable? No

Original Inspection Date 6/1/1988

Current Surveillance Date 6/10/2009

Current Assessment Rating NR Not Required

Cause of Damage No Damage

Accessible No

Potential for Damage Low

Removed No

Planned Response Action O & M

Inspector


George William Ogle

State IN

Accreditation Number 191003027

PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools

Building Name Jeffersonville High School

HA# A

Type of Material Miscellaneous Material

Quantity of Material 60 LF

Material Location
Elevator corridors

Material Description
Cove base molding

Comments

All cove base is new except for the elevator corridors on the 1st and 2nd floor and in the elevator. This material was not in poor condition.

Does Material Contain Asbestos? Assumed

Is it Friable? No

Original Inspection Date 5/31/1995

Current Surveillance Date 6/10/2009

Current Assessment Rating NR Not Required

Cause of Damage No Damage

Accessible Yes

Potential for Damage Low

Removed No

Planned Response Action O & M

Inspector


George William Ogle

State IN

Accreditation Number 191003027

PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools
Building Name Jeffersonville High School
HA# B
Type of Material Miscellaneous Material
Quantity of Material Unquantified LF
Material Location
Throughout the building
Material Description
Cove base mastic
Comments
No mastic was visible to inspect.
Does Material Contain Asbestos? Assumed
Is it Friable? No
Original Inspection Date 5/31/1995
Current Surveillance Date 6/10/2009
Current Assessment Rating NR Not Required
Cause of Damage No Damage
Accessible No
Potential for Damage Low
Removed No
Planned Response Action O & M

Inspector


George William Ogle

State

IN

Accreditation Number

191003027

PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools
Building Name Jeffersonville High School
HA# 03
Type of Material Thermal Material
Quantity of Material 45 EA

Material Location
Boiler room area

Material Description
3" and 12" fittings

Comments

All of the boiler room fittings were removed by an accredited contractor. The remaining 8 large and 37 small fittings are not in poor condition and all are located in the area around the boiler room.

Does Material Contain Asbestos? Yes
Is it Friable? No
Original Inspection Date 6/1/1988
Current Surveillance Date 12/10/2008
Current Assessment Rating NR Not Required
Cause of Damage No Damage
Accessible Yes
Potential for Damage Med
Removed No
Planned Response Action O & M

Inspector


George William Ogle

State Indiana
Accreditation Number 191003027

PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools
Building Name Jeffersonville High School
HA# 05
Type of Material Miscellaneous Material
Quantity of Material 548 SF

Material Location
First and second floors

Material Description
Floor tile

Comments

There are a few broken edges in the elevator and part of a tile missing in the first floor elevator corridor. However, this material was not in poor condition overall.

Does Material Contain Asbestos? Yes
Is it Friable? No
Original Inspection Date 6/1/1988
Current Surveillance Date 12/10/2008
Current Assessment Rating NR Not Required
Cause of Damage Physical Damage
Accessible Yes
Potential for Damage Low
Removed No
Planned Response Action O & M

Inspector


George William Ogle

State Indiana
Accreditation Number 191003027

PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools
Building Name Jeffersonville High School
HA# 08
Type of Material Miscellaneous Material
Quantity of Material 3,000 SF

Material Location
First and second floors


Material Description
Floor tile mastic

Comments

Where exposed on the first floor and on the elevator, this material was not in poor condition.

Does Material Contain Asbestos?	Assumed
Is it Friable?	No
Original Inspection Date	6/1/1988
Current Surveillance Date	12/10/2008
Current Assessment Rating	NR Not Required
Cause of Damage	No Damage
Accessible	No
Potential for Damage	Low
Removed	No
Planned Response Action	O & M

Inspector


George William Ogle

State Indiana
Accreditation Number 191003027

PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools
Building Name Jeffersonville High School
HA# A
Type of Material Miscellaneous Material
Quantity of Material 60 LF

Material Location
Elevator corridors


Material Description
Cove base molding

Comments

All cove base is new except for the elevator corridors on the 1st and 2nd floor and in the elevator. This material was not in poor condition.

Does Material Contain Asbestos? Assumed
Is it Friable? No
Original Inspection Date 5/31/1995
Current Surveillance Date 12/10/2008
Current Assessment Rating NR Not Required
Cause of Damage No Damage
Accessible Yes
Potential for Damage Low
Removed No
Planned Response Action O & M

Inspector



George William Ogle

State Indiana
Accreditation Number 191003027

PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools
Building Name Jeffersonville High School
HA# B
Type of Material Miscellaneous Material
Quantity of Material Unquantified LF
Material Location
Throughout the building
Material Description
Cove base mastic
Comments
No mastic was visible to inspect.
Does Material Contain Asbestos? Assumed
Is it Friable? No
Original Inspection Date 5/31/1995
Current Surveillance Date 12/10/2008
Current Assessment Rating NR Not Required
Cause of Damage No Damage
Accessible No
Potential for Damage Low
Removed No
Planned Response Action O & M

Inspector


George William Ogle

State Indiana
Accreditation Number 191003027

PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools
Building Name Jeffersonville High School
HA# 01
Type of Material Miscellaneous Material
Quantity of Material 0 LF

Material Location
Boiler room


Material Description
Gaskets on boilers

Comments

These gaskets were removed by an accredited contractor. This homogeneous area will be removed from the Management Plan.

Does Material Contain Asbestos? Assumed
Is it Friable? No
Original Inspection Date 6/1/1988
Current Surveillance Date 6/30/2008
Current Assessment Rating NR Not Required
Cause of Damage No Damage
Accessible No
Potential for Damage Low
Removed Yes
Planned Response Action Remove

Inspector


George William Ogle

State Indiana
Accreditation Number 191003027

PERIODIC SURVEILLANCE REPORT

.EA Name Greater Clark County Schools
Building Name Jeffersonville High School
HA# 02
Type of Material Thermal Material
Quantity of Material 0 SF

Material Location
Boiler room


Material Description
Boiler insulation on 2 boilers plus breech

Comments

This material was removed by an accredited contractor. This homogeneous area will be removed from the Management Plan.

Does Material Contain Asbestos? Yes
Is it Friable? No
Original Inspection Date 6/1/1988
Current Surveillance Date 6/30/2008
Current Assessment Rating NR Not Required
Cause of Damage No Damage
Accessible No
Potential for Damage XX
Removed Yes
Planned Response Action Remove

Inspector


George William Ogle

State Indiana
Accreditation Number 191003027

PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools
Building Name Jeffersonville High School
HA# 03
Type of Material Thermal Material
Quantity of Material 45 EA

Material Location
Boiler room

Material Description
3" and 12" 8 total fittings

Comments

Most of these fittings were removed by an accredited contractor. The remaining 8 large and 37 small fittings are not in poor condition.

Does Material Contain Asbestos? Yes
Is it Friable? No
Original Inspection Date 6/1/1988
Current Surveillance Date 6/30/2008
Current Assessment Rating NR Not Required
Cause of Damage No Damage
Accessible Yes
Potential for Damage Med
Removed No
Planned Response Action O & M

Inspector


George William Ogle

State Indiana
Accreditation Number 191003027

PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools
Building Name Jeffersonville High School
HA# 05
Type of Material Miscellaneous Material
Quantity of Material 548 SF

Material Location
First and second floors

Material Description
Floor tile

Comments

There are a few broken edges in the elevator and part of a tile missing in the first floor elevator corridor. However, this material was not in poor condition overall.

Does Material Contain Asbestos? Yes
Is it Friable? No
Original Inspection Date 6/1/1988
Current Surveillance Date 6/30/2008
Current Assessment Rating NR Not Required
Cause of Damage Physical Damage
Accessible Yes
Potential for Damage Low
Removed No
Planned Response Action O & M

Inspector


George William Ogle

State Indiana
Accreditation Number 191003027

PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools
Building Name Jeffersonville High School
HA# 08
Type of Material Miscellaneous Material
Quantity of Material 3,000 SF

Material Location
First and second floors

Material Description
Floor tile mastic

Comments

Where exposed on the first floor and on the elevator, this material was not in poor condition.

Does Material Contain Asbestos?	Assumed
Is it Friable?	No
Original Inspection Date	6/1/1988
Current Surveillance Date	6/30/2008
Current Assessment Rating	NR Not Required
Cause of Damage	No Damage
Accessible	No
Potential for Damage	Low
Removed	No
Planned Response Action	O & M

Inspector


George William Ogle

State Indiana
Accreditation Number 191003027

PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools
Building Name Jeffersonville High School
HA# A
Type of Material Miscellaneous Material
Quantity of Material 60 LF

Material Location
Elevator corridors

Material Description
Cove base molding

Comments

All cove base is new except for the elevator corridors on the 1st and 2nd floor and in the elevator. This material was not in poor condition.

Does Material Contain Asbestos? Assumed
Is it Friable? No
Original Inspection Date 5/31/1995
Current Surveillance Date 6/30/2008
Current Assessment Rating NR Not Required
Cause of Damage No Damage
Accessible Yes
Potential for Damage Low
Removed No
Planned Response Action O & M

Inspector



George William Ogle

State Indiana
Accreditation Number 191003027

PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools
Building Name Jeffersonville High School
HA# B
Type of Material Miscellaneous Material
Quantity of Material Unquantified LF
Material Location
Throughout the building
Material Description
Cove base mastic
Comments
No mastic was visible to inspect.
Does Material Contain Asbestos? Assumed
Is it Friable? No
Original Inspection Date 5/31/1995
Current Surveillance Date 6/30/2008
Current Assessment Rating NR Not Required
Cause of Damage No Damage
Accessible No
Potential for Damage Low
Removed No
Planned Response Action O & M

Inspector


George William Ogle

State Indiana
Accreditation Number 191003027

PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools
Building Name Jeffersonville High School
HA# 01
Type of Material Miscellaneous Material
Quantity of Material 52 LF
Material Location

Boiler room

Material Description


Gaskets on boilers

Comments

The visible edges of this material were not in poor condition. Boiler doors were closed except on the smallest boiler which has a newer fiberglass gasket on the front.

Does Material Contain Asbestos? Assumed
Is it Friable? No
Original Inspection Date 6/1/1988
Current Surveillance Date 12/6/2007
Current Assessment Rating NR Not Required
Cause of Damage No Damage
Accessible No
Potential for Damage Low
Removed No
Planned Response Action O & M

Inspector


George William Ogle

State

Indiana

Accreditation Number

191003027

PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools

Building Name Jeffersonville High School

HA# 02

Type of Material Thermal Material

Quantity of Material 1,800 SF

Material Location
Boiler room

Material Description
Boiler insulation on 2 boilers plus breech

Comments
This material was not in poor condition, although there area a few spots of deterioration on the sides.

Does Material Contain Asbestos? Yes

Is it Friable? No

Original Inspection Date 6/1/1988

Current Surveillance Date 12/6/2007

Current Assessment Rating NR Not Required

Cause of Damage No Damage

Accessible Yes

Potential for Damage Med

Removed No

Planned Response Action O & M

Inspector


George William Ogle

State Indiana

Accreditation Number 191003027

PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools
Building Name Jeffersonville High School
HA# 03
Type of Material Thermal Material
Quantity of Material 222 LF
Material Location
Boiler room

Material Description
3" and 12" fittings

Comments

This material showed minor delamination on a few fittings, but was not in poor condition overall.

Does Material Contain Asbestos?	Yes	
Is it Friable?	No	
Original Inspection Date	6/1/1988	
Current Surveillance Date	12/6/2007	
Current Assessment Rating	NR	Not Required
Cause of Damage	No Damage	
Accessible	Yes	
Potential for Damage	Med	
Removed	No	
Planned Response Action	O & M	

Inspector


George William Ogle

State Indiana
Accreditation Number 191003027

PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools
Building Name Jeffersonville High School
HA# 05
Type of Material Miscellaneous Material
Quantity of Material 548 SF

Material Location
First and second floors

Material Description
Floor tile

Comments

There are a few broken edges in the elevator and part of a tile missing in the first floor elevator corridor. However, this material was not in poor condition overall.

Does Material Contain Asbestos? Yes
Is it Friable? No
Original Inspection Date 6/1/1988
Current Surveillance Date 12/6/2007
Current Assessment Rating NR Not Required
Cause of Damage Physical Damage
Accessible Yes
Potential for Damage Low
Removed No
Planned Response Action O & M

Inspector


George William Ogle

State Indiana
Accreditation Number 191003027

PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools
Building Name Jeffersonville High School
HA# 08
Type of Material Miscellaneous Material
Quantity of Material 3,000 SF
Material Location

First and second floors

Material Description


Floor tile mastic

Comments

Where exposed on the first floor and on the elevator, this material was not in poor condition.

Does Material Contain Asbestos?	Assumed	
Is it Friable?	No	
Original Inspection Date	6/1/1988	
Current Surveillance Date	12/6/2007	
Current Assessment Rating	NR	Not Required
Cause of Damage	No Damage	
Accessible	No	
Potential for Damage	Low	
Removed	No	
Planned Response Action	O & M	

Inspector


George William Ogle

State

Indiana

Accreditation Number

191003027

PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools

Building Name Jeffersonville High School

HA# A

Type of Material Miscellaneous Material

Quantity of Material 60 LF

Material Location
Elevator corridors

Material Description
Cove base molding

Comments

All cove base is new except for the elevator corridors on the 1st and 2nd floor and in the elevator. This material was not in poor condition.

Does Material Contain Asbestos? Assumed

Is it Friable? No

Original Inspection Date 5/31/1995

Current Surveillance Date 12/6/2007

Current Assessment Rating NR Not Required

Cause of Damage No Damage

Accessible Yes

Potential for Damage Low

Removed No

Planned Response Action O & M

Inspector


George William Ogle

State Indiana

Accreditation Number 191003027

PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools
Building Name Jeffersonville High School
HA# B
Type of Material Miscellaneous Material
Quantity of Material Unquantified LF
Material Location
Throughout the building
Material Description
Cove base mastic
Comments
No mastic was visible to inspect.
Does Material Contain Asbestos? Assumed
Is it Friable? No
Original Inspection Date 5/31/1995
Current Surveillance Date 12/6/2007
Current Assessment Rating NR Not Required
Cause of Damage No Damage
Accessible No
Potential for Damage Low
Removed No
Planned Response Action O & M

Inspector


George William Ogle

State Indiana
Accreditation Number 191003027

PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools
Building Name Jeffersonville High School
HA# 01
Type of Material Miscellaneous Material
Quantity of Material 52 LF
Material Location
Boiler room
Material Description

Gaskets on boilers

Comments

The visible edges of this material were not in poor condition. Boiler doors were closed except on the smallest boiler which has a newer fiberglass gasket on the front.

Does Material Contain Asbestos? Assumed
Is it Friable? No
Original Inspection Date 6/1/1988
Current Surveillance Date 12/18/2006
Current Assessment Rating NR Not Required
Cause of Damage No Damage
Accessible No
Potential for Damage Low
Removed No
Planned Response Action O & M

Inspector


George William Ogle

State

Indiana

Accreditation Number

191003027

PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools
Building Name Jeffersonville High School
HA# 02
Type of Material Thermal Material
Quantity of Material 1,800 SF
Material Location
Boiler room

Material Description
Boiler insulation on 2 boilers

Comments

This material was not in poor condition, although there area a few spots of deterioration on the sides.

Does Material Contain Asbestos? Yes
Is it Friable? No
Original Inspection Date 6/1/1988
Current Surveillance Date 12/18/2006
Current Assessment Rating NR Not Required
Cause of Damage No Damage
Accessible Yes
Potential for Damage Med
Removed No
Planned Response Action O & M

Inspector


George William Ogle

State Indiana
Accreditation Number 191003027

PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools

Building Name Jeffersonville High School

HA# 03

Type of Material Thermal Material

Quantity of Material 222 LF

Material Location
Boiler room

Material Description
3" and 12" fittings

Comments

This material showed minor delamination on a few fittings, but was not in poor condition overall.

Does Material Contain Asbestos? Yes

Is it Friable? No

Original Inspection Date 6/1/1988

Current Surveillance Date 12/18/2006

Current Assessment Rating NR Not Required

Cause of Damage No Damage

Accessible Yes

Potential for Damage Med

Removed No

Planned Response Action O & M

Inspector


George William Ogle

State Indiana

Accreditation Number 191003027

PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools
Building Name Jeffersonville High School
HA# 05
Type of Material Miscellaneous Material
Quantity of Material 548 SF

Material Location
First and second floors

Material Description
Floor tile

Comments

There are a few broken edges in the elevator and part of a tile missing in the first floor elevator corridor. However, this material was not in poor condition overall.

Does Material Contain Asbestos? Yes
Is it Friable? No
Original Inspection Date 6/1/1988
Current Surveillance Date 12/18/2006
Current Assessment Rating NR Not Required
Cause of Damage Physical Damage
Accessible Yes
Potential for Damage Low
Removed No
Planned Response Action O & M

Inspector


George William Ogle

State Indiana
Accreditation Number 191003027

PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools

Building Name Jeffersonville High School

HA# 08

Type of Material Miscellaneous Material

Quantity of Material 3,000 SF

Material Location

First and second floors

Material Description

Floor tile mastic

Comments

Where exposed on the first floor and on the elevator, this material was not in poor condition.

Does Material Contain Asbestos? Assumed

Is it Friable? No

Original Inspection Date 6/1/1988

Current Surveillance Date 12/18/2006

Current Assessment Rating NR Not Required

Cause of Damage No Damage

Accessible No

Potential for Damage Low

Removed No

Planned Response Action O & M

Inspector


George William Ogle

State Indiana

Accreditation Number 191003027

PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools
Building Name Jeffersonville High School
HA# A
Type of Material Miscellaneous Material
Quantity of Material 60 LF

Material Location
Elevator corridors

Material Description
Cove base molding

Comments

All cove base is new except for the elevator corridors on the 1st and 2nd floor and in the elevator. This material was not in poor condition.

Does Material Contain Asbestos? Assumed
Is it Friable? No
Original Inspection Date 5/31/1995
Current Surveillance Date 12/18/2006
Current Assessment Rating NR Not Required
Cause of Damage No Damage
Accessible Yes
Potential for Damage Low
Removed No
Planned Response Action O & M

Inspector


George William Ogle

State Indiana
Accreditation Number 191003027

PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools
Building Name Jeffersonville High School
HA# B
Type of Material Miscellaneous Material
Quantity of Material Unquantified LF
Material Location
Throughout the building
Material Description
Cove base mastic
Comments
No mastic was visible to inspect.
Does Material Contain Asbestos? Assumed
Is it Friable? No
Original Inspection Date 5/31/1995
Current Surveillance Date 12/18/2006
Current Assessment Rating NR Not Required
Cause of Damage No Damage
Accessible No
Potential for Damage Low
Removed No
Planned Response Action O & M

Inspector


George William Ogle

State Indiana
Accreditation Number 191003027

PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools
Building Name Jeffersonville High School
HA# 01
Type of Material Miscellaneous Material
Quantity of Material 52 LF

Material Location
Boiler room

Material Description
Gaskets on boilers

Comments

The visible edges of this material were not in poor condition. Boiler doors were closed.

Does Material Contain Asbestos? Assumed
Is it Friable? No
Original Inspection Date 6/1/1988
Current Surveillance Date 6/28/2006
Current Assessment Rating NR Not Required
Cause of Damage No Damage
Accessible No
Potential for Damage Low
Removed No
Planned Response Action O & M

Inspector



Christopher Ames

State Indiana
Accreditation Number 198612124

PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools
Building Name Jeffersonville High School
HA# 02
Type of Material Thermal Material
Quantity of Material 1,800 SF

Material Location
Boiler room

Material Description
Boiler insulation on 2 boilers

Comments

This material was not in poor condition, although there area a few spots of deterioration on the sides.

Does Material Contain Asbestos? Yes
Is it Friable? No
Original Inspection Date 6/1/1988
Current Surveillance Date 6/28/2006
Current Assessment Rating NR Not Required
Cause of Damage No Damage
Accessible Yes
Potential for Damage Med
Removed No
Planned Response Action O & M

Inspector



Christopher Ames

State Indiana
Accreditation Number 198612124

PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools
Building Name Jeffersonville High School
HA# 03
Type of Material Thermal Material
Quantity of Material 222 LF

Material Location
Boiler room

Material Description
3" and 12" fittings

Comments

This material showed minor delamination on a few fittings, but was not in poor condition overall.

Does Material Contain Asbestos? Yes
Is it Friable? No
Original Inspection Date 6/1/1988
Current Surveillance Date 6/28/2006
Current Assessment Rating NR Not Required
Cause of Damage No Damage
Accessible Yes
Potential for Damage Med
Removed No
Planned Response Action O & M

Inspector



Christopher Ames

State Indiana
Accreditation Number 198612124

PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools
Building Name Jeffersonville High School
HA# 05
Type of Material Miscellaneous Material
Quantity of Material 548 SF

Material Location
First and second floors


Material Description
Floor tile

Comments

There are a few broken edges in the elevator and part of a tile missing in the first floor elevator corridor. However, this material was not in poor condition overall.

Does Material Contain Asbestos? Yes
Is it Friable? No
Original Inspection Date 6/1/1988
Current Surveillance Date 6/28/2006
Current Assessment Rating NR Not Required
Cause of Damage Physical Damage
Accessible Yes
Potential for Damage Low
Removed No
Planned Response Action O & M

Inspector



Christopher Ames

State Indiana
Accreditation Number 198612124

PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools
Building Name Jeffersonville High School
HA# 08
Type of Material Miscellaneous Material
Quantity of Material 3,000 SF

Material Location
First and second floors

Material Description
Floor tile mastic

Comments

Where exposed on the first floor and on the elevator, this material was not in poor condition.

Does Material Contain Asbestos? Assumed
Is it Friable? No
Original Inspection Date 6/1/1988
Current Surveillance Date 6/28/2006
Current Assessment Rating NR Not Required
Cause of Damage No Damage
Accessible No
Potential for Damage Low
Removed No
Planned Response Action O & M

Inspector



Christopher Ames

State Indiana
Accreditation Number 198612124

PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools
Building Name Jeffersonville High School
HA# A
Type of Material Miscellaneous Material
Quantity of Material 60 LF
Material Location

Elevator corridors

Material Description

Cove base molding

Comments

All cove base is new except for the elevator corridors on the 1st and 2nd floor and in the elevator. This material was not in poor condition.

Does Material Contain Asbestos? Assumed
Is it Friable? No
Original Inspection Date 5/31/1995
Current Surveillance Date 6/28/2006
Current Assessment Rating NR Not Required
Cause of Damage No Damage
Accessible Yes
Potential for Damage Low
Removed No
Planned Response Action O & M

Inspector



Christopher Ames

State Indiana
Accreditation Number 198612124

PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools
Building Name Jeffersonville High School
HA# B
Type of Material Miscellaneous Material
Quantity of Material Unquantified LF
Material Location
Throughout the building
Material Description
Cove base mastic
Comments
No mastic was visible to inspect.
Does Material Contain Asbestos? Assumed
Is it Friable? No
Original Inspection Date 5/31/1995
Current Surveillance Date 6/28/2006
Current Assessment Rating NR Not Required
Cause of Damage No Damage
Accessible No
Potential for Damage Low
Removed No
Planned Response Action O & M

Inspector _____

Christopher Ames

State Indiana
Accreditation Number 198612124

PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools
Building Name Jeffersonville High School
HA# 01
Type of Material Miscellaneous Material
Quantity of Material 52 LF

Material Location
Boiler room


Material Description
Gaskets on boilers

Comments

The visible edges of this material were not in poor condition. Boiler doors were closed.

Does Material Contain Asbestos? Assumed
Is it Friable? No
Original Inspection Date 6/1/1988
Current Surveillance Date 1/24/2006
Current Assessment Rating NR Not Required
Cause of Damage No Damage
Accessible No
Potential for Damage Low
Removed No
Planned Response Action O & M

Inspector


George William Ogle

State Indiana
Accreditation Number 191523030

PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools

Building Name Jeffersonville High School

HA# 02

Type of Material Thermal Material

Quantity of Material 1,800 SF

Material Location

Boiler room

Material Description

Boiler insulation on 2 boilers

Comments

This material was not in poor condition, although there area a few spots of deterioration on the sides.

Does Material Contain Asbestos? Yes

Is it Friable? No

Original Inspection Date 6/1/1988

Current Surveillance Date 1/24/2006

Current Assessment Rating NR Not Required

Cause of Damage No Damage

Accessible Yes

Potential for Damage Med

Removed No

Planned Response Action O & M

Inspector


George William Ogle

State Indiana

Accreditation Number 191523030

PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools
Building Name Jeffersonville High School
HA# 03
Type of Material Thermal Material
Quantity of Material 222 LF

Material Location
Boiler room

Material Description
3" and 12" fittings

Comments

This material showed minor delamination on a few fittings, but was not in poor condition overall.

Does Material Contain Asbestos? Yes
Is it Friable? No
Original Inspection Date 6/1/1988
Current Surveillance Date 1/24/2006
Current Assessment Rating NR Not Required
Cause of Damage No Damage
Accessible Yes
Potential for Damage Med
Removed No
Planned Response Action O & M

Inspector


George William Ogle

State Indiana
Accreditation Number 191523030

PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools

Building Name Jeffersonville High School

HA# 05

Type of Material Miscellaneous Material

Quantity of Material 548 SF

Material Location

First and second floors

Material Description

Floor tile

Comments

There are a few broken edges in the elevator and part of a tile missing in the first floor elevator corridor. However, this material was not in poor condition overall.

Does Material Contain Asbestos? Yes

Is it Friable? No

Original Inspection Date 6/1/1988

Current Surveillance Date 1/24/2006

Current Assessment Rating NR Not Required

Cause of Damage Physical Damage

Accessible Yes

Potential for Damage Low

Removed No

Planned Response Action O & M

Inspector


George William Ogle

State Indiana

Accreditation Number 191523030

PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools

Building Name Jeffersonville High School

HA# 08

Type of Material Miscellaneous Material

Quantity of Material 3,000 SF

Material Location

First and second floors

Material Description

Floor tile mastic

Comments

Where exposed on the first floor and on the elevator, this material was not in poor condition.

Does Material Contain Asbestos? Assumed

Is it Friable? No

Original Inspection Date 6/1/1988

Current Surveillance Date 1/24/2006

Current Assessment Rating NR Not Required

Cause of Damage No Damage


Accessible No

Potential for Damage Low

Removed No

Planned Response Action O & M

Inspector


George William Ogle

State Indiana

Accreditation Number 191523030

PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools

Building Name Jeffersonville High School

HA# A

Type of Material Miscellaneous Material

Quantity of Material 60 LF

Material Location

Elevator corridors

Material Description

Cove base molding

Comments

All cove base is new except for the elevator corridors on the 1st and 2nd floor and in the elevator. This material was not in poor condition.

Does Material Contain Asbestos? Assumed

Is it Friable? No

Original Inspection Date 5/31/1995

Current Surveillance Date 1/24/2006

Current Assessment Rating NR Not Required

Cause of Damage No Damage

Accessible Yes

Potential for Damage Low

Removed No

Planned Response Action O & M

Inspector


George William Ogle

State Indiana

Accreditation Number 191523030

PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools
Building Name Jeffersonville High School
HA# B
Type of Material Miscellaneous Material
Quantity of Material Unquantified LF
Material Location
Throughout the building
Material Description
Cove base mastic
Comments
No mastic was visible to inspect.
Does Material Contain Asbestos? Assumed
Is it Friable? No
Original Inspection Date 5/31/1995
Current Surveillance Date 1/24/2006
Current Assessment Rating NR Not Required
Cause of Damage No Damage
Accessible No
Potential for Damage Low
Removed No
Planned Response Action O & M

Inspector


George William Ogle

State

Indiana

Accreditation Number

191523030

PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools

Building Name Jeffersonville High School

HA# 01

Type of Material Miscellaneous Material

Quantity of Material 52 LF

Material Location
Boiler room

Material Description
Gaskets on boilers

Comments

The visible edges of this material were not in poor condition. Boiler doors were closed.

Does Material Contain Asbestos? Assumed

Is it Friable? No

Original Inspection Date 6/1/1988

Current Surveillance Date 7/18/2005

Current Assessment Rating NR Not Required

Cause of Damage No Damage


Accessible No

Potential for Damage Low

Removed No

Planned Response Action O & M

Inspector


George William Ogle

State Indiana

Accreditation Number 191523030

PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools
Building Name Jeffersonville High School
HA# 02
Type of Material Thermal Material
Quantity of Material 1,800 SF


Material Location
Boiler room

Material Description
Boiler insulation on 2 boilers

Comments
This material was not in poor condition, although there area a few spots of deterioration on the sides.

Does Material Contain Asbestos? Yes
Is it Friable? No
Original Inspection Date 6/1/1988
Current Surveillance Date 7/18/2005
Current Assessment Rating NR Not Required
Cause of Damage No Damage
Accessible Yes
Potential for Damage Med
Removed No
Planned Response Action O & M

Inspector


George William Ogle

State Indiana
Accreditation Number 191523030

PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools
Building Name Jeffersonville High School
HA# 03
Type of Material Thermal Material
Quantity of Material 222 LF


Material Location
Boiler room

Material Description
3" and 12" fittings

Comments
This material showed minor delamination on a few fittings, but was not in poor condition overall.

Does Material Contain Asbestos? Yes
Is it Friable? No
Original Inspection Date 6/1/1988
Current Surveillance Date 7/18/2005
Current Assessment Rating NR Not Required
Cause of Damage No Damage
Accessible Yes
Potential for Damage Med
Removed No
Planned Response Action O & M

Inspector


George William Ogle

State Indiana
Accreditation Number 191523030

PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools
Building Name Jeffersonville High School
HA# 05
Type of Material Miscellaneous Material
Quantity of Material 548 SF

Material Location
First and second floors


Material Description
Floor tile

Comments

There are a few broken edges in the elevator and part of a tile missing in the first floor elevator corridor. However, this material was not in poor condition overall.

Does Material Contain Asbestos? Yes
Is it Friable? No
Original Inspection Date 6/1/1988
Current Surveillance Date 7/18/2005
Current Assessment Rating NR Not Required
Cause of Damage Physical Damage
Accessible Yes
Potential for Damage Low
Removed No
Planned Response Action O & M

Inspector


George William Ogle

State Indiana
Accreditation Number 191523030

PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools

Building Name Jeffersonville High School

HA# 08

Type of Material Miscellaneous Material

Quantity of Material 3,000 SF

Material Location
First and second floors

Material Description
Floor tile mastic

Comments
Where exposed on the first floor and on the elevator, this material was not in poor condition.

Does Material Contain Asbestos? Assumed

Is it Friable? No

Original Inspection Date 6/1/1988

Current Surveillance Date 7/18/2005

Current Assessment Rating NR Not Required

Cause of Damage No Damage

Accessible No

Potential for Damage Low

Removed No

Planned Response Action O & M

Inspector


George William Ogle

State Indiana

Accreditation Number 191523030

PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools

Building Name Jeffersonville High School

HA# A

Type of Material Miscellaneous Material

Quantity of Material 60 LF

Material Location
Elevator corridors

Material Description
Cove base molding

Comments
All cove base is new except for the elevator corridors on the 1st and 2nd floor and in the elevator. This material was not in poor condition.

Does Material Contain Asbestos? Assumed

Is it Friable? No

Original Inspection Date 5/31/1995

Current Surveillance Date 7/18/2005

Current Assessment Rating NR Not Required

Cause of Damage No Damage


Accessible Yes

Potential for Damage Low

Removed No

Planned Response Action O & M

Inspector


George William Ogilvie

State Indiana

Accreditation Number 191523030

PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools
Building Name Jeffersonville High School
HA# B
Type of Material Miscellaneous Material
Quantity of Material Unquantified LF
Material Location
Throughout the building
Material Description
Cove base mastic
Comments
No mastic was visible to inspect.
Does Material Contain Asbestos? Assumed
Is it Friable? No
Original Inspection Date 5/31/1995
Current Surveillance Date 7/18/2005
Current Assessment Rating NR Not Required
Cause of Damage No Damage
Accessible No
Potential for Damage Low
Removed No
Planned Response Action O & M

Inspector


George William Ogle

State

Indiana

Accreditation Number

191523030

PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools

Building Name Jeffersonville High School

HA# 01

Type of Material Miscellaneous Material

Quantity of Material 52 LF

Material Location
Boiler room

Material Description
Gaskets on boilers

Comments

The visible edges of this material were not in poor condition. Boiler doors were closed.

Does Material Contain Asbestos? Assumed

Is it Friable? No

Original Inspection Date 6/1/1988

Current Surveillance Date 12/8/2004

Current Assessment Rating NR Not Required

Cause of Damage No Damage

Accessible No

Potential for Damage Low

Removed No

Planned Response Action O & M

Inspector



Christiaan Sparks

State Indiana

Accreditation Number 190804103

PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools

Building Name Jeffersonville High School

HA# 02

Type of Material Thermal Material

Quantity of Material 1,800 SF

Material Location
Boiler room

Material Description
Boiler insulation on 2 boilers

Comments
This material was not in poor condition.

Does Material Contain Asbestos? Yes

Is it Friable? No

Original Inspection Date 6/1/1988

Current Surveillance Date 12/8/2004

Current Assessment Rating NR Not Required

Cause of Damage No Damage


Accessible Yes

Potential for Damage Med

Removed No

Planned Response Action O & M

Inspector



Christiaan Sparks

State Indiana

Accreditation Number 190804103

PERIODIC SURVEILLANCE REPORT


LEA Name Greater Clark County Schools
Building Name Jeffersonville High School
HA# 03
Type of Material Thermal Material
Quantity of Material 222 LF
Material Location
Boiler room
Material Description
3" and 12" fittings

Comments

This material showed minor delamination on a few fittings, but was not in poor condition overall.

Does Material Contain Asbestos? Yes
Is it Friable? No
Original Inspection Date 6/1/1988
Current Surveillance Date 12/8/2004
Current Assessment Rating NR Not Required
Cause of Damage No Damage
Accessible Yes
Potential for Damage Med
Removed No
Planned Response Action O & M

Inspector



Christian Sparks

State Indiana
Accreditation Number 190804103

PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools
Building Name Jeffersonville High School
HA# 05
Type of Material Miscellaneous Material
Quantity of Material 548 SF

Material Location
First and second floors


Material Description
Floor tile

Comments

There are a few broken edges in the elevator and part of a tile missing in the first floor elevator corridor. However, this material was not in poor condition overall.

Does Material Contain Asbestos? Yes
Is it Friable? No
Original Inspection Date 6/1/1988
Current Surveillance Date 12/8/2004
Current Assessment Rating NR Not Required
Cause of Damage Physical Damage
Accessible Yes
Potential for Damage Low
Removed No
Planned Response Action O & M

Inspector



Christiaan Sparks

State Indiana
Accreditation Number 190804103

PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools
Building Name Jeffersonville High School
HA# 08
Type of Material Miscellaneous Material
Quantity of Material 3,000 SF


Material Location
First and second floors

Material Description
Floor tile mastic

Comments
Where exposed, this material was not in poor condition.

Does Material Contain Asbestos? Assumed
Is it Friable? No
Original Inspection Date 6/1/1988
Current Surveillance Date 12/8/2004
Current Assessment Rating NR Not Required
Cause of Damage No Damage
Accessible No
Potential for Damage Low
Removed No
Planned Response Action O & M

Inspector



Christiaan Sparks

State Indiana
Accreditation Number 190804103

PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools
Building Name Jeffersonville High School
HA# A
Type of Material Miscellaneous Material
Quantity of Material 60 LF

Material Location
Elevator corridors


Material Description
Cove base molding

Comments

All cove base is new except for the elevator corridors on the 1st and 2nd floor. This material was not in poor condition.

Does Material Contain Asbestos? Assumed
Is it Friable? No
Original Inspection Date 5/31/1995
Current Surveillance Date 12/8/2004
Current Assessment Rating NR Not Required
Cause of Damage No Damage
Accessible Yes
Potential for Damage Low
Removed No
Planned Response Action O & M

Inspector



Christian Sparks

State Indiana
Accreditation Number 190804103

PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools
Building Name Jeffersonville High School
HA# B
Type of Material Miscellaneous Material
Quantity of Material 60 LF

Material Location
Throughout the building

Material Description
Cove base mastic

Comments

Where visible under the old cove base, this material was not in poor condition. New mastic has been used under the new cove base in the first and second floor hallways. It is not suspect for asbestos content.

Does Material Contain Asbestos? Assumed
Is it Friable? No
Original Inspection Date 5/31/1995
Current Surveillance Date 12/8/2004
Current Assessment Rating NR Not Required
Cause of Damage No Damage
Accessible No
Potential for Damage Low
Removed No
Planned Response Action O & M

Inspector



Christiaan Sparks

State Indiana
Accreditation Number 190804103

PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools

Building Name Jeffersonville High School

HA# 01

Type of Material Miscellaneous Material

Quantity of Material 52 LF

Material Location
Boiler room

Material Description
Gaskets on boilers

Comments

The visible edges of this material were not in poor condition. Boiler doors were closed.

Does Material Contain Asbestos? Assumed

Is it Friable? No

Original Inspection Date 06/01/1988

Current Surveillance Date 12/09/2003

Current Assessment Rating NR Not Required

Cause of Damage No Damage


Accessible No

Potential for Damage Low

Removed No

Planned Response Action O & M

Inspector



Christiaan Sparks

State Indiana

Accreditation Number 190804103

PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools

Building Name Jeffersonville High School

HA# 02

Type of Material Thermal Material

Quantity of Material 1,800 SF

Material Location
Boiler room

Material Description
Boiler insulation on 2 boilers

Comments
This material was not in poor condition.

Does Material Contain Asbestos? Yes

Is it Friable? No

Original Inspection Date 06/01/1988

Current Surveillance Date 12/09/2003

Current Assessment Rating NR Not Required

Cause of Damage No Damage

Accessible Yes

Potential for Damage Med

Removed No

Planned Response Action O & M

Inspector



Christiaan Sparks

State Indiana

Accreditation Number 190804103

PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools
Building Name Jeffersonville High School
HA# 03
Type of Material Thermal Material
Quantity of Material 222 LF
Material Location
Boiler room

Material Description
3" and 12" fittings

Comments

This material showed minor delamination on a few fittings, but was not in poor condition overall.

Does Material Contain Asbestos? Yes
Is it Friable? No
Original Inspection Date 06/01/1988
Current Surveillance Date 12/09/2003
Current Assessment Rating NR Not Required
Cause of Damage No Damage
Accessible Yes
Potential for Damage Med
Removed No
Planned Response Action O & M

Inspector



Christiaan Sparks

State Indiana
Accreditation Number 190804103

PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools

Building Name Jeffersonville High School

HA# 05

Type of Material Miscellaneous Material

Quantity of Material 548 SF

Material Location
First and second floors

Material Description
Floor tile

Comments

There are a few broken edges in the elevator and part of a tile missing in the first floor elevator corridor. However, this material was not in poor condition overall.

Does Material Contain Asbestos? Yes

Is it Friable? No

Original Inspection Date 06/01/1988

Current Surveillance Date 12/09/2003

Current Assessment Rating NR Not Required

Cause of Damage Physical Damage

Accessible Yes

Potential for Damage Low

Removed No

Planned Response Action O & M

Inspector



Christiaan Sparks

State Indiana

Accreditation Number 190804103

PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools

Building Name Jeffersonville High School

HA# 08

Type of Material Miscellaneous Material

Quantity of Material 3,000 SF

Material Location
First and second floors

Material Description
Floor tile mastic

Comments
Where exposed, this material was not in poor condition.

Does Material Contain Asbestos? Assumed

Is it Friable? No

Original Inspection Date 06/01/1988

Current Surveillance Date 12/09/2003

Current Assessment Rating NR Not Required

Cause of Damage No Damage


Accessible No

Potential for Damage Low

Removed No

Planned Response Action O & M

Inspector



Christiaan Sparks

State Indiana

Accreditation Number 190804103

PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools

Building Name Jeffersonville High School

HA# A

Type of Material Miscellaneous Material

Quantity of Material 60 LF

Material Location
Elevator corridors

Material Description
Cove base molding

Comments

All cove base is new except for the elevator corridors on the 1st and 2nd floor. This material was not in poor condition.

Does Material Contain Asbestos? Assumed

Is it Friable? No

Original Inspection Date 05/31/1995

Current Surveillance Date 12/09/2003

Current Assessment Rating NR Not Required

Cause of Damage No Damage

Accessible Yes

Potential for Damage Low

Removed No

Planned Response Action O & M

Inspector



Christiaan Sparks

State Indiana

Accreditation Number 190804103

PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools

Building Name Jeffersonville High School

HA# B

Type of Material Miscellaneous Material

Quantity of Material 60 LF

Material Location
Throughout the building


Material Description
Cove base mastic

Comments

Where visible under the old cove base, this material was not in poor condition. New mastic has been used under the new cove base in the first and second floor hallways. It is not suspect for asbestos content.

Does Material Contain Asbestos?	Assumed	
Is it Friable?	No	
Original Inspection Date	05/31/1995	
Current Surveillance Date	12/09/2003	
Current Assessment Rating	NR	Not Required
Cause of Damage	No Damage	
Accessible	No	
Potential for Damage	Low	
Removed	No	
Planned Response Action	O & M	

Inspector



Christiaan Sparks

State Indiana

Accreditation Number 190804103

PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools
Building Name Jeffersonville High School
HA# 01
Type of Material Miscellaneous Material
Quantity of Material 52 LF
Material Location
Boiler room
Material Description
Gaskets on boilers

Comments

The visible edges of this material were not in poor condition. Boiler doors were closed.

Does Material Contain Asbestos? Assumed
Is it Friable? No
Original Inspection Date 06/01/1988
Current Surveillance Date 06/13/2003
Current Assessment Rating NR Not Required
Cause of Damage No Damage
Accessible No
Potential for Damage Low
Removed No
Planned Response Action O & M

Inspector



Christiaan Sparks

State Indiana
Accreditation Number 190804103

PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools
Building Name Jeffersonville High School
HA# 02
Type of Material Thermal Material
Quantity of Material 1,800 SF
Material Location
Boiler room
Material Description
Boiler insulation on 2 boilers
Comments
This material was not in poor condition.
Does Material Contain Asbestos? Yes
Is it Friable? No
Original Inspection Date 06/01/1988
Current Surveillance Date 06/13/2003
Current Assessment Rating NR Not Required
Cause of Damage No Damage
Accessible Yes
Potential for Damage Med
Removed No
Planned Response Action O & M

Inspector



Christiaan Sparks

State Indiana
Accreditation Number 190804103

PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools
Building Name Jeffersonville High School
HA# 03
Type of Material Thermal Material
Quantity of Material 222 LF
Material Location
Boiler room
Material Description
3" and 12" fittings

Comments

This material was not in poor condition.

Does Material Contain Asbestos? Yes
Is it Friable? No
Original Inspection Date 06/01/1988
Current Surveillance Date 06/13/2003
Current Assessment Rating NR Not Required
Cause of Damage No Damage
Accessible Yes
Potential for Damage Med
Removed No
Planned Response Action O & M

Inspector



Christiaan Sparks

State Indiana
Accreditation Number 190804103

PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools
Building Name Jeffersonville High School
HA# 05
Type of Material Miscellaneous Material
Quantity of Material 548 SF

Material Location
First and second floors

Material Description
Floor tile

Comments

There are a few broken edges in the elevator and part of a tile missing in the first floor elevator corridor. However, this material was not in poor condition overall.

Does Material Contain Asbestos? Yes
Is it Friable? No
Original Inspection Date 06/01/1988
Current Surveillance Date 06/13/2003
Current Assessment Rating NR Not Required
Cause of Damage Physical Damage
Accessible Yes
Potential for Damage Low
Removed No
Planned Response Action O & M

Inspector



Christiaan Sparks

State Indiana
Accreditation Number 190804103

PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools
Building Name Jeffersonville High School
HA# 08
Type of Material Miscellaneous Material
Quantity of Material 3,000 SF

Material Location
First and second floors

Material Description
Floor tile mastic

Comments
Where exposed, this material was not in poor condition.

Does Material Contain Asbestos? Assumed
Is it Friable? No
Original Inspection Date 06/01/1988
Current Surveillance Date 06/13/2003
Current Assessment Rating NR Not Required
Cause of Damage No Damage
Accessible No
Potential for Damage Low
Removed No
Planned Response Action O & M

Inspector



Christiaan Sparks

State Indiana
Accreditation Number 190804103

PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools
Building Name Jeffersonville High School
HA# A
Type of Material Miscellaneous Material
Quantity of Material 60 LF

Material Location
Elevator corridors

Material Description
Cove base molding

Comments

All cove base is new except for the elevator corridors on the 1st and 2nd floor. This material was not in poor condition.

Does Material Contain Asbestos? Assumed
Is it Friable? No
Original Inspection Date 05/31/1995
Current Surveillance Date 06/13/2003
Current Assessment Rating NR Not Required
Cause of Damage No Damage
Accessible Yes
Potential for Damage Low
Removed No
Planned Response Action O & M

Inspector



Christiaan Sparks

State Indiana
Accreditation Number 190804103

PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools
Building Name Jeffersonville High School
HA# B
Type of Material Miscellaneous Material
Quantity of Material 60 LF
Material Location
Throughout the building
Material Description
Cove base mastic

Comments

Where visible under the old cove base, this material was not in poor condition. New mastic has been used under the new cove base in the first and second floor hallways. It is not suspect for asbestos content.

Does Material Contain Asbestos? Assumed
Is it Friable? No
Original Inspection Date 05/31/1995
Current Surveillance Date 06/13/2003
Current Assessment Rating NR Not Required
Cause of Damage No Damage
Accessible No
Potential for Damage Low
Removed No
Planned Response Action O & M

Inspector



Christiaan Sparks

State Indiana
Accreditation Number 190804103

PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools
Building Name Jeffersonville High School
HA# 01
Type of Material Miscellaneous Material
Quantity of Material 52 LF
Material Location
Boiler room
Material Description
Gaskets on boilers

Comments

The visible edges of this material were not in poor condition. Boiler doors were closed.

Does Material Contain Asbestos? Assumed
Is it Friable? No
Original Inspection Date 06/01/1988
Current Surveillance Date 12/17/2002
Current Assessment Rating NR Not Required
Cause of Damage No Damage
Accessible No
Potential for Damage Low
Removed No
Planned Response Action O & M


Inspector



Christiaan Sparks

State Indiana
Accreditation Number 190804103

PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools
Building Name Jeffersonville High School
HA# 02
Type of Material Thermal Material
Quantity of Material 1,800 SF
Material Location
Boiler room
Material Description
Boiler insulation on 2 boilers
Comments
This material was not in poor condition.
Does Material Contain Asbestos? Yes
Is it Friable? No
Original Inspection Date 06/01/1988
Current Surveillance Date 12/17/2002
Current Assessment Rating NR Not Required
Cause of Damage No Damage
Accessible Yes
Potential for Damage Med
Removed No
Planned Response Action O & M
Inspector


Christiaan Sparks
State Indiana
Accreditation Number 190804103

PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools

Building Name Jeffersonville High School

HA# 03

Type of Material Thermal Material

Quantity of Material 222 LF

Material Location
Boiler room

Material Description
3" and 12" fittings

Comments
This material was not in poor condition.

Does Material Contain Asbestos? Yes

Is it Friable? No

Original Inspection Date 06/01/1988

Current Surveillance Date 12/17/2002

Current Assessment Rating NR Not Required

Cause of Damage No Damage

Accessible Yes

Potential for Damage Med

Removed No

Planned Response Action O & M

Inspector



Christiaan Sparks

State Indiana

Accreditation Number 190804103

PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools
Building Name Jeffersonville High School
HA# 05
Type of Material Miscellaneous Material
Quantity of Material 548 SF

Material Location
First and second floors

Material Description
Floor tile

Comments

There are a few broken edges in the elevator and part of a tile missing in the first floor elevator corridor. However, this material was not in poor condition overall.

Does Material Contain Asbestos? Yes
Is it Friable? No
Original Inspection Date 06/01/1988
Current Surveillance Date 12/17/2002
Current Assessment Rating NR Not Required
Cause of Damage Physical Damage
Accessible Yes
Potential for Damage Low
Removed No
Planned Response Action O & M

Inspector



Christian Sparks

State Indiana
Accreditation Number 190804103

PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools

Building Name Jeffersonville High School

HA# 08

Type of Material Miscellaneous Material

Quantity of Material 3,000 SF

Material Location

First and second floors

Material Description

Floor tile mastic

Comments

Where exposed, this material was not in poor condition.

Does Material Contain Asbestos? Assumed

Is it Friable? No

Original Inspection Date 06/01/1988

Current Surveillance Date 12/17/2002

Current Assessment Rating NR Not Required

Cause of Damage No Damage

Accessible No

Potential for Damage Low

Removed No

Planned Response Action O & M

Inspector



Christiaan Sparks

State Indiana

Accreditation Number 190804103

PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools
Building Name Jeffersonville High School
HA# A
Type of Material Miscellaneous Material
Quantity of Material 60 LF

Material Location
Elevator corridors

Material Description
Cove base molding

Comments

All cove base is new except for the elevator corridors on the 1st and 2nd floor. This material was not in poor condition.

Does Material Contain Asbestos? Assumed
Is it Friable? No
Original Inspection Date 05/31/1995
Current Surveillance Date 12/17/2002
Current Assessment Rating NR Not Required
Cause of Damage No Damage
Accessible Yes
Potential for Damage Low
Removed No
Planned Response Action O & M

Inspector



Christiaan Sparks

State Indiana
Accreditation Number 190804103

PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools

Building Name Jeffersonville High School

HA# B

Type of Material Miscellaneous Material

Quantity of Material 60 LF

Material Location
Throughout the building

Material Description
Cove base mastic

Comments

Where visible under the old cove base, this material was not in poor condition. New mastic has been used under the new cove base in the first and second floor hallways. It is not suspect for asbestos content.

Does Material Contain Asbestos? Assumed
Is it Friable? No
Original Inspection Date 05/31/1995
Current Surveillance Date 12/17/2002
Current Assessment Rating NR Not Required
Cause of Damage No Damage
Accessible No
Potential for Damage Low
Removed No
Planned Response Action O & M

Inspector



Christiaan Sparks

State Indiana

Accreditation Number 190804103

PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools
Building Name Jeffersonville High School
HA# 01
Type of Material Miscellaneous Material
Quantity of Material 132 SF
Material Location
Boiler room
Material Description
Gaskets on boilers

Comments

The burner assembly was still in place. There does not appear to be 132 square feet of suspect material. The gasket material on the upper, newer boiler appears to be fiberglass. Material is not in poor condition.

Does Material Contain Asbestos? Assumed
Is it Friable? No
Original Inspection Date 06/01/1988
Current Surveillance Date 06/19/2002
Current Assessment Rating NR Not Required
Cause of Damage No Damage
Accessible No
Potential for Damage Low
Removed No
Planned Response Action O & M

Inspector


Richard D. Calvert

State Indiana
Accreditation Number 315989970

PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools

Building Name Jeffersonville High School

HA# 02

Type of Material Thermal Material

Quantity of Material 1,800 SF

Material Location
Boiler room

Material Description
Boiler insulation on 2 boilers

Comments

Material is not in poor condition. Quite a bit of O & M has been performed on the two boilers with encapsulating mastic. Also, less than 3 square feet of mag block was removed by trained school personnel on boiler #1.

Does Material Contain Asbestos? Yes

Is it Friable? No

Original Inspection Date 06/01/1988

Current Surveillance Date 06/19/2002

Current Assessment Rating NR Not Required

Cause of Damage Vibration


Accessible Yes

Potential for Damage Med

Removed No

Planned Response Action O & M

Inspector


Richard D. Calvert

State Indiana

Accreditation Number 315989970

PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools
Building Name Jeffersonville High School
HA# 03
Type of Material Thermal Material
Quantity of Material 222 LF
Material Location
Boiler room
Material Description
3" and 12" fittings
Comments
Fittings are not in poor condition overall.
Does Material Contain Asbestos? Yes
Is it Friable? No
Original Inspection Date 06/01/1988
Current Surveillance Date 06/19/2002
Current Assessment Rating NR Not Required
Cause of Damage No Damage
Accessible Yes
Potential for Damage Med
Removed No
Planned Response Action O & M
Inspector

Richard D. Calvert
State Indiana
Accreditation Number 315989970

PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools
Building Name Jeffersonville High School
HA# 05
Type of Material Miscellaneous Material
Quantity of Material 548 SF

Material Location
First and second floors


Material Description
Floor tile

Comments

There are a few broken edges in the elevator and a part of a tile missing in the first floor elevator corridor. However, the material is not in poor condition overall.

Does Material Contain Asbestos? Yes
Is it Friable? No
Original Inspection Date 06/01/1988
Current Surveillance Date 06/19/2002
Current Assessment Rating NR Not Required
Cause of Damage Physical Damage
Accessible Yes
Potential for Damage Low
Removed No
Planned Response Action O & M

Inspector


Richard D. Calvert

State Indiana
Accreditation Number 315989970

PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools
Building Name Jeffersonville High School
HA# 08
Type of Material Miscellaneous Material
Quantity of Material 3,000 SF
Material Location
First and second floors
Material Description
Floor tile mastic
Comments
Where exposed, the mastic is not in poor condition.
Does Material Contain Asbestos? Assumed
Is it Friable? No
Original Inspection Date 06/01/1988
Current Surveillance Date 06/19/2002
Current Assessment Rating NR Not Required
Cause of Damage No Damage
Accessible No
Potential for Damage Low
Removed No
Planned Response Action O & M
Inspector

Richard D. Calvert
State Indiana
Accreditation Number 315989970

PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools
Building Name Jeffersonville High School
HA# A
Type of Material Miscellaneous Material
Quantity of Material Approx. 4,500 LF

Material Location
Throughout the building

Material Description
Cove base molding

Comments

All material in first and second floor corridors has been replaced with new black cove base molding. The new material is not suspect for asbestos content. Second floor received new carpet in June 2000. Most old cove base is in areas that did not get carpeted. The old cove base is not in poor condition overall with minor scrapes observed.

Does Material Contain Asbestos? Assumed
Is it Friable? No
Original Inspection Date 05/31/1995
Current Surveillance Date 06/19/2002
Current Assessment Rating NR Not Required
Cause of Damage No Damage
Accessible Yes
Potential for Damage Low
Removed No
Planned Response Action O & M

Inspector


Richard D. Calvert

State Indiana
Accreditation Number 315989970

PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools

Building Name Jeffersonville High School

HA# B

Type of Material Miscellaneous Material

Quantity of Material 3,000 SF

Material Location

Throughout the building

Material Description

Cove base mastic

Comments

No mastic was exposed to inspect. New mastic has been used under the new cove base in the first and second floor hallways. It is not suspect for asbestos content.

Does Material Contain Asbestos? Assumed

Is it Friable? No

Original Inspection Date 05/31/1995

Current Surveillance Date 06/19/2002

Current Assessment Rating NR Not Required

Cause of Damage No Damage

Accessible No

Potential for Damage Low

Removed No

Planned Response Action O & M

Inspector


Richard D. Calvert

State Indiana

Accreditation Number 315989970

PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools
Building Name Jeffersonville High School
HA# 01
Type of Material Miscellaneous Material
Quantity of Material 132 SF

Material Location
Boiler room


Material Description
Gaskets on boilers

Comments

The burner assembly was still in place. There does not appear to be 132 square feet of suspect material. The gasket material on the upper, newer boiler appears to be fiberglass. Material is not in poor condition.

Does Material Contain Asbestos? Assumed
Is it Friable? No
Original Inspection Date 06/01/1988
Current Surveillance Date 12/10/2002
Current Assessment Rating NR Not Required
Cause of Damage No Damage
Accessible No
Potential for Damage Low
Removed No
Planned Response Action O & M

Inspector



Stephen Kimbrough

State Indiana
Accreditation Number 191914122

PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools

Building Name Jeffersonville High School

HA# 02

Type of Material Thermal Material

Quantity of Material 1,800 SF

Material Location
Boiler room

Material Description
Boiler insulation on 2 boilers

Comments

Material is not in poor condition. Quite a bit of O & M has been performed on the two boilers with encapsulating mastic.

Does Material Contain Asbestos? Yes

Is it Friable? No

Original Inspection Date 06/01/1988

Current Surveillance Date 12/10/2002

Current Assessment Rating NR Not Required

Cause of Damage Vibration


Accessible Yes

Potential for Damage Med

Removed No

Planned Response Action O & M

Inspector



Stephen Kimbrough

State Indiana

Accreditation Number 191914122

PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools

Building Name Jeffersonville High School

HA# 03

Type of Material Thermal Material

Quantity of Material 222 LF

Material Location
Boiler room

Material Description
3" and 12" fittings

Comments
Fittings are not in poor condition overall.

Does Material Contain Asbestos? Yes

Is it Friable? No

Original Inspection Date 06/01/1988

Current Surveillance Date 12/10/2002

Current Assessment Rating NR Not Required

Cause of Damage No Damage

Accessible Yes

Potential for Damage Med

Removed No

Planned Response Action O & M

Inspector



Stephen Kimbrough

State Indiana

Accreditation Number 191914122

PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools

Building Name Jeffersonville High School

HA# 05

Type of Material Miscellaneous Material

Quantity of Material 548 SF

Material Location
First and second floors

Material Description
Floor tile

Comments

There are a few broken edges in the elevator and a part of a tile missing in the first floor elevator corridor. However, the material is not in poor condition overall.

Does Material Contain Asbestos? Yes

Is it Friable? No

Original Inspection Date 06/01/1988

Current Surveillance Date 12/10/2002

Current Assessment Rating NR Not Required

Cause of Damage Physical Damage

Accessible Yes

Potential for Damage Low

Removed No

Planned Response Action O & M

Inspector




Stephen Kimbrough

State Indiana

Accreditation Number 191914122

PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools
Building Name Jeffersonville High School
HA# 08
Type of Material Miscellaneous Material
Quantity of Material 3,000 SF
Material Location
First and second floors
Material Description
Floor tile mastic
Comments
Where exposed, the mastic is not in poor condition.
Does Material Contain Asbestos? Assumed
Is it Friable? No
Original Inspection Date 06/01/1988
Current Surveillance Date 12/10/2002
Current Assessment Rating NR Not Required
Cause of Damage No Damage
Accessible No
Potential for Damage Low
Removed No
Planned Response Action O & M
Inspector 
Stephen Kimbrough
State Indiana
Accreditation Number 191914122

PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools
Building Name Jeffersonville High School
HA# A
Type of Material Miscellaneous Material
Quantity of Material Approx. 4,500 LF

Material Location
Throughout the building


Material Description
Cove base molding

Comments

All material in first floor corridors has been replaced with new black cove base molding. Second floor received new carpet in June 2000. Most cove base is in areas that did not get carpeted. The old cove base is not in poor condition overall with minor scrapes observed.

Does Material Contain Asbestos? Assumed
Is it Friable? No
Original Inspection Date 05/31/1995
Current Surveillance Date 12/10/2002
Current Assessment Rating NR Not Required
Cause of Damage No Damage
Accessible Yes
Potential for Damage Low
Removed No
Planned Response Action O & M

Inspector



Stephen Kimbrough

State Indiana
Accreditation Number 191914122

PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools
Building Name Jeffersonville High School
HA# B
Type of Material Miscellaneous Material
Quantity of Material 3,000 SF

Material Location
Throughout the building


Material Description
Cove base mastic

Comments

Where material is exposed, it is not in poor condition. A lot of the mastic on the second floor has been painted over with black paint where no molding is present.

Does Material Contain Asbestos? Assumed
Is it Friable? No
Original Inspection Date 05/31/1995
Current Surveillance Date 12/10/2002
Current Assessment Rating NR Not Required
Cause of Damage No Damage
Accessible No
Potential for Damage Low
Removed No
Planned Response Action O & M

Inspector



Stephen Kimbrough

State Indiana
Accreditation Number 191914122

PERIODIC SURVEILLANCE REPORT


LEA Name Greater Clark County Schools
Building Name Jeffersonville High School
HA# 01
Type of Material Miscellaneous Material
Quantity of Material 132 SF
Material Location
Boiler room
Material Description
Gaskets on boilers

Comments

The burner assembly was still in place. There does not appear to be 132 square feet of suspect material. The gasket material on the upper, newer boiler appears to be fiberglass. The boilers were in operation during this surveillance, so I was unable to sample the material.

Does Material Contain Asbestos? Assumed
Is it Friable? No
Original Inspection Date 06/01/1988
Current Surveillance Date 01/09/2001
Current Assessment Rating NR Not Required
Cause of Damage No Damage
Accessible No
Potential for Damage Low
Removed No
Planned Response Action O & M

Inspector



Patrick E. Wilson

State Indiana
Accreditation Number 190824065

PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools

Building Name Jeffersonville High School

HA# 02

Type of Material Thermal Material

Quantity of Material 1,800 SF

Material Location
Boiler room

Material Description
Boiler insulation on 2 boilers

Comments

Material is in good condition. Quite a bit of O & M has been performed on the two boilers with encapsulating mastic. There was a small amount of debris on the floor at the right side of the #2 boiler.

Does Material Contain Asbestos? Yes

Is it Friable? No

Original Inspection Date 06/01/1988

Current Surveillance Date 01/09/2001

Current Assessment Rating NR Not Required

Cause of Damage Vibration

Accessible Yes

Potential for Damage Med

Removed No

Planned Response Action O & M

Inspector



Patrick E. Wilson

State Indiana

Accreditation Number 190824065

PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools

Building Name Jeffersonville High School

HA# 03

Type of Material Thermal Material

Quantity of Material 222 LF

Material Location
Boiler room

Material Description
3" and 12" fittings

Comments

Fittings are in good condition overall. Some elbows by the upper boiler were glovebagged by school personnel.

Does Material Contain Asbestos? Yes

Is it Friable? No

Original Inspection Date 06/01/1988

Current Surveillance Date 01/09/2001

Current Assessment Rating NR Not Required

Cause of Damage No Damage

Accessible Yes

Potential for Damage Med

Removed No

Planned Response Action O & M

Inspector



Patrick E. Wilson

State Indiana

Accreditation Number 190824065

PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools
Building Name Jeffersonville High School
HA# 05
Type of Material Miscellaneous Material
Quantity of Material 548 SF

Material Location
First and second floors


Material Description
Floor tile

Comments

There are a few broken edges in the elevator and a part of a tile missing in the first floor elevator corridor.

Does Material Contain Asbestos? Yes
Is it Friable? No
Original Inspection Date 06/01/1988
Current Surveillance Date 01/09/2001
Current Assessment Rating NR Not Required
Cause of Damage Physical Damage
Accessible Yes
Potential for Damage Low
Removed No
Planned Response Action O & M

Inspector



Patrick E. Wilson

State Indiana
Accreditation Number 190824065

PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools
Building Name Jeffersonville High School
HA# 08
Type of Material Miscellaneous Material
Quantity of Material 3,000 SF
Material Location
First and second floors
Material Description
Floor tile mastic
Comments
Where exposed, the mastic was in good condition.
Does Material Contain Asbestos? Assumed
Is it Friable? No
Original Inspection Date 06/01/1988
Current Surveillance Date 01/09/2001
Current Assessment Rating NR Not Required
Cause of Damage No Damage
Accessible Yes
Potential for Damage Low
Removed No
Planned Response Action O & M

Inspector



Patrick E. Wilson

State Indiana
Accreditation Number 190824065

PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools

Building Name Jeffersonville High School

HA# A

Type of Material Miscellaneous Material

Quantity of Material Approx. 4,500 LF

Material Location
Throughout the building

Material Description
Cove base molding

Comments

All material in first floor corridors has been replaced with new black cove base molding. Second floor received new carpet in June 2000. Most cove base is in areas that did not get carpeted. The old cove base is in good condition overall.

Does Material Contain Asbestos? Assumed

Is it Friable? No

Original Inspection Date 05/31/1995

Current Surveillance Date 01/09/2001

Current Assessment Rating NR Not Required

Cause of Damage No Damage


Accessible Yes

Potential for Damage Low

Removed No

Planned Response Action O & M

Inspector



Patrick E. Wilson

State Indiana

Accreditation Number 190824065

PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools
Building Name Jeffersonville High School
HA# B
Type of Material Miscellaneous Material
Quantity of Material 3,000 SF

Material Location
Throughout the building

Material Description
Cove base mastic

Comments
Where material is exposed, it is in good condition. A lot of the mastic on the second floor has been painted over with black paint where no molding is present.

Does Material Contain Asbestos? Assumed
Is it Friable? No
Original Inspection Date 05/31/1995
Current Surveillance Date 01/09/2001
Current Assessment Rating NR Not Required
Cause of Damage No Damage
Accessible No
Potential for Damage Low
Removed No
Planned Response Action O & M

Inspector



Patrick E. Wilson

State Indiana
Accreditation Number 190824065

PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools
Building Name Jeffersonville High School
HA# 01
Type of Material Miscellaneous Material
Quantity of Material 132 SF
Material Location
Boiler Room
Material Description
Gaskets on Boilers

Comments

Front doors and rear were open on both boilers exposing the fiberglass rope gasket. The burner assembly was still in place and that gasket could not be seen. There does not appear to be 132 square feet of suspect material.

Does Material Contain Asbestos? Assumed
Is it Friable? No
Original Inspection Date 06/01/1988
Current Surveillance Date 06/29/2000
Current Assessment Rating NR Not Required
Cause of Damage No Damage
Accessible No
Potential for Damage Low
Removed No
Planned Response Action O & M

Inspector


George William Ogle

State Indiana
Accreditation Number 191523030

PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools
Building Name Jeffersonville High School
HA# 02
Type of Material Thermal Material
Quantity of Material 1800 SF
Material Location
Boiler Room
Material Description
Boiler Insulation on 2 Boilers
Comments
Material is in good condition.
Does Material Contain Asbestos? Yes
Is it Friable? No
Original Inspection Date 06/01/1988
Current Surveillance Date 06/29/2000
Current Assessment Rating NR Not Required
Cause of Damage No Damage
Accessible Yes
Potential for Damage Med
Removed No
Planned Response Action O & M

Inspector


George William Ogle

State

Indiana


Accreditation Number

191523030

PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools
Building Name Jeffersonville High School
HA# 03
Type of Material Thermal Material
Quantity of Material 222 LF
Material Location
Boiler Room
Material Description
3" and 12" Fittings
Comments
Fittings are in good condition.
Does Material Contain Asbestos? Yes
Is it Friable? No
Original Inspection Date 06/01/1988
Current Surveillance Date 06/29/2000
Current Assessment Rating NR Not Required
Cause of Damage No Damage
Accessible Yes
Potential for Damage Med
Removed No
Planned Response Action O & M

Inspector


George William Ogge

State Indiana
Accreditation Number 191523030

PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools
Building Name Jeffersonville High School
HA# 05
Type of Material Miscellaneous Material
Quantity of Material 548 SF

Material Location
First and second floors

Material Description
Floor Tile

Comments

There are a few broken edges in the elevator abd a oart of a tile missing in the first floor elevator corridor.

Does Material Contain Asbestos? Yes
Is it Friable? No
Original Inspection Date 06/01/1988
Current Surveillance Date 06/29/2000
Current Assessment Rating NR Not Required
Cause of Damage Physical Damage
Accessible Yes
Potential for Damage Low
Removed No
Planned Response Action O & M

Inspector


George William Ogle

State Indiana
Accreditation Number 191523030

PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools
Building Name Jeffersonville High School
HA# 08
Type of Material Miscellaneous Material
Quantity of Material 3000 SF
Material Location
First and second floors
Material Description
Floor Tile Mastic
Comments
Where exposed, the mastic was in good condition.
Does Material Contain Asbestos? Assumed
Is it Friable? No
Original Inspection Date 06/01/1988
Current Surveillance Date 06/29/2000
Current Assessment Rating NR Not Required
Cause of Damage No Damage
Accessible Yes
Potential for Damage Low
Removed No
Planned Response Action O & M

Inspector


George William Ogle

State

Indiana

Accreditation Number

191523030

PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools
Building Name Jeffersonville High School
HA# A
Type of Material Miscellaneous Material
Quantity of Material Unquantified SF

Material Location
Throughout the building

Material Description
Cove Base Molding

Comments

All material in first floor corridors has been replaced with new black cove base molding. Second floor received new carpet in June 2000. Most cove base is in areas that did not get carpeted. The old cove base is in good condition overall.

Does Material Contain Asbestos? Assumed
Is it Friable? No
Original Inspection Date 05/31/1995
Current Surveillance Date 06/29/2000
Current Assessment Rating NR Not Required
Cause of Damage No Damage
Accessible Yes
Potential for Damage Low
Removed No
Planned Response Action O & M

Inspector


George William Ogbe

State Indiana
Accreditation Number 191523030

PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools
Building Name Jeffersonville High School
HA# B
Type of Material Miscellaneous Material
Quantity of Material 3000 SF

Material Location
Throughout the building

Material Description
Cove Base Mastic

Comments

Where material is exposed on 2nd floor, it is in good condition. A lot of the mastic on the second floor has been painted over with black paint where no molding is present.

Does Material Contain Asbestos? Assumed
Is it Friable? No
Original Inspection Date 05/31/1995
Current Surveillance Date 06/29/2000
Current Assessment Rating NR Not Required
Cause of Damage No Damage
Accessible No
Potential for Damage Low
Removed No
Planned Response Action O & M

Inspector



George William Ogle

State Indiana
Accreditation Number 191523030

PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools
Building Name Jeffersonville High School
HA# 01
Type of Material Miscellaneous Material
Quantity of Material 132 SF
Material Location
Boiler Room
Material Description
Gaskets on Boilers
Comments
Good condition.
Does Material Contain Asbestos? Assumed
Is it Friable? No
Original Inspection Date 06/01/1988
Current Surveillance Date 12/08/1999
Current Assessment Rating NR Not Required
Cause of Damage No Damage
Accessible Yes
Potential for Damage Low
Removed No
Planned Response Action O & M

Inspector



Matthew Wallace

State Indiana
Accreditation Number 191219020

PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools
Building Name Jeffersonville High School
HA# 02
Type of Material Thermal Material
Quantity of Material 1800 SF
Material Location
Boiler Room
Material Description
Boiler Insulation on 2 Boilers
Comments
Material had two spots of damage. O & M complete.
Does Material Contain Asbestos? Yes
Is it Friable? Yes
Original Inspection Date 06/01/1988
Current Surveillance Date 12/08/1999
Current Assessment Rating 1B Damaged TSI
Cause of Damage Physical Damage
Accessible Yes
Potential for Damage Med
Removed No
Planned Response Action O & M

Inspector




Matthew Wallace

State Indiana
Accreditation Number 191219020

PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools
Building Name Jeffersonville High School
HA# 03
Type of Material Thermal Material
Quantity of Material 222 LF
Material Location
Boiler Room
Material Description
3" and 12" Fittings
Comments
O & M work has been completed.
Does Material Contain Asbestos? Yes
Is it Friable? Yes
Original Inspection Date 06/01/1988
Current Surveillance Date 12/08/1999
Current Assessment Rating 1B Damaged TSI
Cause of Damage Physical Damage
Accessible Yes
Potential for Damage Med
Removed No
Planned Response Action O & M

Inspector



Matthew Wallace

State Indiana
Accreditation Number 191219020

PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools

Building Name Jeffersonville High School

HA# 05

Type of Material Miscellaneous Material

Quantity of Material 548 SF

Material Location
First and second floors

Material Description
Floor Tile

Comments
There are a few broken edges in the elevator.

Does Material Contain Asbestos? Yes

Is it Friable? No

Original Inspection Date 06/01/1988

Current Surveillance Date 12/08/1999

Current Assessment Rating NR Not Required

Cause of Damage No Damage


Accessible Yes

Potential for Damage Low

Removed Yes

Planned Response Action None

Inspector



Matthew Wallace

State Indiana

Accreditation Number 191219020

PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools
Building Name Jeffersonville High School
HA# 08
Type of Material Miscellaneous Material
Quantity of Material 3000 SF

Material Location
First and second floors


Material Description
Floor Tile Mastic

Comments

Material is exposed on the second floor at the top of the stairs where lockers were removed. Material is in good condition. All corridors on the first floor have new carpet covering the material.

Does Material Contain Asbestos? Assumed
Is it Friable? No
Original Inspection Date 06/01/1988
Current Surveillance Date 12/08/1999
Current Assessment Rating NR Not Required
Cause of Damage No Damage
Accessible Yes
Potential for Damage Low
Removed No
Planned Response Action O & M

Inspector



Matthew Wallace

State Indiana
Accreditation Number 191219020

PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools

Building Name Jeffersonville High School

HA# A

Type of Material Miscellaneous Material

Quantity of Material 3000 SF

Material Location
Throughout the building

Material Description
Cove Base Molding

Comments

All material in first floor corridors has been replaced with new black cove base molding. Material on second floor is in very poor condition. Many sections are missing.

Does Material Contain Asbestos? Assumed
Is it Friable? No
Original Inspection Date 05/31/1995
Current Surveillance Date 12/08/1999
Current Assessment Rating NR Not Required
Cause of Damage Physical Damage
Accessible Yes
Potential for Damage Low
Removed No
Planned Response Action O & M

Inspector



Matthew Wallace

State Indiana

Accreditation Number 191219020

PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools
Building Name Jeffersonville High School
HA# B
Type of Material Miscellaneous Material
Quantity of Material 3000 SF

Material Location
Throughout the building


Material Description
Cove Base Mastic

Comments

Where material is exposed it is in good condition. A lot of the mastic on the second floor has been painted over with black paint where no molding is present.

Does Material Contain Asbestos? Assumed
Is it Friable? No
Original Inspection Date 05/31/1995
Current Surveillance Date 12/08/1999
Current Assessment Rating NR Not Required
Cause of Damage No Damage
Accessible No
Potential for Damage Low
Removed No
Planned Response Action O & M

Inspector



Matthew Wallace

State Indiana
Accreditation Number 191219020

PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools

Building Name Jeffersonville High School

HA# C

Type of Material Miscellaneous Material

Quantity of Material Unquantified SF

Material Location
Second floor balcony and around the gymnasium

Material Description
Transite Walls

Comments
Material was removed in 1987 according to Mr. Dodd.

Does Material Contain Asbestos? No

Is it Friable? No

Original Inspection Date 06/24/1996

Current Surveillance Date 12/08/1999

Current Assessment Rating NA Not Applicable

Cause of Damage Not Applicable


Accessible No

Potential for Damage NA

Removed No

Planned Response Action None

Inspector



Matthew Wallace

State Indiana

Accreditation Number 191219020

PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools
Building Name Jeffersonville High School
HA# 01
Type of Material Miscellaneous Material
Quantity of Material 132 SF
Material Location
Boiler Room
Material Description
Gaskets on Boilers
Comments
Good condition.
Does Material Contain Asbestos? Assumed
Is it Friable? No
Original Inspection Date 06/01/1988
Current Surveillance Date 06/24/1999
Current Assessment Rating NR Not Required
Cause of Damage No Damage
Accessible Yes
Potential for Damage Low
Removed No
Planned Response Action O & M

Inspector


Matthew Wallace

State Indiana
Accreditation Number 191219020

PERIODIC SURVEILLANCE REPORT


LEA Name Greater Clark County Schools
Building Name Jeffersonville High School
HA# 02
Type of Material Thermal Material
Quantity of Material 1800 SF
Material Location
Boiler Room
Material Description
Boiler Insulation on 2 Boilers
Comments
Material had two spots of damage. O & M complete.
Does Material Contain Asbestos? Yes
Is it Friable? Yes
Original Inspection Date 06/01/1988
Current Surveillance Date 06/24/1999
Current Assessment Rating 1B Damaged TSI
Cause of Damage Physical Damage
Accessible Yes
Potential for Damage Med
Removed No
Planned Response Action O & M

Inspector


Matthew Wallace

State Indiana
Accreditation Number 191219020

PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools
Building Name Jeffersonville High School
HA# 03
Type of Material Thermal Material
Quantity of Material 222 LF
Material Location
Boiler Room
Material Description
3" and 12" Fittings
Comments
O & M work has been completed.
Does Material Contain Asbestos? Yes
Is it Friable? Yes
Original Inspection Date 06/01/1988
Current Surveillance Date 06/24/1999
Current Assessment Rating 1B Damaged TSI
Cause of Damage Physical Damage
Accessible Yes
Potential for Damage Med
Removed No
Planned Response Action O & M
Inspector 
Matthew Wallace
State Indiana
Accreditation Number 191219020

PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools

Building Name Jeffersonville High School

HA# 05

Type of Material Miscellaneous Material

Quantity of Material 548 SF

Material Location
First and second floors

Material Description
Floor Tile

Comments
Removed as a non-friable material on the first floor level.

Does Material Contain Asbestos? Yes

Is it Friable? No

Original Inspection Date 06/01/1988

Current Surveillance Date 06/24/1999

Current Assessment Rating NR Not Required

Cause of Damage No Damage

Accessible Yes

Potential for Damage Low

Removed Yes

Planned Response Action None

Inspector


Matthew Wallace

State Indiana

Accreditation Number 191219020

PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools
Building Name Jeffersonville High School
HA# 08
Type of Material Miscellaneous Material
Quantity of Material 3000 SF
Material Location
First and second floors
Material Description
Floor Tile Mastic
Comments
Material is exposed and in good condition.
Does Material Contain Asbestos? Assumed
Is it Friable? No
Original Inspection Date 06/01/1988
Current Surveillance Date 06/24/1999
Current Assessment Rating NR Not Required
Cause of Damage No Damage
Accessible Yes
Potential for Damage Low
Removed No
Planned Response Action O & M

Inspector


Matthew Wallace

State

Indiana

Accreditation Number

191219020

PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools

Building Name Jeffersonville High School

HA# A

Type of Material Miscellaneous Material

Quantity of Material 3000 SF

Material Location
Throughout the building

Material Description
Cove Base Molding

Comments
Material was removed as non-friable on the first floor level. Found a couple of pieces missing on the second floor level.

Does Material Contain Asbestos? Assumed

Is it Friable? No

Original Inspection Date 05/31/1995

Current Surveillance Date 06/24/1999

Current Assessment Rating NR Not Required

Cause of Damage No Damage

Accessible Yes

Potential for Damage Low

Removed No

Planned Response Action O & M

Inspector


Matthew Wallace

State Indiana

Accreditation Number 191219020

PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools

Building Name Jeffersonville High School

HA# B

Type of Material Miscellaneous Material

Quantity of Material 3000 SF

Material Location
Throughout the building

Material Description
Cove Base Mastic

Comments
Material is exposed and is in good condition.

Does Material Contain Asbestos? Assumed

Is it Friable? No

Original Inspection Date 05/31/1995

Current Surveillance Date 06/24/1999

Current Assessment Rating NR Not Required

Cause of Damage No Damage


Accessible No

Potential for Damage Low

Removed No

Planned Response Action O & M

Inspector




Matthew Wallace

State Indiana

Accreditation Number 191219020


PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools
Building Name Jeffersonville High School
HA# C
Type of Material Miscellaneous Material
Quantity of Material Unquantified SF
Material Location
Second floor balcony and around the gymnasium
Material Description
Transite Walls
Comments
Material was removed in 1987 according to Mr. Dodd.
Does Material Contain Asbestos? No
Is it Friable? No
Original Inspection Date 06/24/1996
Current Surveillance Date 06/24/1999
Current Assessment Rating NA Not Applicable
Cause of Damage Not Applicable
Accessible No
Potential for Damage NA
Removed No
Planned Response Action None
Inspector 
Matthew Wallace
State Indiana
Accreditation Number 191219020

PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools
Building Name Jeffersonville High School
HA# 01
Type of Material Miscellaneous Material
Quantity of Material 132 SF
Material Location
Boiler Room
Material Description
Gaskets on Boilers
Comments
Good condition.
Does Material Contain Asbestos? Assumed
Is it Friable? No
Original Inspection Date 06/01/1988
Current Surveillance Date 12/29/1998
Current Assessment Rating NR Not Required
Cause of Damage No Damage
Accessible Yes
Potential for Damage Low
Removed No
Planned Response Action O & M

Inspector



Clint Yates

State

Indiana

Accreditation Number

193804035

PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools

Building Name Jeffersonville High School

HA# 02

Type of Material Thermal Material

Quantity of Material 1800 SF

Material Location
Boiler Room

Material Description
Boiler Insulation on 2 Boilers

Comments

Material had two spots of damage. O & M complete.

Does Material Contain Asbestos? Yes

Is it Friable? Yes

Original Inspection Date 06/01/1988

Current Surveillance Date 12/29/1998

Current Assessment Rating 1B Damaged TSI

Cause of Damage Physical Damage


Accessible Yes

Potential for Damage Med

Removed No

Planned Response Action O & M

Inspector



Clint Yates

State Indiana

Accreditation Number 193804035

PERIODIC SURVEILLANCE REPORT


LEA Name Greater Clark County Schools
Building Name Jeffersonville High School
HA# 03
Type of Material Thermal Material
Quantity of Material 222 LF
Material Location
Boiler Room
Material Description
3" and 12" Fittings

Comments

O & M work has been completed.

Does Material Contain Asbestos? Yes
Is it Friable? Yes
Original Inspection Date 06/01/1988
Current Surveillance Date 12/29/1998
Current Assessment Rating 1B Damaged TSI
Cause of Damage Physical Damage
Accessible Yes
Potential for Damage Med
Removed No
Planned Response Action O & M

Inspector



Clint Yates


State Indiana
Accreditation Number 193804035

PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools
Building Name Jeffersonville High School
HA# 05
Type of Material Miscellaneous Material
Quantity of Material 548 SF
Material Location
 First and second floors
Material Description
 Floor Tile
Comments
 Good condition.

Does Material Contain Asbestos? Yes
Is it Friable? No
Original Inspection Date 06/01/1988
Current Surveillance Date 12/29/1998
Current Assessment Rating NR Not Required
Cause of Damage No Damage
Accessible Yes
Potential for Damage Low
Removed No
Planned Response Action O & M

Inspector



Clint Yates

State Indiana
Accreditation Number 193804035

PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools

Building Name Jeffersonville High School

HA# 08

Type of Material Miscellaneous Material

Quantity of Material 3000 SF

Material Location
First and second floors

Material Description
Floor Tile Mastic

Comments
Material is not exposed, but is assumed to be in good condition.

Does Material Contain Asbestos? Assumed

Is it Friable? No

Original Inspection Date 06/01/1988

Current Surveillance Date 12/29/1998

Current Assessment Rating NR Not Required

Cause of Damage No Damage


Accessible Yes

Potential for Damage Low

Removed No

Planned Response Action O & M

Inspector



Clint Yates

State Indiana

Accreditation Number 193804035

PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools

Building Name Jeffersonville High School

HA# A

Type of Material Miscellaneous Material

Quantity of Material 3000 SF

Material Location
Throughout the building

Material Description
Cove Base Molding

Comments
Material is in good condition.

Does Material Contain Asbestos? Assumed

Is it Friable? No

Original Inspection Date 05/31/1995

Current Surveillance Date 12/29/1998

Current Assessment Rating NR Not Required

Cause of Damage No Damage

Accessible Yes

Potential for Damage Low

Removed No

Planned Response Action O & M

Inspector



Clint Yates

State Indiana

Accreditation Number 193804035

PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools

Building Name Jeffersonville High School

HA# B

Type of Material Miscellaneous Material

Quantity of Material 3000 SF

Material Location
Throughout the building

Material Description
Cove Base Mastic

Comments
Material is not exposed and is assumed to be in good condition.

Does Material Contain Asbestos? Assumed

Is it Friable? No

Original Inspection Date 05/31/1995

Current Surveillance Date 12/29/1998

Current Assessment Rating NR Not Required

Cause of Damage No Damage


Accessible No

Potential for Damage Low

Removed No

Planned Response Action O & M

Inspector



Clint Yates

State Indiana

Accreditation Number 193804035

PERIODIC SURVEILLANCE REPORT


LEA Name Greater Clark County Schools
Building Name Jeffersonville High School
HA# C
Type of Material Miscellaneous Material
Quantity of Material Unquantified SF
Material Location
Second floor balcony and around the gymnasium

Material Description
Transite Walls

Comments
Material was removed in 1987 according to Mr. Dodd.

Does Material Contain Asbestos? No
Is it Friable? No
Original Inspection Date 06/24/1996
Current Surveillance Date 12/29/1998
Current Assessment Rating NA Not Applicable
Cause of Damage Not Applicable
Accessible No
Potential for Damage NA
Removed No
Planned Response Action None

Inspector



Clint Yates

State Indiana
Accreditation Number 193804035

PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools
Building Name Jeffersonville High School
HA# 01
Type of Material Miscellaneous Material
Quantity of Material 132 SF
Material Location
Boiler Room
Material Description
Gaskets on Boilers
Comments
Good condition.
Does Material Contain Asbestos? Assumed
Is it Friable? No
Original Inspection Date 6/ 1/88
Current Surveillance Date 1/15/98
Current Assessment Rating NR Not Required
Cause of Damage No Damage
Accessible Yes
Potential for Damage Low
Removed No
Planned Response Action O & M

Inspector




Karen Foxx

State Indiana
Accreditation Number 191129014

PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools
Building Name Jeffersonville High School
HA# 02
Type of Material Thermal Material
Quantity of Material 1,800 SF
Material Location
Boiler Room
Material Description
Boiler Insulation on 2 Boilers
Comments
Material shows two spots of damage. O & M needed.
Does Material Contain Asbestos? Yes
Is it Friable? Yes
Original Inspection Date 6/ 1/88
Current Surveillance Date 1/15/98
Current Assessment Rating 1B Damaged TSI
Cause of Damage Physical Damage
Accessible Yes
Potential for Damage Med
Removed No
Planned Response Action O & M

Inspector



Karen Foxx

State Indiana
Accreditation Number 191129014

PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools
Building Name Jeffersonville High School
HA# 03
Type of Material Thermal Material
Quantity of Material 222 LF
Material Location
Boiler Room
Material Description
3" and 12" Fittings
Comments
Some minor damage.
Does Material Contain Asbestos? Yes
Is it Friable? Yes
Original Inspection Date 6/ 1/88
Current Surveillance Date 1/15/98
Current Assessment Rating 1B Damaged TSI
Cause of Damage Physical Damage
Accessible Yes
Potential for Damage Med
Removed No
Planned Response Action O & M

Inspector



Karen Foxx

State Indiana
Accreditation Number 191129014

PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools

Building Name Jeffersonville High School

HA# 05

Type of Material Miscellaneous Material

Quantity of Material 548 SF

Material Location
First and second floors

Material Description
Floor Tile

Comments
Good condition.

Does Material Contain Asbestos? Yes

Is it Friable? No

Original Inspection Date 6/ 1/88

Current Surveillance Date 1/15/98

Current Assessment Rating NR Not Required

Cause of Damage No Damage

Accessible Yes

Potential for Damage Low

Removed No

Planned Response Action O & M

Inspector



Karen Foxx

State Indiana

Accreditation Number 191129014

PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools
Building Name Jeffersonville High School
HA# 08
Type of Material Miscellaneous Material
Quantity of Material 3,000 SF

Material Location
First and second floors

Material Description
Floor Tile Mastic

Comments
Material is not exposed, but is assumed to be in good condition.

Does Material Contain Asbestos? Assumed
Is it Friable? No
Original Inspection Date 6/ 1/88
Current Surveillance Date 1/15/98
Current Assessment Rating NR Not Required
Cause of Damage No Damage
Accessible Yes
Potential for Damage Low
Removed No
Planned Response Action O & M

Inspector



Karen Foxx

State Indiana
Accreditation Number 191129014

PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools
Building Name Jeffersonville High School
HA# A
Type of Material Miscellaneous Material
Quantity of Material 3,000 SF
Material Location
Throughout the building
Material Description
Cove Base Molding
Comments
Material is in good condition.
Does Material Contain Asbestos? Assumed
Is it Friable? No
Original Inspection Date 5/31/95
Current Surveillance Date 1/15/98
Current Assessment Rating NR Not Required
Cause of Damage No Damage
Accessible Yes
Potential for Damage Low
Removed No
Planned Response Action O & M

Inspector



Karen Foxx

State Indiana
Accreditation Number 191129014

PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools
Building Name Jeffersonville High School
HA# B
Type of Material Miscellaneous Material
Quantity of Material 3,000 SF


Material Location
Throughout the building

Material Description
Cove Base Mastic

Comments
Material is not exposed and is assumed to be in good condition.

Does Material Contain Asbestos? Assumed
Is it Friable? No
Original Inspection Date 5/31/95
Current Surveillance Date 1/15/98
Current Assessment Rating NR Not Required
Cause of Damage No Damage
Accessible No
Potential for Damage Low
Removed No
Planned Response Action O & M

Inspector



Karen Foxx

State Indiana
Accreditation Number 191129014

PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools
Building Name Jeffersonville High School
HA# C
Type of Material Miscellaneous Material
Quantity of Material SF

Material Location
Second floor balcony and around the gymnasium

Material Description
Transite Walls

Comments
Was not addressed in the original inspection. Material is in good condition.

Does Material Contain Asbestos? Assumed
Is it Friable? No
Original Inspection Date 6/24/96
Current Surveillance Date 1/15/98
Current Assessment Rating NR Not Required
Cause of Damage No Damage
Accessible Yes
Potential for Damage Low
Removed No
Planned Response Action O & M

Inspector



Karen Foxx

State Indiana
Accreditation Number 191129014

PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools

Building Name Jeffersonville High School

HA# 01

Type of Material Miscellaneous Material

Quantity of Material 132 SF

Material Location
Boiler Room

Material Description
Gaskets on Boilers

Comments
Good condition.

Does Material Contain Asbestos? Assumed

Is it Friable? No

Original Inspection Date 6/ 1/88

Current Surveillance Date 7/ 3/97

Current Assessment Rating NR Not Required

Cause of Damage No Damage

Accessible Yes

Potential for Damage Low

Removed No

Planned Response Action O & M

Inspector



Karen Foxx

State Indiana

Accreditation Number 191129014

PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools

Building Name Jeffersonville High School

HA# 02

Type of Material Thermal Material

Quantity of Material 1,800 SF

Material Location
Boiler Room

Material Description
Boiler Insulation on 2 Boilers

Comments

One boiler was removed in May '95. The two remaining boilers have minor damage. O & M is needed.

Does Material Contain Asbestos? Yes

Is it Friable? Yes

Original Inspection Date 6/ 1/88

Current Surveillance Date 7/ 3/97

Current Assessment Rating 1B Damaged TSI

Cause of Damage Physical Damage

Accessible Yes

Potential for Damage Med

Removed No

Planned Response Action O & M

Inspector



Karen Foxx

State Indiana

Accreditation Number 191129014

PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools

Building Name Jeffersonville High School

HA# 03

Type of Material Thermal Material

Quantity of Material 222 LF

Material Location
Boiler Room

Material Description
3" and 12" Fittings

Comments
Some minor damage.

Does Material Contain Asbestos? Yes

Is it Friable? Yes

Original Inspection Date 6/ 1/88

Current Surveillance Date 7/ 3/97

Current Assessment Rating 1B Damaged TSI

Cause of Damage Physical Damage

Accessible Yes

Potential for Damage Med

Removed No

Planned Response Action O & M

Inspector



Karen Foxx

State Indiana

Accreditation Number 191129014

PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools

Building Name Jeffersonville High School

HA# 05

Type of Material Miscellaneous Material

Quantity of Material 548 SF

Material Location
First and second floors

Material Description
Floor Tile

Comments
Good condition.

Does Material Contain Asbestos? Yes

Is it Friable? No

Original Inspection Date 6/ 1/88

Current Surveillance Date 7/ 3/97

Current Assessment Rating NR Not Required

Cause of Damage No Damage

Accessible Yes

Potential for Damage Low

Removed No

Planned Response Action O & M

Inspector



Karen Foxx

State Indiana

Accreditation Number 191129014

PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools
Building Name Jeffersonville High School
HA# 08
Type of Material Miscellaneous Material
Quantity of Material 3,000 SF

Material Location
First and second floors

Material Description
Floor Tile Mastic

Comments
Material is not exposed, but is assumed to be in good condition.

Does Material Contain Asbestos? Assumed
Is it Friable? No
Original Inspection Date 6/ 1/88
Current Surveillance Date 7/ 3/97
Current Assessment Rating NR Not Required
Cause of Damage No Damage
Accessible Yes
Potential for Damage Low
Removed No
Planned Response Action O & M

Inspector



Karen Foxx

State Indiana
Accreditation Number 191129014

PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools

Building Name Jeffersonville High School

HA# A

Type of Material Miscellaneous Material

Quantity of Material 3,000 SF

Material Location
Throughout the building

Material Description
Cove Base Molding

Comments
Material is in good condition.

Does Material Contain Asbestos? Assumed

Is it Friable? No

Original Inspection Date 5/31/95

Current Surveillance Date 7/ 3/97

Current Assessment Rating NR Not Required

Cause of Damage No Damage

Accessible Yes

Potential for Damage Low

Removed No

Planned Response Action O & M

Inspector



Karen Foxx

State Indiana

Accreditation Number 191129014

PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools

Building Name Jeffersonville High School

HA# B

Type of Material Miscellaneous Material

Quantity of Material 3,000 SF

Material Location
Throughout the building

Material Description
Cove Base Mastic

Comments
Material is not exposed and is assumed to be in good condition.

Does Material Contain Asbestos? Assumed

Is it Friable? No

Original Inspection Date 5/31/95

Current Surveillance Date 7/ 3/97

Current Assessment Rating NR Not Required

Cause of Damage No Damage

Accessible No

Potential for Damage Low

Removed No

Planned Response Action O & M

Inspector



Karen Foxx

State Indiana

Accreditation Number 191129014

PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools
Building Name Jeffersonville High School
HA# C
Type of Material Miscellaneous Material
Quantity of Material SF

Material Location
Second floor balcony and around the gymnasium

Material Description
Transite Walls

Comments
Was not addressed in the original inspection. Material is in good condition.

Does Material Contain Asbestos? Assumed
Is it Friable? No
Original Inspection Date 6/24/96
Current Surveillance Date 7/ 3/97
Current Assessment Rating NR Not Required
Cause of Damage No Damage
Accessible Yes
Potential for Damage Low
Removed No
Planned Response Action O & M

Inspector



Karen Foxx


State Indiana
Accreditation Number 191129014

PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools
Building Name Jeffersonville High School
HA# 01
Type of Material Miscellaneous Material
Quantity of Material 132 SF
Material Location
Boiler Room
Material Description
Gaskets on Boilers
Comments
Good condition. No change.

Does Material Contain Asbestos? Assumed
Is it Friable? No
Original Inspection Date 6/ 1/88
Current Surveillance Date 12/16/96
Current Assessment Rating NR Not Required
Cause of Damage No Damage
Accessible Yes
Potential for Damage Low
Removed No
Planned Response Action O & M

Inspector



Clint Yates

State Indiana
Accreditation Number 193804035

PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools

Building Name Jeffersonville High School

HA# 02

Type of Material Thermal Material

Quantity of Material 1,800 SF

Material Location
Boiler Room

Material Description
Boiler Insulation on 2 Boilers

Comments

One boiler was removed in 05/95. The two remaining boilers have minor damage. O & M is needed. No change.

Does Material Contain Asbestos? Yes

Is it Friable? Yes

Original Inspection Date 6/ 1/88

Current Surveillance Date 12/16/96

Current Assessment Rating 1B Damaged TSI

Cause of Damage Physical Damage


Accessible Yes

Potential for Damage Med

Removed No

Planned Response Action O & M

Inspector



Clint Yates

State Indiana


Accreditation Number 193804035

PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools
Building Name Jeffersonville High School
HA# 03
Type of Material Thermal Material
Quantity of Material 222 LF
Material Location
 Boiler Room
Material Description
 3" and 12" Fittings
Comments
 Some minor damage. No change.

Does Material Contain Asbestos? Yes
Is it Friable? Yes
Original Inspection Date 6/ 1/88
Current Surveillance Date 12/16/96
Current Assessment Rating 1B Damaged TSI
Cause of Damage Physical Damage
Accessible Yes
Potential for Damage Med
Removed No
Planned Response Action O & M

Inspector



Clint Yates

State

Indiana

Accreditation Number


193804035

PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools
Building Name Jeffersonville High School
HA# 05
Type of Material Miscellaneous Material
Quantity of Material 548 SF
Material Location
 First and second floors
Material Description
 Floor Tile
Comments
 Good condition. No change.

Does Material Contain Asbestos? Yes
Is it Friable? No
Original Inspection Date 6/ 1/88
Current Surveillance Date 12/16/96
Current Assessment Rating NR Not Required
Cause of Damage No Damage
Accessible Yes
Potential for Damage Low
Removed No
Planned Response Action O & M

Inspector


Clint Yates

State

Indiana

Accreditation Number

193804035

PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools

Building Name Jeffersonville High School

HA# 08

Type of Material Miscellaneous Material

Quantity of Material 3,000 SF

Material Location

First and second floors

Material Description

Floor Tile Mastic

Comments

Material is assumed to be positive. Material is in good condition. No change.

Does Material Contain Asbestos? Assumed

Is it Friable? No

Original Inspection Date 6/ 1/88

Current Surveillance Date 12/16/96

Current Assessment Rating NR Not Required

Cause of Damage No Damage

Accessible Yes

Potential for Damage Low

Removed No

Planned Response Action O & M

Inspector



Clint Yates

State Indiana

Accreditation Number 193804035

PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools

Building Name Jeffersonville High School

HA# A

Type of Material Miscellaneous Material

Quantity of Material 3,000 SF

Material Location
Throughout the building

Material Description
Cove Base Molding

Comments
Material is assumed to be positive until analyzed. It is in good condition.

Does Material Contain Asbestos? Assumed

Is it Friable? No

Original Inspection Date 5/31/95

Current Surveillance Date 12/16/96

Current Assessment Rating NR Not Required

Cause of Damage No Damage


Accessible Yes

Potential for Damage Low

Removed No

Planned Response Action O & M

Inspector


Clint Yates

State Indiana

Accreditation Number 193804035

PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools

Building Name Jeffersonville High School

HA# B

Type of Material Miscellaneous Material

Quantity of Material 3,000 SF

Material Location

Throughout the building

Material Description

Cove Base Mastic

Comments

Material is assumed positive for the presence of asbestos containing materials until analyzed.

Does Material Contain Asbestos? Assumed

Is it Friable? No

Original Inspection Date 5/31/95

Current Surveillance Date 12/16/96

Current Assessment Rating NR Not Required

Cause of Damage No Damage

Accessible No

Potential for Damage Low

Removed No

Planned Response Action O & M

Inspector


Clint Yates

State Indiana

Accreditation Number 193804035

PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools
Building Name Jeffersonville High School
HA# 01
Type of Material Miscellaneous Material
Quantity of Material 132 SF
Material Location
Boiler Room
Material Description
Gaskets on Boilers
Comments
Good condition. No change.

Does Material Contain Asbestos? Assumed
Is it Friable? No
Original Inspection Date 6/ 1/88
Current Surveillance Date 6/24/96
Current Assessment Rating NR Not Required
Cause of Damage No Damage
Accessible Yes
Potential for Damage Low
Removed No
Planned Response Action O & M

Inspector



Rex Gaddis

State Indiana
Accreditation Number 190908032

PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools

Building Name Jeffersonville High School

HA# 02

Type of Material Thermal Material

Quantity of Material 1,800 SF

Material Location
Boiler Room

Material Description
Boiler Insulation on 2 Boilers

Comments

One boiler was removed in 05/95. The two remaining boilers have minor damage. O & M is needed. No change.

Does Material Contain Asbestos? Yes
Is it Friable? Yes
Original Inspection Date 6/ 1/88
Current Surveillance Date 6/24/96
Current Assessment Rating 1B Damaged TSI
Cause of Damage Physical Damage
Accessible Yes
Potential for Damage Med
Removed No
Planned Response Action O & M

Inspector



Rex Gaddis

State Indiana


Accreditation Number 190908032

PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools
Building Name Jeffersonville High School
HA# 03
Type of Material Thermal Material
Quantity of Material 222 LF
Material Location
Boiler Room
Material Description
3" and 12" Fittings
Comments
Some minor damage. No change.

Does Material Contain Asbestos? Yes
Is it Friable? Yes
Original Inspection Date 6/ 1/88
Current Surveillance Date 6/24/96
Current Assessment Rating 1B Damaged TSI
Cause of Damage Physical Damage
Accessible Yes
Potential for Damage Med
Removed No
Planned Response Action O & M

Inspector



Rex Gaddis


State Indiana
Accreditation Number 190908032

PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools
Building Name Jeffersonville High School
HA# 05
Type of Material Miscellaneous Material
Quantity of Material 548 SF
Material Location
First and second floors
Material Description
Floor Tile
Comments
Good condition. No change.

Does Material Contain Asbestos? Assumed
Is it Friable? No
Original Inspection Date 6/ 1/88
Current Surveillance Date 6/24/96
Current Assessment Rating NR Not Required
Cause of Damage No Damage
Accessible Yes
Potential for Damage Low
Removed No
Planned Response Action O & M

Inspector



Rex Gaddis

State Indiana
Accreditation Number 190908032

PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools

Building Name Jeffersonville High School

HA# 08

Type of Material Miscellaneous Material

Quantity of Material 3,000 SF

Material Location
First and second floors

Material Description
Floor Tile Mastic

Comments
Material is assumed to be positive. Material is in good condition. No change.

Does Material Contain Asbestos? Assumed

Is it Friable? No

Original Inspection Date 6/ 1/88

Current Surveillance Date 6/24/96

Current Assessment Rating NR Not Required

Cause of Damage No Damage

Accessible Yes

Potential for Damage Low

Removed No

Planned Response Action O & M

Inspector



Rex Gaddis

State Indiana

Accreditation Number 190908032

PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools

Building Name Jeffersonville High School

HA# A

Type of Material Miscellaneous Material

Quantity of Material 3,000 SF


Material Location
Throughout the building

Material Description
Cove Base Molding

Comments
Material is assumed to be positive until analyzed. It is in good condition.

Does Material Contain Asbestos? Assumed
Is it Friable? No
Original Inspection Date 5/31/95
Current Surveillance Date 6/24/96
Current Assessment Rating NR Not Required
Cause of Damage No Damage
Accessible Yes
Potential for Damage Low
Removed No
Planned Response Action O & M

Inspector



Rex Gaddis

State Indiana

Accreditation Number 190908032

PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools
Building Name Jeffersonville High School
HA# B
Type of Material Miscellaneous Material
Quantity of Material 3,000 SF


Material Location
Throughout the building

Material Description
Cove Base Mastic

Comments
Material is assumed positive for the presence of asbestos containing materials until analyzed.

Does Material Contain Asbestos? Assumed
Is it Friable? No
Original Inspection Date 5/31/95
Current Surveillance Date 6/24/96
Current Assessment Rating NR Not Required
Cause of Damage No Damage
Accessible No
Potential for Damage Low
Removed No
Planned Response Action O & M

Inspector



Rex Gaddis

State Indiana
Accreditation Number 190908032

PERIODIC SURVEILLANCE REPORT

LEA NAME: Greater Clark County Schools

BUILDING NAME: Jeffersonville High School

HA#: 01

TYPE OF MATERIAL: Miscellaneous Material

QUANTITY OF MATERIAL: 132SF

MATERIAL LOCATION:

Boiler Room

MATERIAL DESCRIPTION:

Gaskets on boilers

COMMENTS:

Good condition

IS MATERIAL FRIABLE? NO

ORIGINAL INSPECTION DATE: 06/01/88

CURRENT SURVEILLANCE DATE: 12/06/95

CURRENT ASSESSMENT RATING: NR Not Required

CAUSE OF DAMAGE: No Damage


ACCESSIBLE: YES

POTENTIAL FOR DAMAGE: Low

REMOVED: NO

STATE: Indiana

INSPECTOR NAME:


Clint Yates

PERIODIC SURVEILLANCE REPORT

LEA NAME: Greater Clark County Schools
BUILDING NAME: Jeffersonville High School
HA#: 02
TYPE OF MATERIAL: Thermal Material
QUANTITY OF MATERIAL: 1,800SF
MATERIAL LOCATION:

Boiler Room

MATERIAL DESCRIPTION:


Boiler Insulation on 2 Boilers

COMMENTS:

One boiler was removed in 05/95. Liberty Environmental (contractor) removed all TSI prior to boiler removal. The two remaining boilers have minor damage. O & M is needed.

IS MATERIAL FRIABLE? YES
ORIGINAL INSPECTION DATE: 06/01/88
CURRENT SURVEILLANCE DATE: 12/06/95
CURRENT ASSESSMENT RATING: 1B Damaged TSI
CAUSE OF DAMAGE: Physical Damage
ACCESSIBLE: YES
POTENTIAL FOR DAMAGE: Med
REMOVED: NO
STATE: Indiana

INSPECTOR NAME:


Clint Yates

PERIODIC SURVEILLANCE REPORT

LEA NAME: Greater Clark County Schools

BUILDING NAME: Jeffersonville High School

HA#: 03

TYPE OF MATERIAL: Thermal Material

QUANTITY OF MATERIAL: 222LF

MATERIAL LOCATION:

Boiler Room

MATERIAL DESCRIPTION:


3" and 12" fittings

COMMENTS:

Some minor damage

IS MATERIAL FRIABLE? YES
ORIGINAL INSPECTION DATE: 06/01/88
CURRENT SURVEILLANCE DATE: 12/06/95
CURRENT ASSESSMENT RATING: 1B Damaged TSI
CAUSE OF DAMAGE: Physical Damage
ACCESSIBLE: YES
POTENTIAL FOR DAMAGE: Med
REMOVED: NO
STATE: Indiana

INSPECTOR NAME:


Clint Yates

PERIODIC SURVEILLANCE REPORT

LEA NAME: Greater Clark County Schools

BUILDING NAME: Jeffersonville High School

HA#: 05

TYPE OF MATERIAL: Miscellaneous Material

QUANTITY OF MATERIAL: 548SF

MATERIAL LOCATION:

First and second floors

MATERIAL DESCRIPTION:

Floor tile

COMMENTS:

Good Condition

IS MATERIAL FRIABLE? NO

ORIGINAL INSPECTION DATE: 06/01/88

CURRENT SURVEILLANCE DATE: 12/06/95

CURRENT ASSESSMENT RATING: NR Not Required

CAUSE OF DAMAGE: No Damage


ACCESSIBLE: YES

POTENTIAL FOR DAMAGE: Low

REMOVED: NO

STATE: Indiana

INSPECTOR NAME:


Clint Yates

PERIODIC SURVEILLANCE REPORT

LEA NAME: Greater Clark County Schools

BUILDING NAME: Jeffersonville High School

HA#: 08

TYPE OF MATERIAL: Miscellaneous Material

QUANTITY OF MATERIAL: 3,000SF

MATERIAL LOCATION:

First and second floors

MATERIAL DESCRIPTION:

Floor tile mastic

COMMENTS:

Material is assumed to be positive. Material is in good condition.

IS MATERIAL FRIABLE? NO

ORIGINAL INSPECTION DATE: 06/01/88

CURRENT SURVEILLANCE DATE: 12/06/95

CURRENT ASSESSMENT RATING: NR Not Required

CAUSE OF DAMAGE: No Damage


ACCESSIBLE: YES

POTENTIAL FOR DAMAGE: Low

REMOVED: NO

STATE: Indiana

INSPECTOR NAME:


Clint Yates

PERIODIC SURVEILLANCE REPORT

LEA NAME: Greater Clark County Schools
BUILDING NAME: Jeffersonville High School
HA#: A
TYPE OF MATERIAL: Miscellaneous Material
QUANTITY OF MATERIAL: 3,000SF

MATERIAL LOCATION:

Throughout the building

MATERIAL DESCRIPTION:

Cove-base molding

COMMENTS:

Material was not addressed in the original inspection. It is a suspect material that is assumed to be positive until analyzed. It is in good condition.

IS MATERIAL FRIABLE? NO
ORIGINAL INSPECTION DATE:
CURRENT SURVEILLANCE DATE: 12/06/95
CURRENT ASSESSMENT RATING: NR Not Required
CAUSE OF DAMAGE: No Damage
ACCESSIBLE: YES
POTENTIAL FOR DAMAGE: Low
REMOVED: NO
STATE: Indiana

INSPECTOR NAME:


Clint Yates

PERIODIC SURVEILLANCE REPORT

LEA NAME: Greater Clark County Schools
BUILDING NAME: Jeffersonville High School
HA#: B
TYPE OF MATERIAL: Miscellaneous Material
QUANTITY OF MATERIAL: 3,000SF
MATERIAL LOCATION:

Throughout the building

MATERIAL DESCRIPTION:

Cove-base mastic

COMMENTS:

Was not addressed in the original inspection. Material will be assumed positive for the presence of asbestos-containing materials until analyzed by an accredited NVLAP laboratory.

IS MATERIAL FRIABLE? NO
ORIGINAL INSPECTION DATE:
CURRENT SURVEILLANCE DATE: 12/06/95
CURRENT ASSESSMENT RATING: NR Not Required
CAUSE OF DAMAGE: No Damage
ACCESSIBLE: NO
POTENTIAL FOR DAMAGE: Low
REMOVED: NO
STATE: Indiana

INSPECTOR NAME:


Clint Yates



THIRD YEAR REINSPECTIONS

REINSPECTION PLAN**GREATER CLARK COUNTY SCHOOLS**

Reinspection by an accredited building inspector will be scheduled to be performed not more than three years from the date of the original inspection. The reinspection report will then be made a permanent part of this Management Plan. Reinspections will be performed every three years for as long as the building contains ACBM, and will be reinspected once within three years from the date that all ACBM has been removed.

Records of each reinspection should be maintained in this binder.

DATE PLANNED**DATE COMPLETED****COMPLETED BY**

<u>JUNE 2007</u>	<u>July 2007</u>	<u>Bill Ogle</u>
<u>JUNE 2010</u>	<u>June 2010</u>	<u>Sandy Shadley</u>
<u>JUNE 2013</u>	<u>April 2013</u>	<u>Jeff Nechtin</u>
<u>JUNE 2016</u>	<u>April 2016</u>	<u>Benjamin B</u>
<u>JUNE 2019</u>	<u>May 2019</u>	<u>[Signature]</u>
<u>JUNE 2022</u>	<u>_____</u>	<u>_____</u>
<u>JUNE 2025</u>	<u>_____</u>	<u>_____</u>

REINSPECTION PLAN

GREATER CLARK COUNTY SCHOOLS

JEFFERSONVILLE HIGH SCHOOL

The ACBM in this building shall be reinspected every three years to determine any change in the condition of the materials for as long they remain in the building. This reinspection will be conducted tri-annually by an accredited inspector.

The following table outlines the dates on which these inspections should take place in this school building.

REINSPECTION SCHEDULE

<u>DATE PLANNED</u>	<u>DATE COMPLETED</u>	<u>COMPLETED BY</u>
<u>JUNE 1992</u>	<u>JUNE 1992</u>	<u>ASBESTECH</u>
<u>JUNE 1995</u>	<u>June '95</u>	<u>Alliance</u>
<u>JUNE 1998</u>	<u>June '98</u>	<u>Alliance</u>
<u>JUNE 2001</u>	<u>July '01</u>	<u>P. Wilson</u>
<u>JUNE 2004</u>	<u>July '04</u>	<u>C. Spacks</u>

Triennial Reinspection

LEA Name Greater Clark County School Corporation
Building Name Jeffersonville High School
Building Number 11
HA ID 03
HA Description 3" Fittings (Domestic hot and cold)
HA Type Thermal System Insulation (TSI)
HA Location Mechanical rooms (Basement off of elevator)

Quantity 26 Unit(s)
Comments The remaining fittings are in the custodial room (19), boiler room (3), chiller room (5) and electrical room (3). The remaining fittings are not in poor condition.
Asbestos Known
Friable Yes
Original Inspection 6/1/1988
Current Inspection 5/16/2019

Material Assessment

Assessment Rating 5 ACBM with potential for damage

Damage Assessment and Potential for Damage

<u>Percent Damaged</u>	%	Good Condition
<u>Physical Contact</u>	<u>Vibration</u>	<u>Air</u>
Low/None	Low/None	Low/None

Planned Response Action O&M

Inspector



Sean Stults

State IN

Accreditation Number 19A007184

Triennial Reinspection

LEA Name Greater Clark County School Corporation
Building Name Jeffersonville High School
Building Number 11
HA ID 05
HA Description Floor Tile
HA Type Miscellaneous Material
HA Location Elevator

Quantity 40 SF
Comments This material was removed and replaced. It will be removed from the management plan.
Asbestos Known
Friable No

Original Inspection 6/1/1988
Current Inspection 5/16/2019

Material Assessment

Assessment Rating 5 ACBM with potential for damage

Damage Assessment and Potential for Damage

<u>Percent Damaged</u>	%	Good Condition
<u>Physical Contact</u>	<u>Vibration</u>	<u>Air</u>
Low/None	Low/None	Low/None

Planned Response Action O&M

Inspector



Sean Stults

State IN

Accreditation Number 19A007184

Triennial Reinspection

LEA Name Greater Clark County School Corporation
Building Name Jeffersonville High School
Building Number 11
HA ID 08
HA Description Floor tile mastic
HA Type Miscellaneous Material
HA Location First and second floors

Quantity 3000 SF
Comments Where exposed on the elevator, this material was not in poor condition. The mastic was sealed and left in place under new floor tile.
Asbestos Assumed
Friable No
Original Inspection 6/1/1988
Current Inspection 5/16/2019

Material Assessment

Assessment Rating 5 ACBM with potential for damage

Damage Assessment and Potential for Damage

<u>Percent Damaged</u>	%	Good Condition	
<u>Physical Contact</u>		<u>Vibration</u>	<u>Air</u>
Low/None		Low/None	Low/None

Planned Response Action O&M

Inspector



Sean Stults

State IN

Accreditation Number 19A007184

Triennial Reinspection

LEA Name Greater Clark County School Corporation
Building Name Jeffersonville High School
Building Number 11
HA ID B
HA Description Cove base mastic
HA Type Miscellaneous Material
HA Location Throughout building

Quantity Unquantified LF
Comments Mastic was not visible to inspect newer cove base has been placed over older cove base mastic.
Asbestos Assumed
Friable No
Original Inspection 5/31/1995
Current Inspection 5/16/2019

Material Assessment

Assessment Rating 5 ACBM with potential for damage

Damage Assessment and Potential for Damage

Percent Damaged % Good Condition

<u>Physical Contact</u>	<u>Vibration</u>	<u>Air</u>
Low/None	Low/None	Low/None

Planned Response Action O&M

Inspector



Sean Stults

State IN

Accreditation Number 19A007184

Triennial Reinspection

LEA Name Greater Clark County School Corporation
Building Name Jeffersonville High School
Building Number 11
HA ID 03
HA Description 3" Fittings (Domestic hot and cold)
HA Type Thermal System Insulation (TSI)
HA Location Mechanical rooms (Basement off of elevator)

Quantity 26 Unit(s)
Comments The remaining fittings are in the custodial room (19), boiler room (3), chiller room (5) and electrical room (3). The remaining fittings are not in poor condition.
Asbestos Known
Friable Yes
Original Inspection 6/1/1988
Current Inspection 4/27/2016

Material Assessment

Assessment Rating 5 ACBM with potential for damage

Damage Assessment and Potential for Damage

Percent Damaged	%	Good Condition	
Physical Contact		Vibration	Air
Low/None		Low/None	Low/None

Planned Response Action O&M

Inspector



Benjamin S. Hood

State IN

Accreditation Number 19A001039

Triennial Reinspection

LEA Name Greater Clark County School Corporation
Building Name Jeffersonville High School
Building Number 11
HA ID 05
HA Description Floor Tile
HA Type Miscellaneous Material
HA Location Elevator

Quantity 40 SF
Comments This material was removed and replaced. It will be removed from the management plan.
Asbestos Known
Friable No
Original Inspection 6/1/1988
Current Inspection 4/27/2016

Material Assessment

Assessment Rating 5 ACBM with potential for damage

Damage Assessment and Potential for Damage

Percent Damaged % Good Condition

<u>Physical Contact</u>	<u>Vibration</u>	<u>Air</u>
Low/None	Low/None	Low/None

Planned Response Action O&M

Inspector



Benjamin S. Hood

State IN

Accreditation Number 19A001039

Triennial Reinspection

LEA Name Greater Clark County School Corporation
Building Name Jeffersonville High School
Building Number 11
HA ID 08
HA Description Floor tile mastic
HA Type Miscellaneous Material
HA Location First and second floors

Quantity 3000 SF
Comments Where exposed on the elevator, this material was not in poor condition. The mastic was sealed and left in place under new floor tile.
Asbestos Assumed
Friable No
Original Inspection 6/1/1988
Current Inspection 4/27/2016

Material Assessment

Assessment Rating 5 ACBM with potential for damage

Damage Assessment and Potential for Damage

<u>Percent Damaged</u>	%	Good Condition	
<u>Physical Contact</u>		<u>Vibration</u>	<u>Air</u>
Low/None		Low/None	Low/None

Planned Response Action O&M

Inspector



Benjamin S. Hood

State IN

Accreditation Number 19A001039

Triennial Reinspection

LEA Name Greater Clark County School Corporation
Building Name Jeffersonville High School
Building Number 11
HA ID B
HA Description Cove base mastic
HA Type Miscellaneous Material
HA Location Throughout building

Quantity Unquantified LF
Comments Mastic was not visible to inspect newer cove base has been placed over older cove base mastic.
Asbestos Assumed
Friable No
Original Inspection 5/31/1995
Current Inspection 4/27/2016

Material Assessment

Assessment Rating 5 ACBM with potential for damage

Damage Assessment and Potential for Damage

Percent Damaged % Good Condition

<u>Physical Contact</u>	<u>Vibration</u>	<u>Air</u>
Low/None	Low/None	Low/None

Planned Response Action O&M

Inspector



Benjamin S. Hood

State IN

Accreditation Number 19A001039

THIRD YEAR REINSPECTION REPORT

LEA Name Greater Clark County Schools
Building Name Jeffersonville High School
HA# 03
Type of Material Thermal Material
Quantity of Material 26 EA
Material Location

Boiler room area (Basement off of elevator)

Material Description

3" Fittings (Domestic hot and cold)

Comments

The remaining fittings are in the custodial room (19), boiler room (4), and electrical room (3). The remaining fittings are not in poor condition.

Does Material Contain Asbestos? Yes
Is it Friable? No
Original Inspection Date 6/1/1988
Current Reinspection Date 4/24/2013
Current Assessment Rating NR Not Rated
Cause of Damage No Damage
Accessible Yes
Potential for Damage Med
Removed No
Planned Response Action O & M

Inspector



Jeffrey P. Rehtin

State

Indiana

Accreditation Number

19A003594


THIRD YEAR REINSPECTION REPORT

LEA Name Greater Clark County Schools
Building Name Jeffersonville High School
HA# 05
Type of Material Miscellaneous Material
Quantity of Material 40 SF
Material Location Elevator
Material Description Floor tile
Comments

There are broken edges, however, this material was not in poor condition overall.

Does Material Contain Asbestos? Yes
Is it Friable? No
Original Inspection Date 6/1/1988
Current Reinspection Date 4/24/2013
Current Assessment Rating NR Not Rated
Cause of Damage Physical Damage
Accessible Yes
Potential for Damage Low
Removed No
Planned Response Action O & M

Inspector



Jeffrey P. Rehtin

State

Indiana

Accreditation Number

19A003594

THIRD YEAR REINSPECTION REPORT

LEA Name Greater Clark County Schools
Building Name Jeffersonville High School
HA# 08
Type of Material Miscellaneous Material
Quantity of Material 3,000 SF
Material Location

First and second floors

Material Description

Floor tile mastic

Comments

Where exposed on the elevator, this material was not in poor condition. The mastic was sealed and left in place under new floor tile.

Does Material Contain Asbestos? Assumed
Is it Friable? No
Original Inspection Date 6/1/1988
Current Reinspection Date 4/24/2013
Current Assessment Rating NR Not Rated
Cause of Damage No Damage
Accessible No
Potential for Damage Low
Removed No
Planned Response Action O & M

Inspector



Jeffrey P. Rehtin

State

Indiana

Accreditation Number

19A003594

THIRD YEAR REINSPECTION REPORT

LEA Name Greater Clark County Schools
Building Name Jeffersonville High School
HA# B
Type of Material Miscellaneous Material
Quantity of Material Unquantified LF
Material Location

Throughout the building

Material Description

Cove base mastic

Comments

Mastic was not visible to inspect newer cove base has been placed over older cove base mastic.

Does Material Contain Asbestos? Assumed
Is it Friable? No
Original Inspection Date 5/31/1995
Current Reinspection Date 4/24/2013
Current Assessment Rating NR Not Rated
Cause of Damage No Damage
Accessible No
Potential for Damage Low
Removed No
Planned Response Action O & M

Inspector



Jeffrey P. Rehtin

State Indiana
Accreditation Number 19A003594

THIRD YEAR REINSPECTION REPORT

LEA Name Greater Clark County Schools
Building Name Jeffersonville High School
HA# 03
Type of Material Thermal Material
Quantity of Material 24 EA

Material Location
Boiler room area (Basement off of elevator)

Material Description
3" Fittings

Comments

Most of the fittings were removed by a licensed contractor in 2008. Some were also removed during routine O & M repairs. The remaining fittings are not in poor condition.

Does Material Contain Asbestos? Yes
Is it Friable? No
Original Inspection Date 6/1/1988
Current Reinspection Date 6/30/2010
Current Assessment Rating NR Not Required
Cause of Damage No Damage
Accessible Yes
Potential for Damage Med
Removed No
Planned Response Action O & M

Inspector


Sandra Shadley

State IN
Accreditation Number 19A002323

THIRD YEAR REINSPECTION REPORT

LEA Name Greater Clark County Schools

Building Name Jeffersonville High School

HA# 05

Type of Material Miscellaneous Material

Quantity of Material 50 SF

Material Location

Elevator

Material Description

Floor tile

Comments

There are a few broken edges in the elevator, however, this material was not in poor condition overall. The first and second floor corridor tile were removed in a non-friable manner as part of the renovation in 2008.

Does Material Contain Asbestos? Yes

Is it Friable? No

Original Inspection Date 6/1/1988

Current Reinspection Date 6/30/2010

Current Assessment Rating NR Not Required

Cause of Damage Physical Damage

Accessible Yes

Potential for Damage Low

Removed No

Planned Response Action O & M

Inspector


Sandra Shadley

State IN

Accreditation Number 19A002323

THIRD YEAR REINSPECTION REPORT

LEA Name Greater Clark County Schools
Building Name Jeffersonville High School
HA# 08
Type of Material Miscellaneous Material
Quantity of Material 3,000 SF
Material Location
First and second floors

Material Description


Floor tile mastic

Comments

Where exposed on the elevator, this material was not in poor condition. The mastic was sealed and left in place under new floor tile.

Does Material Contain Asbestos? Assumed
Is it Friable? No
Original Inspection Date 6/1/1988
Current Reinspection Date 6/30/2010
Current Assessment Rating NR Not Required
Cause of Damage No Damage
Accessible No
Potential for Damage Low
Removed No
Planned Response Action O & M

Inspector


Sandra Shadley

State IN
Accreditation Number 19A002323

THIRD YEAR REINSPECTION REPORT

LEA Name Greater Clark County Schools
Building Name Jeffersonville High School
HA# A
Type of Material Miscellaneous Material
Quantity of Material 0 LF

Material Location
Elevator corridor on second floor

Material Description


Cove base molding

Comments

This material was removed in a non-friable manner during renovation activities in 2008; therefore, this material is being removed from the management plan.

Does Material Contain Asbestos? Assumed
Is it Friable? No
Original Inspection Date 5/31/1995
Current Reinspection Date 6/30/2010
Current Assessment Rating NR Not Required
Cause of Damage No Damage
Accessible Yes
Potential for Damage Low
Removed Yes
Planned Response Action O & M

Inspector


Sandra Shadley

State IN
Accreditation Number 19A002323

THIRD YEAR REINSPECTION REPORT

LEA Name Greater Clark County Schools
Building Name Jeffersonville High School
HA# B
Type of Material Miscellaneous Material
Quantity of Material Unquantified LF

Material Location
Throughout the building

Material Description
Cove base mastic

Comments
Mastic was visible to inspect throughout most of the hallways where the newer cove base has been removed exposing the old cove base mastic..

Does Material Contain Asbestos? Assumed
Is it Friable? No
Original Inspection Date 5/31/1995
Current Reinspection Date 6/30/2010
Current Assessment Rating NR Not Required
Cause of Damage No Damage
Accessible No
Potential for Damage Low
Removed No
Planned Response Action O & M

Inspector


Sandra Shadley

State IN
Accreditation Number 19A002323

THIRD YEAR REINSPECTION REPORT

LEA Name Greater Clark County Schools
Building Name Jeffersonville High School
HA# 01
Type of Material Miscellaneous Material
Quantity of Material 52 LF
Material Location
Boiler room
Material Description


Gaskets on boilers

Comments

The visible edges of this material were not in poor condition. Boiler doors were closed except on the smallest boiler which has a newer fiberglass gasket on the front.

Does Material Contain Asbestos? Assumed
Is it Friable? No
Original Inspection Date 6/1/1988
Current Reinspection Date 7/9/2007
Current Assessment Rating NR Not Required
Cause of Damage No Damage
Accessible No
Potential for Damage Low
Removed No
Planned Response Action O & M

Inspector


George William Ogle

State Indiana
Accreditation Number 191003027

THIRD YEAR REINSPECTION REPORT

LEA Name Greater Clark County Schools
Building Name Jeffersonville High School
HA# 02
Type of Material Thermal Material
Quantity of Material 1,800 SF
Material Location
Boiler room
Material Description

Boiler insulation on 2 boilers

Comments

This material was not in poor condition, although there area a few spots of deterioration on the sides.

Does Material Contain Asbestos? Yes
Is it Friable? No
Original Inspection Date 6/1/1988
Current Reinspection Date 7/9/2007
Current Assessment Rating NR Not Required
Cause of Damage No Damage
Accessible Yes
Potential for Damage Med
Removed No
Planned Response Action O & M

Inspector


George William Ogle

State Indiana
Accreditation Number 191003027

THIRD YEAR REINSPECTION REPORT

LEA Name Greater Clark County Schools

Building Name Jeffersonville High School

HA# 03

Type of Material Thermal Material

Quantity of Material 222 LF

Material Location
Boiler room

Material Description
3" and 12" fittings

Comments

This material showed minor delamination on a few fittings, but was not in poor condition overall.

Does Material Contain Asbestos? Yes

Is it Friable? No

Original Inspection Date 6/1/1988

Current Reinspection Date 7/9/2007

Current Assessment Rating NR Not Required

Cause of Damage No Damage

Accessible Yes

Potential for Damage Med

Removed No

Planned Response Action O & M

Inspector


George William Ogle

State Indiana

Accreditation Number 191003027

THIRD YEAR REINSPECTION REPORT

LEA Name Greater Clark County Schools

Building Name Jeffersonville High School

HA# 05

Type of Material Miscellaneous Material

Quantity of Material 548 SF

Material Location

First and second floors

Material Description

Floor tile

Comments

There are a few broken edges in the elevator and part of a tile missing in the first floor elevator corridor. However, this material was not in poor condition overall.

Does Material Contain Asbestos? Yes

Is it Friable? No

Original Inspection Date 6/1/1988

Current Reinspection Date 7/9/2007

Current Assessment Rating NR Not Required

Cause of Damage Physical Damage

Accessible Yes

Potential for Damage Low

Removed No

Planned Response Action O & M

Inspector


George William Ogle

State Indiana

Accreditation Number 191003027

THIRD YEAR REINSPECTION REPORT

LEA Name Greater Clark County Schools

Building Name Jeffersonville High School

HA# 08

Type of Material Miscellaneous Material

Quantity of Material 3,000 SF

Material Location

First and second floors

Material Description

Floor tile mastic

Comments

Where exposed on the first floor and on the elevator, this material was not in poor condition.

Does Material Contain Asbestos? Assumed

Is it Friable? No

Original Inspection Date 6/1/1988

Current Reinspection Date 7/9/2007

Current Assessment Rating NR Not Required

Cause of Damage No Damage

Accessible No

Potential for Damage Low

Removed No

Planned Response Action O & M

Inspector


George William Ogle

State Indiana

Accreditation Number 191003027

THIRD YEAR REINSPECTION REPORT

LEA Name Greater Clark County Schools
Building Name Jeffersonville High School
HA# A
Type of Material Miscellaneous Material
Quantity of Material 60 LF

Material Location
Elevator corridors


Material Description
Cove base molding

Comments

All cove base is new except for the elevator corridors on the 1st and 2nd floor and in the elevator. This material was not in poor condition.

Does Material Contain Asbestos? Assumed
Is it Friable? No
Original Inspection Date 5/31/1995
Current Reinspection Date 7/9/2007
Current Assessment Rating NR Not Required
Cause of Damage No Damage
Accessible Yes
Potential for Damage Low
Removed No
Planned Response Action O & M

Inspector



George William Ogje

State Indiana
Accreditation Number 191003027

THIRD YEAR REINSPECTION REPORT

LEA Name Greater Clark County Schools
Building Name Jeffersonville High School
HA# B
Type of Material Miscellaneous Material
Quantity of Material Unquantified LF
Material Location
Throughout the building
Material Description
Cove base mastic
Comments
No mastic was visible to inspect.
Does Material Contain Asbestos? Assumed
Is it Friable? No
Original Inspection Date 5/31/1995
Current Reinspection Date 7/9/2007
Current Assessment Rating NR Not Required
Cause of Damage No Damage
Accessible No
Potential for Damage Low
Removed No
Planned Response Action O & M

Inspector


George William Ogle

State

Indiana

Accreditation Number

191003027

THIRD YEAR REINSPECTION REPORT

LEA Name Greater Clark County Schools
Building Name Jeffersonville High School
HA# 01
Type of Material Miscellaneous Material
Quantity of Material 52 LF
Material Location
Boiler room
Material Description
Gaskets on boilers

Comments

The visible edges of this material were not in poor condition. Boiler doors were closed.

Does Material Contain Asbestos? Assumed
Is it Friable? No
Original Inspection Date 6/1/1988
Current Reinspection Date 7/2/2004
Current Assessment Rating NR Not Required
Cause of Damage No Damage
Accessible No
Potential for Damage Low
Removed No
Planned Response Action O & M

Inspector



Christian Sparks

State Indiana
Accreditation Number 190804103

THIRD YEAR REINSPECTION REPORT

LEA Name Greater Clark County Schools
Building Name Jeffersonville High School
HA# 02
Type of Material Thermal Material
Quantity of Material 1,800 SF
Material Location
Boiler room
Material Description
Boiler insulation on 2 boilers

Comments

This material was not in poor condition.

Does Material Contain Asbestos? Yes
Is it Friable? No
Original Inspection Date 6/1/1988
Current Reinspection Date 7/2/2004
Current Assessment Rating NR Not Required
Cause of Damage No Damage
Accessible Yes
Potential for Damage Med
Removed No
Planned Response Action O & M

Inspector



Christiaan Sparks

State Indiana
Accreditation Number 190804103

THIRD YEAR REINSPECTION REPORT

LEA Name Greater Clark County Schools
Building Name Jeffersonville High School
HA# 03
Type of Material Thermal Material
Quantity of Material 222 LF
Material Location
Boiler room
Material Description
3" and 12" fittings

Comments

This material showed minor delamination on a few fittings, but was not in poor condition overall.

Does Material Contain Asbestos? Yes
Is it Friable? No
Original Inspection Date 6/1/1988
Current Reinspection Date 7/2/2004
Current Assessment Rating NR Not Required
Cause of Damage No Damage
Accessible Yes
Potential for Damage Med
Removed No
Planned Response Action O & M

Inspector



Christiaan Sparks

State Indiana
Accreditation Number 190804103

THIRD YEAR REINSPECTION REPORT

LEA Name Greater Clark County Schools
Building Name Jeffersonville High School
HA# 05
Type of Material Miscellaneous Material
Quantity of Material 548 SF

Material Location
First and second floors


Material Description
Floor tile

Comments

There are a few broken edges in the elevator and part of a tile missing in the first floor elevator corridor. However, this material was not in poor condition overall.

Does Material Contain Asbestos? Yes
Is it Friable? No
Original Inspection Date 6/1/1988
Current Reinspection Date 7/2/2004
Current Assessment Rating NR Not Required
Cause of Damage Physical Damage
Accessible Yes
Potential for Damage Low
Removed No
Planned Response Action O & M

Inspector



Christiaan Sparks

State Indiana
Accreditation Number 190804103

THIRD YEAR REINSPECTION REPORT

LEA Name Greater Clark County Schools
Building Name Jeffersonville High School
HA# 08
Type of Material Miscellaneous Material
Quantity of Material 3,000 SF

Material Location
First and second floors

Material Description
Floor tile mastic

Comments
Where exposed, this material was not in poor condition.

Does Material Contain Asbestos? Assumed
Is it Friable? No
Original Inspection Date 6/1/1988
Current Reinspection Date 7/2/2004
Current Assessment Rating NR Not Required
Cause of Damage No Damage
Accessible No
Potential for Damage Low
Removed No
Planned Response Action O & M

Inspector



Christiaan Sparks

State Indiana
Accreditation Number 190804103

THIRD YEAR REINSPECTION REPORT

LEA Name Greater Clark County Schools
Building Name Jeffersonville High School
HA# A
Type of Material Miscellaneous Material
Quantity of Material 60 LF

Material Location
Elevator corridors

Material Description
Cove base molding

Comments

All cove base is new except for the elevator corridors on the 1st and 2nd floor. This material was not in poor condition.

Does Material Contain Asbestos? Assumed
Is it Friable? No
Original Inspection Date 5/31/1995
Current Reinspection Date 7/2/2004
Current Assessment Rating NR Not Required
Cause of Damage No Damage
Accessible Yes
Potential for Damage Low
Removed No
Planned Response Action O & M

Inspector



Christiaan Sparks

State Indiana
Accreditation Number 190804103

THIRD YEAR REINSPECTION REPORT

LEA Name Greater Clark County Schools
Building Name Jeffersonville High School
HA# B
Type of Material Miscellaneous Material
Quantity of Material 60 LF

Material Location
Throughout the building

Material Description
Cove base mastic

Comments

Where visible under the old cove base, this material was not in poor condition. New mastic has been used under the new cove base in the first and second floor hallways. It is not suspect for asbestos content.


Does Material Contain Asbestos? Assumed
Is it Friable? No
Original Inspection Date 5/31/1995
Current Reinspection Date 7/2/2004
Current Assessment Rating NR Not Required
Cause of Damage No Damage
Accessible No
Potential for Damage Low
Removed No
Planned Response Action O & M

Inspector



Christiaan Sparks

State Indiana
Accreditation Number 190804103



THIRD YEAR REINSPECTION REPORT

LEA Name Greater Clark County Schools
Building Name Jeffersonville High School
HA# 01
Type of Material Miscellaneous Material
Quantity of Material 132 SF
Material Location
Boiler room
Material Description
Gaskets on boilers

Comments

The burner assembly was still in place. There does not appear to be 132 square feet of suspect material. The gasket material on the upper, newer boiler appears to be fiberglass. The boilers were not in operation during this reinspection, so I was able to observe sample the material in good condition.

Does Material Contain Asbestos? Assumed
Is it Friable? No
Original Inspection Date 06/01/1988
Current Reinspection Date 07/11/2001
Current Assessment Rating NR Not Required
Cause of Damage No Damage
Accessible No
Potential for Damage Low
Removed No
Planned Response Action O & M

Inspector



Patrick E. Wilson

State Indiana
Accreditation Number 190824065

THIRD YEAR REINSPECTION REPORT

LEA Name Greater Clark County Schools
Building Name Jeffersonville High School
HA# 02
Type of Material Thermal Material
Quantity of Material 1,800 SF
Material Location
Boiler room
Material Description
Boiler insulation on 2 boilers

Comments

Material is in good condition. Quite a bit of O & M has been performed on the two boilers with encapsulating mastic. The left boiler has had a small O & M project done to expose the side for repair. This was done by trained school personnel using glovebag methods. The small glovebagged area was approximately 18" X 18" and was sealed up with mastic.

Does Material Contain Asbestos? Yes
Is it Friable? No
Original Inspection Date 06/01/1988
Current Reinspection Date 07/11/2001
Current Assessment Rating NR Not Required
Cause of Damage Vibration
Accessible Yes
Potential for Damage Med
Removed No
Planned Response Action O & M

Inspector



Patrick E. Wilson

State Indiana
Accreditation Number 190824065

THIRD YEAR REINSPECTION REPORT

LEA Name Greater Clark County Schools

Building Name Jeffersonville High School

HA# 03

Type of Material Thermal Material

Quantity of Material 222 LF

Material Location
Boiler room

Material Description
3" and 12" fittings

Comments

Fittings are in good condition overall. Some elbows by the upper boiler were glovebagged by school personnel.

Does Material Contain Asbestos? Yes

Is it Friable? No

Original Inspection Date 06/01/1988

Current Reinspection Date 07/11/2001

Current Assessment Rating NR Not Required

Cause of Damage No Damage

Accessible Yes

Potential for Damage Med

Removed No

Planned Response Action O & M

Inspector



Patrick E. Wilson

State Indiana

Accreditation Number 190824065

THIRD YEAR REINSPECTION REPORT

LEA Name Greater Clark County Schools

Building Name Jeffersonville High School

HA# 05

Type of Material Miscellaneous Material

Quantity of Material 548 SF

Material Location
First and second floors

Material Description
Floor tile

Comments

There are a few broken edges in the elevator and a part of a tile missing in the first floor elevator corridor.

Does Material Contain Asbestos? Yes

Is it Friable? No

Original Inspection Date 06/01/1988

Current Reinspection Date 07/11/2001

Current Assessment Rating NR Not Required

Cause of Damage Physical Damage

Accessible Yes

Potential for Damage Low

Removed No

Planned Response Action O & M

Inspector


Patrick E. Wilson

State Indiana

Accreditation Number 190824065

THIRD YEAR REINSPECTION REPORT

LEA Name Greater Clark County Schools
Building Name Jeffersonville High School
HA# 08
Type of Material Miscellaneous Material
Quantity of Material 3,000 SF
Material Location
First and second floors
Material Description
Floor tile mastic
Comments
Where exposed, the mastic was in good condition.
Does Material Contain Asbestos? Assumed
Is it Friable? No
Original Inspection Date 06/01/1988
Current Reinspection Date 07/11/2001
Current Assessment Rating NR Not Required
Cause of Damage No Damage
Accessible Yes
Potential for Damage Low
Removed No
Planned Response Action O & M

Inspector

Patrick Wilson ew

Patrick E. Wilson

State Indiana
Accreditation Number 190824065

THIRD YEAR REINSPECTION REPORT

LEA Name Greater Clark County Schools
Building Name Jeffersonville High School
HA# A
Type of Material Miscellaneous Material
Quantity of Material Approx. 4,500 LF

Material Location
Throughout the building

Material Description
Cove base molding

Comments
All material in first floor corridors has been replaced with new black cove base molding. Second floor received new carpet in June 2000. Most cove base is in areas that did not get carpeted. The old cove base is in good condition overall with minor scrapes observed.

Does Material Contain Asbestos? Assumed
Is it Friable? No
Original Inspection Date 05/31/1995
Current Reinspection Date 07/11/2001
Current Assessment Rating NR Not Required
Cause of Damage No Damage
Accessible Yes
Potential for Damage Low
Removed No
Planned Response Action O & M

Inspector Patrick E. Wilson kw
Patrick E. Wilson

State Indiana
Accreditation Number 190824065

THIRD YEAR REINSPECTION REPORT

LEA Name Greater Clark County Schools
Building Name Jeffersonville High School
HA# B
Type of Material Miscellaneous Material
Quantity of Material 3,000 SF

Material Location
Throughout the building

Material Description
Cove base mastic

Comments
Where material is exposed, it is in good condition. A lot of the mastic on the second floor has been painted over with black paint where no molding is present.


Does Material Contain Asbestos? Assumed
Is it Friable? No
Original Inspection Date 05/31/1995
Current Reinspection Date 07/11/2001
Current Assessment Rating NR Not Required
Cause of Damage No Damage
Accessible No
Potential for Damage Low
Removed No
Planned Response Action O & M

Inspector



Patrick E. Wilson

State Indiana
Accreditation Number 190824065



THIRD YEAR REINSPECTION REPORT

LEA Name Greater Clark County Schools

Building Name Jeffersonville High School

HA# 01

Type of Material Miscellaneous Material

Quantity of Material 132 SF

Material Location
Boiler Room

Material Description
Gaskets on Boilers

Comments
Good condition.

Does Material Contain Asbestos? Assumed

Is it Friable? No

Original Inspection Date 6/ 1/88

Current Reinspection Date 6/ 1/98

Current Assessment Rating NR Not Required

Cause of Damage No Damage


Accessible Yes

Potential for Damage Low

Removed No

Planned Response Action O & M

Inspector



Clint Yates

State Indiana

Accreditation Number 193804035

THIRD YEAR REINSPECTION REPORT

LEA Name Greater Clark County Schools
Building Name Jeffersonville High School
HA# 02
Type of Material Thermal Material
Quantity of Material 1,800 SF

Material Location
Boiler Room


Material Description
Boiler Insulation on 2 Boilers

Comments

Material shows two spots of damage. O & M needed. Damage was shown to Mr. Dodd and he said he would take care of it ASAP.

Does Material Contain Asbestos? Yes
Is it Friable? Yes
Original Inspection Date 6/ 1/88
Current Reinspection Date 6/ 1/98
Current Assessment Rating 1B Damaged TSI
Cause of Damage Physical Damage
Accessible Yes
Potential for Damage Med
Removed No
Planned Response Action O & M

Inspector


Clint Yates

State Indiana
Accreditation Number 193804035

THIRD YEAR REINSPECTION REPORT

LEA Name Greater Clark County Schools
Building Name Jeffersonville High School
HA# 03
Type of Material Thermal Material
Quantity of Material 222 LF

Material Location
Boiler Room


Material Description
3" and 12" Fittings

Comments

Some minor damage. Mr. Dodd will repair ASAP.

Does Material Contain Asbestos? Yes
Is it Friable? Yes
Original Inspection Date 6/ 1/88
Current Reinspection Date 6/ 1/98
Current Assessment Rating 1B Damaged TSI
Cause of Damage Physical Damage
Accessible Yes
Potential for Damage Med
Removed No
Planned Response Action O & M

Inspector



Clint Yates

State Indiana
Accreditation Number 193804035

THIRD YEAR REINSPECTION REPORT

LEA Name Greater Clark County Schools

Building Name Jeffersonville High School

HA# 05

Type of Material Miscellaneous Material

Quantity of Material 548 SF

Material Location
First and second floors

Material Description
Floor Tile

Comments
Good condition.

Does Material Contain Asbestos? Yes

Is it Friable? No

Original Inspection Date 6/ 1/88

Current Reinspection Date 6/ 1/98

Current Assessment Rating NR Not Required

Cause of Damage No Damage


Accessible Yes

Potential for Damage Low

Removed No

Planned Response Action O & M

Inspector



Clint Yates

State Indiana

Accreditation Number 193804035

THIRD YEAR REINSPECTION REPORT

LEA Name Greater Clark County Schools

Building Name Jeffersonville High School

HA# 08

Type of Material Miscellaneous Material

Quantity of Material 3,000 SF


Material Location
First and second floors

Material Description
Floor Tile Mastic

Comments
Material is not exposed, but is assumed to be in good condition.

Does Material Contain Asbestos? Assumed
Is it Friable? No
Original Inspection Date 6/ 1/88
Current Reinspection Date 6/ 1/98
Current Assessment Rating NR Not Required
Cause of Damage No Damage
Accessible Yes
Potential for Damage Low
Removed No
Planned Response Action O & M

Inspector


Clint Yates

State Indiana

Accreditation Number 193804035

THIRD YEAR REINSPECTION REPORT

LEA Name Greater Clark County Schools

Building Name Jeffersonville High School

HA# A

Type of Material Miscellaneous Material

Quantity of Material 3,000 SF

Material Location
Throughout the building

Material Description
Cove Base Molding

Comments
Material is in good condition.

Does Material Contain Asbestos? Assumed

Is it Friable? No

Original Inspection Date 5/31/95

Current Reinspection Date 6/ 1/98

Current Assessment Rating NR Not Required

Cause of Damage No Damage


Accessible Yes

Potential for Damage Low

Removed No

Planned Response Action O & M

Inspector


Clint Yates

State Indiana

Accreditation Number 193804035

THIRD YEAR REINSPECTION REPORT

LEA Name Greater Clark County Schools

Building Name Jeffersonville High School

HA# B

Type of Material Miscellaneous Material

Quantity of Material 3,000 SF

Material Location
Throughout the building

Material Description
Cove Base Mastic

Comments
Material is not exposed and is assumed to be in good condition.

Does Material Contain Asbestos? Assumed

Is it Friable? No

Original Inspection Date 5/31/95

Current Reinspection Date 6/ 1/98

Current Assessment Rating NR Not Required

Cause of Damage No Damage


Accessible No

Potential for Damage Low

Removed No

Planned Response Action O & M

Inspector


Clint Yates


State Indiana

Accreditation Number 193804035


THIRD YEAR REINSPECTION REPORT

LEA Name Greater Clark County Schools
Building Name Jeffersonville High School
HA# C
Type of Material Miscellaneous Material
Quantity of Material SF
Material Location
Second floor balcony and around the gymnasium
Material Description
Transite Walls
Comments
Material was removed in 1987 according to Mr. Dodd.
Does Material Contain Asbestos? No
Is it Friable? No
Original Inspection Date 6/24/96
Current Reinspection Date 6/ 1/98
Current Assessment Rating NA Not Applicable
Cause of Damage Not Applicable
Accessible No
Potential for Damage NA
Removed No
Planned Response Action None

Inspector


Clint Yates

State Indiana
Accreditation Number 193804035



THIRD YEAR REINSPECTION REPORT

LEA NAME: Greater Clark County School Corp.

BUILDING NAME: Jeffersonville High School

HA#: 01

TYPE OF MATERIAL: Miscellaneous Material

QUANTITY OF MATERIAL: 198SF

MATERIAL LOCATION:

132 (25)

Boiler Room

MATERIAL DESCRIPTION:

Gaskets on boilers

COMMENTS:

Good condition

IS MATERIAL FRIABLE? NO

ORIGINAL INSPECTION DATE: 06/01/88

CURRENT REINSPECTION DATE: 06/26/95

CURRENT ASSESSMENT RATING: NR Not Required

CAUSE OF DAMAGE: No Damage

ACCESSIBLE: NO

POTENTIAL FOR DAMAGE: Low

REMOVED: NO

CURRENT VIDEO TAPE: /
(TAPE NO/FOOTAGE)

INSPECTOR NAME:


Rex Gaddis

STATE: Indiana

ACCREDITATION NO.: 190908032

THIRD YEAR REINSPECTION REPORT

LEA NAME: Greater Clark County School Corp.

BUILDING NAME: Jeffersonville High School

HA#: 02

TYPE OF MATERIAL: Thermal Material

QUANTITY OF MATERIAL: 1,800SF

MATERIAL LOCATION:

Boiler Room

MATERIAL DESCRIPTION:

Boiler Insulation on 2 Boilers

COMMENTS:

Material has some minor damage. One boiler was removed in 05/95. Liberty Environmental (contractor) removed all TSI prior to boiler removal.

IS MATERIAL FRIABLE? YES

ORIGINAL INSPECTION DATE: 06/01/88

CURRENT REINSPECTION DATE: 06/26/95

CURRENT ASSESSMENT RATING: 1B Damaged TSI

CAUSE OF DAMAGE: Physical Damage

ACCESSIBLE: NO

POTENTIAL FOR DAMAGE: Med

REMOVED: NO

CURRENT VIDEO TAPE: /
(TAPE NO/FOOTAGE)

INSPECTOR NAME:


Rex Gaddis

STATE: Indiana

ACCREDITATION NO.: 190908032

THIRD YEAR REINSPECTION REPORT

LEA NAME: Greater Clark County School Corp.

BUILDING NAME: Jeffersonville High School

HA#: 03

TYPE OF MATERIAL: Thermal Material

QUANTITY OF MATERIAL: 222LF

MATERIAL LOCATION:

Boiler Room

MATERIAL DESCRIPTION:

3" and 12" fittings

COMMENTS:

Some minor damage

IS MATERIAL FRIABLE? YES

ORIGINAL INSPECTION DATE: 06/01/88

CURRENT REINSPECTION DATE: 06/26/95

CURRENT ASSESSMENT RATING: 1B Damaged TSI

CAUSE OF DAMAGE: Physical Damage

ACCESSIBLE: NO

POTENTIAL FOR DAMAGE: Med

REMOVED: NO

CURRENT VIDEO TAPE: /
(TAPE NO/FOOTAGE)

INSPECTOR NAME:


Rex Gaddis

STATE: Indiana

ACCREDITATION NO.: 190908032

THIRD YEAR REINSPECTION REPORT

LEA NAME: Greater Clark County School Corp.

BUILDING NAME: Jeffersonville High School

HA#: 05

TYPE OF MATERIAL: Miscellaneous Material

QUANTITY OF MATERIAL: 548SF

MATERIAL LOCATION:
First and second floors

MATERIAL DESCRIPTION:
Floor tile

COMMENTS:
Good Condition

IS MATERIAL FRIABLE? NO
ORIGINAL INSPECTION DATE: 06/01/88
CURRENT REINSPECTION DATE: 06/26/95
CURRENT ASSESSMENT RATING: NR Not Required
CAUSE OF DAMAGE: No Damage
ACCESSIBLE: NO
POTENTIAL FOR DAMAGE: Low
REMOVED: NO
CURRENT VIDEO TAPE:
(TAPE NO/FOOTAGE) /

INSPECTOR NAME:



Rex Gaddis

STATE: Indiana

ACCREDITATION NO.: 190908032

THIRD YEAR REINSPECTION REPORT

LEA NAME: Greater Clark County School Corp.

BUILDING NAME: Jeffersonville High School

HA#: 08

TYPE OF MATERIAL: Miscellaneous Material

QUANTITY OF MATERIAL: 3,000SF

MATERIAL LOCATION:

First and second floors

MATERIAL DESCRIPTION:

Floor tile mastic

COMMENTS:

Material is assumed to be positive. Material is in good condition.

IS MATERIAL FRIABLE? NO

ORIGINAL INSPECTION DATE: 06/01/88

CURRENT REINSPECTION DATE: 06/26/95

CURRENT ASSESSMENT RATING: NR Not Required

CAUSE OF DAMAGE: No Damage

ACCESSIBLE: NO

POTENTIAL FOR DAMAGE: Low

REMOVED: NO

CURRENT VIDEO TAPE: /
(TAPE NO/FOOTAGE)

INSPECTOR NAME:



Rex Gaddis

STATE: Indiana

ACCREDITATION NO.: 190908032

THIRD YEAR REINSPECTION REPORT

LEA NAME: Greater Clark County School Corp.

BUILDING NAME: Jeffersonville High School

HA#: A

TYPE OF MATERIAL: Miscellaneous Material

QUANTITY OF MATERIAL: 3,000SF

MATERIAL LOCATION:

Throughout the building

MATERIAL DESCRIPTION:

Cove-base molding

COMMENTS:

Material was not addressed in the original inspection. It is a suspect material that is assumed to be positive until analyzed. It is in good condition.

IS MATERIAL FRIABLE? NO

ORIGINAL INSPECTION DATE:

CURRENT REINSPECTION DATE: 06/26/95

CURRENT ASSESSMENT RATING: NR Not Required

CAUSE OF DAMAGE: No Damage

ACCESSIBLE: NO

POTENTIAL FOR DAMAGE: Low

REMOVED: NO

CURRENT VIDEO TAPE: /
(TAPE NO/FOOTAGE)

INSPECTOR NAME:



Rex Gaddis

STATE: Indiana

ACCREDITATION NO.: 190908032

THIRD YEAR REINSPECTION REPORT

LEA NAME: Greater Clark County School Corp.

BUILDING NAME: Jeffersonville High School

HA#: B

TYPE OF MATERIAL: Miscellaneous Material

QUANTITY OF MATERIAL: 3,000SF

MATERIAL LOCATION:

Throughout the building

MATERIAL DESCRIPTION:

Cove-base mastic

COMMENTS:

Was not addressed in the original inspection. Material will be assumed positive for the presence of asbestos-containing materials until analyzed by an accredited NVLAP laboratory.

IS MATERIAL FRIABLE? NO

ORIGINAL INSPECTION DATE:

CURRENT REINSPECTION DATE: 06/26/95

CURRENT ASSESSMENT RATING: NR Not Required

CAUSE OF DAMAGE: No Damage

ACCESSIBLE: NO

POTENTIAL FOR DAMAGE: Low

REMOVED: NO

CURRENT VIDEO TAPE: /
(TAPE NO/FOOTAGE)

INSPECTOR NAME:


Rex Gaddis

STATE: Indiana

ACCREDITATION NO.: 190908032

THIRD YEAR REINSPECTION REPORT

LEA NAME: Greater Clark County School Corp.

BUILDING NAME: Jeffersonville High School

HA#: C

TYPE OF MATERIAL: Miscellaneous Material

QUANTITY OF MATERIAL: SF

MATERIAL LOCATION:

Second floor balcony and around the gymnasium

MATERIAL DESCRIPTION:

Transite walls

COMMENTS:

Was not addressed in the original inspection. Material is in good condition. Material is assumed positive until analyzed.

IS MATERIAL FRIABLE? NO

ORIGINAL INSPECTION DATE:

CURRENT REINSPECTION DATE: 06/26/95

CURRENT ASSESSMENT RATING: NR Not Required

CAUSE OF DAMAGE: No Damage

ACCESSIBLE: NO

POTENTIAL FOR DAMAGE: Low

REMOVED: NO

CURRENT VIDEO TAPE: /
(TAPE NO/FOOTAGE)

INSPECTOR NAME:



Rex Gaddis

STATE: Indiana

ACCREDITATION NO.: 190908032

ADDITIONAL BULK SAMPLES

ALLIANCE ENVIRONMENTAL GROUP, INC.

5340 Commerce Circle, Suite E
 Indianapolis, IN 46237
 317/865-3400 Fax 317/865-3401

24 HOUR

Project Name- JEFFERSONVILLE HIGH SCHOOL

Project Location- BOILER ROOM

City/State- JEFFERSONVILLE, INDIANA

Project Number- NGR 11 A 02 Date- 25 MARCH 2008

Samples Collected By- BILL OGLE

PLEASE STOP AT FIRST POSITIVE IN EACH GROUP

SAMPLE I.D. NUMBER	LOCATION OF SAMPLE	DESCRIPTION OF SAMPLE MATERIAL
HFB-01	BOILER INTERIOR - 1 ST LAYER	BEIGE CEMENTICIOUS
HFB-02	BOILER INTERIOR - 2 ND LAYER	TAN CEMENTICIOUS
HFB-03	BOILER INTERIOR - 1 ST LAYER	BEIGE CEMENTICIOUS
HEAVY FIRE BRICK - 2 LAYERS		
LFB-01	BOILER INTERIOR - 3 RD LAYER	TAN CEMENTICIOUS
LFB-02	BOILER INTERIOR - 3 RD LAYER	TAN CEMENTICIOUS
LFB-03	BOILER INTERIOR - 3 RD LAYER	TAN CEMENTICIOUS
LIGHTWEIGHT FIRE BRICK - 1 LAYER		
GFP-01	BOILER INTERIOR - 4 TH LAYER	GREEN FIBROUS
GFP-02	BOILER INTERIOR - 4 TH LAYER	GREEN FIBROUS
GFP-03	BOILER INTERIOR - 4 TH LAYER	GREEN FIBROUS
GREEN FIBROUS PAD - 1 LAYER (ABOUT 2" THICK)		

CHAIN OF CUSTODY

Sample By: BILL OGLE Received By: DRIP BOX Recorded By: _____
 Date: 25 MARCH 2008 Date: _____ Date: _____ Log#: _____
 Signature: Bill Ogle Signature: _____ Signature: _____
 Date Shipped: 26 March 2008 Shipped Via: _____ Shipped To: _____

ALLIANCE ENVIRONMENTAL GROUP, INC.

5340 Commerce Circle, Suite E
Indianapolis, IN 46237
317/865-3400 Fax 317/865-3401

24 HOUR
160803891

Project Name- JEFFERSONVILLE HIGH SCHOOL

Project Location- BOILER ROOM

City/State- JEFFERSONVILLE, INDIANA

Project Number- NGR 11A02 Date- 25 MARCH 2008

Samples Collected By- BILL OGLE

PLEASE STOP AT FIRST POSITIVE EACH GROUP

SAMPLE I.D. NUMBER	LOCATION OF SAMPLE	DESCRIPTION OF SAMPLE MATERIAL
HFB-01	BOILER INTERIOR - 1 ST LAYER	BEIGE CEMENTICIOUS
HFB-02	BOILER INTERIOR - 2 ND LAYER	TAN CEMENTICIOUS
HFB-03	BOILER INTERIOR - 1 ST LAYER	BEIGE CEMENTICIOUS
HEAVY FIRE BRICK - 2 LAYERS		
LFB-01	BOILER INTERIOR - 3 RD LAYER	TAN CEMENTICIOUS
LFB-02	BOILER INTERIOR - 3 RD LAYER	TAN CEMENTICIOUS
LFB-03	BOILER INTERIOR - 3 RD LAYER	TAN CEMENTICIOUS
LIGHT WEIGHT FIRE BRICK - 1 LAYER		
GFP-01	BOILER INTERIOR - 4 TH LAYER	GREEN FIBROUS
GFP-02	BOILER INTERIOR - 4 TH LAYER	GREEN FIBROUS
GFP-03	BOILER INTERIOR - 4 TH LAYER	GREEN FIBROUS
GREEN FIBROUS PAD - 1 LAYER (ABOUT 2" THICK)		

CHAIN OF CUSTODY

Sample By: BILL OGLE

Received By: DRAPBAX

Recorded By: _____

Date: 25 MARCH 2008

Date: 3-27-08 800

Date: _____ Log#: _____

Signature: Bill Ogle

Signature: [Signature]

Signature: _____

Date Shipped: 26 March 2008

Shipped Via: _____

Shipped To: _____



EMSL Analytical

2001 East 52nd St., Indianapolis, IN 46205

Phone: (317) 803-2997 Fax: (317) 803-3047 Email: indianapolislab@emsl.com

Attn: **Bill Ogle**
Alliance Environmental Group, Inc.
5340 Commerce Circle
Indianapolis, IN 46237

Fax: (317) 865-3401 Phone: (317) 865-3400
Project: **NGR 11A02**

Customer ID: ALLI65
Customer PO:
Received: 03/27/08 7:00 AM
EMSL Order: 160803891
EMSL Proj:
Analysis Date: 3/27/2008
Report Date: 3/27/2008

Asbestos Analysis of Bulk Materials via EPA 600/R-93/116 Method using Polarized Light Microscopy

Sample	Location	Appearance	Non-Asbestos		Asbestos
			% Fibrous	% Non-Fibrous	% Type
HFB-01 160803891-0001		Beige Non-Fibrous Homogeneous		100% Non-fibrous (other)	None Detected
HFB-02 160803891-0002		Tan Non-Fibrous Homogeneous		100% Non-fibrous (other)	None Detected
HFB-03 891-0003		Beige Non-Fibrous Homogeneous		100% Non-fibrous (other)	None Detected
LFB-01 160803891-0004		Tan Non-Fibrous Homogeneous		100% Non-fibrous (other)	None Detected
LFB-02 160803891-0005		Tan Non-Fibrous Homogeneous		100% Non-fibrous (other)	None Detected
LFB-03 160803891-0006		Tan Non-Fibrous Homogeneous		100% Non-fibrous (other)	None Detected
GFP-01 160803891-0007		Green Fibrous Homogeneous	95% Min. Wool	5% Non-fibrous (other)	None Detected
GFP-02 160803891-0008		Green Fibrous Homogeneous	95% Min. Wool	5% Non-fibrous (other)	None Detected

Analyst(s)

Craig Nixon (9)

Richard Harding, Laboratory Manager
or other approved signatory

Due to magnification limitations inherent in PLM, asbestos fibers in dimensions below the resolution capability of PLM may not be detected. The limit of detection as stated in the report is 1%. The above test report relates only to the items tested and may not be reproduced in any form without the express written approval of EMSL Analytical, Inc. EMSL's liability is limited to the cost of analysis. EMSL bears no responsibility for sample collection activities or analytical method limitations. Interpretation and use of test results are the responsibility of the client. Samples received in good condition unless otherwise noted. This report must not be used to claim product endorsement by NVLAP or any agency of the U.S. Government.

ACCREDITATION: NVLAP Lab Code 200188-0



EMSL Analytical

2001 East 52nd St., Indianapolis, IN 46205

Phone: (317) 803-2997 Fax: (317) 803-3047 Email: indianapolislaboratory@emsl.com

Attn: **Bill Ogle**
Alliance Environmental Group, Inc.
5340 Commerce Circle
Indianapolis, IN 46237

Customer ID: ALLI65
Customer PO:
Received: 03/27/08 7:00 AM
EMSL Order: 160803891

Fax: (317) 865-3401 Phone: (317) 865-3400
Project: NGR 11A02

EMSL Proj:
Analysis Date: 3/27/2008
Report Date: 3/27/2008

Asbestos Analysis of Bulk Materials via EPA 600/R-93/116 Method using Polarized Light Microscopy

Sample	Location	Appearance	Non-Asbestos		Asbestos
			% Fibrous	% Non-Fibrous	% Type
GFP-03 160803891-0009		Green Fibrous Homogeneous	95% Min. Wool	5% Non-fibrous (other)	None Detected

Analyst(s)

Craig Nixon (9)

Richard Harding, Laboratory Manager
or other approved signatory

Due to magnification limitations inherent in PLM, asbestos fibers in dimensions below the resolution capability of PLM may not be detected. The limit of detection as stated in the report is 1%. The above test report relates only to the items tested and may not be reproduced in any form without the express written approval of EMSL Analytical, Inc. EMSL's liability is limited to the cost of analysis. EMSL bears no responsibility for sample collection activities or analytical method limitations. Interpretation and use of test results are the responsibility of the client. Samples received in good condition unless otherwise noted. This report must not be used to claim product endorsement by NVLAP or any agency of the U.S. Government.

ACCREDITATION: NVLAP Lab Code 200188-0

January 29, 1998

Alliance Indiana, Inc.
Attention: Rex Gaddis
1433 Sadlier Circle, West Dr.
Indianapolis, IN 46239

RE: 1 PLM Analysis

Client Project Name:	Greater Clark
Client Project Number:	NGR-00A02
Results Faxed to:	Clint Yates
Date:	January 26, 1998
Time:	12:12 pm
Laboratory Batch Number:	980110
ATC Project Number:	70424.9701


Dear Mr. Gaddis:

Enclosed are the results from the bulk asbestos analysis for the 1 sample submitted to the ATC Asbestos Laboratory on January 26, 1998. Percentages were determined by visually estimating the area percentage for each type of fibrous material. Samples estimated to contain less than ten percent asbestos fibers may require quantification by point counting. These samples may be resubmitted at your discretion.

ATC will hold your samples for thirty days after the completion of the analysis. At the end of the thirty day period, it will be our policy to dispose of the samples unless prior arrangements are made.

It has been a pleasure serving you. If there are any questions, please contact me at (317) 849-4990.

Respectfully submitted,
ATC Associates Inc.



Patrick Stanford
Group Leader


ATC ASSOCIATES INC.
BULK SAMPLE ANALYSIS REPORT
 NVLAP Accredited
 NVLAP Code Number 101265-00

Date: January 29, 1998

Client: Alliance Indiana, Inc.

Project Identification: NGR-00A02 - Greater Clark
 Date Sample Received: January 26, 1998
 ATC Lab Batch Number: 980110

Lab ID	Client ID	Color / Description	Layer(s)	Asbestos Type	%	Other Fibrous Material	%	Non-Fibrous Material
001	JHS-01	Black Material	1	No Asbestos Detected		Cellulose Manmade	<1 5-10	Binder


 Jennifer Winders, Analyst


 Patrick Stanford, Group Leader

- Analytical Methods: EPA 600/M4-82-020, December 82, EPA 600/R-93/116, July 1993
- Enclosed test results relates only to items tested.
- This report shall not be reproduced, except in full without written approval of the laboratory.
- This report can not be used to claim product endorsement by NVLAP or any agency of the U.S. Government.
- Method limitations: Analysis of floor tile and other resinously bound materials by Polarized Light Microscopy (PLM) may yield false negative results due to method limitations. In these cases ATC recommends alternative methods of analysis.
- For all heterogeneous samples easily separated into sub-samples each component will be analyzed separately. When layers cannot be separated without compromising the layer they will be analyzed as one sample. When a heterogeneous sample contains no asbestos in any layer reported results will be combined into one. When asbestos is detected in a layer or layers of a heterogeneous sample each individual layer will be reported separately.

ALLIANCE INDIANA, INC.
 1433 Sadlier Circle West Dr.
 Indianapolis, IN 46239
 317/351-5600 Fax 317/351-5610

980110
 1/26

Project Name- Incinerator Clark

Project Location- Jefferson High School

City/State- Jeffersonville Indiana

Project Number- NGR00A02 Date- 1-15-98

Samples Collected By- C. Yates

SAMPLE I.D. NUMBER	LOCATION OF SAMPLE	DESCRIPTION OF SAMPLE MATERIAL
JHS 01	Incinerator room	Incinerator internal material
		NAD
(NOTE) Please analyze for asbestos		

CHAIN OF CUSTODY

Sample By: C. Yates Received By: Drop Box Recorded By: _____
 Date: 1-15-98 Date: 1/26/98 8:00 Date: _____ Log#: _____
 Signature: [Signature] Signature: [Signature] Signature: _____
 Date Shipped: _____ Shipped Via: 0 Shipped To: _____

EMSL Analytical, Inc.

6330 E. 75th St., Suite 152

Indianapolis, IN 46250

Phone: (317) 570-5892 Fax: (317) 570-5894



Attn.: Bruce Wallace
Alliance Indiana, Inc.
1433 Sadler Circle West Drive
Indianapolis, IN 46239

Friday, July 07, 2000

Ref Number: IN003277

POLARIZED LIGHT MICROSCOPY (PLM) - POINT COUNT

Performed by EPA 600/R-93/116 Method*

Project: N8R-00A02

Sample	Location	Appearance	Sample Treatment	ASBESTOS		NON-ASBESTOS	
				%	Type	%	Fibrous % Non-Fibrous
13331-D		Green Non-Fibrous Homogeneous	Dissolved	1.25%	Chrysotile		
13330-D		Tan Non-Fibrous Homogeneous	Dissolved	0.25%	Chrysotile		

Comments: For all obviously heterogeneous samples easily separated into subsamples, and for layered samples, each component is analyzed separately. Also, "# of Layers" refers to number of separable subsamples.

* NY samples analyzed by ELAP 198.1 Method.


Margaret S. Phillips

Margaret Phillips
Analyst

Robert L. Harding

Approved
Signatory

Disclaimers: PLM has been known to miss asbestos in a small percentage of samples which contain asbestos. Thus negative PLM results cannot be guaranteed. EMSL suggests that samples reported as <1% or none detected be tested with either SEM or TEM. The above test report relates only to the items tested. This report may not be reproduced, except in full, without written approval by EMSL. The above test must not be used by the client to claim product endorsement by NVLAP nor any agency of the United States Government. Laboratory is not responsible for the accuracy of results when requested to physically separate and analyze layered samples.



EMSL Analytical, Inc.

6330 E. 75th St., Suite 152

Indianapolis, IN 46250

Phone: (317) 570-5892 Fax: (317) 570-5894



Attn.: Bruce Wallace
Alliance Indiana, Inc.
1433 Sadlier Circle West Drive
Indianapolis, IN 46239

Friday, July 07, 2000

Ref Number: IN003221

POLARIZED LIGHT MICROSCOPY (PLM)

Performed by EPA 600/R-93/116 Method*

Project: N8R-00A02


Sample	Location	Appearance	Sample Treatment	ASBESTOS		NON-ASBESTOS	
				%	Type	%	Fibrous % Non-Fibrous
13331-D		Green Non-Fibrous Homogeneous	Dissolved	3%	Chrysotile		97% Other
13330-D		Tan Non-Fibrous Homogeneous	Dissolved	3%	Chrysotile		97% Other

Comments: For all obviously heterogeneous samples easily separated into subsamples, and for layered samples, each component is analyzed separately. Also, "# of Layers" refers to number of separable subsamples.

* NY samples analyzed by ELAP 198.1 Method.



Margaret Phillips
Analyst



Approved
Signatory

Disclaimers: PLM has been known to miss asbestos in a small percentage of samples which contain asbestos. Thus negative PLM results cannot be guaranteed. EMSL suggests that samples reported as <1% or none detected be tested with either SEM or TEM. The above test report relates only to the items tested. This report may not be reproduced, except in full, without written approval by EMSL. The above test must not be used by the client to claim product endorsement by NVLAP nor any agency of the United States Government. Laboratory is not responsible for the accuracy of results when requested to physically separate and analyze layered samples.

FRIDAY

ALLIANCE INDIANA, INC.
1433 Sadlier Circle West Dr.
Indianapolis, IN 46239
317/351-5600 Fax 317/351-5610

1N003221

Project Name- GREATER CLARK COUNTY SCHOOLS

Project Location- JEFFERSONVILLE HIGH SCHOOL

City/State- JEFFERSONVILLE INDIANA

Project Number- NBR-00A02 Date- 28 JUNE 2000

Samples Collected By- BILL OGLE

SAMPLE I.D. NUMBER	LOCATION OF SAMPLE	DESCRIPTION OF SAMPLE MATERIAL
13331-D	ROOM 211 AT DOORWAY ENTRANCE	GREEN FLOOR TILE
13330-D	LANGUAGE PRACTICE ROOMS BENEATH CARPET (FORMERLY LABELED ROOM 315-A)	TAN FLOOR TILE
IF SAMPLES TEST POSITIVE FOR ASBESTOS, PLEASE POINT COUNT		

CHAIN OF CUSTODY

Sample By: BILL OGLE

Date: 28 JUNE 2000

Signature: [Signature]

Date Shipped: 03 July 2000

Received By: Rita Mordy DROPPBOX

Date: 7-5-00 8 AM.

Signature: _____

Shipped Via: _____

Recorded By: _____

Date: _____ Log#: _____

Signature: _____

Shipped To: _____

**ANNUAL NOTIFICATIONS
ACCREDITATIONS
TRAINING
INFORMATION**

NOTICES

NOTIFICATION LOG

LEA Name - Greater Clark County Schools

<u>Date of Notification</u>	<u>Copy of Notification in Supplemental Book?</u>
1989	
1990	
1991	
1992	
1993	
1994	
1995	✓
1996	✓
1997	✓
1998	✓
1999	✓
2000	✓
2001	✓
2002	✓
2003	✓
2004	✓
2005	✓
2006	✓
2007	✓
2008	✓

March 2015

AHERA ANNUAL NOTICE
GREATER CLARK COUNTY SCHOOLS

This information is being published to comply with the requirements of 40 CFR 763, Subpart E, Asbestos Containing Materials in Schools. This regulation, commonly known as the "AHERA" rule, requires local education agencies, such as this one, to perform certain tasks in regards to the presence and control of asbestos containing materials in the buildings under the jurisdiction of the local education agency.

These include but are not limited to:

1. Developing an asbestos management plan which is designed to outline procedures and guidelines for the initial inspection, triennial reinspections, and 6 month periodic surveillance of asbestos-containing materials that are present in the buildings.
2. Provide awareness training and additional training to selected school employees.
3. Periodically notify all workers and occupants, or their local guardians, parent teacher organizations, and collective bargaining organizations of the availability of asbestos management plans, the location of same and the times that the plans may be reviewed.

This notification is to advise all patrons, occupants, or their legal guardians, collective bargaining organizations, and parent-teachers organizations, that the asbestos management plans required under this act are available for review upon request. The plans can be viewed by any person during normal business hours of the particular school. Interested parties wishing to inquire about the plans should contact the individual school office. Master copies of the plans for all buildings under the jurisdiction of this local education agency are available in the Auxiliary Services at River Valley Middle School, which is located at 2220 Veteran's Parkway, Jeffersonville, Indiana 47130; telephone number (812) 288-4821. Inquiries regarding any facet of the regulation or the management plans should be directed to Mr. Steve Hobgood at the above telephone number during regular business hours.

Greater Clark County Schools, school facilities, and buildings which contain asbestos-containing materials (ACMs) and must comply with the 40 CFR 763, Subpart E (AHERA) regulations include:

Jeffersonville, Charlestown and New Washington High Schools; Parkview, River Valley and Charlestown Middle Schools; Wilson, Thomas Jefferson, Northaven, New Washington, Jonathan Jennings, Bridgepoint, Maple, Spring Hill, and Parkwood Elementary Schools, Service Center, Corden Porter Storage, Auto Tech Program- Witten Property, and Corden Porter Center with Gym.

Listed is a brief description of asbestos projects currently ongoing and completed at our facilities this past school year, as well as activities currently scheduled for the 2015/2016 school year. Detailed reports of each activity will become a part of each school's asbestos management plan and may be reviewed in the school office.

* The required triennial re-inspection will be performed in April 2016.

* The required six month periodic surveillance was performed in October 2014.

* The required six month periodic surveillance activities are scheduled for April and October each year.

School facilities and buildings that are asbestos free and require no surveillance or reinspection are:

Pleasant Ridge Elementary School, Utica Elementary School, Corden Porter former Options Building and the Administration Building

March 2014

AHERA ANNUAL NOTICE
GREATER CLARK COUNTY SCHOOLS

This information is being published to comply with the requirements of 40 CFR 763, Subpart E, Asbestos Containing Materials in Schools. This regulation, commonly known as the "AHERA" rule, requires local education agencies, such as this one, to perform certain tasks in regards to the presence and control of asbestos containing materials in the buildings under the jurisdiction of the local education agency.

These include but are not limited to:

1. Developing an asbestos management plan which is designed to outline procedures and guidelines for the initial inspection, triennial reinspections, and 6 month periodic surveillance of asbestos-containing materials that are present in the buildings.
2. Provide awareness training and additional training to selected school employees.
3. Periodically notify all workers and occupants, or their local guardians, parent teacher organizations, and collective bargaining organizations of the availability of asbestos management plans, the location of same and the times that the plans may be reviewed.

This notification is to advise all patrons, occupants, or their legal guardians, collective bargaining organizations, and parent-teachers organizations, that the asbestos management plans required under this act are available for review upon request. The plans can be viewed by any person during normal business hours of the particular school. Interested parties wishing to inquire about the plans should contact the individual school office. Master copies of the plans for all buildings under the jurisdiction of this local education agency are available in the Auxiliary Services building, which is located at 2220 Veteran's Parkway, Jeffersonville, Indiana 47130; telephone number (812) 288-4821. Inquiries regarding any facet of the regulation or the management plans should be directed to Mr. Steve Hobgood at the above telephone number during regular business hours.

Greater Clark County Schools, school facilities, and buildings which contain asbestos-containing materials (ACMs) and must comply with the 40 CFR 763, Subpart E (AHERA) regulations include:

Jeffersonville, Charlestown and New Washington High Schools; Parkview, River Valley and Charlestown Middle Schools; Wilson, Thomas Jefferson, Northaven, New Washington, Jonathan Jennings, Bridgepoint, Maple, Spring Hill, and Parkwood Elementary Schools, the Auxiliary Services Building, Service Center, Corden Porter Storage, and Corden Porter Center with Gym.

Listed is a brief description of asbestos projects currently ongoing and completed at our facilities this past school year, as well as activities currently scheduled for the 2014/2015 school year. Detailed reports of each activity will become a part of each school's asbestos management plan and may be reviewed in the school office.

* The required triennial re-inspection will be performed in April 2013.

* The required six month periodic surveillance was performed in October 2013.

* The required six month periodic surveillance activities are scheduled for April and October each year.

School facilities and buildings that are asbestos free and require no surveillance or reinspection are:

Pleasant Ridge Elementary School, Utica Elementary School, Cordon Porter former Options Building and the Administration Building

March 2013

AHERA ANNUAL NOTICE
GREATER CLARK COUNTY SCHOOLS

This information is being published to comply with the requirements of 40 CFR 763, Subpart E, Asbestos Containing Materials in Schools. This regulation, commonly known as the "AHERA" rule, requires local education agencies, such as this one, to perform certain tasks in regards to the presence and control of asbestos containing materials in the buildings under the jurisdiction of the local education agency.

These include but are not limited to:

1. Developing an asbestos management plan which is designed to outline procedures and guidelines for the initial inspection, triennial reinspections, and 6 month periodic surveillance of asbestos-containing materials that are present in the buildings.
2. Provide awareness training and additional training to selected school employees.
3. Periodically notify all workers and occupants, or their local guardians, parent teacher organizations, and collective bargaining organizations of the availability of asbestos management plans, the location of same and the times that the plans may be reviewed.

This notification is to advise all patrons, occupants, or their legal guardians, collective bargaining organizations, and parent-teachers organizations, that the asbestos management plans required under this act are available for review upon request. The plans can be viewed by any person during normal business hours of the particular school. Interested parties wishing to inquire about the plans should contact the individual school office. Master copies of the plans for all buildings under the jurisdiction of this local education agency are available in the Auxiliary Services building, which is located at 2710 E 10th Street, Jeffersonville, Indiana 47130; telephone number (812) 288-4821. Inquiries regarding any facet of the regulation or the management plans should be directed to Mr. Steve Hobgood at the above telephone number during regular business hours.

Greater Clark County Schools, school facilities, and buildings which contain asbestos-containing materials (ACMs) and must comply with the 40 CFR 763, Subpart E (AHERA) regulations include:

Jeffersonville, Charlestown and New Washington High Schools; Parkview, River Valley and Charlestown Middle Schools; Wilson, Thomas Jefferson, Northaven, New Washington, Jonathan Jennings, Bridgepoint, Maple, Spring Hill, and Parkwood Elementary Schools, the Auxiliary Services Building, Service Center, Corden Porter Storage, and Corden Porter Center with Gym.

Listed is a brief description of asbestos projects currently ongoing and completed at our facilities this past school year, as well as activities currently scheduled for the 2013/2014 school year. Detailed reports of each activity will become a part of each school's asbestos management plan and may be reviewed in the school office.

- * The required triennial re-inspection will be performed in April 2013.
- * The required six month periodic surveillance was performed in October 2012.
- * The required six month periodic surveillance activities are scheduled for April and October each year.
- * Projects completed in 2012: Parkview Middle School.

School facilities and buildings that are asbestos free and require no surveillance or reinspection are:

Pleasant Ridge Elementary School, Utica Elementary School, Cordon Porter former Options Building and the Administration Building

March 2012

AHERA ANNUAL NOTICE
GREATER CLARK COUNTY SCHOOLS

This information is being published to comply with the requirements of 40 CFR 763, Subpart E, Asbestos Containing Materials in Schools. This regulation, commonly known as the "AHERA" rule, requires local education agencies, such as this one, to perform certain tasks in regards to the presence and control of asbestos containing materials in the buildings under the jurisdiction of the local education agency.

These include but are not limited to:

1. Developing an asbestos management plan which is designed to outline procedures and guidelines for the initial inspection, triennial reinspections, and 6 month periodic surveillance of asbestos-containing materials that are present in the buildings.
2. Provide awareness training and additional training to selected school employees.
3. Periodically notify all workers and occupants, or their local guardians, parent teacher organizations, and collective bargaining organizations of the availability of asbestos management plans, the location of same and the times that the plans may be reviewed.

This notification is to advise all patrons, occupants, or their legal guardians, collective bargaining organizations, and parent-teachers organizations, that the asbestos management plans required under this act are available for review upon request. The plans can be viewed by any person during normal business hours of the particular school. Interested parties wishing to inquire about the plans should contact the individual school office. Master copies of the plans for all buildings under the jurisdiction of this local education agency are available in the Auxiliary Services building, which is located at 2710 E 10th Street, Jeffersonville, Indiana 47130; telephone number (812) 288-4821. Inquiries regarding any facet of the regulation or the management plans should be directed to Mr. Steve Hobgood at the above telephone number during regular business hours.

Greater Clark County Schools, school facilities, and buildings which contain asbestos-containing materials (ACMs) and must comply with the 40 CFR 763, Subpart E (AHERA) regulations include:

Jeffersonville, Charlestown and New Washington High Schools; Parkview, River Valley and Charlestown Middle Schools; Wilson, Thomas Jefferson, Northaven, New Washington, Jonathan Jennings, Bridgepoint, Maple, Spring Hill, and Parkwood Elementary Schools, the Auxiliary Services Building, Service Center, and Corden Porter Center with Gym.

Listed is a brief description of asbestos projects currently ongoing and completed at our facilities this past school year, as well as activities currently scheduled for the 2012/2013 school year. Detailed reports of each activity will become a part of each school's asbestos management plan and may be reviewed in the school office.

- * The required triennial re-inspection will be performed in June 2013.
- * The required six month periodic surveillance was performed in December 2011.
- * The required six month periodic surveillance activities are scheduled for June and December each year.
- * Projects completed in 2011: Options building and Parkwood Elementary.
- * Projects scheduled for 2012: Parkview Middle School and Bridgepoint Elementary.
- * Cordon Porter storage building was sold in 2012.

School facilities and buildings that are asbestos free and require no surveillance or reinspection are:

Pleasant Ridge Elementary School, Utica Elementary School, Cordon Porter former Options Building and the Administration Building

AHERA ANNUAL NOTICE
GREATER CLARK COUNTY SCHOOLS

This information is being published to comply with the requirements of 40 CFR 763 Subpart E Asbestos Containing Materials in Schools. This regulation, commonly known as the "AHERA" rule, requires local education agencies, such as this one, to perform certain tasks in regards to the presence and control of asbestos containing materials in the buildings under the jurisdiction of the local education agency.

These include but are not limited to:

1. Developing an asbestos management plan which is designed to outline procedures and guidelines for the inspection, reinspection and periodic surveillance of asbestos containing materials that are present in the buildings.
2. Provide awareness training and additional training to selected school employees.
3. Periodically notify all workers and occupants, or their local guardians, parent teacher organizations, and collective bargaining organizations of the availability of asbestos management plans, the location of same and the times that the plans may be reviewed.

This notification is to advise all patrons, occupants, or their legal guardians, collective bargaining organizations, and parent-teachers organizations, that the asbestos management plans required under this act are available for review upon request. A copy of the plans for all buildings under the jurisdiction of this local education agency are available in the Auxillary Services building, which is located at 2710 E 10th Street, Jeffersonville, Indiana 47130; telephone number (812) 288-4821. Plans for individual schools and other buildings are located in the administration office of each school. The plans can be viewed by any person during normal business hours of the particular school. Interested parties wishing to inquire about the hours and times that the plans are available should call the above number.

At this time, the management plans can provide information regarding inspections, response actions, and post-response action activities, including periodic reinspection and surveillance activities that are planned or in progress. Inquiries regarding any facet of the regulation or the management plans should be directed to Mr. Steve Hobgood at the above telephone number during regular business hours.

Listed is a brief description of asbestos work that has been completed in our schools this year. Detailed reports have become part of each school's asbestos management plan and may be reviewed in the school office.

Jeffersonville, Charlestown and New Washington High Schools; Parkview, River Valley and Charlestown Middle Schools; Wilson, Thomas Jefferson, Northaven, New Washington, Jonathan Jennings, Bridgepoint, Maple, Spring Hill, and Parkwood Elementary Schools; the former Administration Building, Service Center, Options and Corden Porter Center Buildings and Alternative School-

- * The required triennial reinspection will be performed in June 2013.
- * The required six month periodic surveillance was performed in December 2010.
- * The next scheduled activity is the required six month periodic surveillance in June 2011.
- * Charlestown High School asbestos removal project was completed in 2010.
- * Options Building is under renovation in 2011.
- * Parkwood Elementary is under renovation in 2011.

Pleasant Ridge Elementary School, Utica Elementary School and the (New) Administration Building
– These buildings are asbestos free and **Riverside Elementary** was demolished in 2006.
No surveillances or reinspections are required for these buildings.

March 2011

AHERA ANNUAL NOTICE
GREATER CLARK COUNTY SCHOOLS

This information is being published to comply with the requirements of 40 CFR 763 Subpart E Asbestos Containing Materials in Schools. This regulation, commonly known as the "AHERA" rule, requires local education agencies, such as this one, to perform certain tasks in regards to the presence and control of asbestos containing materials in the buildings under the jurisdiction of the local education agency.

These include but are not limited to:

1. Developing an asbestos management plan which is designed to outline procedures and guidelines for the inspection, reinspection and periodic surveillance of asbestos containing materials that are present in the buildings.
2. Provide awareness training and additional training to selected school employees.
3. Periodically notify all workers and occupants, or their local guardians, parent teacher organizations, and collective bargaining organizations of the availability of asbestos management plans, the location of same and the times that the plans may be reviewed.

This notification is to advise all patrons, occupants, or their legal guardians, collective bargaining organizations, and parent-teachers organizations, that the asbestos management plans required under this act are available for review upon request. A copy of the plans for all buildings under the jurisdiction of this local education agency are available in the Auxillary Services building, which is located at 2710 E 10th Street, Jeffersonville, Indiana 47130; telephone number (812) 288-4821. Plans for individual schools and other buildings are located in the administration office of each school. The plans can be viewed by any person during normal business hours of the particular school. Interested parties wishing to inquire about the hours and times that the plans are available should call the above number.

At this time, the management plans can provide information regarding inspections, response actions, and post-response action activities, including periodic reinspection and surveillance activities that are planned or in progress. Inquiries regarding any facet of the regulation or the management plans should be directed to Mr. Steve Hobgood at the above telephone number during regular business hours.

Listed is a brief description of asbestos work that has been completed in our schools this year. Detailed reports have become part of each school's asbestos management plan and may be reviewed in the school office.

Jeffersonville, Charlestown and New Washington High Schools; Parkview, River Valley and Charlestown Middle Schools; Wilson, Thomas Jefferson, Northaven, New Washington, Jonathan Jennings, Bridgepoint, Maple, Spring Hill, and Parkwood Elementary Schools; the former Administration Building, Service Center, and Corden Porter Center Buildings -

- * The required triennial reinspection will be performed in June 2010.
- * The required six month periodic surveillance was performed in December 2009.
- * The next scheduled activity is the required six month periodic surveillance in December 2010.
Charlestown High School is an ongoing asbestos removal project which will be complete prior to partial demolition.

Pleasant Ridge Elementary School, Utica Elementary School and the (New) Administration Building –
These buildings are asbestos free and Riverside Elementary was demolished in 2006.
No surveillances or reinspections are required for these buildings.

March 2010

**AHERA ANNUAL NOTICE
GREATER CLARK COUNTY SCHOOLS**

This information is being published to comply with the requirements of 40 CFR 763 Subpart E Asbestos Containing Materials in Schools. This regulation, commonly known as the "AHERA" rule, requires local education agencies, such as this one, to perform certain tasks in regards to the presence and control of asbestos containing materials in the buildings under the jurisdiction of the local education agency.

These include but are not limited to:

1. Developing an asbestos management plan which is designed to outline procedures and guidelines for the inspection, reinspection and periodic surveillance of asbestos containing materials that are present in the buildings.
2. Provide awareness training and additional training to selected school employees.
3. Periodically notify all workers and occupants, or their local guardians, parent teacher organizations, and collective bargaining organizations of the availability of asbestos management plans, the location of same and the times that the plans may be reviewed.

This notification is to advise all patrons, occupants, or their legal guardians, collective bargaining organizations, and parent-teachers organizations, that the asbestos management plans required under this act are available for review upon request. A copy of the plans for all buildings under the jurisdiction of this local education agency are available in the Service Center building, which is located at 301 E. 11th Street, Jeffersonville, Indiana 47130; telephone number (812) 288-4821. Plans for individual schools and other buildings are located in the administration office of each school. The plans can be viewed by any person during normal business hours of the particular school. Interested parties wishing to inquire about the hours and times that the plans are available should call the above number.

At this time, the management plans can provide information regarding inspections, response actions, and post-response action activities, including periodic reinspection and surveillance activities that are planned or in progress. Inquiries regarding any facet of the regulation or the management plans should be directed to Mr. Steve Hobgood at the above telephone number during regular business hours.

Listed is a brief description of asbestos work that has been completed in our schools this year. Detailed reports have become part of each school's asbestos management plan and may be reviewed in the school office.

Jeffersonville, Charlestown and New Washington High Schools; Parkview, River Valley and Charlestown Middle Schools; Wilson, Thomas Jefferson, Northaven, New Washington, Jonathan Jennings, Bridgepoint, Maple, Spring Hill, and Parkwood Elementary Schools; the former Administration Building, Service Center, and Corden Porter Center Buildings -

- * The required triennial reinspection was performed in June 2007.
- * The required six month periodic surveillance was performed in December 2008.
- * The next scheduled activities are the required six month periodic surveillance in June 2009 and Dec 2009. Charlestown High School has undergone an asbestos removal project prior to partial demolition.

Pleasant Ridge Elementary School, Utica Elementary School and the (New) Administration Building – These buildings are asbestos free and **Riverside Elementary** was demolished in 2006. No surveillances or re-inspections are required for these buildings.

April 2009

AHERA ANNUAL NOTICE
GREATER CLARK COUNTY SCHOOLS

This information is being published to comply with the requirements of 40 CFR 763 Subpart E asbestos containing materials in schools. This regulation, commonly known as the "AHERA" rule, requires local education agencies, such as this one, to perform certain tasks in regards to the presence and control of asbestos containing materials in the buildings under the jurisdiction of the local education agency.

These include but are not limited to:

1. Developing an asbestos management plan which is designed to outline procedures and guidelines for the inspection, reinspection and periodic surveillance of asbestos containing materials that are present in the buildings.
2. Provide awareness training and additional training to selected school employees.
3. Periodically notify all workers and occupants, or their local guardians, parent teacher organizations, and collective bargaining organizations of the availability of asbestos management plans, the location of same and the times that the plans may be reviewed.

This notification is to advise all patrons, occupants, or their legal guardians, collective bargaining organizations, and parent-teachers organizations, that the asbestos management plans required under this act are available for review upon request. A copy of the plans for all buildings under the jurisdiction of this local education agency are available in the Service Center building, which is located at 301 E. 11th Street, Jeffersonville, Indiana 47130; telephone number (812)288-4821. Plans for individual schools and other buildings are located in the administration office of each school. The plans can be viewed by any person during normal business hours of the particular school. Interested parties wishing to inquire about the hours and times that the plans are available should call the above number.

At this time, the management plans can provide information regarding inspections, response actions, and post-response action activities, including periodic reinspection and surveillance activities that are planned or in progress. Inquiries regarding any facet of the regulation or the management plans should be directed to Mr. Steve Hobgood at the above telephone number during regular business hours.

Listed is a brief description of asbestos work that has been completed in our schools this year. Detailed reports have become part of each school's asbestos management plan and may be reviewed in the school office.

Jeffersonville, Charlestown, and New Washington High Schools; Parkview, Charlestown, and River Valley Middle Schools; Wilson, Thomas Jefferson, Northaven, New Washington, Jonathan Jennings, Bridgepoint, Maple, Spring Hill, and Parkwood Elementary Schools; the former Administration Building, Service Center, and Corden Porter Center Buildings -

- * The required triennial reinspection was performed in June 2007.
- * The required six month periodic surveillance was performed in December 2007.
- * The next scheduled activities are the required six month periodic surveillance in June 2008 and Dec 2008.

Pleasant Ridge Elementary School, Utica Elementary School and the (New) Administration Building – These buildings are asbestos free. **Riverside Elementary** was Demolition in 2006. No surveillances or reinspections are required.

April 2008

AHERA ANNUAL NOTICE
GREATER CLARK COUNTY SCHOOLS

This information is being published to comply with the requirements of 40 CFR 763 Subpart E asbestos containing materials in schools. This regulation, commonly known as the "AHERA" rule, requires local education agencies, such as this one, to perform certain tasks in regards to the presence and control of asbestos containing materials in the buildings under the jurisdiction of the local education agency.

These include but are not limited to:

1. Developing an asbestos management plan which is designed to outline procedures and guidelines for the inspection, reinspection and periodic surveillance of asbestos containing materials that are present in the buildings.
2. Provide awareness training and additional training to selected school employees.
3. Periodically notify all workers and occupants, or their local guardians, parent teacher organizations, and collective bargaining organizations of the availability of asbestos management plans, the location of same and the times that the plans may be reviewed.

This notification is to advise all patrons, occupants, or their legal guardians, collective bargaining organizations, and parent-teachers organizations, that the asbestos management plans required under this act are available for review upon request. A copy of the plans for all buildings under the jurisdiction of this local education agency are available in the Service Center building, which is located at 301 E. 11th Street, Jeffersonville, Indiana 47130; telephone number 288-4821. Plans for individual schools and other buildings are located in the administration office of each school. The plans can be viewed by any person during normal business hours of the particular school. Interested parties wishing to inquire about the hours and times that the plans are available should call the above number.

At this time, the management plans can provide information regarding inspections, response actions, and post-response action activities, including periodic reinspection and surveillance activities that are planned or in progress. Inquiries regarding any facet of the regulation or the management plans should be directed to Mr. Chuck Graves at the above telephone number during regular business hours.

Listed is a brief description of asbestos work that has been completed in our schools this year. Detailed reports have become part of each school's asbestos management plan and may be reviewed in the school office.

Jeffersonville, Charlestown, and New Washington High Schools; Parkview, Charlestown, and River Valley Middle Schools; Wilson, Thomas Jefferson, Northaven, New Washington, Jonathan Jennings, Bridgepoint, Maple, Spring Hill, and Parkwood Elementary Schools; the former Administration Building, Service Center, and Corden Porter Center Buildings -

- * The required six month periodic surveillance was performed in June 2006.
- * The required six month periodic surveillance was performed in December 2006.
- * The next scheduled activities are the required six month periodic surveillance in June 2007 and Dec 2007.

Pleasant Ridge Elementary School, Utica Elementary School and the (New) Administration Building – These buildings are asbestos free. **Riverside Elementary** was Demolition in 2006. No surveillances or reinspections are required.

March 2007

AHERA ANNUAL NOTICE
GREATER CLARK COUNTY SCHOOLS

This information is being published to comply with the requirements of 40 CFR 763 Subpart E asbestos containing materials in schools. This regulation, commonly known as the "AHERA" rule, requires local education agencies, such as this one, to perform certain tasks in regards to the presence and control of asbestos containing materials in the buildings under the jurisdiction of the local education agency.

These include but are not limited to:

1. Developing an asbestos management plan which is designed to outline procedures and guidelines for the inspection, reinspection and periodic surveillance of asbestos containing materials that are present in the buildings.
2. Provide awareness training and additional training to selected school employees.
3. Periodically notify all workers and occupants, or their local guardians, parent teacher organizations, and collective bargaining organizations of the availability of asbestos management plans, the location of same and the times that the plans may be reviewed.

This notification is to advise all patrons, occupants, or their legal guardians, collective bargaining organizations, and parent-teachers organizations, that the asbestos management plans required under this act are available for review upon request. A copy of the plans for all buildings under the jurisdiction of this local education agency are available in the Service Center building, which is located at 301 E. 11th Street, Jeffersonville, Indiana 47130; telephone number 288-4821. Plans for individual schools and other buildings are located in the administration office of each school. The plans can be viewed by any person during normal business hours of the particular school. Interested parties wishing to inquire about the hours and times that the plans are available should call the above number.

At this time, the management plans can provide information regarding inspections, response actions, and post-response action activities, including periodic reinspection and surveillance activities that are planned or in progress. Inquiries regarding any facet of the regulation or the management plans should be directed to Mr. Chuck Graves at the above telephone number during regular business hours.

Listed is a brief description of asbestos work that has been completed in our schools this year. Detailed reports have become part of each school's asbestos management plan and may be reviewed in the school office.

Jeffersonville, Charlestown, and New Washington High Schools; Parkview, Charlestown, and River Valley Middle Schools; Wilson, Thomas Jefferson, Northaven, New Washington, Jonathan Jennings, Bridgepoint, Maple, Riverside, Spring Hill, and Parkwood Elementary Schools; the former Administration Building, Service Center, and Corden Porter Center Buildings -

* The required triennial reinspection was performed in June 2005.

* The required six month periodic surveillance was performed in December 2005.

* The next scheduled activities are the required six month periodic surveillance in June 2006 and Dec 2006.

Pleasant Ridge Elementary School, Utica Elementary School and the (New) Administration Building –
These buildings are asbestos free. No surveillances or reinspections are required.

March 2006

AHERA Annual Notice
GREATER CLARK COUNTY SCHOOLS

This information is being published to comply with the requirements of 40 CFR 763 Subpart E asbestos containing materials in schools. This regulation, commonly known as the "AHERA" rule, requires local education agencies, such as this one, to perform certain tasks in regards to the presence and control of asbestos containing materials in the buildings under the jurisdiction of the local education agency.

These include but are not limited to:

1. Developing an asbestos management plan which is designed to outline procedures and guidelines for the inspection, reinspection and periodic surveillance of asbestos containing materials that are present in the buildings.
2. Provide awareness training and additional training to selected school employees.
3. Periodically notify all workers and occupants, or their local guardians, parent teacher organizations, and collective bargaining organizations of the availability of asbestos management plans, the location of same and the times that the plans may be reviewed.

This notification is to advise all patrons, occupants, or their legal guardians, collective bargaining organizations, and parent-teachers organizations, that the asbestos management plans required under this act are available for review upon request. A copy of the plans for all buildings under the jurisdiction of this local education agency are available in the Service Center building, which is located at 301 E. 11th Street, Jeffersonville, Indiana 47130; telephone number 288-4821. Plans for individual schools and other buildings are located in the administration office of each school. The plans can be viewed by any person during normal business hours of the particular school. Interested parties wishing to inquire about the hours and times that the plans are available should call the above number.

At this time, the management plans can provide information regarding inspections, response actions, and post-response action activities, including periodic reinspection and surveillance activities that are planned or in progress. Inquiries regarding any facet of the regulation or the management plans should be directed to Mr. Chuck Graves at the above telephone number during regular business hours.

Listed is a brief description of asbestos work that has been completed in our schools this year. Detailed reports have become part of each school's asbestos management plan and may be reviewed in the school office.

Jeffersonville, Charlestown, and New Washington High Schools; Parkview, Charlestown, and River Valley Middle Schools; Wilson, Thomas Jefferson, Northaven, New Washington, Jonathan Jennings, Bridgepoint, Maple, Riverside, Spring Hill, and Parkwood Elementary Schools; the former Administration Building, Service Center, and Corden Porter Center Buildings -

- * The required triennial reinspection was performed in June 2004.
- * The required six month periodic surveillance was performed in December 2004.
- * The next scheduled activities are the required six month periodic surveillance in June 2005 and December 2005.

Pleasant Ridge Elementary School, Utica Elementary School and the (New) Administration Building -

- * These buildings are asbestos free. No surveillances or reinspections are required.

AHERA Annual Notice
GREATER CLARK COUNTY SCHOOLS

This information is being published to comply with the requirements of 40 CFR 763 Subpart E asbestos containing materials in schools. This regulation, commonly known as the "AHERA" rule, requires local education agencies, such as this one, to perform certain tasks in regards to the presence and control of asbestos containing materials in the buildings under the jurisdiction of the local education agency.

These include but are not limited to:

1. Developing an asbestos management plan which is designed to outline procedures and guidelines for the inspection, reinspection and periodic surveillance of asbestos containing materials that are present in the buildings.
2. Provide awareness training and additional training to selected school employees.
3. Periodically notify all workers and occupants, or their local guardians, parent teacher organizations, and collective bargaining organizations of the availability of asbestos management plans, the location of same and the times that the plans may be reviewed.

This notification is to advise all patrons, occupants, or their legal guardians, collective bargaining organizations, and parent-teachers organizations, that the asbestos management plans required under this act are available for review upon request. A copy of the plans for all buildings under the jurisdiction of this local education agency are available in the Service Center building, which is located at 301 E. 11th Street, Jeffersonville, Indiana 47130; telephone number 288-4821. Plans for individual schools and other buildings are located in the administration office of each school. The plans can be viewed by any person during normal business hours of the particular school. Interested parties wishing to inquire about the hours and times that the plans are available should call the above number.

At this time, the management plans can provide information regarding inspections, response actions, and post-response action activities, including periodic reinspection and surveillance activities that are planned or in progress. Inquiries regarding any facet of the regulation or the management plans should be directed to Mr. Tony Nauert at the above telephone number during regular business hours.

Listed is a brief description of asbestos work that has been completed in our schools this year. Detailed reports have become part of each school's asbestos management plan and may be reviewed in the school office.

Jeffersonville, Charlestown, and New Washington High Schools; Parkview, Charlestown, and River Valley Middle Schools; Wilson, Thomas Jefferson, Northaven, New Washington, Jonathan Jennings, Bridgepoint, Maple, Riverside, Spring Hill, and Parkwood Elementary Schools; the former Administration Building, Service Center, and Corden Porter Center Buildings -

- * The required six month periodic surveillance was performed in June 2003.
- * The required six month periodic surveillance was performed in December 2003.
- * The next scheduled activities are the required triennial reinspection in June 2004 and a required six month periodic surveillance in December 2004.

Pleasant Ridge Elementary School, Utica Elementary School and the (New) Administration Building -

- * These buildings are asbestos free. No surveillances or reinspections are required.

March 2004

AHERA Annual Notice
GREATER CLARK COUNTY SCHOOLS

This information is being published to comply with the requirements of 40 CFR 763 Subpart E asbestos containing materials in schools. This regulation, commonly known as the "AHERA" rule, requires local education agencies, such as this one, to perform certain tasks in regards to the presence and control of asbestos containing materials in the buildings under the jurisdiction of the local education agency.

These include but are not limited to:

1. Developing an asbestos management plan which is designed to outline procedures and guidelines for the inspection, reinspection and periodic surveillance of asbestos containing materials that are present in the buildings.
2. Provide awareness training and additional training to selected school employees.
3. Periodically notify all workers and occupants, or their local guardians, parent teacher organizations, and collective bargaining organizations of the availability of asbestos management plans, the location of same and the times that the plans may be reviewed.

This notification is to advise all patrons, occupants, or their legal guardians, collective bargaining organizations, and parent-teachers organizations, that the asbestos management plans required under this act are available for review upon request. A copy of the plans for all buildings under the jurisdiction of this local education agency are available in the Service Center building, which is located at 301 E. 11th Street, Jeffersonville, Indiana 47130; telephone number 288-4821. Plans for individual schools and other buildings are located in the administration office of each school. The plans can be viewed by any person during normal business hours of the particular school. Interested parties wishing to inquire about the hours and times that the plans are available should call the above number.

At this time, the management plans can provide information regarding inspections, response actions, and post-response action activities, including periodic reinspection and surveillance activities that are planned or in progress. Inquiries regarding any facet of the regulation or the management plans should be directed to Mr. Tony Nauert at the above telephone number during regular business hours.

Listed is a brief description of asbestos work that has been completed in our schools this year. Detailed reports have become part of each school's asbestos management plan and may be reviewed in the school office.

Jeffersonville, Charlestown, and New Washington High Schools; Parkview, Charlestown, and River Valley Middle Schools; Wilson, Thomas Jefferson, Northaven, New Washington, Jonathan Jennings, Bridgepoint, Maple, Riverside, Spring Hill, and Parkwood Elementary Schools; the former Administration Building, Service Center, and Corden Porter Center Buildings -

- * The required six month periodic surveillance was performed in June 2002.
- * The required six month periodic surveillance was performed in December 2002.
- * The next scheduled activity is the required periodic surveillance in June 2003.

Pleasant Ridge Elementary School, Utica Elementary School and the (New) Administration Building -

- * These buildings are asbestos free. No surveillances or reinspections are required.

May 2003

AHERA Annual Notice
GREATER CLARK COUNTY SCHOOLS

This information is being published to comply with the requirements of 40 CFR 763 Subpart E asbestos containing materials in schools. This regulation, commonly known as the "AHERA" rule, requires local education agencies, such as this one, to perform certain tasks in regards to the presence and control of asbestos containing materials in the buildings under the jurisdiction of the local education agency.

These include but are not limited to:

1. Developing an asbestos management plan which is designed to outline procedures and guidelines for the inspection, reinspection and periodic surveillance of asbestos containing materials that are present in the buildings.
2. Provide awareness training and additional training to selected school employees.
3. Periodically notify all workers and occupants, or their local guardians, parent teacher organizations, and collective bargaining organizations of the availability of asbestos management plans, the location of same and the times that the plans may be reviewed.

This notification is to advise all patrons, occupants, or their legal guardians, collective bargaining organizations, and parent-teachers organizations, that the asbestos management plans required under this act are available for review upon request. A copy of the plans for all buildings under the jurisdiction of this local education agency are available in the Service Center building, which is located at 301 E. 11th Street, Jeffersonville, Indiana 47130; telephone number 288-4821. Plans for individual schools and other buildings are located in the administration office of each school. The plans can be viewed by any person during normal business hours of the particular school. Interested parties wishing to inquire about the hours and times that the plans are available should call the above number.

At this time, the management plans can provide information regarding inspections, response actions, and post-response action activities, including periodic reinspection and surveillance activities that are planned or in progress. Inquiries regarding any facet of the regulation or the management plans should be directed to Mr. Tony Nauert at the above telephone number during regular business hours.

Listed is a brief description of asbestos work that has been completed in our schools this year. Detailed reports have become part of each school's asbestos management plan and may be reviewed in the school office.

Jeffersonville, Charlestown, and New Washington High Schools; Parkview, Charlestown, and River Valley Middle Schools; Wilson, Thomas Jefferson, Northaven, New Washington, Jonathan Jennings, Bridgepoint, Maple, Riverside, Spring Hill, and Parkwood Elementary Schools; the Administration Building, Service Center, and Corden Porter Center Buildings -

- * The required triennial reinspection was performed in July 2001.
- * The required six month periodic surveillance was performed in December 2001.
- * The next scheduled activities are the required periodic surveillances in June 2002 and December 2002.

Pleasant Ridge Elementary School and (New) Utica Elementary School -

- * These buildings are asbestos free. No surveillances or reinspections are required.

(Old) Utica Elementary School -

- * In accordance with information collected from the GCCS this building has been deeded to the town of Utica. No further AHERA periodic surveillances or triennial reinspections will be conducted by the designated person.

AHERA Annual Notice
GREATER CLARK COUNTY SCHOOLS

This information is being published to comply with the requirements of 40 CFR 763 Subpart E asbestos containing materials in schools. This regulation, commonly known as the "AHERA" rule, requires local education agencies, such as this one, to perform certain tasks in regards to the presence and control of asbestos containing materials in the buildings under the jurisdiction of the local education agency.

These include but are not limited to:

1. Developing an asbestos management plan which is designed to outline procedures and guidelines for the inspection, reinspection and periodic surveillance of asbestos containing materials that are present in the buildings.
2. Provide awareness training and additional training to selected school employees.
3. Periodically notify all workers and occupants, or their local guardians, parent teacher organizations, and collective bargaining organizations of the availability of asbestos management plans, the location of same and the times that the plans may be reviewed.

This notification is to advise all patrons, occupants, or their legal guardians, collective bargaining organizations, and parent-teachers organizations, that the asbestos management plans required under this act are available for review upon request. A copy of the plans for all buildings under the jurisdiction of this local education agency are available in the Service Center building, which is located at 301 E. 11th Street, Jeffersonville, Indiana 47130; telephone number 288-4821. Plans for individual schools and other buildings are located in the administration office of each school. The plans can be viewed by any person during normal business hours of the particular school. Interested parties wishing to inquire about the hours and times that the plans are available should call the above number.

At this time, the management plans can provide information regarding inspections, response actions, and post-response action activities, including periodic reinspection and surveillance activities that are planned or in progress. Inquiries regarding any facet of the regulation or the management plans should be directed to Mr. Tony Nauert at the above telephone number during regular business hours.

Listed is a brief description of asbestos work that has been completed in our schools this year. Detailed reports have become part of each school's asbestos management plan and may be reviewed in the school office.

Jeffersonville, Charlestown, and New Washington High Schools; Parkview, Charlestown, and River Valley Middle Schools; Wilson, Thomas Jefferson, Northaven, (Old) Utica, New Washington, Jonathan Jennings, Bridgepoint, Maple, Riverside, Spring Hill, and Parkwood Elementary Schools; the Administration Building, Service Center, and Corden Porter Center -

- * The required six month periodic surveillance was performed in June 2000.
- * The required six month periodic surveillance was performed in January 2001.
- * The next scheduled activity is a required triennial reinspection in June 2001.

Pleasant Ridge Elementary School and (New) Utica Elementary School -

- * This building is asbestos free. No surveillances or reinspections are required.

June 2001

AHERA Annual Notice
GREATER CLARK COUNTY SCHOOLS

This information is being published to comply with the requirements of 40 CFR 763 Subpart E asbestos containing materials in schools. This regulation, commonly known as the "AHERA" rule, requires local education agencies, such as this one, to perform certain tasks in regards to the presence and control of asbestos containing materials in the buildings under the jurisdiction of the local education agency.

These include but are not limited to:

1. Developing an asbestos management plan which is designed to outline procedures and guidelines for the inspection, reinspection and periodic surveillance of asbestos containing materials that are present in the buildings.
2. Provide awareness training and additional training to selected school employees.
3. Periodically notify all workers and occupants, or their local guardians, parent teacher organizations, and collective bargaining organizations of the availability of asbestos management plans, the location of same and the times that the plans may be reviewed.

This notification is to advise all patrons, occupants, or their legal guardians, collective bargaining organizations, and parent-teachers organizations, that the asbestos management plans required under this act are available for review upon request. A copy of the plans for all buildings under the jurisdiction of this local education agency are available in the Service Center building, which is located at 301 E. 11th Street, Jeffersonville, Indiana 47130; telephone number 288-4821. Plans for individual schools and other buildings are located in the administration office of each school. The plans can be viewed by any person during normal business hours of the particular school. Interested parties wishing to inquire about the hours and times that the plans are available should call the above number.

At this time, the management plans can provide information regarding inspections, response actions, and post-response action activities, including periodic reinspection and surveillance activities that are planned or in progress. Inquiries regarding any facet of the regulation or the management plans should be directed to Mr. Tony Nauert at the above telephone number during regular business hours.

Listed is a brief description of asbestos work that has been completed in our schools this year. Detailed reports have become part of each school's asbestos management plan and may be reviewed in the school office.

Jeffersonville, Charlestown, and New Washington High Schools; Parkview, Charlestown, and River Valley Middle Schools; Wilson, Thomas Jefferson, Northaven, Utica, New Washington, Jonathan Jennings, Bridgepoint, Maple, Riverside, Spring Hill, and Parkwood Elementary Schools; the Administration Building, Service Center, and Corden Porter Center -

- * The required six month periodic surveillance was performed in June 1999.
- * The required six month periodic surveillance was performed in December 1999.
- * The next scheduled activity is a required periodic surveillance in June 2000.

Pleasant Ridge Elementary School -

- * This building is asbestos free. No surveillances or reinspections are required.

June 2000

AHERA Annual Notice

This information is being published to comply with the requirements of 40 CFR 763 Subpart E asbestos containing materials in schools. This regulation, commonly known as the "AHERA" rule, requires local education agencies, such as this one, to perform certain tasks in regards to the presence and control of asbestos containing materials in the buildings under the jurisdiction of the local education agency.

These include but are not limited to:

1. Developing an asbestos management plan which is designed to outline procedures and guidelines for the inspection, reinspection and periodic surveillance of asbestos containing materials that are present in the buildings.
2. Provide awareness training and additional training to selected school employees.
3. Periodically notify all workers and occupants, or their local guardians, parent teacher organizations, and collective bargaining organizations of the availability of asbestos management plans, the location of same and the times that the plans may be reviewed.

This notification is to advise all patrons, occupants, or their legal guardians, collective bargaining organizations, and parent-teachers organizations, that the asbestos management plans required under this act are available for review upon request. A copy of the plans for all buildings under the jurisdiction of this local education agency are available in the Service Center building, which is located at 301 E. 11th Street, Jeffersonville, Indiana 47130; telephone number 288-4821. Plans for individual schools and other buildings are located in the administration office of each school. The plans can be viewed by any person during normal business hours of the particular school. Interested parties wishing to inquire about the hours and times that the plans are available should call the above number.

At this time, the management plans can provide information regarding inspections, response actions, and post-response action activities, including periodic reinspection and surveillance activities that are planned or in progress. Inquiries regarding any facet of the regulation or the management plans should be directed to Mr. Steve Meredith at the above telephone number during regular business hours.

Listed is a brief description of asbestos work that has been completed in our schools this year. Detailed reports have become part of each school's asbestos management plan and may be reviewed in the school office.

All school and support buildings where it is required -

- * The required six month periodic surveillance was performed in June 1998.
- * The required six month periodic surveillance was performed in December 1998.
- * The next scheduled activity is a required periodic surveillance in June 1999.

Parkwood Elementary School

- * O & M was performed in the boiler room in May 1998.

June 1999

AHERA Annual Notice

This information is being published to comply with the requirements of 40 CFR 763 Subpart E asbestos containing materials in schools. This regulation, commonly known as the "AHERA" rule, requires local education agencies, such as this one, to perform certain tasks in regards to the presence and control of asbestos containing materials in the buildings under the jurisdiction of the local education agency.

These include but are not limited to:

1. Developing an asbestos management plan which is designed to outline procedures and guidelines for the inspection, reinspection and periodic surveillance of asbestos containing materials that are present in the buildings.
2. Provide awareness training and additional training to selected school employees.
3. Periodically notify all workers and occupants, or their local guardians, parent teacher organizations, and collective bargaining organizations of the availability of asbestos management plans, the location of same and the times that the plans may be reviewed.

This notification is to advise all patrons, occupants, or their legal guardians, collective bargaining organizations, and parent-teachers organizations, that the asbestos management plans required under this act are available for review upon request. A copy of the plans for all buildings under the jurisdiction of this local education agency are available in the Service Center building, which is located at 301 E. 11th Street, Jeffersonville, Indiana 47130; telephone number 288-4821. Plans for individual schools and other buildings are located in the administration office of each school. The plans can be viewed by any person during normal business hours of the particular school. Interested parties wishing to inquire about the hours and times that the plans are available should call the above number.

At this time, the management plans can provide information regarding inspections, response actions, and post-response action activities, including periodic reinspection and surveillance activities that are planned or in progress. Inquiries regarding any facet of the regulation or the management plans should be directed to Mr. Steve Meredith at the above telephone number during regular business hours.

Listed is a brief description of asbestos work that has been completed in our schools this year. Detailed reports have become part of each school's asbestos management plan and may be reviewed in the school office.

All school and support buildings where it is required -

- * The required periodic surveillance was performed in June 1997 and December 1997.
- * Next activity scheduled activity is a required third year reinspection in June 1998.

AHERA Annual Notice

This information is being published to comply with the requirements of 40 CFR 763 Subpart E asbestos containing materials in schools. This regulation, commonly known as the "AHERA" rule, requires local education agencies, such as this one, to perform certain tasks in regards to the presence and control of asbestos containing materials in the buildings under the jurisdiction of the local education agency.

These include but are not limited to:

1. Developing an asbestos management plan which is designed to outline procedures and guidelines for the inspection, reinspection and periodic surveillance of asbestos containing materials that are present in the buildings.
2. Provide awareness training and additional training to selected school employees.
3. Periodically notify all workers and occupants, or their local guardians, parent teacher organizations, and collective bargaining organizations of the availability of asbestos management plans, the location of same and the times that the plans may be reviewed.

This notification is to advise all patrons, occupants, or their legal guardians, collective bargaining organizations, and parent-teachers organizations, that the asbestos management plans required under this act are available for review upon request. A copy of the plans for all buildings under the jurisdiction of this local education agency are available in the Service Center building, which is located at 301 E. 11th Street, Jeffersonville, Indiana 47130; telephone number 288-4821. Plans for individual schools and other buildings are located in the administration office of each school. The plans can be viewed by any person during normal business hours of the particular school. Interested parties wishing to inquire about the hours and times that the plans are available, should call the above number.

At this time, the management plans can provide information regarding inspections, response actions, and post-response action activities, including periodic reinspection and surveillance activities that are planned or in progress. Inquiries regarding any facet of the regulation or the management plans should be directed to Mr. Steve Meredith at the above telephone number during regular business hours.

Listed is a brief description of asbestos work that has been completed in our schools this year. Detailed reports have become part of each school's asbestos management plan and may be reviewed in the school office.

All school and support buildings where it is required -

- * The required periodic surveillance was performed in June 1996 and December 1996.
- * The next required periodic surveillance will be performed in June 1997 and December 1997.

June 97

This information is being published to comply with the requirements of 40 CFR 763 Subpart E asbestos containing materials in schools. This regulation, commonly known as the "AHERA" rule, requires local education agencies, such as this one, to perform certain tasks in regards to the presence and control of asbestos containing materials in the buildings under the jurisdiction of the local education agency.

These include but are not limited to:

1. Developing an asbestos management plan which is designed to outline procedures and guidelines for the inspection, reinspection and periodic surveillance of asbestos containing materials that are present in the buildings.
2. Provide awareness training and additional training to selected school employees.
3. Periodically notify all workers and occupants, or their local guardians, parent teacher organizations, and collective bargaining organizations of the availability of asbestos management plans, the location of same and the times that the plans may be reviewed.

This notification is to advise all patrons, occupants, or their legal guardians, collective bargaining organizations, and parent-teachers organizations, that the asbestos management plans required under this act are available for review upon request. A copy of the plans for all buildings under the jurisdiction of this local education agency are available in the Service Center building, which is located at 301 E. 11th Street, Jeffersonville, Indiana 47130; telephone number 288-4821. Plans for individual schools and other buildings are located in the administration office of each school. The plans can be viewed by any person during normal business hours of the particular school. The plans can be viewed by any person during normal business hours of the particular school. Interested parties wishing to inquire about the hours and times that the plans are available should call the above number.

At this time, the management plans can provide information regarding inspections, response actions, and post-response action activities, including periodic reinspection and surveillance activities that are planned or in progress. Inquiries regarding any facet of the regulation or the management plans should be directed to Mr. Denny Johanson at the above telephone number during regular business hours.

Listed is a brief description of asbestos work that has been completed in our schools this year. Detailed reports have become part of each school's asbestos management plan and may be reviewed in the school office.

All buildings where it is required -

- * The required third year reinspection was performed in June 1995.
- * The required periodic surveillance was performed in December 1995.
- * Next activity scheduled is a periodic surveillance in June 1996.

Charlestown High School -

- * Transite panels were compliantly removed from the exterior of the building.

Corden Porter Building #3 -

- * TSI was compliantly removed from the boiler room.

June 96

This information is being published to comply with the requirements of 40 CFR 763 Subpart E asbestos containing materials in schools. This regulation, commonly known as the "AHERA" rule, requires local education agencies, such as this one, to perform certain tasks in regards to the presence and control of asbestos containing materials in the buildings under the jurisdiction of the local education agency.

These include but are not limited to:

1. Developing an asbestos management plan which is designed to outline procedures and guidelines for the inspection, reinspection and periodic surveillance of asbestos containing materials that are present in the buildings.
2. Provide awareness training and additional training to selected school employees.
3. Periodically notify all workers and occupants, or their local guardians, parent teacher organizations, and collective bargaining organizations of the availability of asbestos management plans, the location of same and the times that the plans may be reviewed.

This notification is to advise all patrons, occupants, or their legal guardians, collective bargaining organizations, and parent-teachers organizations, that the asbestos management plans required under this act are available for review upon request. A copy of the plans for all buildings under the jurisdiction of this local education agency are available in the Service Center building, which is located at 301 E. 11th Street, Jeffersonville, Indiana 47130; telephone number 288-4821. Plans for individual schools and other buildings are located in the administration office of each school. The plans can be viewed by any person during normal business hours of the particular school. Interested parties wishing to inquire about the hours and times that the plans are available, should call the above number.

At this time, the management plans can provide information regarding inspections, response actions, and post-response action activities, including periodic reinspection and surveillance activities that are planned or in progress. Inquiries regarding any facet of the regulation or the management plans should be directed to Mr. Dennis Johanson at the above telephone number during regular business hours.

Listed is a brief description of asbestos work that has been completed in our schools this year. Detailed reports have become part of each school's asbestos management plan and may be reviewed in the school office.

All school and support buildings where it is required -

- * The required periodic surveillance was performed in June 1995 and December 1995.
- * The required triennial reinspection was performed in June 1995.
- * The next required periodic surveillance will be performed in June 1996 and December 1996.

June 95

ACCREDITATIONS



Environmental Management Institute

5610 Crawfordsville Road, Suite 15, Indianapolis, Indiana 46224-3714

317/248-4848 • 800/488-8842 • FAX 317/248-4846
www.envtlmgmt.org

This confirms that

Sandy Shadley

Completed the Required Initial Training for
Asbestos Accreditation Under TSCA Title II
and has
passed with a Score of 70 or Greater the Examination for

Asbestos Management Planner

Course Date
December 10 - 11, 2009

Examination Date
December 11, 2009



Jack E. Leonard, President

Certificate: MP(I) 2248
Expires: December 11, 2010

Approved by: Illinois Department of Public Health
Indiana Department of Environmental Management

Indiana Department of Environmental Management
100 N. Senate Avenue
Mail Code 61-52 IGCN 1003
Indianapolis, IN 46204-2251



January 21, 2010

RECEIVED JAN 23 2010

Sandra S. Shadley
Alliance Environmental Grp
5340 Commerce Circle Ste E
Indianapolis IN 46237

Re: Asbestos Management Planner # 19A002720

Based upon the review of your license application, the Office of Air Quality has determined that you have fulfilled the requirements of 326 IAC 18 and are eligible for licensing in the following discipline:

Asbestos Management Planner

Your Asbestos Management Planner license is attached below. The license is waterproof and tear resistant. Please sign your license and do not laminate or alter your license in anyway. Your license must be available for review at all times while implementing an asbestos project. This license may be revoked, pursuant to 326 IAC 18-1-7, if you:

- (1) Violate any requirements of these rules (326 IAC 18), 326 IAC 14-10, or any requirement of the Asbestos-Containing Materials in Schools Rule or any other federal, state, or local regulation pertaining to asbestos in buildings or to asbestos projects.
- (2) Falsify information on your application for licensing.
- (3) Fail to meet any qualifications specified in 326-IAC 18-1-4.
- (4) Conduct asbestos project, or related asbestos handling activity, in a manner which is hazardous to the public health.

Your license is valid effective 01/21/2010, and will expire on 01/21/2011, as indicated on your card. We suggest that you attend the required training and submit an application for license renewal early to insure your license does not lapse. NOTE: 326 IAC 18-1-4(h) and 326 IAC 18-1-6(e) require that any individual who has an eighteen (18) month lapse between any two training courses of the same discipline to attend an initial training course for the discipline in which they are seeking a license. In order to avoid re-taking the initial training course you must have attended a refresher in the discipline you are seeking a license within eighteen (18) months from the date of issuance of your last training course certificate.

Office of Air Quality, Asbestos Licensing Section (317) 233-3861



Indiana Dept. of Environmental Management

Sandra S. Shadley

Asbestos Management Planner License #: 19A002720

Effective: 01/21/2010	Expiration: 01/21/2011
Birth Date: 04/21/1959	Gender: F
Height: 5-08	Eye Color: Blue
Weight: 140	Hair Color: Brown

ENVIRONMENTAL SAFETY ASSURANCE INSTITUTE
1435 Sadlier Circle West Drive
Indianapolis, Indiana 46239
(317) 352 -1270 / (317) 352 - 0669

CHRISTIAAN SPARKS
306 - 04 - 2616

Has Successfully Completed The Course
Required Under TSCA Title II
And Passed The Written Examination
With a Score of 70% or Better

For
ASBESTOS BUILDING INSPECTOR REFRESHER

Accredited by the
Indiana Department of Environmental Management.

Certificate # ES03/BIR755

Course Dates: 09/26/2003
Test Date: 09/26/ 2003 Expires: 09/26/2004



Sharyn Reyes
Sharyn Reyes
Instructor / Manager

ENVIRONMENTAL SAFETY ASSURANCE INSTITUTE
1435 Sadler Circle West Drive
Indianapolis, Indiana 46239
(317) 352-1270 / (317) 352-06

GEORGE Wm. (BILL) OGLE

Has Successfully Completed The Course
Required Under TSCA Title II
And Passed The Written Examination
With a Score of 70% or Better
For

**ASBESTOS MANAGEMENT PLANNER
REFRESHER**

Accredited by the
Indiana Department of Environmental Management.

Certificate # ES03/MPR045

Course Dates: 09/05/2003
Test Date: 09/05/2003 Expires: 09/05/2004




Sharyn Reyes
Instructor

ENVIRONMENTAL SAFETY ASSURANCE INSTITUTE
1435 Sadlier Circle West Drive
Indianapolis, Indiana 46239
(317) 352-1270 / (317) 352-0669

GEORGE WM. (BILL) OGLE

Has Successfully Completed The Course
Required Under TSCA Title II
And Passed The Written Examination
With a Score of 70% or Better
For

**ASBESTOS MANAGEMENT PLANNER
REFRESHER**

Management.
Accredited by the
Indiana Department of Environmental

Certificate # ES02/MPR032

Course Dates: 06/21/2002
Test Date: 06/21/2002 Expires: 06/21/2003

Sharyn Reyes

Sharyn Reyes
Instructor / Manager

ENVIRONMENTAL SAFETY ASSURANCE INSTITUTE

**1435 Sadlier Circle West Drive
Indianapolis, Indiana 46236
(317) 352-1270 / (317) 352 - 0669**

PATRICK E. WILSON

309 - 90 - 6909

**Has Successfully Completed The Course
Required Under TSCA Title II
And Passed The Written Examination
With a Score of 70% or Better
For**

ASBESTOS BUILDING INSPECTOR REFRESHER

**Accredited by the
Indiana Department of Environmental Management.**

Certificate # ES00/BIR482

**Course Dates: 11/29/2000
Test Date: 11/29/2000 Expires: 11/29/2001**

Sharyn Reyes

**Sharyn Reyes
Instructor**



Environmental Management Institute

5610 Crawfordsville Road, Suite 15, Indianapolis, Indiana 46224-3714

317/248-4848 • 800/488-8842 • FAX 317/248-4846
www.spea.iupui.edu/Envtl_mgmt


This confirms that

George Wm. (Bill) Ogle

Completed the Requisite Initial Training for
Asbestos Accreditation Under TSCA Title II
and has
Passed with a Score of 70 or Greater the Examination for
Asbestos Management Planner

Course date
March 2 - 3, 2000

Examination Date
March 3, 2000



Jack E. Leonard, President

Certificate: MP(I) 2157
Expires March 3, 2001

Approved by: Illinois Department of Public Health
Indiana Department of Environmental Management



ENVIRONMENTAL SAFETY ASSURANCE INSTITUTE
1435 Sadlier Circle West Drive
Indianapolis, Indiana 46239
(317) 352-1270 / (317) 352-0669

CLINT YATES

316 - 92 - 7065

Has Successfully Completed The Course
Required Under TSCA Title II
And Passed The Written Examination
With a Score of 70% or Better
For

ASBESTOS BUILDING INSPECTOR REFRESHER

Accredited by the
Indiana Department of Environmental Management.

Certificate # ES/BIR98/004.

Course Dates: 01/22/98 - 01/22/98
Test Date: 01/22/98 Expires: 01/22/99

Sharyn Reyes

Sharyn Reyes
Assistant / Instructor

Environmental Management Institute

Environmental and Occupational Training Service
5610 Crawfordsville Road, Suite 15
Indianapolis, Indiana 46224-3714
317/248-4848


This confirms that

Rex Gaddis

Completed the Requisite Refresher Training for
Asbestos Accreditation Under TSCA Title II
and has
Passed with a Score of 70 or Greater the Examination for
Asbestos Building Inspector

Course date
November 22, 1994

Examination Date
November 22, 1994



Jack E. Leonard, President

Certificate: IN(R) 2713
Expires November 22, 1995

Approved by: Illinois Department of Public Health
Indiana Department of Environmental Management

INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT
ASBESTOS CERTIFICATE OF ACCREDITATION
CERTIFICATE # 102248026 EXPIRATION DATE 2/18/96
Rex Gaddis
IS CERTIFIED IN THE FOLLOWING DISCIPLINE(S):
INSPECTOR PLANNER DESIGNER
SUPERVISOR WORKER
WASTE DISPOSAL MANAGER
BIRTHDATE: 3/24/52 SEX: M EYES: BLU
HEIGHT: 5-10 WEIGHT: 220 HAIR: BRO

INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT
ASBESTOS CERTIFICATE OF ACCREDITATION
CERTIFICATE # 190908032 EXPIRATION DATE 3/16/96
Rex Gaddis
IS CERTIFIED IN THE FOLLOWING DISCIPLINE(S):
INSPECTOR PLANNER DESIGNER
SUPERVISOR WORKER
WASTE DISPOSAL MANAGER
BIRTHDATE: 3/24/52 SEX: M EYES: BLU
HEIGHT: 5-10 WEIGHT: 220 HAIR: BRO

TRAINING

**OPERATIONS AND MAINTENANCE
INFORMATION**

MINOR FIBER RELEASE EPISODE

The local education agency shall ensure that the procedures described below are followed in the event of a minor fiber release episode (i.e., the falling or dislodging of not more than 3 square or linear feet of friable ACBM):

1. Thoroughly saturate the debris using wet methods.
2. Clean the area using wet methods, protective clothing, HEPA-vacuums, mini-enclosures, glove bags, as necessary to inhibit the spread of any released fibers. At a minimum, workers should use air-purifying respirators with HEPA filters.
3. Place the asbestos debris in a sealed, leak-tight container, preferably a 6 mil. labeled plastic bag.
4. Repair the area of damaged ACM with materials such as asbestos-free spackling, plaster, cement, or insulation, or seal with latex paint or an encapsulant, or immediately have the appropriate response action implemented.
5. Each fiber release episode should be documented.

MAJOR FIBER RELEASE EPISODE

The local education agency shall ensure that the procedures described below are followed in the event of a major fiber release episode (i.e., the falling or dislodging of more than 3 square or linear feet of friable ACM):

1. Restrict entry into the area and post signs to prevent entry into the area by persons other than those necessary to perform the response action.
2. Shut off or temporarily modify the air-handling system to prevent the distribution of fibers to other areas in the building.
3. AHERA requires that major fiber release episodes be designed by accredited Project Designers. However, the following response procedures should form the basis for response actions.
4. All the procedures recommended by EPA and required by OSHA for large-scale removal of ACM should be used. These include containment barrier, negative pressure ventilation, personal respiratory protection and protective clothing, decontamination facilities, and air testing.
5. Workers should wear "type C" respirators and protective clothing, including a body suit, hood, boots and gloves. Personal air monitoring may be conducted on representative workers, but is not required by OSHA when "type C" respirators are used.
6. Fallen debris should be sprayed with amended water and placed in plastic bags for disposal. Shovels are useful for collecting the debris. The floor should be thoroughly cleaned with a HEPA vacuum cleaner.
7. Walls, ceiling, pipes, boilers, or other surfaces where ACM was damaged or delaminated should be repaired temporarily. This might involve replastering with asbestos-free material, spraying with an encapsulant, or taping with duct tape. In some cases, ACM beyond the immediate area of damage may need to be removed to prevent additional episodes.
8. The air should be tested for asbestos fibers before the plastic barriers are removed and the area reoccupied. Testing should follow guidelines in Chapter 6 of the Purple Book and Chapter 4 of the Silver Book. That is, air should be sampled at the specified number of locations and analyzed by either phase contrast microscopy or transmission electron microscopy. However, sampling should not be done aggressively since the use of blowers and fans may dislodge fibers from the remaining ACM.

9. After the barriers have been taken down, a decontamination of the entire building or a portion of it should be considered. The need for this will depend on how rapidly the response team reacted to the episode and, in particular, how quickly the HVAC system was turned off. A thorough decontamination includes HEPA-vacuuming and/or wet wiping all carpets, furniture, and other surfaces. Decontamination of the HVAC system would involve disassembling and cleaning (HEPA-vacuuming or wet wiping) ducts, ventilators, registers, and other system parts. System filters should also be removed and replaced.

10. All equipment used in the cleanup operation should be washed or wiped with damp cloths. All disposable materials (e.g., cloths, mop heads, filters, coveralls) should be discarded as asbestos wastes.

11. Each fiber release episode should be documented.

OPERATIONS AND MAINTENANCE REPORT
(Use only for O&M work less than 3 square or 3 linear feet)

L.E.A.: _____

BUILDING: _____

DATE: _____

The following information is provided in accordance with 40 CFR 763.91 and 763.94.

1. Location: _____

Homogeneous Area/Material Description _____

2. Response: Clean _____ Repair _____ Encapsulation _____

Enclosure _____ Removal _____

Reason: _____

3. Work Description: _____

4. Date: Start _____ Stop _____

Time: Start _____ Stop _____

5. Material: Surface _____ SF Thermal _____ LF

Other: _____ SF or _____ LF

6. Asbestos Control Method: Wet Methods _____ HEPA Vacuum _____

Glovebag _____ Mini-Enclosure _____

7. Respiratory Protection: N.A.P.R. _____ P.A.P.R. _____

Were all employees properly fit tested? YES NO NOT APPLICABLE

8. Equipment Used:

Low Vol. Pumps	_____	High Vol. Pumps	_____
FAM	_____	AFD	_____
HEPA Vac	_____		

Other: _____

9. Material Used:

6 Mil. Disposable Bags	_____	Poly	_____
Glovebags	_____	HEPA Filters	_____
Duct Tape	_____	Spray Glue	_____
Disposable Coveralls	_____	3M Pads	_____
Sponges	_____		

Encapsulants: Penetrating _____ Bridging _____

Other: _____

10. Work Personnel:

<u>NAME</u>	<u>16 HOUR TRAINED - IDEM ACCREDITED</u>			
-------------	--	--	--	--

Supervisor: _____	YES	NO	YES	NO
-------------------	-----	----	-----	----

Worker(s): _____	YES	NO	YES	NO
------------------	-----	----	-----	----

_____	YES	NO	YES	NO
-------	-----	----	-----	----

_____	YES	NO	YES	NO
-------	-----	----	-----	----

_____	YES	NO	YES	NO
-------	-----	----	-----	----

_____	YES	NO	YES	NO
-------	-----	----	-----	----

11. ACBM Disposal: Storage: YES NO, If yes, where stored: _____

If no, where disposed: Landfill: _____

12. Final Visual Inspection Approved: _____

(LEA Designated Person - Printed Name)

(LEA Designated Person - Signature)

**REMOVAL PROJECT
INFORMATION**

SHORT TERM WORKER PROGRAM

GREATER CLARK COUNTY SCHOOLS

SHORT-TERM WORKER SIGN OFF SHEET

This form should be signed each and every time before a "short-term worker" (telephone repair worker, utility worker, etc.) performs work that may cause him to come in contact with ACBM or suspected ACBM assumed to be ACM. One copy of this form should then be forwarded to the LEA designated person, and one copy should be maintained in the school building's copy of the supplemental binder provided by Alliance Indiana, Inc., in order to fulfill the LEA's recordkeeping requirements. The third copy should be forwarded to Alliance Indiana, Inc. for placement in its copy of the supplemental binder.

School Building Name - Jeffersonville High School Date _____

I certify that before performing any work which would possibly cause me to come in contact with Asbestos Containing Building Materials (ACBM), I was provided with adequate information regarding the locations of ACBM and suspected ACBM assumed to be ACM in the above-mentioned school building where I performed the work.

Signature - _____

Company - _____

Description of work (including number of days on site) - _____
