

GREATER CLARK COUNTY SCHOOLS

THOMAS JEFFERSON ELEMENTARY SCHOOL

AHERA ASBESTOS MANAGEMENT PLAN

DESIGNATED PERSON TRUTH AND CORRECT STATEMENT

Local Education Agency – Greater Clark County Schools

2112 Utica-Sellersburg Road Jeffersonville, Indiana 47130

Designated Person - Alliance Environmental Group, Inc.

Sandra Shadley

5153 Commerce Square Drive, Suite E

Indianapolis, Indiana 46237

This Truth and Correct Statement, as outlined in 40 CFR 763.93(i), certifies that the general, local education agency responsibilities, as stipulated by 40 CFR 763.84, have been or will be met. These responsibilities include:

- 1. Ensure that the activities of any persons who perform inspections, reinspections, and periodic surveillance, develop and update management plans, and develop and implement response actions, including operations and maintenance, are carried out in accordance with 40 CFR 763 Subpart E.
- 2. Ensure all custodial and maintenance employees are properly trained as required by 40 CFR 763 Subpart E and other applicable Federal and/or State regulations (e.g., the Occupational Safety and Health Administration Asbestos Standard for Construction, the EPA Worker Protection Rule, or applicable State regulations).
- 3. Ensure that workers and building occupants, or their legal guardians, are informed at least once each school year about inspections, response actions, and post-response action activities, including periodic reinspection and surveillance activities that are planned or in progress.
- 4. Ensure that short-term workers (e.g., telephone repair workers, utility workers, or exterminators) who may come in contact with asbestos in a school are provided information regarding the locations of ACBM and suspected ACBM assumed to be ACM.
- 5. Ensure that warning labels are posted in accordance with Section 763.95.
- 6. Ensure management plans are available for inspection and notification of such availability has been provided as specified in the management plan under Section 763.93(g).
- 7. The undersigned person designated by the LEA pursuant to Section 763.84(g) (1) has received adequate training as stipulated in Section 763.84(g) (2).
- 8. The LEA has and will consider whether any conflict of interest may arise from the interrelationship among accredited personnel and whether that should influence the selection of accredited personnel to perform activities under Part 763.

Signature: _______ Date: November 6, 2016

Sandra S. Shadley

ASBESTOS PROGRAM MASTER INDEX

The following volumes are part of the Asbestos Program for the **GREATER CLARK COUNTY SCHOOLS**:

- A. Original Asbestos Management Plan for each school building.
- B. Asbestos Management Plan Supplement for each school building.
 - 1. Amendments to Management Plan
 - 2. Remaining Materials Report
 - 3. Surveillance, Reinspection and Additional Bulk Sampling Information
 - 4. Annual Notifications, Accreditations and Training Records
 - 5. Operations and Maintenance Records
 - 6. Asbestos Removal Projects
 - 7. Short Term Worker Program

Copies of both volumes are found in the respective buildings. The Administration Building also contains duplicate copies of both volumes for each building in their entirety.

GREATER CLARK COUNTY SCHOOLS THOMAS JEFFERSON ELEMENTARY SCHOOL TABLE OF CONTENTS

AMENDMENTS TO MANAGEMENT PLAN	1
REMAINING MATERIALS REPORT	2
SURVEILLANCE, REINSPECTION AND ADDITIONAL BULK SAMPLING INFORMATION	3
ANNUAL NOTIFICATIONS, ACCREDITATIONS, AND TRAINING	4
OPERATIONS AND MAINTENANCE RECORDS	5
ASBESTOS REMOVAL PROJECTS	e
SHORT TERM WORKER INFORMATION	7

Alliance I	ndiana, I	lnc.
------------	-----------	------

AHERA Program

AMENDMENTS TO THE MANAGEMENT PLAN

GREATER CLARK COUNTY SCHOOLS JEFFERSON ELEMENTARY SCHOOL

LEA RESPONSIBILITY CERTIFICATION

LEA Designated Person - ALLIANCE INDIANA, INC.

May 1, 1995 Date

ACCREDITATION STATEMENT

The Greater Clark County Schools ensures that the following items will be carried out:

Activities of any persons who perform inspections, reinspections, and periodic surveillance, develop and update management plans, and develop and implement response actions, including operations and maintenance, are carried out in accordance with Subpart E of this part.

All custodial and maintenance employees are properly trained as required by this Subpart E and other applicable Federal and/or State regulations (e.g., the OSHA asbestos standard for construction, the EPA worker protection rule, or applicable State regulations).

Workers and building occupants, or their legal guardians, are informed at least once each school year about inspections, response actions, and post response action activities, including periodic reinspection and surveillance activities that are planned or in progress.

Short-term workers (e.g., telephone repair workers, utility workers, or exterminators) who may come in contact with asbestos in a school are provided information regarding the locations of ACBM and suspected ACBM assumed to be ACM.

Warning labels are posted in accordance with 763.95.

Management plans are available for inspection and notification of such availability has been provided as specified in the management plan under 763.93(g).

Designate a person to ensure that requirements under this section are properly implemented.

Designated person receives adequate training to perform duties assigned under this section. Such training shall provide, as necessary, basic knowledge of:

Health effects of asbestos

Detection, identification, and assessment of ACM

Options for controlling ACBM

Asbestos management programs

Relevant Federal and State regulations concerning asbestos, including those in this Subpart E and those of the OSHA, U.S. Department of Labor, the U.S. Department of Transportation and the u.S. Environmental Protection Agency.

Consider whether any conflict of interest may arise from the interrelationship among accredited personnel and whether that should influence the selection of accredited personnel to perform activities under this subpart.

LEA Name -

Greater Clark County Schools

Building -

Thomas Jefferson Elementary School

Subject -

LEA Designated Person Change

Effective May 1, 1995 the Designated Person for the

Greater Clark County Schools is:

Alliance Indiana, Inc.

1433 Sadlier Circle West Drive Indianapolis, Indiana 46239

(317) 351-5600

Management Planner: Rex Gaddis

X Xadels

Accreditation No. 192218025

Signature

May 1, 1995

AMENDMENT TO THE AHERA MANAGEMENT PLAN

Building -	Thomas Jeff	erson Elementary	School		
Subject-	Deletion of a	material			
Reference -	HA 14 Chalk	boards			
Original Ass	essment -				
Amended A	ssessment -	This material is need to be include			
	1000				
Managemen	t Planner				Rex Gaddis
Indiana Depa	artment of En	vironmental Mana	gement Acci	reditation	192218025
Signature Signature	Tudous_		D	9/5/95 ate	

AMENDMENT TO THE AHERA MANAGEMENT PLAN

Building - Thomas Jefferson Elementary School									
Subject-	New materia	ıl							
Reference -	HA A Cove I	Base							
Original Ass	essment -	No assessment in original inspection.							
Amended A	ssessment -	The cove base in the building was not original inspection. The material is considered by EPA. The material will be assumed to and treated as such until a future renoval sampled.	lered to be suspect o contain asbestos						
Management	t Planner		Rex Gaddis						
_		vironmental Management Accreditation	192218025						
Signature	<u> Saddlo</u>	9/5/45 Date							

AMENDMENT TO THE AHERA MANAGEMENT PLAN

Building -	Thomas Jef	ferson Elementary School	
Subject-	New materia	al	
Reference -	HA B Cove	Base Mastic	
Original Ass	sessment -	No assessment in original inspection.	
Amended A	ssessment	The cove base mastic in the building was rethe original inspection. The material is consumed suspect by EPA. The material will be assumed as such until a future it will be sampled.	onsidered to be umed to contain
Managemen	t Planner		Rex Gaddis
Indiana Depa	artment of Er	nvironmental Management Accreditation	192218025
Dux Signature	<u>Saddus</u>	9/5/45 Date	

Building Name - (Now Form

(Now Former) Administration Building, W.E. Wilson Elementary School, Thomas Jefferson Elementary School, Jeffersonville High School, River Valley Middle School, Corden Porter Center, Corden Porter Building #3, Corden Porter Building #4, and the Service

Center/Bus Garage

Subject -

Typographical Error

Amendment -

A typographical error was made on the paperwork for the Periodic Surveillance that was conducted in December 2001. The pages in the Management Plan Supplement which are dated 12/10/2002

should read 12/10/2001.

Management Planner: George Wm. Ogle

Accreditation Number: 191523030

Signature

Building Name -

Thomas Jefferson Elementary School

Subject -

Combination and Removal of Homogeneous Area Designation

from Management Plan

Amendment -

Homogeneous area designation "04" covering debris in the tunnel has been combined with homogeneous area designation "01" covering mag block pipe insulation in the tunnels and boiler room. Homogeneous area designation "04" will be removed from the

Management Plan.

Management Planner: George Wm. Ogle

Accreditation Number: 191523030

Signature

LEA Name -

Greater Clark County Schools

Subject -

LEA Designated Person Change

Amendment -

Effective March 2005, the Designated Person for the Greater Clark

County Schools is:

Alliance Environmental Group, Inc. 5340 Commerce Circle, Suite E Indianapolis, Indiana 46237

(317) 865-3400

Personnel contributing to this Management Plan are licensed in

according with 40 CFR 763.93(e)(12).

Management Planner: Sandra S. Shadley

Accreditation Number: 19A002720

Signature

Building Name -

Thomas Jefferson Elementary School

Subject -

Addition of Homogeneous Area E

Amendment -

Gray sink insulation in classrooms, art room and teachers lounge was noted during the June 2011 surveillance and was not included in the original inspection. It is suspected to contain asbestos; therefore, it is being added to the management plan until properly sampled.

Management Planner: Sandra Shadley

Accreditation Number: 19A002720

Building Name -

Thomas Jefferson Elementary School

Subject -

Addition of Homogeneous Area D

Amendment -

Wooden fire doors were noted during the June 2011 surveillance and they were not included in the original inspection. They are suspected to contain asbestos; therefore, they are being added to the management plan until

properly sampled.

Management Planner: Sandra Shadley

Accreditation Number: 19A002720

Building Name -

Thomas Jefferson Elementary School

Subject -

Addition of Homogeneous Area C

Amendment -

Cloth expansion joints on the AHU on stage ends were noted during the June 2011 surveillance and they were not included in the original inspection. This material is suspect to contain asbestos; therefore, it is being added to the management plan until properly sampled.

Management Planner: Sandra Shadley

Accreditation Number: 19A002720

Building Name - Thomas Jefferson Elementary School

Subject - Addition of Homogeneous Area F

Amendment - This material was noted by the licensed inspector during the April 2015

6 month inspection. The pipe insulation was not identified in previous inspection records. This is a suspect asbestos-containing building material and is being added to the management plan until proper sampling has

been completed.

Sandia S. Shadley

Management Planner: Sandra Shadley

Accreditation Number: 19A002720

Signature

May 7, 2015

REMAINING MATERIALS

Remaining Materials Report 4/23/2020

HA ID	HA Description	Quant	ity	Asbestos	HA Location	Plannned Response Action					
Thomas J	Thomas Jefferson Elementary School										
01	Pipe Insulation	10	LF	Known	Boiler room	0&M					
02	Pipe Insulation	230	LF	Known	Tunnels	Patch and Repair					
03	Fittings	48	Unit(s)	Known	Boiler room and tunnel	O&M					
05-A	VAT-underneath carpet	Unquantified	SF	Known	Throughout the building (classrooms, hallways & office)	O&M					
05-B	12" x 12" newer off-white floor tile	Unquantified	SF	Known	Throughout the building (first aid office, cafeteria, workroom, water fountain area, office hallway, entrance, and art room)	O&M					
05-C	12" x 12" original floor tile	Unquantified	SF	Known	Throughout the building (gym and custodial closets).	O&M					
05-D	12" x 12" original light blue floor tile	Unquantified	SF	Known	Throughout the building (gym)	O&M					
07	Mastic	33750	SF	Assumed	Throughout the building	O&M					
11	Fire door-Metal clad	6	Unit(s)	Assumed	Boiler room (2) Gym Exterior Doors (4)	O&M					
15	Boiler gaskets	2	Unit(s)	Assumed	Boiler room	O&M					

Remaining Materials Report 4/23/2020

HA ID	HA Description	Quantit	.y	Asbestos	HA Location	Plannned Response Action
Α	Cove Base	Approx. 3800	LF	Assumed	Throughout the building	O&M
В	Cove base mastic	Approx. 1200	SF	Assumed	Throughout the building	O&M
С	AHU Cloth Expansion Joints	2	Unit(s)	Assumed	Stage ends	O&M
D	Fire Doors-Original to building (wooden)	Unquantified	Unit(s)	Assumed	Gym & throughout the building	O&M
E	Gray Sink Insulation	Unquantified	LF	Assumed	Classrooms, Art Room & Teachers Lounge	O&M
F	Pipe Insulation	N/A	LF	Assumed	Storage Rooms Near Crawlspace Tunnel Access	Patch and Repair

Remaining Materials Report 1/14/2020

HA ID	HA Description	Quant	ity	Asbestos	HA Location	Plannned Response Action
Thomas Je	efferson Elementary School					
01	Pipe Insulation	10	LF	Known	Boiler room	O&M
02	Pipe Insulation	230	LF	Known	Tunnels	Patch and Repair
03	Fittings	48	Unit(s)	Known	Boiler room and tunnel	O&M
05-A	VAT-underneath carpet	Unquantified	SF	Known	Throughout the building (classrooms, hallways & office)	O&M
05-B	12" x 12" newer off-white floor tile	Unquantified	SF	Known	Throughout the building (first aid office, cafeteria, workroom, water fountain area, office hallway, entrance, and art room)	O&M
05-C	12" x 12" original floor tile	Unquantified	SF	Known	Throughout the building (gym and custodial closets).	O&M
05-D	12" x 12" original light blue floor tile	Unquantified	SF	Known	Throughout the building (gym)	O&M
07	Mastic	33750	SF	Assumed	Throughout the building	O&M
11	Fire door-Metal clad	6	Unit(s)	Assumed	Boiler room (2) Gym Exterior Doors (4)	O&M
15	Boiler gaskets	0	Unit(s)	Assumed	Boiler room	Removed

Remaining Materials Report

1/14/2020

HA ID	HA Description	Quant	ity	Asbestos	HA Location	Plannned Response Action
Α	Cove Base	Approx. 3800	LF	Assumed	Throughout the building	O&M
В	Cove base mastic	Approx. 1200	SF	Assumed	Throughout the building	O&M
С	AHU Cloth Expansion Joints	2	Unit(s)	Assumed	Stage ends	O&M
D	Fire Doors-Original to building (wooden)	Unquantified	Unit(s)	Assumed	Gym & throughout the building	O&M
Е	Gray Sink Insulation	Unquantified	LF	Assumed	Classrooms, Art Room & Teachers Lounge	O&M
F	Pipe Insulation	N/A	LF	Assumed	Storage Rooms Near Crawlspace Tunnel Access	Patch and Repair

Greater Clark County School Corporation Remaining Materials Report

5/16/2019

HA ID	HA Description	Quant	ity	Asbestos	HA Location	Plannned Response Action
Thomas J	efferson Elementary School					
01	Pipe Insulation	10	LF	Known	Boiler room	O&M
02	Pipe Insulation	230	LF	Known	Tunnels	Patch and Repair
03	Fittings	48	Unit(s)	Known	Boiler room and tunnel	O&M
05-A	VAT-underneath carpet	Unquantified	SF	Known	Throughout the building (classrooms, hallways & office)	O&M
05-В	12" x 12" newer off-white floor tile	Unquantified	SF	Known	Throughout the building (first aid office, cafeteria, workroom, water fountain area, office hallway, entrance, and art room)	O&M
05-C	12" x 12" original floor tile	Unquantified	SF	Known	Throughout the building (gym and custodial closets).	O&M
05-D	12" x 12" original light blue floor tile	Unquantified	SF	Known	Throughout the building (gym)	O&M
07	Mastic	33750	SF	Assumed	Throughout the building	O&M
11	Fire door-Metal clad	6	Unit(s)	Assumed	Boiler room (2) Gym Exterior Doors (4)	O&M
15	Boiler gaskets	2	Unit(s)	Assumed	Boiler room	O&M

Greater Clark County School Corporation Remaining Materials Report 5/16/2019

HA ID	HA Description	Quanti	ity	Asbestos	HA Location	Plannned Response Action
А	Cove Base	Approx. 3800	LF	Assumed	Throughout the building	O&M
В	Cove base mastic	Approx. 1200	SF	Assumed	Throughout the building	O&M
С	AHU Cloth Expansion Joints	2	Unit(s)	Assumed	Stage ends	O&M
D	Fire Doors-Original to building (wooden)	Unquantified	Unit(s)	Assumed	Gym & throughout the building	O&M
E	Gray Sink Insulation	Unquantified	LF	Assumed	Classrooms, Art Room & Teachers Lounge	O&M
F	Pipe Insulation	N/A	LF	Assumed	Storage Rooms Near Crawlspace Tunnel Access	Patch and Repair

Remaining Materials Report 11/13/2018

HA ID	HA Description	Quant	ity	Asbestos	HA Location	Plannned Response Action
Thomas Jo	efferson Elementary School					
01	Pipe Insulation	10	LF	Known	Boiler room	O&M
02	Pipe Insulation	230	LF	Known	Tunnels	Patch and Repair
03	Fittings	48	Unit(s)	Known	Boiler room and tunnel	O&M
05-A	VAT-underneath carpet	Unquantified	SF	Known	Throughout the building (classrooms, hallways & office)	O&M
05-В	12" x 12" newer off-white floor tile	Unquantified	SF	Known	Throughout the building (first aid office, cafeteria, workroom, water fountain area, office hallway, entrance, and art room)	O&M
05-C	12" x 12" original floor tile	Unquantified	SF	Known	Throughout the building (gym and custodial closets).	O&M
05-D	12" x 12" original light blue floor tile	Unquantified	SF	Known	Throughout the building (gym)	O&M
07	Mastic	33750	SF	Assumed	Throughout the building	O&M
11	Fire door-Metal clad	6	Unit(s)	Assumed	Boiler room (2) Gym Exterior Doors (4)	O&M
15	Boiler gaskets	0	Unit(s)	Assumed	Boiler room	Removed

Greater Clark County School Corporation Remaining Materials Report 11/13/2018

HA ID	HA Description	Quanti	Quantity		HA Location	Plannned Response Action
А	Cove Base	Approx. 3800	LF	Assumed	Throughout the building	O&M
В	Cove base mastic	Approx. 1200	SF	Assumed	Throughout the building	O&M
С	AHU Cloth Expansion Joints	2	Unit(s)	Assumed	Stage ends	O&M
D	Fire Doors-Original to building (wooden)	Unquantified	Unit(s)	Assumed	Gym & throughout the building	O&M
E	Gray Sink Insulation	Unquantified	LF	Assumed	Classrooms, Art Room & Teachers Lounge	O&M
F	Pipe Insulation	N/A	LF	Assumed	Storage Rooms Near Crawlspace Tunnel Access	Patch and Repair

Remaining Materials Report 5/2/2018

HA ID	HA Description	Quant	ity	Asbestos	HA Location	Plannned Response Action
Thomas J	efferson Elementary School					
01	Pipe Insulation	10	LF	Known	Boiler room	O&M
02	Pipe Insulation	230	LF	Known	Tunnels	Patch and Repair
03	Fittings	48	Unit(s)	Known	Boiler room and tunnel	O&M
05-A	VAT-underneath carpet	Unquantified	SF	Known	Throughout the building (classrooms, hallways & office)	O&M
05-В	12" x 12" newer off-white floor tile	Unquantified	SF	Known	Throughout the building (first aid office, cafeteria, workroom, water fountain area, office hallway, entrance, and art room)	O&M
05-C	12" x 12" original floor tile	Unquantified	SF	Known	Throughout the building (gym and custodial closets).	O&M
05-D	12" x 12" original light blue floor tile	Unquantified	SF	Known	Throughout the building (gym)	O&M
07	Mastic	33750	SF	Assumed	Throughout the building	O&M
11	Fire door-Metal clad	6	Unit(s)	Assumed	Boiler room (2) Gym Exterior Doors (4)	O&M
15	Boiler gaskets	2	Unit(s)	Assumed	Boiler room	O&M

Remaining Materials Report 5/2/2018

HA ID	HA Description	Quantity		Asbestos	HA Location	Plannned Response Action
А	Cove Base	Approx. 3800	LF	Assumed	Throughout the building	O&M
В	Cove base mastic	Approx. 1200	SF	Assumed	Throughout the building	O&M
С	AHU Cloth Expansion Joints	2	Unit(s)	Assumed	Stage ends	O&M
D	Fire Doors-Original to building (wooden)	Unquantified	Unit(s)	Assumed	Gym & throughout the building	O&M
Е	Gray Sink Insulation	Unquantified	LF	Assumed	Classrooms, Art Room & Teachers Lounge	O&M
F	Pipe Insulation	N/A	LF	Assumed	Storage Rooms Near Crawlspace Tunnel Access	Patch and Repair

Remaining Materials Report 10/18/2017

HA ID	HA Description	Quant	ity	Asbestos	HA Location	Plannned Response Action
Thomas J	efferson Elementary School					
01	Pipe Insulation	10	LF	Known	Boiler room	O&M
02	Pipe Insulation	230	LF	Known	Tunnels	Patch and Repair
03	Fittings	48	Unit(s)	Known	Boiler room and tunnel	O&M
05-A	VAT-underneath carpet	Unquantified	SF	Known	Throughout the building (classrooms, hallways & office)	O&M
05-B	12" x 12" newer off-white floor tile	Unquantified	SF	Known	Throughout the building (first aid office, cafeteria, workroom, water fountain area, office hallway, entrance, and art room)	O&M
05-C	12" x 12" original floor tile	Unquantified	SF	Known	Throughout the building (gym and custodial closets).	O&M
05-D	12" x 12" original light blue floor tile	Unquantified	SF	Known	Throughout the building (gym)	O&M
07	Mastic	33750	SF	Assumed	Throughout the building	O&M
11	Fire door-Metal clad	6	Unit(s)	Assumed	Boiler room (2) Gym Exterior Doors (4)	O&M
15	Boiler gaskets	2	Unit(s)	Assumed	Boiler room	O&M

Remaining Materials Report 10/18/2017

HA ID	HA Description	Quantity		Asbestos	HA Location	Plannned Response Action
Α	Cove Base	Approx. 3800	LF	Assumed	Throughout the building	O&M
В	Cove base mastic	Approx. 1200	SF	Assumed	Throughout the building	O&M
С	AHU Cloth Expansion Joints	2	Unit(s)	Assumed	Stage ends	O&M
D	Fire Doors-Original to building (wooden)	Unquantified	Unit(s)	Assumed	Gym & throughout the building	O&M
E	Gray Sink Insulation	Unquantified	LF	Assumed	Classrooms, Art Room & Teachers Lounge	O&M
F	Pipe Insulation	N/A	LF	Assumed	Storage Rooms Near Crawlspace Tunnel Access	Patch and Repair

Remaining Materials Report

4/13/2017

HA ID	HA Description	Quant	ity	Asbestos	HA Location	Plannned Response Action
Thomas Je	efferson Elementary School					
01	Pipe Insulation	10	LF	Known	Boiler room	O&M
02	Pipe Insulation	230	LF	Known	Tunnels	Patch and Repair
03	Fittings	48	Unit(s)	Known	Boiler room and tunnel	O&M
05-A	VAT-underneath carpet	Unquantified	SF	Known	Throughout the building (classrooms, hallways & office)	O&M
05-B	12" x 12" newer off-white floor tile	Unquantified	SF	Known	Throughout the building (first aid office, cafeteria, workroom, water fountain area, office hallway, entrance, and art room)	O&M
05-C	12" x 12" original floor tile	Unquantified	SF	Known	Throughout the building (gym and custodial closets).	O&M
05-D	12" x 12" original light blue floor tile	Unquantified	SF	Known	Throughout the building (gym)	O&M
07	Mastic	33750	SF	Assumed	Throughout the building	O&M
11	Fire door-Metal clad	6	Unit(s)	Assumed	Boiler room (2) Gym Exterior Doors (4)	O&M
15	Boiler gaskets	2	Unit(s)	Assumed	Boiler room	O&M

Greater Clark County School Corporation Remaining Materials Report

4/13/2017

HA ID	HA Description	Quantity		Asbestos	HA Location	Plannned Response Action
Α	Cove Base	Approx. 3800	LF	Assumed	Throughout the building	O&M
В	Cove base mastic	Approx. 1200	SF	Assumed	Throughout the building	O&M
С	AHU Cloth Expansion Joints	2	Unit(s)	Assumed	Stage ends	O&M
D	Fire Doors-Original to building (wooden)	Unquantified	Unit(s)	Assumed	Gym & throughout the building	O&M
E	Gray Sink Insulation	Unquantified	LF	Assumed	Classrooms, Art Room & Teachers Lounge	O&M
F	Pipe Insulation	N/A	LF	Assumed	Storage Rooms Near Crawlspace Tunnel Access	Patch and Repair

Remaining Materials Report

11/3/2016

HA ID	HA Description	Quant	ity	Asbestos	HA Location	Plannned Response Action
Thomas J	efferson Elementary School					
01	Pipe Insulation	10	LF	Known	Boiler room	O&M
02	Pipe Insulation	230	LF	Known	Tunnels	Patch and Repair
03	Fittings	48	Unit(s)	Known	Boiler room and tunnel	O&M
05-A	VAT-underneath carpet	Unquantified	SF	Known	Throughout the building (classrooms, hallways & office)	O&M
05-В	12" x 12" newer off-white floor tile	Unquantified	SF	Known	Throughout the building (first aid office, cafeteria, workroom, water fountain area, office hallway, entrance, and art room)	O&M
05-C	12" x 12" original floor tile	Unquantified	SF	Known	Throughout the building (gym and custodial closets).	O&M
05-D	12" x 12" original light blue floor tile	Unquantified	SF	Known	Throughout the building (gym)	O&M
07	Mastic	33750	SF	Assumed	Throughout the building	O&M
11	Fire door-Metal clad	6	Unit(s)	Assumed	Boiler room (2) Gym Exterior Doors (4)	O&M
15	Boiler gaskets	2	Unit(s)	Assumed	Boiler room	O&M

Greater Clark County School Corporation Remaining Materials Report 11/3/2016

HA ID	HA Description	Quantity		Asbestos	HA Location	Plannned Response Action
Α	Cove Base	Approx. 3800	LF	Assumed	Throughout the building	O&M
В	Cove base mastic	Approx. 1200	SF	Assumed	Throughout the building	O&M
С	AHU Cloth Expansion Joints	2	Unit(s)	Assumed	Stage ends	O&M
D	Fire Doors-Original to building (wooden)	Unquantified	Unit(s)	Assumed	Gym & throughout the building	O&M
E	Gray Sink Insulation	Unquantified	LF	Assumed	Classrooms, Art Room & Teachers Lounge	O&M
F	Pipe Insulation	N/A	LF	Assumed	Storage Rooms Near Crawlspace Tunnel Access	Patch and Repair

Remaining Materials Report 4/28/2016

HA ID	HA Description	Quant	ity	Asbestos	HA Location	Plannned Response Action
Thomas J	lefferson Elementary School					
01	Pipe Insulation	10	LF	Known	Boiler room	0&M
02	Pipe Insulation	230	LF	Known	Tunnels	Patch and Repair
03	Fittings	48	Unit(s)	Known	Boiler room and tunnel	O&M
05-A	VAT-underneath carpet	Unquantified	SF	Known	Throughout the building (classrooms, hallways & office)	O&M
05-B	12" x 12" newer off-white floor tile	Unquantified	SF	Known	Throughout the building (first aid office, cafeteria, workroom, water fountain area, office hallway, entrance, and art room)	O&M
05-C	12" x 12" original floor tile	Unquantified	SF	Known	Throughout the building (gym and custodial closets).	O&M
05-D	12" x 12" original light blue floor tile	Unquantified	SF	Known	Throughout the building (gym)	O&M
07	Mastic	33750	SF	Assumed	Throughout the building	O&M
11	Fire door-Metal clad	6	Unit(s)	Assumed	Boiler room (2) Gym Exterior Doors (4)	O&M
15	Boiler gaskets	2	Unit(s)	Assumed	Boiler room	O&M

Remaining Materials Report 4/28/2016

HA ID	HA Description	Quantit	ty	Asbestos	HA Location	Plannned Response Action
Α	Cove Base	Approx. 3800	LF	Assumed	Throughout the building	O&M
В	Cove base mastic	Approx. 1200	SF	Assumed	Throughout the building	O&M
С	AHU Cloth Expansion Joints	2	Unit(s)	Assumed	Stage ends	O&M
D	Fire Doors-Original to building (wooden)	Unquantified	Unit(s)	Assumed	Gym & throughout the building	O&M
Е	Gray Sink Insulation	Unquantified	LF	Assumed	Classrooms, Art Room & Teachers Lounge	O&M
F	Pipe Insulation	N/A	LF	Assumed	Storage Rooms Near Crawlspace Tunnel Access	Patch and Repair

Greater Clark County School Corporation

Remaining Materials Report 10/20/2015

HA ID	HA Description	Quant	ity	Asbestos	HA Location	Plannned Response Action
Thomas J	lefferson Elementary School					
01	Pipe Insulation	10	LF	Known	Boiler room	0&M
02	Pipe Insulation	230	LF	Known	Tunnels	Patch and Repair
03	Fittings	48	Unit(s)	Known	Boiler room and tunnel	O&M
05-A	VAT-underneath carpet	Unquantified	SF	Known	Throughout the building (classrooms, hallways & office)	O&M
05-B	12" x 12" newer off-white floor tile	Unquantified	SF	Known	Throughout the building (first aid office, cafeteria, workroom, water fountain area, office hallway, entrance, and art room)	O&M
05-C	12" x 12" original floor tile	Unquantified	SF	Known	Throughout the building (gym and custodial closets).	O&M
05-D	12" x 12" original light blue floor tile	Unquantified	SF	Known	Throughout the building (gym)	O&M
07	Mastic	33750	SF	Assumed	Throughout the building	O&M
11	Fire door-Metal clad	6	Unit(s)	Assumed	Boiler room (2) Gym Exterior Doors (4)	O&M
15	Boiler gaskets	2	Unit(s)	Assumed	Boiler room	O&M

Greater Clark County School Corporation

Remaining Materials Report 10/20/2015

HA ID	HA Description	Quant	ity	Asbestos	HA Location	Plannned Response Action
Α	Cove Base	Approx. 3800	LF	Assumed	Throughout the building	O&M
В	Cove base mastic	Approx. 1200	SF	Assumed	Throughout the building	O&M
С	AHU Cloth Expansion Joints	2	Unit(s)	Assumed	Stage ends	O&M
D	Fire Doors-Original to building (wooden)	Unquantified	Unit(s)	Assumed	Gym & throughout the building	O&M
E	Gray Sink Insulation	Unquantified	LF	Assumed	Classrooms, Art Room & Teachers Lounge	O&M
F	Pipe Insulation	N/A	LF	Assumed	Storage Rooms Near Crawlspace Tunnel Access	Patch and Repair

Greater Clark County Schools Remaining Materials Report April 22, 2015

HA#	Material	Quantity	ACBM Y/A	Location	Planned Activities
Thomas	Jefferson Elementary				
01	Pipe insulation	10 LF	Υ	Boiler room	Remove
02	Pipe insulation	230 LF	Υ	Tunnels	Remove
03	Fittings	48 Eac	Υ	Boiler room and tunnel	Remove
07	Mastic	33,750 SF	Α	Throughout the building	O & M
11	Fire door-Metal clad	6 Eac	Α	Boiler room (2) Gym Exterior Doors (4)	O & M
15	Boiler gaskets	2 Eac	Α	Boiler room	O & M
05-A	VAT-underneath carpet	Unquantified SF	Υ	Throughout the building (classrooms, hallways & office)	O & M
05-B	12" x 12" newer off-white floor tile	Unquantified SF	Υ	Throughout the building (first aid office, cafeteria, workroom, water fountain area, office hallway, entrance, and art room)	O & M
05-C	12" x 12" original floor tile	Unquantified SF	Υ	Throughout the building (gym and custodial closets).	O & M
05-D	12" x 12" original light blue floor tile	Unquantified SF	Υ	Throughout the building (gym)	O & M
Α	Cove base	Approx. 3,800 LF	Α	Throughout the building	O & M
В	Cove base mastic	Approx. 1,200 SF	Α	Throughout the building	O & M
С	AHU Cloth Expansion Joints	2 Eac	Α	Stage Ends	O & M
D	Fire Doors-Original to building (wooden)	Unquantified Eac	Α	Gym & throughout the building	O & M

Greater Clark County Schools Remaining Materials Report April 22, 2015

HA#	Material	Quantity	ACBM Y/A	Location	Planned Activities
E	Gray Sink Insulation	Unquantified LF	Α	Classrooms, Art Room & Teachers Lounge	O & M
F	Pipe Insulation	N/A LF	Α	Storage Rooms Near Crawlspace Tunnel Access	O & M

Greater Clark County Schools Remaining Materials Report October 22, 2014

HA#	Material	Quantity	ACBM Y/A	Location	Planned Activities
Thomas	s Jofforson Flomontary				
IIIOIIIa	s Jefferson Elementary				
01	Pipe insulation	10 LF	Υ	Boiler room	Remove
02	Pipe insulation	230 LF	Υ	Tunnels	Remove
03	Fittings	48 Eac	Υ	Boiler room and tunnel	Remove
07	Mastic	33,750 SF	Α	Throughout the building	O & M
11	Fire door-Metal clad	6 Eac	Α	Boiler room (2) Gym Exterior Doors (4)	O & M
15	Boiler gaskets	2 Eac	Α	Boiler room	O & M
05-A	VAT-underneath carpet	Unquantified SF	Υ	Throughout the building (classrooms, hallways & office)	O & M
05-B	12" x 12" newer off-white floor tile	Unquantified SF	Y	Throughout the building (first aid office, cafeteria, workroom, water fountain area, office hallway, entrance, and art room)	O & M
05-C	12" x 12" original floor tile	Unquantified SF	Υ	Throughout the building (gym and custodial closets).	O & M
05-D	12" x 12" original light blue floor tile	Unquantified SF	Υ	Throughout the building (gym)	O & M
Α	Cove base	Approx. 3,800 LF	Α	Throughout the building	O & M
В	Cove base mastic	Approx. 1,200 SF	Α	Throughout the building	O & M
С	AHU Cloth Expansion Joints	2 Eac	Α	Stage Ends	O & M
D	Fire Doors-Original to building (wooden)	Unquantified Eac	Α	Gym & throughout the building	O & M

Greater Clark County Schools Remaining Materials Report October 22, 2014

HA#	Material	Quantity	ACBM Y/A	Location	Planned Activities
Е	Gray Sink Insulation	Unquantified LF	А	Classrooms, Art Room & Teachers Lounge	O & M

Greater Clark County Schools Remaining Materials Report April 21, 2014

HA#	Material	Quantity	ACBM Y/A	Location	Planned Activities
Thomas	Jefferson Elementary				
01	Pipe insulation	10 LF	Υ	Boiler room	Remove
02	Pipe insulation	230 LF	Υ	Tunnels	Remove
03	Fittings	48 Eac	Υ	Boiler room and tunnel	Remove
07	Mastic	33,750 SF	Α	Throughout the building	O & M
11	Fire door-Metal clad	6 Eac	Α	Boiler room (2) Gym Exterior Doors (4)	O & M
15	Boiler gaskets	2 Eac	Α	Boiler room	O & M
05-A	VAT-underneath carpet	Unquantified SF	Υ	Throughout the building (classrooms, hallways & office)	O & M
05-B	12" x 12" newer off-white floor tile	Unquantified SF	Υ	Throughout the building (first aid office, cafeteria, workroom, water fountain area, office hallway, entrance, and art room)	O & M
05-C	12" x 12" original floor tile	Unquantified SF	Υ	Throughout the building (gym and custodial closets).	O & M
05-D	12" x 12" original light blue floor tile	Unquantified SF	Υ	Throughout the building (gym)	O & M
Α	Cove base	Approx. 3,800 LF	Α	Throughout the building	O & M
В	Cove base mastic	Approx. 1,200 SF	Α	Throughout the building	O & M
С	AHU Cloth Expansion Joints	2 Eac	Α	Stage Ends	O & M
D	Fire Doors-Original to building (wooden)	Unquantified Eac	Α	Gym & throughout the building	O & M

Greater Clark County Schools Remaining Materials Report April 21, 2014

HA#	Material	Quantity	ACBM Y/A	Location	Planned Activities
Е	Gray Sink Insulation	Unquantified LF	А	Classrooms, Art Room & Teachers Lounge	O & M

Greater Clark County Schools Remaining Materials Report April 18, 2014

HA#	Material	Quantity	ACBM Y/A	Location	Diamond Anti-str
	-				Planned Activities
<u>homa</u>	s Jefferson Elementary				
1	Pipe insulation	10 LF	Y	Boiler room	Remove
	Pipe insulation	230 LF	Υ	Tunnels	Remove
	Fittings	48 Eac	Υ	Boiler room and tunnel	Remove
	Mastic	33,750 SF	Α	Throughout the building	O & M
	Fire door-Metal clad	6 Eac	Α	Boiler room (2) Gym Exterior Doors (4)	O & M
	Boiler gaskets	2 Eac	Α	Boiler room	O & M
-A	VAT-underneath carpet	Unquantified SF	Υ	Throughout the building (classrooms, hallways & office)	•
·B	12" x 12" newer off-white floor tile	Unquantified SF	Y	Throughout the building (first aid office, cafeteria, workroom, water fountain area, office hallway, entrance, and art room)	O & M
-C	12" x 12" original floor tile	Unquantified SF	Y	Throughout the building (gym and custodial closets).	O & M
D	12" x 12" original light blue floor tile	Unquantified SF	Υ	Throughout the building (gym)	O & M
	Cove base	Approx. 3,800 LF	Α	Throughout the building	O & M
	Cove base mastic	Approx. 1,200 SF	Α	Throughout the building	O&M
	AHU Cloth Expansion Joints	2 Eac	Α	<u> </u>	O&M
	Fire Doors-Original to building (wooden)	Unquantified Eac	Α	•	O&M

-)

Greater Clark County Schools Remaining Materials Report April 18, 2014

HA#	Material	Quantity	ACBM Y/A	Location	Planned Activities
E	Gray Sink Insulation	Unquantified LF	Α	Classrooms, Art Room & Teachers Lounge	O & M

Greater Clark County Schools Remaining Materials Report April 24, 2013

HA#	Material	Quantity	ACBM Y/A	Location	Planned Activities
Thoma	s Jefferson Elementary				
01	Pipe insulation	10 LF	Υ	Boiler room	Remove
02	Pipe insulation	230 LF	Υ	Tunnels	Remove
03	Fittings	48 Eac	Υ	Boiler room and tunnel	Remove
07	Mastic	33,750 SF	Α	Throughout the building	O & M
11	Fire door-Metal clad	6 Eac	Α	Boiler room (2) Gym Exterior Doors (4)	O & M
15	Boiler gaskets	2 Eac	Α	Boiler room	O & M
05-A	VAT-underneath carpet	Unquantified SF	Υ	Throughout the building (classrooms hallways & office)	, O & M
05-B	12" x 12" newer off-white floor tile	Unquantified SF	Υ	Throughout the building (first aid office, cafeteria, workroom, water fountain area, office hallway, entrance, and art room)	O & M
05-C	12" x 12" original floor tile	Unquantified SF	Υ	Throughout the building (gym and custodial closets).	O & M
05-D	12" x 12" original light blue floor tile	Unquantified SF	Υ	Throughout the building (gym)	O & M
Α	Cove base	Approx. 3,800 LF	Α	Throughout the building	O & M
В	Cove base mastic	Approx. 1,200 SF	Α	Throughout the building	O & M
С	AHU Cloth Expansion Joints	2 Eac	Α	Stage Ends	O & M
D	Fire Doors-Original to building (wooden)	Unquantified Eac	Α	Gym & throughout the building	O & M

Greater Clark County Schools Remaining Materials Report April 24, 2013

HA#	Material	Quantity	ACBM Y/A	Location	Planned Activities
E	Gray Sink Insulation	Unquantified LF	Α	Classrooms, Art Room & Teachers Lounge	O & M

Greater Clark County Schools Remaining Materials Report October 24, 2012

HA#	Material	Quantity	ACBM Y/A	Location	Planned Activities
<u>Thoma</u>	s Jefferson Elementary				
01	Pipe insulation	10 LF	Y	Boiler room	Remove
02	Pipe insulation	230 LF	Υ	Tunnels	Remove
03	Fittings	48 Eac	Υ	Boiler room and tunnel	Remove
07	Mastic	33,750 SF	Α	Throughout the building	O & M
11	Fire door-Metal clad	6 Eac	Α	Boiler room (2) Gym Exterior Doors (4)	O & M
15	Boiler gaskets	2 Eac	Α	Boiler room	O & M
05-A	VAT-underneath carpet	Unquantified SF	Υ	Throughout the building (classrooms hallways & office)	, O & M
05-B	12" x 12" newer off-white floor tile	Unquantified SF	Y	Throughout the building (first aid office, cafeteria, workroom, water fountain area, office hallway, entrance, and art room)	O & M
05-C	12" x 12" original floor tile	Unquantified SF	Υ	Throughout the building (gym and custodial closets).	O & M
05-D	12" x 12" original light blue floor tile	Unquantified SF	Υ	Throughout the building (gym)	O & M
Α	Cove base	Approx. 3,800 LF	Α	Throughout the building	O & M
В	Cove base mastic	Approx. 1,200 SF	Α	Throughout the building	O & M
С	AHU Cloth Expansion Joints	2 Eac	Α	Stage Ends	O & M
D	Fire Doors-Original to building (wooden)	Unquantified Eac	Α	Gym & throughout the building	O & M

Greater Clark County Schools Remaining Materials Report October 24, 2012

HA#	Material		Quantity	ACBM Y/A	Location	Planned Activities
Е	Gray Sink Insulation	0	Unquantified LF	Α	Classrooms, Art Room & Teachers Lounge	O & M

Greater Clark County Schools Remaining Materials Report June 25, 2012

HA#	Material	Quantity	ACBM Y/A	Location	Planned Activities
Thoma	s Jefferson Elementary				
01	Pipe insulation	10 LF	Υ	Boiler room	Remove
)2	Pipe insulation	230 LF	Υ	Tunnels	Remove
)3	Fittings	48 Eac	Υ	Boiler room and tunnel	Remove
7	Mastic	33,750 SF	Α	Throughout the building	O & M
1	Fire door-Metal clad	6 Eac	Α	Boiler room (2) Gym Exterior Doors (4)	O & M
5	Boiler gaskets	2 Eac	Α	Boiler room	O & M
5-A	VAT-underneath carpet	Unquantified SF	Υ	Throughout the building (classrooms, hallways & office)	O & M
5-B	12" x 12" newer off-white floor tile	Unquantified SF	Y	Throughout the building (first aid office, cafeteria, workroom, water fountain area, office hallway, entrance, and art room)	O & M
5-C	12" x 12" original floor tile	Unquantified SF	Υ	Throughout the building (gym and custodial closets).	O & M
5-D	12" x 12" original light blue floor tile	Unquantified SF	Υ	Throughout the building (gym)	O & M
	Cove base	Approx. 3,800 LF	Α	Throughout the building	O & M
3	Cove base mastic	Approx. 1,200 SF	Α	Throughout the building	O & M
;	AHU Cloth Expansion Joints	2 Eac	Α	Stage Ends	O & M
)	Fire Doors-Original to building (wooden)	Unquantified Eac	Α	Gym & throughout the building	O & M

Greater Clark County Schools Remaining Materials Report June 25, 2012

HA#	Material	Quantity	ACBM Y/A	Location	Planned Activities
E	Gray Sink Insulation	Unquantified LF	Α	Classrooms, Art Room & Teachers Lounge	O & M

Greater Clark County Schools Remaining Materials Report June 27, 2011

HA#	Material	Quantity	ACBM Y/A	Location	Planned Activities
Thoma	s Jefferson Elementary				
01	Pipe insulation	10 LF	Υ	Boiler room	Remove
02	Pipe insulation	230 LF	Υ	Tunnels	Remove
03	Fittings	48 Eac	Υ	Boiler room and tunnel	Remove
)5	VAT	33,750 SF	Υ	Throughout the building (classrooms, hallways & office)	, O & M
)7	Mastic	33,750 SF	Α	Throughout the building	O & M
1	Fire door-Metal clad	6 Eac	Α	Boiler room (2) Gym Exterior Doors (4)	O & M
5	Boiler gaskets	2 Eac	Α	Boiler room	O & M
\	Cove base	Approx. 3,800 LF	Α	Throughout the building	O & M
3	Cove base mastic	Approx. 1,200 SF	Α	Throughout the building	O & M
	AHU Cloth Expansion Joints	2 Eac	Α	Stage Ends	O & M
)	Fire Doors-Original to building (wooden)	Unquantified Eac	Α	Gym & throughout the building	O & M
Ε	Gray Sink Insulation	Unquantified LF	Α	Classrooms, Art Room & Teachers Lounge	O & M

Greater Clark County Schools Remaining Materials Report December 6, 2010

HA#	Material	Quantity	ACBM Y/A	Location	Planned Activities
<u>Thoma</u>	s Jefferson Elementary				
01	Pipe insulation	10 LF	Υ	Boiler room	O & M
)2	Pipe insulation	230 LF	Υ	Tunnels	O & M
)3	Fittings	48 Eac	Υ	Boiler room and tunnel	O & M
5	VAT	33,750 SF	Υ	Throughout the building (classrooms, hallways & office)	O & M
7	Mastic	33,750 SF	Α	Throughout the building	O & M
1	Fire door	30 SF	Α	Boiler room	O & M
5	Boiler gaskets	2 Eac	Α	Boiler room	O & M
١.	Cove base	Approx. 3,800 LF	Α	Throughout the building	O & M
3	Cove base mastic	Approx. 1,200 SF	Α	Throughout the building	O & M

Greater Clark County Schools Remaining Materials Report June 30, 2010

HA#	Material	Quantity	ACBM Y/A	Location	Planned Activities
<u> Fhoma</u>	s Jefferson Elementary				
01	Pipe insulation	10 LF	Υ	Boiler room	O & M
12	Pipe insulation	230 LF	Υ	Tunnels	O & M
3	Fittings	48 Eac	Υ	Boiler room and tunnel	O & M
5	VAT	33,750 SF	Υ	Throughout the building (classro hallways & office)	ooms, O & M
7	Mastic	33,750 SF	Α	Throughout the building	O & M
Ι	Fire door	30 SF	Α	Boiler room	O & M
5	Boiler gaskets	2 Eac	Α	Boiler room	O & M
	Cove base	Approx. 3,800 LF	Α	Throughout the building	O & M
	Cove base mastic	Approx. 1,200 SF	Α	Throughout the building	O & M

Greater Clark County Schools Remaining Materials Report December 7, 2009

	•					
HA#	Material	Quantity	ACBM Y/A	Location	Planned Activities	
Thoma	s Jefferson Elementary					
01	Pipe insulation	10 LF	Υ	Boiler room	O & M	
	Pipe insulation	230 LF	Υ	Tunnels	O & M	
02	•	48 Eac	Υ	Boiler room and tunnel	O & M	
03 05	Fittings VAT	33,750 SF	Υ	Throughout the building (classrooms hallways & office)	, O & M	
0.7	Mantia	33,750 SF	Α	Throughout the building	O & M	
07	Mastic	30 SF	Α	Boiler room	O & M	
11	Fire door	2 Eac		Boiler room	O & M	
15	Boiler gaskets		Α	Throughout the building	O & M	
Α	Cove base	Approx. 3,800 LF		•	O & M	
В	Cove base mastic	Approx. 1,200 SF	Α	Throughout the building	W 50 171	

Greater Clark County Schools Remaining Materials Report June 11, 2009

IA#	Material	Quantity	ACBM Y/A	Location	Planned Activities
<u>homa</u>	s Jefferson Elementary				
)1	Pipe insulation	10 LF	Υ	Boiler room	O & M
2	Pipe insulation	230 LF	Υ	Tunnels	O & M
3	Fittings	48 Eac	Υ	Boiler room and tunnel	O & M
5	VAT	33,750 SF	Υ	Throughout the building (classrooms, hallways & office)	, O & M
7	Mastic	33,750 SF	Α	Throughout the building	O & M
i	Fire door	30 SF	Α	Boiler room	O & M
5	Boiler gaskets	2 Eac	Α	Boiler room	O & M
	Cove base	Approx. 3,800 LF	Α	Throughout the building	O & M
	Cove base mastic	Approx. 1,200 SF	Α	Throughout the building	O & M

Greater Clark County Schools Remaining Materials Report December 10, 2008

HA#	Material	Quantity	ACBM Y/A	Location .	Planned Activities
Thoma	ıs Jefferson Elementary				
01	Pipe insulation	10 LF	Υ	Boiler room	O & M
02	Pipe insulation	230 LF	Υ	Tunnels	O & M
03	Fittings	48 Eac	Υ	Boiler room and tunnel	O & M
05	VAT	33,750 SF	Υ	Throughout the building (classrooms hallways & office)	, O & M
)7	Mastic	33,750 SF	Α	Throughout the building	O & M
11	Fire door	30 SF	Α	Boiler room	O & M
15	Boiler gaskets	2 Eac	Α	Boiler room	O & M
4	Cove base	Approx. 3,800 LF	Α	Throughout the building	O & M
В	Cove base mastic	Approx. 1,200 SF	Α	Throughout the building	O & M

Greater Clark County Schools Remaining Materials Report June 30, 2008

HA#	Material	Quantity	ACBM Y/A	Location	Planned Activities
<u>Thoma</u>	s Jefferson Elementary				
01	Pipe insulation	10 LF	Υ	Boiler room	O & M
)2	Pipe insulation	230 LF	Υ	Tunnels	O & M
3	Fittings	48 Eac	Υ	Boiler room and tunnel	O & M
)5	VAT	33,750 SF	Υ	Throughout the building (classrooms, hallways & office)	, O & M
7	Mastic	33,750 SF	Α	Throughout the building	O & M
1	Fire door	30 SF	Α	Boiler room	O & M
5	Boiler gaskets	2 Eac	Α	Boiler room	O & M
١	Cove base	Approx. 3,800 LF	Α	Throughout the building	O & M
3	Cove base mastic	Approx. 1,200 SF	Α	Throughout the building	O & M

Greater Clark County Schools Remaining Materials Report December 14, 2007

HA#	Material	Quantity	ACBM Y/A	Location	Planned Activities
<u> Thoma</u>	s Jefferson Elementary				
01	Pipe insulation	10 LF	Υ	Boiler room	O & M
02	Pipe insulation	230 LF	Υ	Tunnels	O & M
03	Fittings	48 Eac	Y	Boiler room and tunnel	O & M
)5	VAT	33,750 SF	Υ	Throughout the building (classrooms, hallways & office)	O & M
7	Mastic	33,750 SF	Α	Throughout the building	O & M
1	Fire door	30 SF	Α	Boiler room	O & M
5	Boiler gaskets	2 Eac	Α	Boiler room	O & M
	Cove base	Approx. 3,800 LF	Α	Throughout the building	O & M
}	Cove base mastic	Approx. 1,200 SF	Α	Throughout the building	O & M

Greater Clark County Schools Remaining Materials Report July 9, 2007

HA#	Material	Quantity	ACBM Y/A	Location	Planned Activities
<u> Thoma</u>	s Jefferson Elementary				
01	Pipe insulation	10 LF	Y	Boiler room	O & M
)2	Pipe insulation	230 LF	Υ	Tunnels	O & M
03	Fittings	48 Eac	Υ	Boiler room and tunnel	O & M
)5	VAT	33,750 SF	Υ	Throughout the building (classrooms, hallways & office)	O & M
07	Mastic	33,750 SF	Α	Throughout the building	O & M
11	Fire door	30 SF	Α	Boiler room	O & M
15	Boiler gaskets	2 Eac	Α	Boiler room	O & M
4	Cove base	Approx. 3,800 LF	Α	Throughout the building	O & M
В	Cove base mastic	Approx. 1,200 SF	Α	Throughout the building	O & M

Greater Clark County Schools Remaining Materials Report December 18, 2006

HA#	Material	Quantity	ACBM Y/A	Location	Planned Activities
<u> Thoma</u>	s Jefferson Elementary				
01	Pipe insulation	10 LF	Υ	Boiler room	O & M
02	Pipe insulation	230 LF	Υ	Tunnels	O & M
03	Fittings	48 Eac	Υ	Boiler room and tunnel	O & M
)5	VAT	33,750 SF	Υ	Throughout the building (classrooms, hallways & office)	O & M
)7	Mastic	33,750 SF	Α	Throughout the building	O & M
1	Fire door	30 SF	Α	Boiler room	O & M
15	Boiler gaskets	2 Eac	Α	Boiler room	O & M
4	Cove base	Approx. 3,800 LF	Α	Throughout the building	O & M
3	Cove base mastic	Approx. 1,200 SF	Α	Throughout the building	O & M

Greater Clark County Schools Remaining Materials Report June 28, 2006

HA#	Material	Quantity	ACBM Y/A	Location	Planned Activities
<u> Thoma</u>	s Jefferson Elementary				
01	Pipe insulation	10 LF	Υ	Boiler room	O & M
)2	Pipe insulation	230 LF	Υ	Tunnels	O & M
03	Fittings	48 Eac	Υ	Boiler room and tunnel	O & M
)5	VAT	33,750 SF	Υ	Throughout the building (classrooms, hallways & office)	O & M
7	Mastic	33,750 SF	Α	Throughout the building	O & M
1	Fire door	30 SF	Α	Boiler room	O & M
15	Boiler gaskets	2 Eac	Α	Boiler room	O & M
١.	Cove base	Approx. 3,800 LF	Α	Throughout the building	O & M
3	Cove base mastic	Approx. 1,200 SF	Α	Throughout the building	O & M

Greater Clark County Schools Remaining Materials Report January 25, 2006

HA#	Material	Quantity	ACBM Y/A	Location	Planned Activities
Thoma	ns Jefferson Elementary				
01	Pipe insulation	10 LF	Υ	Boiler room	O & M
02	Pipe insulation	230 LF	Υ	Tunnels	O & M
03	Fittings	48 Eac	Υ	Boiler room and tunnel	O & M
)5	VAT	33,750 SF	Y	Throughout the building (classrooms, hallways & office)	O & M
)7	Mastic	33,750 SF	Α	Throughout the building	O & M
11	Fire door	30 SF	Α	Boiler room	O & M
15	Boiler gaskets	2 Eac	Α	Boiler room	O & M
A	Cove base	Approx. 3,800 LF	Α	Throughout the building	O & M
В	Cove base mastic	Approx. 1,200 SF	Α	Throughout the building	O & M

Greater Clark County Schools Remaining Materials Report July 20, 2005

IA#	Material	Quantity		ACBM Y/A	Location	Planned Activities
homas	Jefferson Elementary					
)1	Pipe insulation	10	LF	Υ	Boiler room	O & M
2	Pipe insulation	230	LF	Υ	Tunnels	O & M
3	Fittings	48	Each	Υ	Boiler room and tunnel	O & M
5	VAT	33,750	SF	Υ	Throughout the building (classrooms, hallways & office)	O & M
7	Mastic	33,750	SF	Α	Throughout the building	O & M
	Fire door	30	SF	Α	Boiler room	O & M
5	Boiler gaskets	2	Each	Α	Boiler room	O & M
	Cove base	Approx. 3,800	LF	Α	Throughout the building	O & M
	Cove base mastic	Approx. 1,200	SF	Α	Throughout the building	O & M

Greater Clark County Schools Remaining Materials Report December 9, 2004

HA#	Material	Quantity		ACBM Y/A	Location	Planned Activities
<u> Thoma:</u>	s Jefferson Elementary					
01	Pipe insulation	10	LF	Υ	Boiler room	O & M
)2	Pipe insulation	230	LF	Υ	Tunnels	O & M
3	Fittings	48	Each	Υ	Boiler room and tunnel	O & M
15	VAT	33,750	SF	Υ	Throughout the building (classrooms, hallways & office)	O & M
7	Mastic	33,750	, SF	Α	Throughout the building	O & M
1	Fire door	30	SF	Α	Boiler room	O & M
5	Boiler gaskets	2	Each	Α	Boiler room	O & M
	Cove base	Approx. 3,800	LF	Α	Throughout the building	O & M
3	Cove base mastic	Approx. 1,200	SF	Α	Throughout the building	O & M

Greater Clark County Schools Remaining Materials Report July 2, 2004

HA#	Material	Quantity		ACBM Y/A	Location	Planned Activities
<u> Thoma</u>	s Jefferson Elementary					
01	Pipe insulation	10	LF	Υ	Boiler room	O & M
2	Pipe insulation	230	LF	Υ	Tunnels	O & M
3	Fittings	48	Each	Y	Boiler room and tunnel	O & M
5	VAT	33,750	SF	Υ	Throughout the building (classrooms, hallways & office)	O & M
7	Mastic	33,750	SF	Α	Throughout the building	O & M
1	Fire door	30	SF	Α	Boiler room	O & M
5	Boiler gaskets	2	Each	Α Α	Boiler room	O & M
	Cove base	Approx. 3,800	LF	Α	Throughout the building	O & M
}	Cove base mastic	Approx. 1,200	SF	Α	Throughout the building	O & M

Greater Clark County Schools Remaining Materials Report December 9, 2003

Material	Quantity		ACBM Y/A	Location	Planned Activities
Jefferson Elementary					
Pipe insulation	10	LF	Y	Boiler room	O & M
Pipe insulation	230	LF	Υ	Tunnels	O & M
Fittings	48	Each	ı Y	Boiler room and tunnel	O & M
VAT	33,750	SF	Υ	Throughout the building (classrooms, hallways & office)	O & M
Mastic	33,750	SF	Α	Throughout the building	O & M
Fire door	30	SF	Α	Boiler room	O & M
Boiler gaskets	2	Each	ı A	Boiler room	O & M
Cove base	Approx. 3,800	LF	Α	Throughout the building	O & M
Cove base mastic	Approx. 1,200	SF	Α	Throughout the building	O & M
	Pipe insulation Pipe insulation Fittings VAT Mastic Fire door Boiler gaskets Cove base	Pipe insulation 10 Pipe insulation 230 Fittings 48 VAT 33,750 Mastic 33,750 Fire door 30 Boiler gaskets 2 Cove base Approx. 3,800	Pipe insulation 10 LF Pipe insulation 230 LF Fittings 48 Each VAT 33,750 SF Mastic 33,750 SF Fire door 30 SF Boiler gaskets 2 Each Cove base Approx. 3,800 LF	Pipe insulation Pipe insulation Pipe insulation Pipe insulation Pittings Pi	Pipe insulation Pipe insulation Pipe insulation Pipe insulation Pipe insulation Pittings Pitt

Greater Clark County Schools Remaining Materials Report June 13, 2003

HA#	Material	Quantity		ACBM Y/A	Location	Planned Activities
Thom <u>a</u>	s Jefferson Elementary					
01	Pipe insulation - mag Debris (40 square feet)	90	LF	Y	Tunnels and boiler room	O & M
02	Pipe insulation - air cell	150	LF	Υ	Tunnels and boiler room	O & M
)3	Fittings	48	Each	ı Y	Boiler room and tunnel	O & M
5	VAT	33,750	SF	Υ	Throughout the building (classrooms, hallways & office)	O & M
7	Mastic	33,750	SF	Α	Throughout the building	O & M
1	Fire door	30	SF	Α	Boiler room	O & M
5	Boiler gaskets	2	Each	n A	Boiler room	O & M
	Cove base	Approx. 3,800	LF	Α	Throughout the building	O & M
3	Cove base mastic	Approx. 1,200	SF	Α	Throughout the building	O & M

Greater Clark County Schools Remaining Materials Report December 18, 2003

HA#	Material	Quantity		ACBM Y/A	Location	Planned Activities
<u>Γhoma</u>	s Jefferson Elementary					
)1	Pipe insulation - mag	90	LF	Υ	Tunnels and boiler room	O & M
2	Pipe insulation - air cell	150	LF	Υ	Tunnels and boiler room	O & M
3	Fittings	48	Each	Υ	Boiler room and tunnel	O & M
4	Debris	40	SF	Υ	Tunnel	O & M
5	VAT	33,750	SF	Υ	Throughout the building (classrooms, hallways & office)	O & M
7	Mastic	33,750	SF	Α	Throughout the building	O & M
1	Fire door	30	SF	Α	Boiler room	O & M
5	Boiler gaskets	2	Each	Α	Boiler room	O & M
	Cove base	Approx. 3,800	LF	Α	Throughout the building	O & M
	Cove base mastic	Арргох. 1,200	SF	Α	Throughout the building	O & M

Greater Clark County Schools Remaining Materials Report June 19, 2002

HA#	Material	Quantity		ACBM Y/A	Location	Planned Activities
<u> Thoma</u>	s Jefferson Elementary					
01	Pipe insulation - mag	90	LF	Υ	Tunnels	O & M
2	Pipe insulation - air cell	150	LF	Υ	Tunnels and boiler room	O & M
3	Fittings	48	Each	ı Y	Boiler room and tunnel	O & M
4	Debris	40	SF	Υ	Tunnel	O & M
5	VAT	33,750	SF	Υ	Throughout the building (classrooms, hallways & office)	O & M
7	Mastic	33,750	SF	Α	Throughout the building	O & M
1	Fire door	30	SF	Α	Boiler room	O & M
5	Boiler gaskets	2	Each	ı A	Boiler room	O & M
	Cove base	Approx. 3,800	LF	Α	Throughout the building	O & M
1	Cove base mastic	Approx. 1,200	SF	Α	Throughout the building	O & M

Greater Clark County Schools Remaining Materials Report December 12, 2001

HA#	Material	Quantity		ACBM Y/A	Location	Planned Activities
Thoma	s Jefferson Elementary					
01	Pipe insulation - mag	90	LF	Υ	Tunnels	O & M
)2	Pipe insulation - air cell	150	LF	Υ	Tunnels and boiler room	O & M
3	Fittings	48	Each	ı Y	Boiler room and tunnel	O & M
4	Debris	40	SF	Υ	Tunnel	O & M
5	VAT	33,750	SF	Υ	Throughout the building (classrooms, hallways & office)	O & M
7	Mastic	33,750	SF	Α	Throughout the building	O & M
1	Fire door	30	SF	Α	Boiler room	O & M
5	Boiler gaskets	2	Each	A	Boiler room	O & M
	Cove base	Approx. 3,800	LF	Α	Throughout the building	O & M
3	Cove base mastic	Approx. 1,200	SF	Α	Throughout the building	O & M

Greater Clark County Schools Remaining Materials Report July 12, 2001

HA#	Material	Quantity		ACBM Y/A	Location	Planned Activities
<u>Thoma</u>	s Jefferson Elementary					
01	Pipe insulation - mag	90	LF	Υ	Tunnels	O & M
02	Pipe insulation - air cell	150	LF	Υ	Tunnels and boiler room	O & M
)3	Fittings	48	Each	ı Y	Boiler room and tunnel	O & M
)4	Debris	40	SF	Υ	Tunnel	O & M
5	VAT	33,750	SF	Υ	Throughout the building (classrooms, hallways & office)	O & M
17	Mastic	33,750	SF	Α	Throughout the building	O & M
1	Fire door	30	SF	Α	Boiler room	O & M
5	Boiler gaskets	2	Each	ı A	Boiler room	O & M
	Cove base	Approx. 3,800	LF	Α	Throughout the building	O & M
3	Cove base mastic	Approx. 1,200	SF	Α	Throughout the building	O & M

Greater Clark County Schools Remaining Materials Report January 11, 2001

HA#	Material	Quantity		ACBM Y/A	Location	Planned Activities
<u> Thoma</u>	s Jefferson Elementary					
01	Pipe insulation - mag	90	LF	Υ	Tunnels	O & M
2	Pipe insulation - air cell	150	LF	Υ	Tunnels and boiler room	O & M
3	Fittings	48	Each	Y	Boiler room and tunnel	O & M
4	Debris	40	SF	Υ	Tunnel	O & M
5	VAT	33,750	SF	Y	Throughout the building (classrooms, hallways & office)	O & M
7	Mastic	33,750	SF	Α	Throughout the building	O & M
1	Fire door	30	SF	Α	Boiler room	O & M
5	Boiler gaskets	2	Each	Α	Boiler room	O & M
	Cove base	Approx. 3,800	LF	Α	Throughout the building	O & M
	Cove base mastic	Approx. 1,200	SF	Α	Throughout the building	O & M

Greater Clark County Schools Remaining Materials Report June 29, 2000

HA#	Material	Quantity		ACBM Y/A	Location	Planned Activities
<u>Thoma</u>	s Jefferson Elementary					
01	Pipe Insulation - Mag	90	LF	Υ	Tunnels	O & M
02	Pipe Insulation - Air Cell	150	LF	Υ	Tunnels and Boiler Room	O & M
13	Fittings	48	Each	Y	Boiler Room and Tunnel	O & M
4	Debris	40	SF	Υ	Tunnel	O & M
5	VAT	33,750	SF	Υ	Throughout the building (classrooms, hallways & office)	O & M
7	Mastic	33750	SF	Α	Throughout the building	O & M
1	Fire Door	30	SF	Α	Boiler Room	O & M
5	Boiler Gaskets	2	Each	ı A	Boiler Room	O & M
	Cove Base	Unquantified	LF	Α	Throughout the building	O & M
}	Cove Base Mastic	Unquantified	LF	Α	Throughout Building	O & M

Greater Clark County Schools Remaining Materials Report February 23, 2000

HA#	Material	Quantity		ACBM Y/A	Location	Planned Activities
<u>Thoma</u>	s Jefferson Elementary					e K
01	Pipe Insulation - Mag	90	LF	Y	Tunnels	O & M
02	Pipe Insulation - Air Cell	150	LF	Υ	Tunnels and Boiler Room	O & M
)3	Fittings	48	Each	ΙΥ	Boiler Room and Tunnel	O & M
14	Debris	40	SF	Υ	Tunnel	O & M
5	VAT	33750	SF	Υ	Throughout the building (classrooms, hallways & office)	O & M
7	Mastic	33750	SF	Α	Throughout the building	O & M
1	Fire Door	30	SF	Α	Boiler Room	O & M
5	Boiler Gaskets	2	Each	Α Α	Boiler Room	O & M
	Cove Base	Unquantified	LF	Α	Throughout the building	O & M
3	Cove Base Mastic	Unquantified	LF	Α	Throughout Building	O & M

Greater Clark County Schools Remaining Materials Report July 6, 1999

HA#	Material	Quantity		ACBM Y/A	Location	Planned Activities
<u>Thoma</u>	s Jefferson Elementary					
01	Pipe Insulation - Mag	90	LF	Υ	Tunnels	O & M
02	Pipe Insulation - Air Cell	150	LF	Υ	Tunnels and Boiler Room	O & M
)3	Fittings	48	Each	ΙΥ	Boiler Room and Tunnel	O & M
14	Debris	40	SF	Υ	Tunnel	O & M
5	VAT	33750	SF	Y	Throughout Building (Classrooms, Halls & Office)	O & M
7	Mastic	33750	SF	Α	Throughout Building	O & M
1	Fire Door	30	SF	Α	Boiler Room	O & M
5	Boiler Gaskets	2	Each	Α	Boiler Room	O & M
	Cove Base	Unquantified	LF	Α	Throughout the building	O & M
3	Cove Base Mastic	Unquantified	LF	Α	Throughout Building	O & M

PERIODIC SURVEILLANCE
REINSPECTION
ADDITIONAL BULK SAMPLING
INFORMATION

ASSESSMENTS FOR AHERA

- 1. Damaged or significantly damaged thermal systems insulation.
- 2. Damaged friable surfacing ACM.
- 3. Significantly damaged friable surfacing ACM.
- 4. Damaged or significantly damaged friable miscellaneous ACM.
- 5. ACBM with potential for damage.
- 6. ACBM with potential for significant damage.
- 7. Any remaining friable ACBM or friable suspected ACBM.

If a material is non-friable, it does not require an assessment rating under AHERA.

Due to the differences in what is required of the LEA for damaged material compared to significantly damaged material, Alliance has modified the assessment scale to the following:

- 1A. Significantly damaged thermal systems insulation.
- 1B. Damaged thermal systems insulation.
- 4A. Significantly damaged friable miscellaneous ACM.
- 4B. Damaged friable miscellaneous ACM.

PERIODIC SURVEILLANCES

SURVEILLANCE INFORMATION PERIODIC SURVEILLANCE PLAN

GREATER CLARK COUNTY SCHOOLS

The ACBM in this building will be periodically inspected to determine any change in the condition of the materials for as long as the material remain in the building, as required by the Asbestos Hazard Emergency Response Act (AHERA). This periodic surveillance shall be conducted on a semi-annual basis as required by law.

Records of each re-inspection will be maintained in this binder.

DATE PLANNED	DATE COMPLETED	COMPLETED BY
October 2014	October 22, 2014	Rivair (Ko)
<u> April 2015</u>	April 22, 2015	Brigan (Ko)
October 2015	October 20, 2016	Rougan (And
<u> April 2016</u>	RE-INSPECTION	Roigin (Se
October 2016	November 3, 2016	DAR
<u>April 2017</u>	April 13, 2017	Gernie Arblinne.
October 2017	October 18, 2017	D-AHC
<u>April 2018</u>	May 2, 2018	Rosigin (Ka)
October 2018	November 13, 2018	Reigan (Kor)
April 2019	RE-INSPECTION	
October 2019	January 14, 2020	Mill Is
April 2020	April 23, 2020	Mill Is
October 2020		
COLODE! ZUZU		

SURVEILLANCE INFORMATION

PERIODIC SURVEILLANCE PLAN

GREATER CLARK COUNTY SCHOOLS

The ACBM in this building will be periodically inspected to determine any change in the condition of the materials for as long as the material remain in the building, as required by the Asbestos Hazard Emergency Response Act (AHERA). This periodic surveillance shall be conducted on a semi-annual basis as required by law.

Records of each re-inspection will be maintained in this binder.

<u>April 2021</u>		
October 2021		
<u>April 2022</u>	RE-INSPECTION	
October 2022		
<u>April 2023</u>		
October 2023		
<u>April 2024</u>		
October 2024		
<u>April 2025</u>	RE-INSPECTION	
October 2025		
<u>April 2026</u>		
October 2026		

SURVEILLANCE INFORMATION

PERIODIC SURVEILLANCE PLAN SCHEDULE

GREATER CLARK COUNTY SCHOOLS

The ACBM in this building will be periodically inspected to determine any change in the condition of the materials for as long as the material remain in the building, as required by the Asbestos Hazard Emergency Response Act (AHERA). This periodic surveillance shall be conducted on a semi-annual basis as required by law.

Records of each re-inspection will be maintained in this binder.

DATE PLANNED	DATE COMPLETED	COMPLETED BY
JUNE 2009	JUNE 2009	Dru Cour
DECEMBER 2009	Dec 2009	Bill Ogle
JUNE 2010	Reinspection	Sandy Stradley
DECEMBER 2010	December 2010	Paul Brick
JUNE 2011	June 2011	Sandy Smadley
DECEMBER 2011		0 0
JUNE 2012_	June 2012	Jeff hechtin
DECEMBER 2012	October 2012	Jeff hechtin
JUNE 2013_	heirspection	Jeff hechtin
	1 with the same	
DECEMBER 2013		

PERIODIC SURVEILLANCE PLAN

GREATER CLARK COUNTY SCHOOLS

The ACBM in this building will be periodically inspected to determine any change in the condition of the materials for as long as the material remain in the building, as required by the Asbestos Hazard Emergency Response Act (AHERA). This periodic surveillance shall be conducted on a semi-annual basis as required by law.

Records of each reinspection will be maintained in this binder.

DATE PLANNED	DATE COMPLETED	COMPLETED BY
JUNE 2003	June '03	C Spacks
DECEMBER 2003	Dec. '03	C. Spacks
JUNE 2004	REINSPECTION	C. Apacks
DECEMBER 2004	Dec '04	C. Sporks
JUNE 2005	July'05	J. Dle
DECEMBER 2005	Dan Ole	Bager
JUNE 2006	Done ole	C Anes
DECEMBER 2006	Dec 00	30gl
JUNE 2007	July 2007 REINSPECTION	Bill Ugle
DECEMBER 2007	December 2007	Will Ugle
JUNE 2008	June 2008	Bill Udle
DECEMBER 2008	December 2008	Bill Ople

PERIODIC SURVEILLANCE PLAN

GREATER CLARK COUNTY SCHOOLS

JEFFERSON ELEMENTARY SCHOOL

The ACBM in this building will be periodically inspected to determine any change in the condition of the materials for as long they remain in the building. This inspection will be conducted semi-annually.

The following table outlines the dates on which these inspections should take place in this school building.

PERIODIC SURVEILLANCE SCHEDULE

DATE PLANNED	DATE COMPLETED	COMPLETED BY
DECEMBER 1995	12-95	alliance
JUNE 1996	6-96	alliance
DECEMBER 1996	12-96	alliance
JUNE 1997	7-97	alliance
DECEMBER 1997	1-98	alliance
JUNE 1998	REINSPECTION	alliance
DECEMBER 1998	12-98	alliance
JUNE 1999	June 199	alliance
DECEMBER 1999	Dec. 199	alliance
JUNE 2000	Jane 2000	alliance
DECEMBER 2000	Jan. 101	Pat Wilson
JUNE 2001	REINSPECTION	P. Wilson
DECEMBER 2001	Dec. '01	A. Kimbrough
JUNE 2002	June 'OZ	R. Calvert
DECEMBER 2002	Dec. '02	C. Spacks

LEA Name Greater Clark County School Corporation

Building Name Thomas Jefferson Elementary School

Building Number 03

HA ID 01

HA Description Pipe Insulation

HA Type Thermal System Insulation (TSI)

HA Location Boiler room

Quantity 10 LF

Comments This material was not in poor condition along east wall near east boiler by tunnel

entry.

Scheduled for abatement in 2012/2013 renovation.

Asbestos Known

Friable No

Original Inspection 6/1/1992

Current Inspection 4/23/2020

Material Assessment

Assessment Rating 5 ACBM with potential for damage

Damage Assessment and Potential for Damage

Percent Damaged % Good Condition

Physical ContactVibrationAirLow/NoneLow/NoneLow/None

Planned Response Action O&M

Michael J. Ardis

State IN

Accreditation Number 19A007304

Inspector

LEA Name Greater Clark County School Corporation

Building Name Thomas Jefferson Elementary School

Building Number 03

HA ID 02

HA Description Pipe Insulation

HA Type Thermal System Insulation (TSI)

HA Location Tunnels

Quantity 230 LF

Comments Entrances to tunnels are restricted, as this material is in poor condition. There is

debris

all over the floor of the dirt crawl. No one should enter this area without proper

training

and protection. Clean up recommended. Scheduled for abatement in 2012/2013

renovation.

Asbestos Known

Friable Yes

Original Inspection 6/1/1992

Current Inspection 4/23/2020

Material Assessment

Assessment Rating 1 Damaged or significantly damaged thermal syste

Damage Assessment and Potential for Damage

<u>Percent Damaged</u> % Damanged - Localized

<u>Physical Contact</u> <u>Vibration</u> <u>Air</u>

High Low/None Low/None

<u>Planned Response Action</u> Patch and Repair

Inspector

Michael J. Ardis

State IN Accreditation Number 19A007304

LEA Name Greater Clark County School Corporation

Building Name Thomas Jefferson Elementary School

Building Number 03

HA ID 03

HA Description Fittings

HA Type Thermal System Insulation (TSI)

HA Location Boiler room and tunnel

Quantity 48 Unit(s)

Comments Material in tunnel is in poor condition. Entry to tunnel is restricted. No one

should enter

without proper training and protection. Clean up recommended. Scheduled for

abatement in 2012/2013 renovation.

Asbestos Known

Friable Yes

Original Inspection 6/1/1992

Current Inspection 4/23/2020

Material Assessment

Assessment Rating 1 Damaged or significantly damaged thermal syste

Damage Assessment and Potential for Damage

<u>Percent Damaged</u> % Damanged - Localized

<u>Physical Contact</u> <u>Vibration</u> <u>Air</u>

High Low/None Low/None

Planned Response Action O&M

Michael J. Ardis

State IN

Accreditation Number 19A007304

Inspector

LEA Name Greater Clark County School Corporation

Building Name Thomas Jefferson Elementary School

Building Number 03

HA ID 05-A

HA TypeVAT-underneath carpet

Miscellaneous Material

HA Location Throughout the building (classrooms, hallways & office)

Quantity Unquantified SF

Comments Floor Tile (installed in 1994)

Asbestos Known

Friable No

Original Inspection 6/1/1992

Current Inspection 4/23/2020

Material Assessment

Assessment Rating 5 ACBM with potential for damage

Damage Assessment and Potential for Damage

Percent Damaged % Good Condition

Physical ContactVibrationAirLow/NoneLow/NoneLow/None

Planned Response Action O&M

Inspector

Michael J. Ardis

State IN

LEA Name Greater Clark County School Corporation

Building Name Thomas Jefferson Elementary School

Building Number 03

HA ID 05-B

HA Description 12" x 12" newer off-white floor tile

HA Type Miscellaneous Material

HA Location Throughout the building (first aid office, cafeteria, workroom, water fountain

area, office

hallway, entrance, and art room)

Quantity Unquantified SF

Comments Minor chipping near water fountain. Overall, this material is not in poor

condition.

Asbestos Known

Friable No

Original Inspection 6/1/1992

Current Inspection 4/23/2020

Material Assessment

Assessment Rating 5 ACBM with potential for damage

Damage Assessment and Potential for Damage

Percent Damaged % Good Condition

 Physical Contact
 Vibration
 Air

 Low/None
 Low/None
 Low/None

Planned Response Action O&M

Inspector

Michael J. Ardis

State IN

LEA Name Greater Clark County School Corporation

Building Name Thomas Jefferson Elementary School

Building Number 03

HA ID 05-C

HA Type Miscellaneous Material

HA Location Throughout the building (gym and custodial closets).

Quantity Unquantified SF

Comments Minor chipping in closets. Overall, this material is not in poor condition.

Asbestos Known

Friable No

Original Inspection 6/1/1992

Current Inspection 4/23/2020

Material Assessment

Assessment Rating 5 ACBM with potential for damage

Damage Assessment and Potential for Damage

Percent Damaged % Good Condition

Physical ContactVibrationAirLow/NoneLow/NoneLow/None

Planned Response Action O&M

Inspector

Michael J. Ardis

State IN

LEA Name Greater Clark County School Corporation

Building Name Thomas Jefferson Elementary School

Building Number 03

HA ID 05-D

HA Description 12" x 12" original light blue floor tile

HA Type Miscellaneous Material

HA Location Throughout the building (gym)

Quantity Unquantified SF

Comments Where visible, this material is not in poor condition.

Asbestos Known

Friable No

Original Inspection 6/1/1992

Current Inspection 4/23/2020

Material Assessment

Assessment Rating 5 ACBM with potential for damage

Damage Assessment and Potential for Damage

Percent Damaged % Good Condition

Physical ContactVibrationAirLow/NoneLow/NoneLow/None

Planned Response Action O&M

Inspector

Michael J. Ardis

State IN

LEA Name Greater Clark County School Corporation

Building Name Thomas Jefferson Elementary School

Building Number 03

HA ID 07

HA Description Mastic

HA Type Miscellaneous Material

HA Location Throughout the building

Quantity 33750 SF

Comments This material was not visible to inspect.

Asbestos Assumed

Friable No

Original Inspection 6/1/1992

Current Inspection 4/23/2020

Material Assessment

Assessment Rating 5 ACBM with potential for damage

Damage Assessment and Potential for Damage

Percent Damaged % Good Condition

Physical ContactVibrationAirLow/NoneLow/NoneLow/None

Planned Response Action O&M

Inspector

Michael J. Ardis

State IN

LEA Name Greater Clark County School Corporation

Building Name Thomas Jefferson Elementary School

Building Number 03

HA ID 11

HA Description Fire door-Metal cladHA Type Miscellaneous Material

HA Location Boiler room (2) Gym Exterior Doors (4)

Quantity 6 Unit(s)

Comments The fire door shell is intact with no core material visible to inspect.

Asbestos Assumed

Friable No

Original Inspection 6/1/1992

Current Inspection 4/23/2020

Material Assessment

Assessment Rating 5 ACBM with potential for damage

Damage Assessment and Potential for Damage

Percent Damaged % Good Condition

Physical ContactVibrationAirLow/NoneLow/NoneLow/None

Planned Response Action O&M

Inspector

Michael J. Ardis

State IN

LEA Name Greater Clark County School Corporation

Building Name Thomas Jefferson Elementary School

Building Number 03

HA ID 15

HA Description Boiler gaskets

HA Type Miscellaneous Material

HA Location Boiler room

Quantity 2 Unit(s)

Comments Boiler doors were closed. The visible edges of this material were not in poor

condition.

There is some fiberglass rope visible, but also some older looking gasket

material.

Asbestos Assumed

Friable No

Original Inspection 6/1/1992

Current Inspection 4/23/2020

Material Assessment

Assessment Rating 5 ACBM with potential for damage

Damage Assessment and Potential for Damage

Percent Damaged % Good Condition

Physical ContactVibrationAirLow/NoneLow/NoneLow/None

Planned Response Action O&M

Michael J. Ardis

State IN

Accreditation Number 19A007304

Inspector

LEA Name Greater Clark County School Corporation

Building Name Thomas Jefferson Elementary School

Building Number 03

HA ID A

HA Description Cove Base

HA Type Miscellaneous Material
HA Location Throughout the building

Quantity Approx. 3800 LF

Comments Material is not in poor condition overall with minor signs of wear. Loose and

missing in

a few locations. (installed in 1994)

Asbestos Assumed

Friable No

Original Inspection 5/31/1995

Current Inspection 4/23/2020

Material Assessment

Assessment Rating 5 ACBM with potential for damage

Damage Assessment and Potential for Damage

Percent Damaged % Good Condition

Physical ContactVibrationAirLow/NoneLow/NoneLow/None

Planned Response Action O&M

Inspector

Michael J. Ardis

State IN

LEA Name Greater Clark County School Corporation

Building Name Thomas Jefferson Elementary School

Building Number 03

HA ID B

HA Description Cove base mastic

HA Type Miscellaneous Material

HA Location Throughout the building

Quantity Approx. 1200 SF

Comments Mastic was visible to inspect at corner near custodial closet in the cafateria

where cove

base was missing.

Asbestos Assumed

Friable No

Original Inspection 5/31/1995

Current Inspection 4/23/2020

Material Assessment

Assessment Rating 5 ACBM with potential for damage

Damage Assessment and Potential for Damage

Percent Damaged % Good Condition

Physical ContactVibrationAirLow/NoneLow/NoneLow/None

Planned Response Action O&M

Inspector

Michael J. Ardis

State IN

LEA Name Greater Clark County School Corporation

Building Name Thomas Jefferson Elementary School

Building Number 03

HA ID C

HA Type AHU Cloth Expansion Joints

HA Type Miscellaneous Material

HA Location Stage ends

Quantity 2 Unit(s)

Comments These were noted during the June 2011 6 month surveillance and will remain in

the

management plan until properly sampled.

Asbestos Assumed

Friable No

Original Inspection 6/27/2011

Current Inspection 4/23/2020

Material Assessment

Assessment Rating 5 ACBM with potential for damage

Damage Assessment and Potential for Damage

Percent Damaged % Good Condition

Physical ContactVibrationAirLow/NoneLow/NoneLow/None

Planned Response Action O&M

Inspector

Michael J. Ardis

State IN

LEA Name Greater Clark County School Corporation

Building Name Thomas Jefferson Elementary School

Building Number 03

HA ID D

HA Description Fire Doors-Original to building (wooden)

HA Type Miscellaneous Material

HA Location Gym & throughout the building

Quantity Unquantified Unit(s)

Comments These were noted during the June 2011 6 month surveillance and will remain in

the

management plan until properly sampled.

Asbestos Assumed

Friable No

Original Inspection 6/27/2011

Current Inspection 4/23/2020

Material Assessment

Assessment Rating 5 ACBM with potential for damage

Damage Assessment and Potential for Damage

Percent Damaged % Good Condition

Physical ContactVibrationAirLow/NoneLow/NoneLow/None

Planned Response Action O&M

Inspector

Michael J. Ardis

State IN

LEA Name Greater Clark County School Corporation

Building Name Thomas Jefferson Elementary School

Building Number 03

HA ID E

HA Description Gray Sink InsulationHA Type Miscellaneous Material

HA Location Classrooms, Art Room & Teachers Lounge

Quantity Unquantified LF

Comments This was noted during the June 2011 6 month surveillance and will remain in the

management plan until properly sampled.

Asbestos Assumed

Friable No

Original Inspection 6/27/2011

Current Inspection 4/23/2020

Material Assessment

Assessment Rating 5 ACBM with potential for damage

Damage Assessment and Potential for Damage

Percent Damaged % Good Condition

Physical ContactVibrationAirLow/NoneLow/NoneLow/None

Planned Response Action O&M

Inspector

Michael J. Ardis

State IN

LEA Name Greater Clark County School Corporation

Building Name Thomas Jefferson Elementary School

Building Number 03

HAID F

HA Description Pipe Insulation

HA Type Thermal System Insulation (TSI)

HA Location Storage Rooms Near Crawlspace Tunnel Access

Quantity N/A LF

Comments This material was noted by the licensed inspector during the April 2015 6 month

inspection. A tear (less than 1 LF) in a four inch line was noted during the

inspection

with a small amount of debris (less than 1 LF) was noted below the damaged

pipe

insulation. The debris should be cleaned up and the pipe repaired as soon as

possible. Multiple open exposed spots on the line with damage.

Overall material is not in poor condition.

Asbestos Assumed

Friable Yes

Original Inspection 4/22/2015

Current Inspection 4/23/2020

Material Assessment

<u>Assessment Rating</u> 1 Damaged or significantly damaged thermal syste

Damage Assessment and Potential for Damage

Percent Damaged % Damanged - Localized

Physical ContactVibrationAirMediumLow/NoneLow/None

Planned Response Action Patch and Repair

Inspector Line 1

Michael J. Ardis

State IN Accreditation Number 19A007304

LEA Name Greater Clark County School Corporation

Building Name Thomas Jefferson Elementary School

Building Number 03

HA ID 01

HA Description Pipe Insulation

HA Type Thermal System Insulation (TSI)

HA Location Boiler room

Quantity 10 LF

Comments Cracks and minor delamination was observed in boiler tunnel entry.

Asbestos Known

Friable No

Original Inspection 6/1/1992

Current Inspection 1/14/2020

Material Assessment

Assessment Rating 5 ACBM with potential for damage

Damage Assessment and Potential for Damage

Percent Damaged % Good Condition

Physical ContactVibrationAirLow/NoneLow/NoneLow/None

Planned Response Action O&M

Inspector

Michael J. Ardis

State IN

LEA Name Greater Clark County School Corporation

Building Name Thomas Jefferson Elementary School

Building Number 03

HA ID 02

HA Description Pipe Insulation

HA Type Thermal System Insulation (TSI)

HA Location Tunnels

Quantity 230 LF

Comments Entrances to tunnels are restricted, as this material is in poor condition. There is

debris

all over the floor of the dirt crawl. No one should enter this area without proper

training

and protection. Clean up recommended. Scheduled for abatement in 2012/2013

renovation.

Asbestos Known

Friable Yes

Original Inspection 6/1/1992

Current Inspection 1/14/2020

Material Assessment

Assessment Rating 1 Damaged or significantly damaged thermal syste

Damage Assessment and Potential for Damage

<u>Percent Damaged</u> % Damanged - Localized

<u>Physical Contact</u> <u>Vibration</u> <u>Air</u>

High Low/None Low/None

<u>Planned Response Action</u> Patch and Repair

Inspector

Michael J. Ardis

State IN Accreditation Number 19A007304

LEA Name Greater Clark County School Corporation

Building Name Thomas Jefferson Elementary School

Building Number 03

HA ID 03

HA Description Fittings

HA Type Thermal System Insulation (TSI)

HA Location Boiler room and tunnel

Quantity 48 Unit(s)

Comments Material in tunnel is in poor condition. Entry to tunnel is restricted. No one

should enter without proper training and protection. Clean up recommended.

Asbestos Known

Friable Yes

Original Inspection 6/1/1992

Current Inspection 1/14/2020

Material Assessment

Assessment Rating 1 Damaged or significantly damaged thermal syste

Damage Assessment and Potential for Damage

<u>Percent Damaged</u> % Damanged - Localized

Physical ContactVibrationAirHighLow/NoneLow/None

Planned Response Action O&M

Inspector

Michael J. Ardis

State IN

LEA Name Greater Clark County School Corporation

Building Name Thomas Jefferson Elementary School

Building Number 03

HA ID 05-A

HA Type VAT-underneath carpet

Miscellaneous Material

HA Location Throughout the building (classrooms, hallways & office)

Quantity Unquantified SF

Comments Floor Tile (installed in 1994)

Asbestos Known

Friable No

Original Inspection 6/1/1992

Current Inspection 1/14/2020

Material Assessment

Assessment Rating 5 ACBM with potential for damage

Damage Assessment and Potential for Damage

Percent Damaged % Good Condition

Physical ContactVibrationAirLow/NoneLow/NoneLow/None

Planned Response Action O&M

Inspector

Michael J. Ardis

State IN

LEA Name Greater Clark County School Corporation

Building Name Thomas Jefferson Elementary School

Building Number 03

HA ID 05-B

HA Description 12" x 12" newer off-white floor tile

HA Type Miscellaneous Material

HA Location Throughout the building (first aid office, cafeteria, workroom, water fountain

area, office

hallway, entrance, and art room)

Quantity Unquantified SF

Comments Minor chipping near water fountain. Overall, this material is not in poor

condition.

Asbestos Known

Friable No

Original Inspection 6/1/1992

Current Inspection 1/14/2020

Material Assessment

Assessment Rating 5 ACBM with potential for damage

Damage Assessment and Potential for Damage

Percent Damaged % Good Condition

 Physical Contact
 Vibration
 Air

 Low/None
 Low/None
 Low/None

Planned Response Action O&M

Inspector

Michael J. Ardis

State IN

LEA Name Greater Clark County School Corporation

Building Name Thomas Jefferson Elementary School

Building Number 03

HA ID 05-C

HA Description 12" x 12" original floor tileHA Type Miscellaneous Material

HA Location Throughout the building (gym and custodial closets).

Quantity Unquantified SF

Comments Minor chipping in closets. Overall, this material is not in poor condition.

Asbestos Known

Friable No

Original Inspection 6/1/1992

Current Inspection 1/14/2020

Material Assessment

Assessment Rating 5 ACBM with potential for damage

Damage Assessment and Potential for Damage

Percent Damaged % Good Condition

Physical ContactVibrationAirLow/NoneLow/NoneLow/None

Planned Response Action O&M

Inspector

Michael J. Ardis

State IN

LEA Name Greater Clark County School Corporation

Building Name Thomas Jefferson Elementary School

Building Number 03

HA ID 05-D

HA Description 12" x 12" original light blue floor tile

HA Type Miscellaneous Material

HA Location Throughout the building (gym)

Quantity Unquantified SF

Comments Where visible, this material is not in poor condition.

Asbestos Known

Friable No

Original Inspection 6/1/1992

Current Inspection 1/14/2020

Material Assessment

Assessment Rating 5 ACBM with potential for damage

Damage Assessment and Potential for Damage

Percent Damaged % Good Condition

Physical ContactVibrationAirLow/NoneLow/NoneLow/None

Planned Response Action O&M

Inspector

Michael J. Ardis

State IN

LEA Name Greater Clark County School Corporation

Building Name Thomas Jefferson Elementary School

Building Number 03

HA ID 07

HA Description Mastic

HA Type Miscellaneous Material

HA Location Throughout the building

Quantity 33750 SF

Comments This material was not visible to inspect.

Asbestos Assumed

Friable No

Original Inspection 6/1/1992

Current Inspection 1/14/2020

Material Assessment

Assessment Rating 5 ACBM with potential for damage

Damage Assessment and Potential for Damage

Percent Damaged % Good Condition

Physical ContactVibrationAirLow/NoneLow/NoneLow/None

Planned Response Action O&M

Inspector

Michael J. Ardis

State IN

LEA Name Greater Clark County School Corporation

Building Name Thomas Jefferson Elementary School

Building Number 03

HA ID 11

HA Description Fire door-Metal cladHA Type Miscellaneous Material

HA Location Boiler room (2) Gym Exterior Doors (4)

Quantity 6 Unit(s)

Comments The fire door shell is intact with no core material visible to inspect.

Asbestos Assumed

Friable No

Original Inspection 6/1/1992

Current Inspection 1/14/2020

Material Assessment

Assessment Rating 5 ACBM with potential for damage

Damage Assessment and Potential for Damage

Percent Damaged % Good Condition

Physical ContactVibrationAirLow/NoneLow/NoneLow/None

Planned Response Action O&M

Inspector

Michael J. Ardis

State IN

LEA Name Greater Clark County School Corporation

Building Name Thomas Jefferson Elementary School

Building Number 03

HA ID 15

HA Description Boiler gaskets

HA Type Miscellaneous Material

HA Location Boiler room

Quantity 0 Unit(s)

Comments The boilers were removed and replaced during 2018 renovations.

Asbestos Assumed

Friable No

Original Inspection 6/1/1992

Current Inspection 1/14/2020

Material Assessment

Assessment Rating 5 ACBM with potential for damage

Damage Assessment and Potential for Damage

Percent Damaged % Good Condition

Physical ContactVibrationAirLow/NoneLow/NoneLow/None

Planned Response Action Removed

Inspector

Michael J. Ardis

State IN

LEA Name Greater Clark County School Corporation

Building Name Thomas Jefferson Elementary School

Building Number 03

HAID A

HA Description Cove Base

HA Type Miscellaneous Material

HA Location Throughout the building

Quantity Approx. 3800 LF

Comments Material is not in poor condition overall with minor signs of wear. Loose and

missing in

a few locations. (installed in 1994)

Asbestos Assumed

Friable No

Original Inspection 5/31/1995

Current Inspection 1/14/2020

Material Assessment

Assessment Rating 5 ACBM with potential for damage

Damage Assessment and Potential for Damage

Percent Damaged % Good Condition

Physical ContactVibrationAirLow/NoneLow/NoneLow/None

Planned Response Action O&M

Inspector

Michael J. Ardis

State IN

LEA Name Greater Clark County School Corporation

Building Name Thomas Jefferson Elementary School

Building Number 03

HA ID B

HA Description Cove base mastic

HA Type Miscellaneous Material

HA Location Throughout the building

Quantity Approx. 1200 SF

Comments Mastic was visible to inspect at corner near custodial closet in the cafateria

where cove

base was missing.

Asbestos Assumed

Friable No

Original Inspection 5/31/1995

Current Inspection 1/14/2020

Material Assessment

Assessment Rating 5 ACBM with potential for damage

Damage Assessment and Potential for Damage

Percent Damaged % Good Condition

Physical ContactVibrationAirLow/NoneLow/NoneLow/None

Planned Response Action O&M

Inspector

Michael J. Ardis

State IN

LEA Name Greater Clark County School Corporation

Building Name Thomas Jefferson Elementary School

Building Number 03

HAID C

HA Description AHU Cloth Expansion JointsHA Type Miscellaneous Material

HA Location Stage ends

Quantity 2 Unit(s)

Comments These were noted during the June 2011 6 month surveillance and will remain in

the

management plan until properly sampled.

Asbestos Assumed

Friable No

Original Inspection 6/27/2011

Current Inspection 1/14/2020

Material Assessment

Assessment Rating 5 ACBM with potential for damage

Damage Assessment and Potential for Damage

Percent Damaged % Good Condition

Physical ContactVibrationAirLow/NoneLow/NoneLow/None

Planned Response Action O&M

Inspector

Michael J. Ardis

State IN

LEA Name Greater Clark County School Corporation

Building Name Thomas Jefferson Elementary School

Building Number 03

HA ID D

HA Description Fire Doors-Original to building (wooden)

HA Type Miscellaneous Material

HA Location Gym & throughout the building

Quantity Unquantified Unit(s)

Comments These were noted during the June 2011 6 month surveillance and will remain in

the

management plan until properly sampled.

Asbestos Assumed

Friable No

Original Inspection 6/27/2011

Current Inspection 1/14/2020

Material Assessment

Assessment Rating 5 ACBM with potential for damage

Damage Assessment and Potential for Damage

Percent Damaged % Good Condition

Physical ContactVibrationAirLow/NoneLow/NoneLow/None

Planned Response Action O&M

Inspector

Michael J. Ardis

State IN

LEA Name Greater Clark County School Corporation

Building Name Thomas Jefferson Elementary School

Building Number 03

HA ID E

HA Description Gray Sink InsulationHA Type Miscellaneous Material

HA Location Classrooms, Art Room & Teachers Lounge

Quantity Unquantified LF

Comments This was noted during the June 2011 6 month surveillance and will remain in the

management plan until properly sampled.

Asbestos Assumed

Friable No

Original Inspection 6/27/2011

Current Inspection 1/14/2020

Material Assessment

Assessment Rating 5 ACBM with potential for damage

Damage Assessment and Potential for Damage

Percent Damaged % Good Condition

Physical ContactVibrationAirLow/NoneLow/NoneLow/None

Planned Response Action O&M

Inspector

Michael J. Ardis

State IN

LEA Name Greater Clark County School Corporation

Building Name Thomas Jefferson Elementary School

Building Number 03

HAID F

HA Description Pipe Insulation

HA Type Thermal System Insulation (TSI)

HA Location Storage Rooms Near Crawlspace Tunnel Access

Quantity N/A LF

Comments This material was noted by the licensed inspector during the April 2015 6 month

inspection. A tear (less than 1 LF) in a four inch line was noted during the

inspection

with a small amount of debris (less than 1 LF) was noted below the damaged

pipe

insulation. The debris should be cleaned up and the pipe repaired as soon as

possible. Multiple open exposed spots on the line with damage.

Overall material is not in poor condition.

Asbestos Assumed

Friable Yes

Original Inspection 4/22/2015

Current Inspection 1/14/2020

Material Assessment

<u>Assessment Rating</u> 1 Damaged or significantly damaged thermal syste

Damage Assessment and Potential for Damage

Percent Damaged % Damanged - Localized

Physical ContactVibrationAirMediumLow/NoneLow/None

Planned Response Action Patch and Repair

Inspector Ull S

Michael J. Ardis

State IN Accreditation Number 19A007304

LEA Name Greater Clark County School Corporation

Building Name Thomas Jefferson Elementary School

Building Number 03

HA ID 01

HA Description Pipe Insulation

HA Type Thermal System Insulation (TSI)

HA Location Boiler room

Quantity 10 LF

Comments This material was not in poor condition along east wall near east boiler by

tunnel entry.

Scheduled for abatement in 2012/2013 renovation.

Asbestos Known

Friable No

Original Inspection 6/1/1992

Current Inspection 11/13/2018

Material Assessment

Assessment Rating 5 ACBM with potential for damage

Damage Assessment and Potential for Damage

Percent Damaged % Good Condition

Physical ContactVibrationAirLow/NoneLow/NoneLow/None

Planned Response Action O&M

Inspector

Benjamin S. Hood

State IN

LEA Name Greater Clark County School Corporation

Building Name Thomas Jefferson Elementary School

Building Number 03

HA ID 02

HA Description Pipe Insulation

HA Type Thermal System Insulation (TSI)

HA Location Tunnels

Quantity 230 LF

Comments Entrances to tunnels are restricted, as this material is in poor condition. There is

debris

all over the floor of the dirt crawl. No one should enter this area without proper

training

and protection. Clean up recommended. Scheduled for abatement in 2012/2013

renovation.

Asbestos Known

Friable Yes

Original Inspection 6/1/1992

Current Inspection 11/13/2018

Material Assessment

Assessment Rating 1 Damaged or significantly damaged thermal syste

Damage Assessment and Potential for Damage

<u>Percent Damaged</u> % Damanged - Localized

<u>Physical Contact</u> <u>Vibration</u> <u>Air</u>

High Low/None Low/None

Planned Response Action Patch and Repair

Inspector

Benjamin S. Hood

State IN Accreditation Number 19A001039

LEA Name Greater Clark County School Corporation

Building Name Thomas Jefferson Elementary School

Building Number 03

HA ID 03

HA Description Fittings

HA Type Thermal System Insulation (TSI)

HA Location Boiler room and tunnel

Quantity 48 Unit(s)

Comments Material in tunnel is in poor condition. Entry to tunnel is restricted. No one

should enter

without proper training and protection. Clean up recommended. Scheduled for

abatement in 2012/2013 renovation.

Asbestos Known

Friable Yes

Original Inspection 6/1/1992

Current Inspection 11/13/2018

Material Assessment

Assessment Rating 1 Damaged or significantly damaged thermal syste

Damage Assessment and Potential for Damage

<u>Percent Damaged</u> % Damanged - Localized

Physical Contact Vibration Air

High Low/None Low/None

Planned Response Action O&M

Inspector

Benjamin S. Hood

State IN

LEA Name Greater Clark County School Corporation

Building Name Thomas Jefferson Elementary School

Building Number 03

HA ID 05-A

HA TypeVAT-underneath carpet
Miscellaneous Material

HA Location Throughout the building (classrooms, hallways & office)

Quantity Unquantified SF

Comments Floor Tile (installed in 1994)

Asbestos Known

Friable No

Original Inspection 6/1/1992

Current Inspection 11/13/2018

Material Assessment

Assessment Rating 5 ACBM with potential for damage

Damage Assessment and Potential for Damage

Percent Damaged % Good Condition

Physical ContactVibrationAirLow/NoneLow/NoneLow/None

Planned Response Action O&M

Inspector

Benjamin S. Hood

State IN

LEA Name Greater Clark County School Corporation

Building Name Thomas Jefferson Elementary School

Building Number 03

HA ID 05-B

HA Description 12" x 12" newer off-white floor tile

HA Type Miscellaneous Material

HA Location Throughout the building (first aid office, cafeteria, workroom, water fountain

area, office

hallway, entrance, and art room)

Quantity Unquantified

Comments Minor chipping near water fountain. Overall, this material is not in poor

condition.

Asbestos Known

Friable No

Original Inspection 6/1/1992

Current Inspection 11/13/2018

Material Assessment

Assessment Rating 5 ACBM with potential for damage

Damage Assessment and Potential for Damage

Percent Damaged % Good Condition

<u>Physical Contact</u> <u>Vibration</u> <u>Air</u>

Low/None Low/None Low/None

Planned Response Action O&M

Inspector

Benjamin S. Hood

State IN

LEA Name Greater Clark County School Corporation

Building Name Thomas Jefferson Elementary School

Building Number 03

HA ID 05-C

HA Type 12" x 12" original floor tile
Miscellaneous Material

HA Location Throughout the building (gym and custodial closets).

Quantity Unquantified SF

Comments Minor chipping in closets. Overall, this material is not in poor condition.

Asbestos Known

Friable No

Original Inspection 6/1/1992

Current Inspection 11/13/2018

Material Assessment

Assessment Rating 5 ACBM with potential for damage

Damage Assessment and Potential for Damage

Percent Damaged % Good Condition

Physical ContactVibrationAirLow/NoneLow/NoneLow/None

Planned Response Action O&M

Inspector

Benjamin S. Hood

State IN

LEA Name Greater Clark County School Corporation

Building Name Thomas Jefferson Elementary School

Building Number 03

HA ID 05-D

HA Description 12" x 12" original light blue floor tile

HA Type Miscellaneous Material

HA Location Throughout the building (gym)

Quantity Unquantified SF

Comments Where visible, this material is not in poor condition.

Asbestos Known

Friable No

Original Inspection 6/1/1992

Current Inspection 11/13/2018

Material Assessment

Assessment Rating 5 ACBM with potential for damage

Damage Assessment and Potential for Damage

Percent Damaged % Good Condition

Physical ContactVibrationAirLow/NoneLow/NoneLow/None

Planned Response Action O&M

Inspector

Benjamin S. Hood

State IN

LEA Name Greater Clark County School Corporation

Building Name Thomas Jefferson Elementary School

Building Number 03

HA ID 07

HA Description Mastic

HA Type Miscellaneous Material
HA Location Throughout the building

Quantity 33750 SF

Comments This material was not visible to inspect.

Asbestos Assumed

Friable No

Original Inspection 6/1/1992

Current Inspection 11/13/2018

Material Assessment

Assessment Rating 5 ACBM with potential for damage

Damage Assessment and Potential for Damage

Percent Damaged % Good Condition

Physical ContactVibrationAirLow/NoneLow/NoneLow/None

Planned Response Action O&M

Inspector

Benjamin S. Hood

State IN

LEA Name Greater Clark County School Corporation

Building Name Thomas Jefferson Elementary School

Building Number 03

HA ID 11

HA Description Fire door-Metal cladHA Type Miscellaneous Material

HA Location Boiler room (2) Gym Exterior Doors (4)

Quantity 6 Unit(s)

Comments The fire door shell is intact with no core material visible to inspect.

Asbestos Assumed

Friable No

Original Inspection 6/1/1992

Current Inspection 11/13/2018

Material Assessment

Assessment Rating 5 ACBM with potential for damage

Damage Assessment and Potential for Damage

Percent Damaged % Good Condition

Physical ContactVibrationAirLow/NoneLow/NoneLow/None

Planned Response Action O&M

Inspector

Benjamin S. Hood

State IN

LEA Name Greater Clark County School Corporation

Building Name Thomas Jefferson Elementary School

Building Number 03

HA ID 15

HA Description Boiler gaskets

HA Type Miscellaneous Material

HA Location Boiler room

Quantity 0 Unit(s)

Comments Both boilers removed in the summer of 2018. No removal information was

provided.

Asbestos Assumed

Friable No

Original Inspection 6/1/1992

Current Inspection 11/13/2018

Material Assessment

Assessment Rating 5 ACBM with potential for damage

Damage Assessment and Potential for Damage

Percent Damaged % Good Condition

Physical ContactVibrationAirLow/NoneLow/NoneLow/None

<u>Planned Response Action</u> Removed

Inspector

Benjamin S. Hood

State IN

LEA Name Greater Clark County School Corporation

Building Name Thomas Jefferson Elementary School

Building Number 03

HAID A

HA Description Cove Base

HA Type Miscellaneous Material
HA Location Throughout the building

Quantity Approx. 3800 LF

Comments Material is not in poor condition overall with minor signs of wear. Loose and

missing in

a few locations. (installed in 1994)

Asbestos Assumed

Friable No

Original Inspection 5/31/1995

Current Inspection 11/13/2018

Material Assessment

Assessment Rating 5 ACBM with potential for damage

Damage Assessment and Potential for Damage

Percent Damaged % Good Condition

Physical ContactVibrationAirLow/NoneLow/NoneLow/None

Planned Response Action O&M

Inspector

Benjamin S. Hood

State IN

LEA Name Greater Clark County School Corporation

Building Name Thomas Jefferson Elementary School

Building Number 03

HA ID B

HA Description Cove base mastic

HA Type Miscellaneous MaterialHA Location Throughout the building

Quantity Approx. 1200 SF

Comments Mastic was visible to inspect at corner near custodial closet in the cafateria

where cove

base was missing.

Asbestos Assumed

Friable No

Original Inspection 5/31/1995

Current Inspection 11/13/2018

Material Assessment

Assessment Rating 5 ACBM with potential for damage

Damage Assessment and Potential for Damage

Percent Damaged % Good Condition

Physical ContactVibrationAirLow/NoneLow/NoneLow/None

Planned Response Action O&M

Inspector

Benjamin S. Hood

State IN

LEA Name Greater Clark County School Corporation

Building Name Thomas Jefferson Elementary School

Building Number 03

HA ID C

HA Description AHU Cloth Expansion Joints

HA Type Miscellaneous Material

HA Location Stage ends

Quantity 2 Unit(s)

Comments These were noted during the June 2011 6 month surveillance and will remain in

the

management plan until properly sampled.

Asbestos Assumed

Friable No

Original Inspection 6/27/2011

Current Inspection 11/13/2018

Material Assessment

Assessment Rating 5 ACBM with potential for damage

Damage Assessment and Potential for Damage

Percent Damaged % Good Condition

<u>Physical Contact</u> <u>Vibration</u> <u>Air</u>

Low/None Low/None Low/None

Planned Response Action O&M

Inspector

Benjamin S. Hood

State IN

LEA Name Greater Clark County School Corporation

Thomas Jefferson Elementary School **Building Name**

Building Number 03

HAID D

HA Description Fire Doors-Original to building (wooden)

HA Type Miscellaneous Material

Gym & throughout the building **HA Location**

Quantity Unquantified Unit(s)

Comments These were noted during the June 2011 6 month surveillance and will remain in

management plan until properly sampled.

Asbestos Assumed

Friable No

Original Inspection 6/27/2011 **Current Inspection** 11/13/2018

Material Assessment

Assessment Rating 5 ACBM with potential for damage

Damage Assessment and Potential for Damage

% **Percent Damaged Good Condition**

> **Physical Contact Vibration** <u>Air</u> Low/None Low/None Low/None

Planned Response Action 0&M

Inspector

Benjamin S. Hood

State IN

LEA Name Greater Clark County School Corporation

Building Name Thomas Jefferson Elementary School

Building Number 03

HAID E

HA Description Gray Sink InsulationHA Type Miscellaneous Material

HA Location Classrooms, Art Room & Teachers Lounge

Quantity Unquantified LF

Comments This was noted during the June 2011 6 month surveillance and will remain in the

management plan until properly sampled.

Asbestos Assumed

Friable No

Original Inspection 6/27/2011

Current Inspection 11/13/2018

Material Assessment

Assessment Rating 5 ACBM with potential for damage

Damage Assessment and Potential for Damage

Percent Damaged % Good Condition

Physical ContactVibrationAirLow/NoneLow/NoneLow/None

Planned Response Action O&M

Inspector

Benjamin S. Hood

State IN

LEA Name Greater Clark County School Corporation Building Name Thomas Jefferson Elementary School **Building Number** 03 **HAID** F **HA Description** Pipe Insulation **HA Type** Thermal System Insulation (TSI) Storage Rooms Near Crawlspace Tunnel Access **HA Location** Quantity N/A LF Comments This material was noted by the licensed inspector during the April 2015 6 month inspection. A tear (less than 1 LF) in a four inch line was noted during the inspection with a small amount of debris (less than 1 LF) was noted below the damaged pipe insulation. The debris should be cleaned up and the pipe repaired as soon as possible. Multiple open exposed spots on the line with damage. Overall material is not in poor condition. Asbestos **Assumed** Friable Yes Original Inspection 4/22/2015 **Current Inspection** 11/13/2018 **Material Assessment Assessment Rating** 1 Damaged or significantly damaged thermal syste Damage Assessment and Potential for Damage **Percent Damaged** Damanged - Localized % **Physical Contact Vibration** Air Medium Low/None Low/None **Planned Response Action** Patch and Repair

Inspector

Benjamin S. Hood

State IN

LEA Name Greater Clark County School Corporation

Building Name Thomas Jefferson Elementary School

Building Number 03

HA ID 01

HA Description Pipe Insulation

HA Type Thermal System Insulation (TSI)

HA Location Boiler room

Quantity 10 LF

Comments This material was not in poor condition along east wall near east boiler by

tunnel entry.

Scheduled for abatement in 2012/2013 renovation.

Asbestos Known

Friable No

Original Inspection 6/1/1992

Current Inspection 5/2/2018

Material Assessment

Assessment Rating 5 ACBM with potential for damage

Damage Assessment and Potential for Damage

Percent Damaged % Good Condition

Physical ContactVibrationAirLow/NoneLow/NoneLow/None

Planned Response Action O&M

Inspector

Benjamin S. Hood

State IN

LEA Name Greater Clark County School Corporation

Building Name Thomas Jefferson Elementary School

Building Number 03

HA ID 02

HA Description Pipe Insulation

HA Type Thermal System Insulation (TSI)

HA Location Tunnels

Quantity 230 LF

Comments Entrances to tunnels are restricted, as this material is in poor condition. There is

debris

all over the floor of the dirt crawl. No one should enter this area without proper

training

and protection. Clean up recommended. Scheduled for abatement in 2012/2013

renovation.

Asbestos Known

Friable Yes

Original Inspection 6/1/1992

Current Inspection 5/2/2018

Material Assessment

Assessment Rating 1 Damaged or significantly damaged thermal syste

Damage Assessment and Potential for Damage

<u>Percent Damaged</u> % Damanged - Localized

Physical Contact Vibration Air

High Low/None Low/None

<u>Planned Response Action</u> Patch and Repair

Inspector

Benjamin S. Hood

State IN Accreditation Number 19A001039

LEA Name Greater Clark County School Corporation

Building Name Thomas Jefferson Elementary School

Building Number 03

HA ID 03

HA Description Fittings

HA Type Thermal System Insulation (TSI)

HA Location Boiler room and tunnel

Quantity 48 Unit(s)

Comments Material in tunnel is in poor condition. Entry to tunnel is restricted. No one

should enter

without proper training and protection. Clean up recommended. Scheduled for

abatement in 2012/2013 renovation.

Asbestos Known

Friable Yes

Original Inspection 6/1/1992

Current Inspection 5/2/2018

Material Assessment

Assessment Rating 1 Damaged or significantly damaged thermal syste

Damage Assessment and Potential for Damage

Percent Damaged % Damanged - Localized

Physical Contact Vibration Air

High Low/None Low/None

Planned Response Action O&M

Inspector

Benjamin S. Hood

State IN

LEA Name Greater Clark County School Corporation

Building Name Thomas Jefferson Elementary School

Building Number 03

HA ID 05-A

HA Type VAT-underneath carpet Miscellaneous Material

HA Location Throughout the building (classrooms, hallways & office)

Quantity Unquantified SF

Comments Floor Tile (installed in 1994)

Asbestos Known

Friable No

Original Inspection 6/1/1992

Current Inspection 5/2/2018

Material Assessment

Assessment Rating 5 ACBM with potential for damage

Damage Assessment and Potential for Damage

Percent Damaged % Good Condition

Physical ContactVibrationAirLow/NoneLow/NoneLow/None

Planned Response Action O&M

Inspector

Benjamin S. Hood

State IN

LEA Name Greater Clark County School Corporation

Building Name Thomas Jefferson Elementary School

Building Number 03

HA ID 05-B

HA Description 12" x 12" newer off-white floor tile

HA Type Miscellaneous Material

HA Location Throughout the building (first aid office, cafeteria, workroom, water fountain

SF

area, office

hallway, entrance, and art room)

Quantity Unquantified

Comments Minor chipping near water fountain. Overall, this material is not in poor

condition.

Asbestos Known

Friable No

Original Inspection 6/1/1992

Current Inspection 5/2/2018

Material Assessment

Assessment Rating 5 ACBM with potential for damage

Damage Assessment and Potential for Damage

Percent Damaged % Good Condition

Physical ContactVibrationAirLow/NoneLow/NoneLow/None

Planned Response Action O&M

Inspector

Benjamin S. Hood

State IN

LEA Name Greater Clark County School Corporation

Building Name Thomas Jefferson Elementary School

Building Number 03

HA ID 05-C

HA Type 12" x 12" original floor tile
Miscellaneous Material

HA Location Throughout the building (gym and custodial closets).

Quantity Unquantified SF

Comments Minor chipping in closets. Overall, this material is not in poor condition.

Asbestos Known

Friable No

Original Inspection 6/1/1992

Current Inspection 5/2/2018

Material Assessment

Assessment Rating 5 ACBM with potential for damage

Damage Assessment and Potential for Damage

Percent Damaged % Good Condition

Physical ContactVibrationAirLow/NoneLow/NoneLow/None

Planned Response Action O&M

Inspector

Benjamin S. Hood

State IN

LEA Name Greater Clark County School Corporation

Building Name Thomas Jefferson Elementary School

Building Number 03

HA ID 05-D

HA Description 12" x 12" original light blue floor tile

HA Type Miscellaneous Material

HA Location Throughout the building (gym)

Quantity Unquantified SF

Comments Where visible, this material is not in poor condition.

Asbestos Known

Friable No

Original Inspection 6/1/1992

Current Inspection 5/2/2018

Material Assessment

Assessment Rating 5 ACBM with potential for damage

Damage Assessment and Potential for Damage

Percent Damaged % Good Condition

Physical ContactVibrationAirLow/NoneLow/NoneLow/None

Planned Response Action O&M

Inspector

Benjamin S. Hood

State IN

LEA Name Greater Clark County School Corporation

Building Name Thomas Jefferson Elementary School

Building Number 03

HA ID 07

HA Description Mastic

HA Type Miscellaneous Material

HA Location Throughout the building

Quantity 33750 SF

Comments This material was not visible to inspect.

Asbestos Assumed

Friable No

Original Inspection 6/1/1992

Current Inspection 5/2/2018

Material Assessment

Assessment Rating 5 ACBM with potential for damage

Damage Assessment and Potential for Damage

Percent Damaged % Good Condition

Physical ContactVibrationAirLow/NoneLow/NoneLow/None

Planned Response Action O&M

Inspector

Benjamin S. Hood

State IN

LEA Name Greater Clark County School Corporation

Building Name Thomas Jefferson Elementary School

Building Number 03

HA ID 11

HA Description Fire door-Metal cladHA Type Miscellaneous Material

HA Location Boiler room (2) Gym Exterior Doors (4)

Quantity 6 Unit(s)

Comments The fire door shell is intact with no core material visible to inspect.

Asbestos Assumed

Friable No

Original Inspection 6/1/1992

Current Inspection 5/2/2018

Material Assessment

Assessment Rating 5 ACBM with potential for damage

Damage Assessment and Potential for Damage

Percent Damaged % Good Condition

Physical ContactVibrationAirLow/NoneLow/NoneLow/None

Planned Response Action O&M

Inspector

Benjamin S. Hood

State IN

LEA Name Greater Clark County School Corporation

Building Name Thomas Jefferson Elementary School

Building Number 03

HA ID 15

HA Description Boiler gaskets

HA Type Miscellaneous Material

HA Location Boiler room

Quantity 2 Unit(s)

Comments Boiler doors were closed. The visible edges of this material were not in poor

condition.

There is some fiberglass rope visible, but also some older looking gasket

material.

Asbestos Assumed

Friable No

Original Inspection 6/1/1992

Current Inspection 5/2/2018

Material Assessment

Assessment Rating 5 ACBM with potential for damage

Damage Assessment and Potential for Damage

Percent Damaged % Good Condition

Physical ContactVibrationAirLow/NoneLow/NoneLow/None

Planned Response Action O&M

Inspector

Benjamin S. Hood

State IN

Greater Clark County School Corporation

Building Name Thomas Jefferson Elementary School **Building Number** 03 **HAID** Α **HA Description** Cove Base **HA Type** Miscellaneous Material Throughout the building **HA Location** Quantity Approx. 3800 LF Comments Material is not in poor condition overall with minor signs of wear. Loose and missing in a few locations. (installed in 1994) **Asbestos** Assumed **Friable** No **Original Inspection** 5/31/1995 **Current Inspection** 5/2/2018 **Material Assessment Assessment Rating** 5 ACBM with potential for damage **Damage Assessment and Potential for Damage Good Condition Percent Damaged** % **Physical Contact** Vibration <u>Air</u> Low/None Low/None Low/None **Planned Response Action** 0&M

State IN

Benjamin S. Hood

Accreditation Number 19A001039

Inspector

LEA Name

LEA Name Greater Clark County School Corporation

Building Name Thomas Jefferson Elementary School

Building Number 03

HA ID B

HA Description Cove base mastic

HA Type Miscellaneous Material

HA Location Throughout the building

Quantity Approx. 1200 SF

Comments Mastic was visible to inspect at corner near custodial closet in the cafateria

where cove

base was missing.

Asbestos Assumed

Friable No

Original Inspection 5/31/1995

Current Inspection 5/2/2018

Material Assessment

Assessment Rating 5 ACBM with potential for damage

Damage Assessment and Potential for Damage

Percent Damaged % Good Condition

 Physical Contact
 Vibration
 Air

 Low/None
 Low/None
 Low/None

Planned Response Action O&M

Inspector

Benjamin S. Hood

State IN

LEA Name Greater Clark County School Corporation

Building Name Thomas Jefferson Elementary School

Building Number 03

HA ID C

HA Type AHU Cloth Expansion Joints

HA Type Miscellaneous Material

HA Location Stage ends

Quantity 2 Unit(s)

Comments These were noted during the June 2011 6 month surveillance and will remain in

the

management plan until properly sampled.

Asbestos Assumed

Friable No

Original Inspection 6/27/2011

Current Inspection 5/2/2018

Material Assessment

Assessment Rating 5 ACBM with potential for damage

Damage Assessment and Potential for Damage

Percent Damaged % Good Condition

 Physical Contact
 Vibration
 Air

 Low/None
 Low/None
 Low/None

Planned Response Action O&M

Inspector

Benjamin S. Hood

State IN

LEA Name Greater Clark County School Corporation

Building Name Thomas Jefferson Elementary School

Building Number 03

HA ID D

HA Description Fire Doors-Original to building (wooden)

HA Type Miscellaneous Material

HA Location Gym & throughout the building

Quantity Unquantified Unit(s)

Comments These were noted during the June 2011 6 month surveillance and will remain in

the

management plan until properly sampled.

Asbestos Assumed

Friable No

Original Inspection 6/27/2011

Current Inspection 5/2/2018

Material Assessment

Assessment Rating 5 ACBM with potential for damage

Damage Assessment and Potential for Damage

Percent Damaged % Good Condition

 Physical Contact
 Vibration
 Air

 Low/None
 Low/None
 Low/None

Planned Response Action O&M

Inspector

Benjamin S. Hood

State IN

LEA Name Greater Clark County School Corporation

Building Name Thomas Jefferson Elementary School

Building Number 03

HA ID E

HA Description Gray Sink InsulationHA Type Miscellaneous Material

HA Location Classrooms, Art Room & Teachers Lounge

Quantity Unquantified LF

Comments This was noted during the June 2011 6 month surveillance and will remain in the

management plan until properly sampled.

Asbestos Assumed

Friable No

Original Inspection 6/27/2011

Current Inspection 5/2/2018

Material Assessment

Assessment Rating 5 ACBM with potential for damage

Damage Assessment and Potential for Damage

Percent Damaged % Good Condition

Physical ContactVibrationAirLow/NoneLow/NoneLow/None

Planned Response Action O&M

Inspector

Benjamin S. Hood

State IN

LEA Name Greater Clark County School Corporation Building Name Thomas Jefferson Elementary School **Building Number** 03 HA ID F **HA Description** Pipe Insulation **HA Type** Thermal System Insulation (TSI) Storage Rooms Near Crawlspace Tunnel Access **HA Location** Quantity N/A LF Comments This material was noted by the licensed inspector during the April 2015 6 month inspection. A tear (less than 1 LF) in a four inch line was noted during the inspection with a small amount of debris (less than 1 LF) was noted below the damaged pipe insulation. The debris should be cleaned up and the pipe repaired as soon as possible. Multiple open exposed spots on the line with damage. Overall material is not in poor condition. Asbestos Assumed Friable Yes Original Inspection 4/22/2015 **Current Inspection** 5/2/2018 **Material Assessment Assessment Rating** 1 Damaged or significantly damaged thermal syste **Damage Assessment and Potential for Damage Percent Damaged** % Damanged - Localized **Physical Contact** Vibration Air Low/None Medium Low/None **Planned Response Action** Patch and Repair

Inspector

Benjamin S. Hood

State IN

LEA Name Greater Clark County School Corporation Thomas Jefferson Elementary School **Building Name Building Number** 03 **HAID** 01 **HA Description** Pipe Insulation **HA Type** Thermal System Insulation (TSI) Boiler room **HA Location** Quantity 10 LF Comments This material was not in poor condition along east wall near east boiler by tunnel entry. Scheduled for abatement in 2012/2013 renovation. **Asbestos** Known Friable No **Original Inspection** 6/1/1992 **Current Inspection** 10/18/2017 **Material Assessment Assessment Rating** 5 ACBM with potential for damage **Damage Assessment and Potential for Damage Percent Damaged** % **Good Condition Physical Contact Vibration** <u>Air</u> Low/None Low/None Low/None **Planned Response Action 0&M** Inspector **Dustin Hawkins** State IN

LEA Name Greater Clark County School Corporation Thomas Jefferson Elementary School **Building Name Building Number** 03 **HAID** 02 **HA Description** Pipe Insulation **HA Type** Thermal System Insulation (TSI) **Tunnels HA Location** Quantity 230 LF Comments Entrances to tunnels are restricted, as this material is in poor condition. There is all over the floor of the dirt crawl. No one should enter this area without proper training and protection. Clean up recommended. Scheduled for abatement in 2012/2013 renovation. **Asbestos** Known Friable Yes **Original Inspection** 6/1/1992 **Current Inspection** 10/18/2017 **Material Assessment** 1 Damaged or significantly damaged thermal syste **Assessment Rating Damage Assessment and Potential for Damage Percent Damaged** % Damanged - Localized **Physical Contact** Vibration <u>Air</u> Low/None High Low/None **Planned Response Action** Patch and Repair Inspector

Dustin Hawkins

State IN Accreditation Number 19A007194

LEA Name Greater Clark County School Corporation Thomas Jefferson Elementary School **Building Name Building Number** 03 HA ID 03 **HA Description Fittings HA Type** Thermal System Insulation (TSI) Boiler room and tunnel **HA Location** Quantity 48 Unit(s) Comments Material in tunnel is in poor condition. Entry to tunnel is restricted. No one should enter without proper training and protection. Clean up recommended. Scheduled for abatement in 2012/2013 renovation. **Asbestos** Known Friable Yes Original Inspection 6/1/1992 **Current Inspection** 10/18/2017 **Material Assessment Assessment Rating** 1 Damaged or significantly damaged thermal syste **Damage Assessment and Potential for Damage Percent Damaged** % Damanged - Localized **Physical Contact Vibration** Air High Low/None Low/None **Planned Response Action 0&M** Inspector **Dustin Hawkins**

Accreditation Number 19A007194

State IN

LEA Name Greater Clark County School Corporation Building Name Thomas Jefferson Elementary School **Building Number** 03 **HAID** 05-A **HA Description** VAT-underneath carpet **HA Type** Miscellaneous Material Throughout the building (classrooms, hallways & office) **HA Location** Quantity Unquantified SF Comments Floor Tile (installed in 1994) **Asbestos** Known Friable No Original Inspection 6/1/1992 **Current Inspection** 10/18/2017 **Material Assessment Assessment Rating** 5 ACBM with potential for damage **Damage Assessment and Potential for Damage Percent Damaged** % **Good Condition Physical Contact** Vibration Air Low/None Low/None Low/None **Planned Response Action 0&M** Inspector **Dustin Hawkins**

State IN

LEA Name Greater Clark County School Corporation Thomas Jefferson Elementary School **Building Name Building Number** 03 HA ID 05-B 12" x 12" newer off-white floor tile **HA Description HA Type** Miscellaneous Material Throughout the building (first aid office, cafeteria, workroom, water fountain **HA Location** area, office hallway, entrance, and art room) Quantity Unquantified SF Comments Minor chipping near water fountain. Overall, this material is not in poor condition. **Asbestos** Known Friable No **Original Inspection** 6/1/1992 **Current Inspection** 10/18/2017 **Material Assessment Assessment Rating** 5 ACBM with potential for damage **Damage Assessment and Potential for Damage Percent Damaged** % **Good Condition Physical Contact** Vibration <u>Air</u> Low/None Low/None Low/None **Planned Response Action** 0&M Inspector **Dustin Hawkins**

State IN

LEA Name	Greater Clark County School Corporation							
Building Name	Thomas Jefferson Elementary School							
Building Number	03							
HA ID	05-C							
HA Description	12" x 12" original floor tile							
НА Туре	Miscellaneous Material							
HA Location	Throughout the building (gym and custodial closets).							
Quantity	Unquantified	SF						
Comments	Minor chipping in closets. Overall, this material is not in poor condition.							
Asbestos	Known							
Friable	No							
Original Inspection	6/1/1992							
Current Inspection	10/18/2017							
Material Assessment								
Assessment Rating 5 ACBM with potential for damage								
Damage Assessment and Potential for Damage								
Percent Damag	<u>ed</u> %	Good Condition						
Physical Contact		<u>Vibration</u>	<u>Air</u>					
Low/None		Low/None	Low/None					
<u>Planned</u>	Response Actio	<u>n</u> O&M						
D-AA-C								
Inspector	× ·							
	Dustin Ha	awkins						

State IN

LEA Name Greater Clark County School Corporation Thomas Jefferson Elementary School **Building Name Building Number** 03 **HAID** 05-D 12" x 12" original light blue floor tile **HA Description HA Type** Miscellaneous Material Throughout the building (gym) **HA Location** Quantity Unquantified SF Comments Where visible, this material is not in poor condition. **Asbestos** Known **Friable** No **Original Inspection** 6/1/1992 **Current Inspection** 10/18/2017 **Material Assessment Assessment Rating** 5 ACBM with potential for damage **Damage Assessment and Potential for Damage Percent Damaged Good Condition Physical Contact** Vibration <u>Air</u> Low/None Low/None Low/None **Planned Response Action 0&M** Inspector **Dustin Hawkins**

State IN

Greater Clark County School Corporation LEA Name Building Name Thomas Jefferson Elementary School **Building Number** 03 **HAID** 07 **HA Description** Mastic **HA Type** Miscellaneous Material Throughout the building **HA Location** Quantity 33750 SF Comments This material was not visible to inspect. **Asbestos** Assumed **Friable** No **Original Inspection** 6/1/1992 **Current Inspection** 10/18/2017 **Material Assessment Assessment Rating** 5 ACBM with potential for damage **Damage Assessment and Potential for Damage Percent Damaged** % **Good Condition Physical Contact** Vibration <u>Air</u> Low/None Low/None Low/None **Planned Response Action** 0&M Inspector **Dustin Hawkins**

State IN

LEA Name Greater Clark County School Corporation Thomas Jefferson Elementary School **Building Name Building Number** 03 **HAID** 11 **HA Description** Fire door-Metal clad **HA Type** Miscellaneous Material Boiler room (2) Gym Exterior Doors (4) **HA Location** Quantity 6 Unit(s) Comments The fire door shell is intact with no core material visible to inspect. **Asbestos** Assumed **Friable** No **Original Inspection** 6/1/1992 **Current Inspection** 10/18/2017 **Material Assessment Assessment Rating** 5 ACBM with potential for damage **Damage Assessment and Potential for Damage Percent Damaged** % **Good Condition Physical Contact** Vibration <u>Air</u> Low/None Low/None Low/None **Planned Response Action 0&M** Inspector **Dustin Hawkins**

State IN Accreditation Number 19A007194

LEA Name Greater Clark County School Corporation Thomas Jefferson Elementary School **Building Name Building Number** 03 **HAID** 15 **HA Description Boiler** gaskets **HA Type** Miscellaneous Material Boiler room **HA Location** Quantity 2 Unit(s) Comments Boiler doors were closed. The visible edges of this material were not in poor There is some fiberglass rope visible, but also some older looking gasket material. **Asbestos** Assumed Friable No Original Inspection 6/1/1992 **Current Inspection** 10/18/2017 **Material Assessment Assessment Rating** 5 ACBM with potential for damage **Damage Assessment and Potential for Damage Percent Damaged** % **Good Condition Physical Contact** Vibration <u>Air</u> Low/None Low/None Low/None **Planned Response Action 0&M** Inspector **Dustin Hawkins**

State IN

LEA Name Greater Clark County School Corporation Building Name Thomas Jefferson Elementary School **Building Number** 03 **HAID** Α **HA Description** Cove Base **HA Type** Miscellaneous Material Throughout the building **HA Location** Quantity Approx. 3800 LF Comments Material is not in poor condition overall with minor signs of wear. Loose and missing in a few locations. (installed in 1994) **Asbestos** Assumed **Friable** No **Original Inspection** 5/31/1995 **Current Inspection** 10/18/2017 **Material Assessment Assessment Rating** 5 ACBM with potential for damage **Damage Assessment and Potential for Damage Good Condition Percent Damaged** % **Physical Contact** Vibration <u>Air</u> Low/None Low/None Low/None **Planned Response Action** 0&M Inspector **Dustin Hawkins** State IN

LEA Name Greater Clark County School Corporation Thomas Jefferson Elementary School **Building Name Building Number** 03 **HAID** В **HA Description** Cove base mastic **HA Type** Miscellaneous Material Throughout the building **HA Location** Approx. 1200 Quantity SF Comments Mastic was visible to inspect at corner near custodial closet in the cafateria where cove base was missing. **Asbestos** Assumed Friable No **Original Inspection** 5/31/1995 **Current Inspection** 10/18/2017 **Material Assessment Assessment Rating** 5 ACBM with potential for damage **Damage Assessment and Potential for Damage Percent Damaged** % **Good Condition Physical Contact Vibration** <u>Air</u> Low/None Low/None Low/None **Planned Response Action 0&M** Inspector **Dustin Hawkins**

State IN

LEA Name	Greater Clark County School Corporation					
Building Name	Thomas Jefferson Elementary School					
Building Number	03					
HA ID	С					
HA Description	AHU Cloth Exp	ansion Joints				
НА Туре	Miscellaneous Material					
HA Location	Stage ends					
Quantity	2	Unit(s)				
Comments	These were noted during the June 2011 6 month surveillance and will remain in the management plan until properly sampled.					
Asbestos	Assumed					
Friable	No					
Original Inspection	6/27/2011					
Current Inspection	10/18/2017					
		Material Assessmen	<u>nt</u>			
	ment Rating	5 ACBM with potential fo	r damage			
<u>Da</u>	image Asso	essment and Potent	iai for Damage			
Percent Damag	<u>ed</u> %	Good Condition				
<u>Phy</u>	sical Contact	<u>Vibration</u>	<u>Air</u>			
L	ow/None	Low/None	Low/None			
<u>Planned</u>	Response Action	on O&M				
Inspector	Dustin H	awkins				

State IN

LEA Name Greater Clark County School Corporation Thomas Jefferson Elementary School **Building Name Building Number** 03 HA ID D **HA Description** Fire Doors-Original to building (wooden) **HA Type** Miscellaneous Material Gym & throughout the building **HA Location** Quantity Unquantified Unit(s) Comments These were noted during the June 2011 6 month surveillance and will remain in management plan until properly sampled. **Asbestos** Assumed Friable No **Original Inspection** 6/27/2011 **Current Inspection** 10/18/2017 **Material Assessment Assessment Rating** 5 ACBM with potential for damage **Damage Assessment and Potential for Damage** % **Percent Damaged Good Condition Physical Contact Vibration** <u>Air</u> Low/None Low/None Low/None **Planned Response Action 0&M** Inspector **Dustin Hawkins**

State IN

LEA Name	Greater Clark County School Corporation							
Building Name	Thomas Jefferson Elementary School							
Building Number	03							
HA ID	E	E						
HA Description	Gray Sink Insul	ation						
НА Туре	Miscellaneous	Miscellaneous Material						
HA Location	Classrooms, Ar	Classrooms, Art Room & Teachers Lounge						
Quantity	Unquantified		LF					
Comments	This was noted during the June 2011 6 month surveillance and will remain in the management plan until properly sampled.							
Asbestos	Assumed							
Friable	No							
Original Inspection	6/27/2011							
Current Inspection	10/18/2017							
Material Assessment								
Assess	5 ACBM with	5 ACBM with potential for damage						
<u>Da</u>	amage Asse	essment an	d Potentia	al for Damage				
Percent Damag	<u>ed</u> %	Good Conditio	n					
<u>Phy</u>	vsical Contact	<u>Vibra</u>	<u>ition</u>	<u>Air</u>				
I	Low/None	Low/I	None	Low/None				
Planned Response Action O&M								
2 stale								
Inspector								
Dustin Hawkins								

State IN

LEA Name Greater Clark County School Corporation Building Name Thomas Jefferson Elementary School **Building Number** 03 HA ID F **HA Description** Pipe Insulation **HA Type** Thermal System Insulation (TSI) Storage Rooms Near Crawlspace Tunnel Access **HA Location** Quantity N/A LF Comments This material was noted by the licensed inspector during the April 2015 6 month inspection. A tear (less than 1 LF) in a four inch line was noted during the inspection with a small amount of debris (less than 1 LF) was noted below the damaged pipe insulation. The debris should be cleaned up and the pipe repaired as soon as possible. Multiple open exposed spots on the line with damage. Overall material is not in poor condition. Asbestos Assumed Friable Yes Original Inspection 4/22/2015 **Current Inspection** 10/18/2017 **Material Assessment Assessment Rating** 1 Damaged or significantly damaged thermal syste **Damage Assessment and Potential for Damage Percent Damaged** % Damanged - Localized **Physical Contact** Vibration Air Low/None Medium Low/None **Planned Response Action** Patch and Repair

Inspector

Dustin Hawkins

State IN

Greater Clark County School Corporation

LEA Name

Thomas Jefferson Elementary School **Building Name Building Number** 03 **HAID** 01 **HA Description** Pipe Insulation **HA Type** Thermal System Insulation (TSI) Boiler room **HA Location** Quantity 10 LF Comments This material was not in poor condition along east wall near east boiler by tunnel entry. Scheduled for abatement in 2012/2013 renovation. **Asbestos** Known Friable No **Original Inspection** 6/1/1992 **Current Inspection** 4/13/2017 **Material Assessment Assessment Rating** 5 ACBM with potential for damage **Damage Assessment and Potential for Damage Percent Damaged** % **Good Condition Physical Contact Vibration** <u>Air</u> Low/None Low/None Low/None **Planned Response Action 0&M** Janie Attoin Inspector Jamie Hosier

State Indiana

LEA Name Greater Clark County School Corporation Thomas Jefferson Elementary School **Building Name Building Number** 03 **HAID** 02 **HA Description** Pipe Insulation **HA Type** Thermal System Insulation (TSI) **Tunnels HA Location** Quantity 230 LF Comments Entrances to tunnels are restricted, as this material is in poor condition. There is all over the floor of the dirt crawl. No one should enter this area without proper training and protection. Clean up recommended. Scheduled for abatement in 2012/2013 renovation. **Asbestos** Known Friable Yes Original Inspection 6/1/1992 **Current Inspection** 4/13/2017 **Material Assessment** 1 Damaged or significantly damaged thermal syste **Assessment Rating Damage Assessment and Potential for Damage Percent Damaged** % Damanged - Localized **Physical Contact** Vibration <u>Air</u> Low/None High Low/None **Planned Response Action** Patch and Repair Janie XHoin

Inspector

Jamie Hosier

State Indiana **Accreditation Number** 19A007179

LEA Name Greater Clark County School Corporation

Thomas Jefferson Elementary School **Building Name**

Building Number 03

HAID 03

HA Description Fittings

HA Type Thermal System Insulation (TSI)

Boiler room and tunnel **HA Location**

Quantity 48 Unit(s)

Comments Material in tunnel is in poor condition. Entry to tunnel is restricted. No one

should enter

without proper training and protection. Clean up recommended. Scheduled for

abatement in 2012/2013 renovation.

Asbestos Known

Friable Yes

Original Inspection 6/1/1992 **Current Inspection** 4/13/2017

Material Assessment

Assessment Rating 1 Damaged or significantly damaged thermal syste

Damage Assessment and Potential for Damage

Percent Damaged % Damanged - Localized

> **Physical Contact Vibration** <u>Air</u> High Low/None Low/None

Planned Response Action 0&M

Janua XHosin Inspector

Jamie Hosier

State Indiana Accreditation Number 19A007179

LEA Name Greater Clark County School Corporation

Building Name Thomas Jefferson Elementary School

Building Number 03

HAID 05-A

HA Description VAT-underneath carpet **HA Type** Miscellaneous Material

Throughout the building (classrooms, hallways & office) **HA Location**

Quantity Unquantified SF

Comments Floor Tile (installed in 1994)

Asbestos Known

Friable No

Original Inspection 6/1/1992 **Current Inspection** 4/13/2017

Material Assessment

Assessment Rating 5 ACBM with potential for damage

Damage Assessment and Potential for Damage

Percent Damaged % **Good Condition**

> **Physical Contact** Vibration Air Low/None Low/None Low/None

Planned Response Action 0&M

Janie AHoin Inspector Jamie Hosier

State Indiana **Accreditation Number** 19A007179

LEA Name Greater Clark County School Corporation

Building Name Thomas Jefferson Elementary School

Building Number 03

HA ID 05-B

HA Description 12" x 12" newer off-white floor tile

HA Type Miscellaneous Material

HA Location Throughout the building (first aid office, cafeteria, workroom, water fountain

area, office

hallway, entrance, and art room)

Quantity Unquantified SF

Comments Minor chipping near water fountain. Overall, this material is not in poor

condition.

Asbestos Known

Friable No

Original Inspection 6/1/1992

Current Inspection 4/13/2017

Material Assessment

Assessment Rating 5 ACBM with potential for damage

Damage Assessment and Potential for Damage

Percent Damaged % Good Condition

Physical ContactVibrationAirLow/NoneLow/NoneLow/None

Planned Response Action O&M



State Indiana

Julille 110310

LEA Name Greater Clark County School Corporation

Building Name Thomas Jefferson Elementary School

Building Number 03

HA ID 05-C

HA Description 12" x 12" original floor tileHA Type Miscellaneous Material

HA Location Throughout the building (gym and custodial closets).

Quantity Unquantified SF

Comments Minor chipping in closets. Overall, this material is not in poor condition.

Asbestos Known

Friable No

Original Inspection 6/1/1992

Current Inspection 4/13/2017

Material Assessment

Assessment Rating 5 ACBM with potential for damage

Damage Assessment and Potential for Damage

Percent Damaged % Good Condition

Physical ContactVibrationAirLow/NoneLow/NoneLow/None

Planned Response Action O&M

Inspector

Jamie Hosier

State Indiana

LEA Name Greater Clark County School Corporation Thomas Jefferson Elementary School **Building Name Building Number** 03 **HAID** 05-D 12" x 12" original light blue floor tile **HA Description HA Type** Miscellaneous Material Throughout the building (gym) **HA Location** Quantity Unquantified SF Comments Where visible, this material is not in poor condition. **Asbestos** Known **Friable** No **Original Inspection** 6/1/1992 **Current Inspection** 4/13/2017 **Material Assessment**

Assessment Rating 5 ACBM with potential for damage

Damage Assessment and Potential for Damage

Percent Damaged % Good Condition

Physical ContactVibrationAirLow/NoneLow/NoneLow/None

Planned Response Action O&M

Inspector

Jamie Hosier

State Indiana

Greater Clark County School Corporation LEA Name Thomas Jefferson Elementary School **Building Name Building Number** 03 **HAID** 07 **HA Description** Mastic **HA Type** Miscellaneous Material Throughout the building **HA Location** Quantity 33750 SF Comments This material was not visible to inspect. **Asbestos** Assumed **Friable** No **Original Inspection** 6/1/1992 **Current Inspection** 4/13/2017 **Material Assessment Assessment Rating** 5 ACBM with potential for damage **Damage Assessment and Potential for Damage Percent Damaged Good Condition Physical Contact** Vibration <u>Air</u> Low/None Low/None Low/None **Planned Response Action** 0&M

Jamie Hosier

Janie Attoin

State Indiana
Accreditation Number 19A007179

Inspector

LEA Name Greater Clark County School Corporation Thomas Jefferson Elementary School **Building Name Building Number** 03 **HAID** 11 **HA Description** Fire door-Metal clad **HA Type** Miscellaneous Material Boiler room (2) Gym Exterior Doors (4) **HA Location** Quantity 6 Unit(s) Comments The fire door shell is intact with no core material visible to inspect. **Asbestos** Assumed **Friable** No **Original Inspection** 6/1/1992 **Current Inspection** 4/13/2017 **Material Assessment Assessment Rating** 5 ACBM with potential for damage **Damage Assessment and Potential for Damage Percent Damaged Good Condition Physical Contact** Vibration <u>Air</u> Low/None Low/None Low/None **Planned Response Action** 0&M Janie Attoin Inspector

Jamie Hosier

State Indiana

LEA Name Greater Clark County School Corporation

Thomas Jefferson Elementary School **Building Name**

Building Number 03

HAID 15

HA Description Boiler gaskets

HA Type Miscellaneous Material

Boiler room **HA Location**

Quantity 2 Unit(s)

Comments Boiler doors were closed. The visible edges of this material were not in poor

There is some fiberglass rope visible, but also some older looking gasket

material.

Asbestos Assumed

Friable No

Original Inspection 6/1/1992 **Current Inspection** 4/13/2017

Material Assessment

Assessment Rating 5 ACBM with potential for damage

Damage Assessment and Potential for Damage

Percent Damaged % **Good Condition**

> **Physical Contact** Vibration <u>Air</u> Low/None Low/None Low/None

Planned Response Action 0&M

Janua XHosin Inspector Jamie Hosier

State Indiana Accreditation Number 19A007179

Greater Clark County School Corporation

Building Name Thomas Jefferson Elementary School **Building Number** 03 **HAID** Α **HA Description** Cove Base **HA Type** Miscellaneous Material Throughout the building **HA Location** Quantity Approx. 3800 LF Comments Material is not in poor condition overall with minor signs of wear. Loose and missing in a few locations. (installed in 1994) **Asbestos** Assumed **Friable** No **Original Inspection** 5/31/1995 **Current Inspection** 4/13/2017 **Material Assessment Assessment Rating** 5 ACBM with potential for damage **Damage Assessment and Potential for Damage Good Condition Percent Damaged** % **Physical Contact Vibration** <u>Air</u> Low/None Low/None Low/None **Planned Response Action** 0&M Janie Stolow Inspector

State Indiana
Accreditation Number 19A007179

Jamie Hosier

LEA Name

Greater Clark County School Corporation

Thomas Jefferson Elementary School

LEA Name

Building Name

Building Number

03

State Indiana

Accreditation Number 19A007179

HAID В **HA Description** Cove base mastic **HA Type** Miscellaneous Material Throughout the building **HA Location** Quantity Approx. 1200 SF **Comments** Mastic was visible to inspect at corner near custodial closet in the cafateria where cove base was missing. **Asbestos** Assumed Friable No Original Inspection 5/31/1995 **Current Inspection** 4/13/2017 **Material Assessment Assessment Rating** 5 ACBM with potential for damage **Damage Assessment and Potential for Damage Percent Damaged** % **Good Condition Physical Contact Vibration** <u>Air</u> Low/None Low/None Low/None **Planned Response Action 0&M** Janie Attoin Inspector Jamie Hosier

Greater Clark County School Corporation Thomas Jefferson Elementary School **Building Name Building Number** 03 **HAID** С **HA Description AHU Cloth Expansion Joints HA Type** Miscellaneous Material Stage ends **HA Location** Quantity 2 Unit(s) Comments These were noted during the June 2011 6 month surveillance and will remain in management plan until properly sampled. Asbestos Assumed Friable No **Original Inspection** 6/27/2011 **Current Inspection** 4/13/2017 **Material Assessment Assessment Rating** 5 ACBM with potential for damage **Damage Assessment and Potential for Damage Percent Damaged** % **Good Condition Physical Contact Vibration** <u>Air</u> Low/None Low/None Low/None **Planned Response Action 0&M** Janie AHoin Inspector

State Indiana **Accreditation Number** 19A007179

Jamie Hosier

LEA Name

Greater Clark County School Corporation

Thomas Jefferson Elementary School **Building Name Building Number** 03 **HAID** D **HA Description** Fire Doors-Original to building (wooden) **HA Type** Miscellaneous Material Gym & throughout the building **HA Location** Quantity Unquantified Unit(s) Comments These were noted during the June 2011 6 month surveillance and will remain in management plan until properly sampled. **Asbestos** Assumed Friable No **Original Inspection** 6/27/2011 **Current Inspection** 4/13/2017 **Material Assessment Assessment Rating** 5 ACBM with potential for damage **Damage Assessment and Potential for Damage Percent Damaged** % **Good Condition Physical Contact Vibration** <u>Air</u> Low/None Low/None Low/None **Planned Response Action 0&M**

Jamie Hosier

Janie Attoin

Accreditation Number 19A007179

State Indiana

Inspector

LEA Name

LEA Name Greater Clark County School Corporation Thomas Jefferson Elementary School **Building Name Building Number** 03 HA ID Ε **HA Description Gray Sink Insulation HA Type** Miscellaneous Material Classrooms, Art Room & Teachers Lounge **HA Location** Quantity Unquantified LF Comments This was noted during the June 2011 6 month surveillance and will remain in the management plan until properly sampled. **Asbestos** Assumed Friable No Original Inspection 6/27/2011 **Current Inspection** 4/13/2017 **Material Assessment Assessment Rating** 5 ACBM with potential for damage **Damage Assessment and Potential for Damage Percent Damaged** % **Good Condition Physical Contact Vibration** <u>Air</u> Low/None Low/None Low/None **Planned Response Action** 0&M Janie AHoin Inspector

State Indiana

Jamie Hosier

LEA Name	Greater Clark Co	ounty School Corporation	
Building Name	Thomas Jefferso	on Elementary School	
Building Number	03		
HA ID	F		
HA Description	Pipe Insulation		
НА Туре	Thermal System	Insulation (TSI)	
HA Location	Storage Rooms	Near Crawlspace Tunnel Acc	ess
Quantity	N/A	LF	
Comments	inspection. A te inspection with a small am pipe insulation. The opossible. Multip	ar (less than 1 LF) in a four in	pector during the April 2015 6 month inch line was noted during the F) was noted below the damaged and the pipe repaired as soon as the line with damage.
Asbestos	Assumed		
Friable	Yes		
Original Inspection	4/22/2015		
Current Inspection	4/13/2017		
	<u>r</u>	Material Assessmer	<u>ıt</u>
<u>Asses</u> :	sment Rating	1 Damaged or significantly	y damaged thermal syste
<u>Da</u>	amage Asses	ssment and Potent	al for Damage
Percent Damag	<u>red</u> %	Damanged - Localized	
<u>Ph</u> y	sical Contact	<u>Vibration</u>	<u>Air</u>
	Medium	Low/None	Low/None
<u>Planned</u>	Response Action	Patch and Repair	
Inspector	Janu SH	one	

Jamie Hosier

State Indiana

LEA Name Greater Clark County School Corporation Thomas Jefferson Elementary School **Building Name Building Number** 03 **HAID** 01 **HA Description** Pipe Insulation **HA Type** Thermal System Insulation (TSI) Boiler room **HA Location** LF Quantity 10 Comments This material was not in poor condition along east wall near east boiler by tunnel entry. Scheduled for abatement in 2012/2013 renovation. **Asbestos** Known **Friable** No **Original Inspection** 6/1/1992 **Current Inspection** 11/3/2016 **Material Assessment Assessment Rating** 5 ACBM with potential for damage **Damage Assessment and Potential for Damage Percent Damaged** % **Good Condition Physical Contact Vibration** <u>Air</u> Low/None Low/None Low/None **Planned Response Action 0&M** Inspector **Dustin Hawkins** State IN

LEA Name Greater Clark County School Corporation Thomas Jefferson Elementary School **Building Name Building Number** 03 **HAID** 02 **HA Description Pipe Insulation HA Type** Thermal System Insulation (TSI) **Tunnels HA Location** Quantity 230 LF Comments Entrances to tunnels are restricted, as this material is in poor condition. There is all over the floor of the dirt crawl. No one should enter this area without proper training and protection. Clean up recommended. Scheduled for abatement in 2012/2013 renovation. **Asbestos** Known Friable Yes **Original Inspection** 6/1/1992 **Current Inspection** 11/3/2016 **Material Assessment** 1 Damaged or significantly damaged thermal syste **Assessment Rating Damage Assessment and Potential for Damage Percent Damaged** % Damanged - Localized **Physical Contact** Vibration Air High Low/None Low/None **Planned Response Action** Patch and Repair Inspector

Dustin Hawkins

State IN Accreditation Number 19A007194

LEA Name Greater Clark County School Corporation Thomas Jefferson Elementary School **Building Name Building Number** 03 **HAID** 03 **HA Description Fittings HA Type** Thermal System Insulation (TSI) Boiler room and tunnel **HA Location** Quantity 48 Unit(s) Comments Material in tunnel is in poor condition. Entry to tunnel is restricted. No one should enter without proper training and protection. Clean up recommended. Scheduled for abatement in 2012/2013 renovation. **Asbestos** Known Friable Yes **Original Inspection** 6/1/1992 **Current Inspection** 11/3/2016 **Material Assessment Assessment Rating** 1 Damaged or significantly damaged thermal syste **Damage Assessment and Potential for Damage Percent Damaged** % Damanged - Localized **Physical Contact Vibration** Air High Low/None Low/None **Planned Response Action** 0&M Inspector **Dustin Hawkins**

Accreditation Number 19A007194

State IN

LEA Name	Greater Clark (County School Corporation		
Building Name	Thomas Jeffers	son Elementary School		
Building Number	03			
HA ID	05-A			
HA Description	VAT-undernea	th carpet		
НА Туре	Miscellaneous	Material		
HA Location	Throughout the	e building (classrooms, hallw	ays & office)	
Quantity	Unquantified	SF		
Comments	Floor Tile (inst	alled in 1994)		
Asbestos	Known			
Friable	No			
Original Inspection	6/1/1992			
Current Inspection	11/3/2016			
		Material Assessmen	<u>nt</u>	
Assess	sment Rating	5 ACBM with potential fo	or damage	
			-	
Da	amage Asse	essment and Potent	<u>ial for Damage</u>	
Percent Damag	ed %	Good Condition		
<u>Phy</u>	rsical Contact	<u>Vibration</u>	<u>Air</u>	
1	Low/None	Low/None	Low/None	
<u>Planned</u>	Response Actio	o <u>n</u> O&M		
		tsle		
Inchestor	U- 0	711		
Inspector	Duntin III			
Dustin Hawkins				

State IN

LEA Name Greater Clark County School Corporation Thomas Jefferson Elementary School **Building Name Building Number** 03 HA ID 05-B 12" x 12" newer off-white floor tile **HA Description HA Type** Miscellaneous Material Throughout the building (first aid office, cafeteria, workroom, water fountain **HA Location** area, office hallway, entrance, and art room) Quantity Unquantified Comments Minor chipping near water fountain. Overall, this material is not in poor condition. **Asbestos** Known **Friable** No **Original Inspection** 6/1/1992 **Current Inspection** 11/3/2016 **Material Assessment Assessment Rating** 5 ACBM with potential for damage **Damage Assessment and Potential for Damage Percent Damaged** % **Good Condition Physical Contact** Vibration Air Low/None Low/None Low/None **Planned Response Action** 0&M Inspector **Dustin Hawkins**

State IN

LEA Name	Greater Clark County School Corporation					
Building Name	Thomas Jefferson Elementary School					
Building Number	03	03				
HA ID	05-C					
HA Description	12" x 12" orig	inal floor tile				
НА Туре	Miscellaneous	s Material				
HA Location	Throughout th	ne building (gym and cu	istodial closets).			
Quantity	Unquantified	SF				
Comments	Minor chippir	ng in closets. Overall, th	is material is not in poor condition			
Asbestos	Known					
Friable	No					
Original Inspection	6/1/1992					
Current Inspection	11/3/2016	11/3/2016				
		Material Asses	<u>sment</u>			
<u>Assess</u>	sment Rating	5 ACBM with pote	ntial for damage			
<u>Da</u>	amage Ass	essment and Po	tential for Damage			
Percent Damag	ed %	Good Condition				
Physical Cont		<u>Vibration</u>	<u>Air</u>			
I	_ow/None	Low/None	Low/None			
<u>Planned</u>	Response Acti	on O&M				
		421-6				
Inspector		/ (\				
	Dustin H					
•	State IN	is trains				
•						

LEA Name	Greater Clark County School Corporation			
Building Name	Thomas Jeffer	son Elementary School		
Building Number	03			
HA ID	05-D			
HA Description	12" x 12" origi	nal light blue floor tile		
НА Туре	Miscellaneous	Material		
HA Location	Throughout th	ne building (gym)		
Quantity	Unquantified	SF		
Comments	Where visible	, this material is not in poor	condition.	
Asbestos	Known			
Friable	No			
Original Inspection	6/1/1992			
Current Inspection	11/3/2016			
		Material Assessme	<u>ent</u>	
Asses	sment Rating	5 ACBM with potential	for damage	
Da	amage Ass	essment and Poter	ntial for Damage	
Percent Damag		Good Condition	-	
		Vibration	۸:۰	
	vsical Contact Low/None	Low/None	<u>Air</u> Low/None	
			LOW/NOTIC	
<u>Planned</u>	Response Action	on O&M		
		Ale		
Inspector				
	Dustin H	awkins		
	2 00 0	· · · · · · · · · · · ·		

Accreditation Number 19A007194

State IN

Greater Clark County School Corporation LEA Name Building Name Thomas Jefferson Elementary School **Building Number** 03 HA ID 07 **HA Description** Mastic **HA Type** Miscellaneous Material Throughout the building **HA Location** Quantity 33750 SF Comments This material was not visible to inspect. **Asbestos** Assumed **Friable** No **Original Inspection** 6/1/1992 **Current Inspection** 11/3/2016 **Material Assessment Assessment Rating** 5 ACBM with potential for damage **Damage Assessment and Potential for Damage Percent Damaged Good Condition Physical Contact** Vibration Air Low/None Low/None Low/None **Planned Response Action** 0&M Inspector **Dustin Hawkins**

State IN

LEA Name	Greater Clark County School Corporation				
Building Name	Thomas Jefferson Elementary School				
Building Number	03	03			
HA ID	11				
HA Description	Fire door-Meta	l clad			
НА Туре	Miscellaneous I	Material			
HA Location	Boiler room (2)	Gym Exterior Doors (4)			
Quantity	6	Unit(s)			
Comments	The fire door sl	hell is intact with no core mat	erial visible to inspect.		
Asbestos	Assumed				
Friable	No				
Original Inspection	6/1/1992				
Current Inspection	11/3/2016				
Material Assessment					
Assessment Rating 5 ACBM with potential for damage					
<u>Da</u>	amage Asse	ssment and Potenti	al for Damage		
Percent Damag	<u>red</u> %	Good Condition			
<u>Phy</u>	sical Contact	<u>Vibration</u>	<u>Air</u>		
I	Low/None	Low/None	Low/None		
<u>Planned</u>	Response Action	<u>n</u> O&M			
	Def	He.			
Inspector	ector				
	Dustin Ha	wkins			

State IN

LEA Name Greater Clark County School Corporation Thomas Jefferson Elementary School **Building Name Building Number** 03 HA ID 15 **HA Description Boiler** gaskets **HA Type** Miscellaneous Material Boiler room **HA Location** Quantity 2 Unit(s) Comments Boiler doors were closed. The visible edges of this material were not in poor There is some fiberglass rope visible, but also some older looking gasket material. **Asbestos Assumed** Friable No **Original Inspection** 6/1/1992 **Current Inspection** 11/3/2016 **Material Assessment Assessment Rating** 5 ACBM with potential for damage **Damage Assessment and Potential for Damage Percent Damaged** % **Good Condition Physical Contact** Vibration <u>Air</u> Low/None Low/None Low/None **Planned Response Action** 0&M Inspector **Dustin Hawkins**

State IN

LEA Name Greater Clark County School Corporation Building Name Thomas Jefferson Elementary School **Building Number** 03 **HAID** Α **HA Description** Cove Base **HA Type** Miscellaneous Material Throughout the building **HA Location** Quantity Approx. 3800 LF Comments Material is not in poor condition overall with minor signs of wear. Loose and missing in a few locations. (installed in 1994) **Asbestos Assumed Friable** No **Original Inspection** 5/31/1995 **Current Inspection** 11/3/2016 **Material Assessment Assessment Rating** 5 ACBM with potential for damage **Damage Assessment and Potential for Damage Percent Damaged** % **Good Condition Physical Contact Vibration** <u>Air</u> Low/None Low/None Low/None **Planned Response Action** 0&M Inspector **Dustin Hawkins** State IN

LEA Name Greater Clark County School Corporation Thomas Jefferson Elementary School **Building Name Building Number** 03 **HAID** В **HA Description** Cove base mastic **HA Type** Miscellaneous Material Throughout the building **HA Location** Quantity Approx. 1200 SF Comments Mastic was visible to inspect at corner near custodial closet in the cafateria where cove base was missing. **Asbestos** Assumed **Friable** No Original Inspection 5/31/1995 **Current Inspection** 11/3/2016 **Material Assessment Assessment Rating** 5 ACBM with potential for damage **Damage Assessment and Potential for Damage Percent Damaged** % **Good Condition Physical Contact Vibration** <u>Air</u> Low/None Low/None Low/None **Planned Response Action 0&M** Inspector **Dustin Hawkins**

State IN

LEA Name Greater Clark County School Corporation Thomas Jefferson Elementary School **Building Name Building Number** 03 HA ID С **HA Description AHU Cloth Expansion Joints HA Type** Miscellaneous Material Stage ends **HA Location** Quantity 2 Unit(s) Comments These were noted during the June 2011 6 month surveillance and will remain in management plan until properly sampled. **Asbestos** Assumed **Friable** No Original Inspection 6/27/2011 **Current Inspection** 11/3/2016 **Material Assessment Assessment Rating** 5 ACBM with potential for damage **Damage Assessment and Potential for Damage Percent Damaged** % **Good Condition Physical Contact Vibration** <u>Air</u> Low/None Low/None Low/None **Planned Response Action 0&M** Inspector **Dustin Hawkins** State IN

LEA Name	Greater Clark County School Corporation				
Building Name	Thomas Jeffer	Thomas Jefferson Elementary School			
Building Number	03	03			
HA ID	D				
HA Description	Fire Doors-Ori	ginal to building (wooden)			
НА Туре	Miscellaneous	Material			
HA Location	Gym & throug	hout the building			
Quantity	Unquantified	Unit(s)			
Comments	These were noted during the June 2011 6 month surveillance and will remain in the management plan until properly sampled.				
Asbestos	Assumed				
Friable	No				
Original Inspection	6/27/2011				
Current Inspection	11/3/2016				
		Material Assessm	<u>ent</u>		
Assess	sment Rating	5 ACBM with potentia	for damage		
<u>Da</u>	amage Ass	essment and Pote	ntial for Damage		
Percent Damag	red %	Good Condition			
<u>Phy</u>	sical Contact	<u>Vibration</u>	<u>Air</u>		
1	Low/None	Low/None	Low/None		
<u>Planned</u>	Response Action	<u>on</u> 0&M			
	D-76	Ale			
Inspector					
	Dustin H	awkins			

State IN

LEA Name	Greater Clark	County School Co	orporation		
Building Name	Thomas Jeffers	son Elementary S	School		
Building Number	03				
HA ID	E				
HA Description	Gray Sink Insul	ation			
НА Туре	Miscellaneous	Material			
HA Location	Classrooms, Ar	t Room & Teach	ers Lounge		
Quantity	Unquantified		LF		
Comments		d during the June plan until proper		surveillance and will rem	ain in the
Asbestos	Assumed				
Friable	No				
Original Inspection	6/27/2011				
Current Inspection	11/3/2016				
		Material A	ssessment		
Assess	sment Rating	5 ACBM with	potential for da	mage	
Da	amage Asse	essment an	d Potential	for Damage	
Percent Damag	ged %	Good Conditio	n		
<u>Phy</u>	rsical Contact	<u>Vibra</u>	<u>tion</u>	<u>Air</u>	
1	Low/None	Low/N	lone	Low/None	
<u>Planned</u>	Response Actio	o <u>n</u> O&M			
	5-4	AC.			
Inspector			<u>—</u>		
	Dustin Ha	awkins			

State IN

Greater Clark County School Corporation LEA Name Building Name Thomas Jefferson Elementary School **Building Number** 03 **HAID HA Description** Pipe Insulation **HA Type** Thermal System Insulation (TSI) Storage Rooms Near Crawlspace Tunnel Access **HA Location** Quantity N/A LF Comments This material was noted by the licensed inspector during the April 2015 6 month inspection. A tear (less than 1 LF) in a four inch line was noted during the inspection with a small amount of debris (less than 1 LF) was noted below the damaged pipe insulation. The debris should be cleaned up and the pipe repaired as soon as possible. Multiple open exposed spots on the line with damage. Overall material is not in poor condition. Asbestos **Assumed** Friable Yes Original Inspection 4/22/2015 **Current Inspection** 11/3/2016 **Material Assessment Assessment Rating** 1 Damaged or significantly damaged thermal syste Damage Assessment and Potential for Damage **Percent Damaged** Damanged - Localized % **Physical Contact** Vibration Air Medium Low/None Low/None **Planned Response Action** Patch and Repair

Inspector

Dustin Hawkins

State IN Accreditation Number 19A007194

LEA Name Greater Clark County School Corporation

Building Name Thomas Jefferson Elementary School

Building Number 03

HA ID 05-D

HA Description 12" x 12" original light blue floor tile

HA Type Miscellaneous Material

HA Location Throughout the building (gym)

Quantity Unquantified SF

Comments Where visible, this material is not in poor condition.

Asbestos Known

Friable No

Original Inspection 6/1/1992

Current Inspection 10/20/2015

Material Assessment

Assessment Rating 5 ACBM with potential for damage

Damage Assessment and Potential for Damage

Percent Damaged % Good Condition

Physical ContactVibrationAirLow/NoneLow/NoneLow/None

Planned Response Action O&M

Inspector

Benjamin S. Hood

State IN

LEA Name Greater Clark County School Corporation

Building Name Thomas Jefferson Elementary School

Building Number 03

HA ID 07

HA Description Mastic

HA Type Miscellaneous Material

HA Location Throughout the building

Quantity 33750 SF

Comments This material was not visible to inspect.

Asbestos Assumed

Friable No

Original Inspection 6/1/1992

Current Inspection 10/20/2015

Material Assessment

Assessment Rating 5 ACBM with potential for damage

Damage Assessment and Potential for Damage

Percent Damaged % Good Condition

Physical ContactVibrationAirLow/NoneLow/NoneLow/None

Planned Response Action O&M

Inspector

Benjamin S. Hood

State IN

LEA Name Greater Clark County School Corporation

Building Name Thomas Jefferson Elementary School

Building Number 03

HA ID 11

HA Description Fire door-Metal cladHA Type Miscellaneous Material

HA Location Boiler room (2) Gym Exterior Doors (4)

Quantity 6 Unit(s)

Comments The fire door shell is intact with no core material visible to inspect.

Asbestos Assumed

Friable No

Original Inspection 6/1/1992

Current Inspection 10/20/2015

Material Assessment

Assessment Rating 5 ACBM with potential for damage

Damage Assessment and Potential for Damage

Percent Damaged % Good Condition

Physical ContactVibrationAirLow/NoneLow/NoneLow/None

Planned Response Action O&M

Inspector

Benjamin S. Hood

State IN

LEA Name Greater Clark County School Corporation

Building Name Thomas Jefferson Elementary School

Building Number 03

HA ID 15

HA Description Boiler gaskets

HA Type Miscellaneous Material

HA Location Boiler room

Quantity 2 Unit(s)

Comments Boiler doors were closed. The visible edges of this material were not in poor

condition.

There is some fiberglass rope visible, but also some older looking gasket

material.

Asbestos Assumed

Friable No

Original Inspection 6/1/1992

Current Inspection 10/20/2015

Material Assessment

Assessment Rating 5 ACBM with potential for damage

Damage Assessment and Potential for Damage

Percent Damaged % Good Condition

Physical ContactVibrationAirLow/NoneLow/NoneLow/None

Planned Response Action O&M

Inspector

Benjamin S. Hood

State IN

Greater Clark County School Corporation

Building Name Thomas Jefferson Elementary School **Building Number** 03 **HAID** Α **HA Description** Cove Base **HA Type** Miscellaneous Material Throughout the building **HA Location** Quantity Approx. 3800 LF Comments Material is not in poor condition overall with minor signs of wear. Loose and missing in a few locations. (installed in 1994) **Asbestos** Assumed Friable No **Original Inspection** 5/31/1995 **Current Inspection** 10/20/2015 **Material Assessment Assessment Rating** 5 ACBM with potential for damage **Damage Assessment and Potential for Damage Good Condition Percent Damaged** % **Physical Contact** Vibration <u>Air</u> Low/None Low/None Low/None **Planned Response Action 0&M**

State IN

Benjamin S. Hood

Accreditation Number 19A001039

Inspector

LEA Name

LEA Name Greater Clark County School Corporation

Building Name Thomas Jefferson Elementary School

Building Number 03

HA ID B

HA Description Cove base mastic

HA Type Miscellaneous Material

HA Location Throughout the building

Quantity Approx. 1200 SF

Comments Mastic was visible to inspect at corner near custodial closet in the cafateria

where cove

base was missing.

Asbestos Assumed

Friable No

Original Inspection 5/31/1995

Current Inspection 10/20/2015

Material Assessment

Assessment Rating 5 ACBM with potential for damage

Damage Assessment and Potential for Damage

Percent Damaged % Good Condition

Physical ContactVibrationAirLow/NoneLow/NoneLow/None

Planned Response Action O&M

Inspector

Benjamin S. Hood

State IN

LEA Name Greater Clark County School Corporation

Building Name Thomas Jefferson Elementary School

Building Number 03

HA ID 01

HA Description Pipe Insulation

HA Type Thermal System Insulation (TSI)

HA Location Boiler room

Quantity 10 LF

Comments This material was not in poor condition along east wall near east boiler by

tunnel entry.

Scheduled for abatement in 2012/2013 renovation.

Asbestos Known

Friable No

Original Inspection 6/1/1992

Current Inspection 10/20/2015

Material Assessment

Assessment Rating 5 ACBM with potential for damage

Damage Assessment and Potential for Damage

Percent Damaged % Good Condition

Physical ContactVibrationAirLow/NoneLow/NoneLow/None

Planned Response Action O&M

Inspector

Benjamin S. Hood

State IN

LEA Name Greater Clark County School Corporation

Building Name Thomas Jefferson Elementary School

Building Number 03

HA ID 02

HA Description Pipe Insulation

HA Type Thermal System Insulation (TSI)

HA Location Tunnels

Quantity 230 LF

Comments Entrances to tunnels are restricted, as this material is in poor condition. There is

debris

all over the floor of the dirt crawl. No one should enter this area without proper

training

and protection. Clean up recommended. Scheduled for abatement in 2012/2013

renovation.

Asbestos Known

Friable Yes

Original Inspection 6/1/1992

Current Inspection 10/20/2015

Material Assessment

Assessment Rating 1 Damaged or significantly damaged thermal syste

Damage Assessment and Potential for Damage

<u>Percent Damaged</u> % Damanged - Localized

<u>Physical Contact</u> <u>Vibration</u> <u>Air</u>

High Low/None Low/None

<u>Planned Response Action</u> Patch and Repair

Inspector

Benjamin S. Hood

State IN Accreditation Number 19A001039

LEA Name Greater Clark County School Corporation

Building Name Thomas Jefferson Elementary School

Building Number 03

HA ID 03

HA Description Fittings

HA Type Thermal System Insulation (TSI)

HA Location Boiler room and tunnel

Quantity 48 Unit(s)

Comments Material in tunnel is in poor condition. Entry to tunnel is restricted. No one

should enter

without proper training and protection. Clean up recommended. Scheduled for

abatement in 2012/2013 renovation.

Asbestos Known

Friable Yes

Original Inspection 6/1/1992

Current Inspection 10/20/2015

Material Assessment

Assessment Rating 1 Damaged or significantly damaged thermal syste

Damage Assessment and Potential for Damage

<u>Percent Damaged</u> % Damanged - Localized

<u>Physical Contact</u> <u>Vibration</u> <u>Air</u>

High Low/None Low/None

Planned Response Action O&M

Inspector

Benjamin S. Hood

State IN

LEA Name Greater Clark County School Corporation

Building Name Thomas Jefferson Elementary School

Building Number 03

HA ID 05-A

HA Type VAT-underneath carpet Miscellaneous Material

HA Location Throughout the building (classrooms, hallways & office)

Quantity Unquantified SF

Comments Floor Tile (installed in 1994)

Asbestos Known

Friable No

Original Inspection 6/1/1992

Current Inspection 10/20/2015

Material Assessment

Assessment Rating 5 ACBM with potential for damage

Damage Assessment and Potential for Damage

Percent Damaged % Good Condition

Physical ContactVibrationAirLow/NoneLow/NoneLow/None

Planned Response Action O&M

Inspector

Benjamin S. Hood

State IN

LEA Name Greater Clark County School Corporation

Building Name Thomas Jefferson Elementary School

Building Number 03

HA ID 05-B

HA Description 12" x 12" newer off-white floor tile

HA Type Miscellaneous Material

HA Location Throughout the building (first aid office, cafeteria, workroom, water fountain

SF

area, office

hallway, entrance, and art room)

Quantity Unquantified

Comments Minor chipping near water fountain. Overall, this material is not in poor

condition.

Asbestos Known

Friable No

Original Inspection 6/1/1992

Current Inspection 10/20/2015

Material Assessment

Assessment Rating 5 ACBM with potential for damage

Damage Assessment and Potential for Damage

Percent Damaged % Good Condition

Physical Contact <u>Vibration</u> <u>Air</u>

Low/None Low/None Low/None

Planned Response Action O&M

Inspector

Benjamin S. Hood

State IN

LEA Name Greater Clark County School Corporation

Building Name Thomas Jefferson Elementary School

Building Number 03

HA ID C

HA Description AHU Cloth Expansion JointsHA Type Miscellaneous Material

HA Location Stage ends

Quantity 2 Unit(s)

Comments These were noted during the June 2011 6 month surveillance and will remain in

the

management plan until properly sampled.

Asbestos Assumed

Friable No

Original Inspection 6/27/2011

Current Inspection 10/20/2015

Material Assessment

Assessment Rating 5 ACBM with potential for damage

Damage Assessment and Potential for Damage

Percent Damaged % Good Condition

Physical ContactVibrationAirLow/NoneLow/NoneLow/None

Planned Response Action O&M

Inspector

Benjamin S. Hood

State IN

LEA Name Greater Clark County School Corporation

Building Name Thomas Jefferson Elementary School

Building Number 03

HA ID D

HA Description Fire Doors-Original to building (wooden)

HA Type Miscellaneous Material

HA Location Gym & throughout the building

Quantity Unquantified Unit(s)

Comments These were noted during the June 2011 6 month surveillance and will remain in

the

management plan until properly sampled.

Asbestos Assumed

Friable No

Original Inspection 6/27/2011

Current Inspection 10/20/2015

Material Assessment

Assessment Rating 5 ACBM with potential for damage

Damage Assessment and Potential for Damage

Percent Damaged % Good Condition

Physical ContactVibrationAirLow/NoneLow/NoneLow/None

Planned Response Action O&M

Inspector

Benjamin S. Hood

State IN

LEA Name Greater Clark County School Corporation

Building Name Thomas Jefferson Elementary School

Building Number 03

HA ID E

HA Description Gray Sink InsulationHA Type Miscellaneous Material

HA Location Classrooms, Art Room & Teachers Lounge

Quantity Unquantified LF

Comments This was noted during the June 2011 6 month surveillance and will remain in the

management plan until properly sampled.

Asbestos Assumed

Friable No

Original Inspection 6/27/2011

Current Inspection 10/20/2015

Material Assessment

Assessment Rating 5 ACBM with potential for damage

Damage Assessment and Potential for Damage

Percent Damaged % Good Condition

Physical ContactVibrationAirLow/NoneLow/NoneLow/None

Planned Response Action O&M

Inspector

Benjamin S. Hood

State IN

LEA Name Greater Clark County School Corporation Building Name Thomas Jefferson Elementary School **Building Number** 03 HA ID F **HA Description Pipe Insulation HA Type** Thermal System Insulation (TSI) **Storage Rooms Near Crawlspace Tunnel Access HA Location** Quantity N/A LF Comments This material was noted by the licensed inspector during the April 2015 6 month inspection. A tear (less than 1 LF) in a four inch line was noted during the inspection with a small amount of debris (less than 1 LF) was noted below the damaged pipe insulation. The debris should be cleaned up and the pipe repaired as soon as possible. Multiple open exposed spots on the line with damage. Overall material is not in poor condition. Asbestos Assumed Friable Yes Original Inspection 4/22/2015 **Current Inspection** 10/20/2015 **Material Assessment Assessment Rating** 1 Damaged or significantly damaged thermal syste Damage Assessment and Potential for Damage **Percent Damaged** % Damanged - Localized **Physical Contact** Vibration Air Medium Low/None Low/None **Planned Response Action** Patch and Repair

Inspector

Benjamin S. Hood

State IN

LEA Name Greater Clark County School Corporation

Building Name Thomas Jefferson Elementary School

Building Number 03

HA ID 05-C

HA Description 12" x 12" original floor tileHA Type Miscellaneous Material

HA Location Throughout the building (gym and custodial closets).

Quantity Unquantified SF

Comments Minor chipping in closets. Overall, this material is not in poor condition.

Asbestos Known

Friable No

Original Inspection 6/1/1992

Current Inspection 10/20/2015

Material Assessment

Assessment Rating 5 ACBM with potential for damage

Damage Assessment and Potential for Damage

Percent Damaged % Good Condition

Physical ContactVibrationAirLow/NoneLow/NoneLow/None

Planned Response Action O&M

Inspector

Benjamin S. Hood

State IN

LEA Name Greater Clark County Schools

Building Name Thomas Jefferson Elementary

HA# 01

Type of Material Thermal Material

Quantity of Material 10 LF

Material Location

Boiler room

Material Description

Pipe insulation

Comments

This material was not in poor condition along east wall near east boiler by tunnel entry. Scheduled for abatement in 2012/2013 renovation.

Does Material Contain Asbestos? Yes
Is it Friable? No

Original Inspection Date 6/1/1992

Current Surveillance Date 4/22/2015

Current Assessment Rating NR Not Rated

Cause of Damage No Damage

Accessible Yes
Potential for Damage Low
Removed No

Planned Response Action Remove

Inspector _____

Benjamin S. Hood

State Indiana

LEA Name Greater Clark County Schools

Building Name Thomas Jefferson Elementary

HA# 02

Type of Material Thermal Material

Quantity of Material 230 LF

Material Location
Tunnels

Material Description

Pipe insulation

Comments

Entrances to tunnels are restricted, as this material is in poor condition. There is debris all over the floor of the dirt crawl. No one should enter this area without proper training and protection. Clean up recommended. Scheduled for abatement in 2012/2013 renovation.

Does Material Contain Asbestos? Yes Is it Friable? Yes

Original Inspection Date 6/1/1992

Current Surveillance Date 4/22/2015

Current Assessment Rating 1B Damaged TSI

Cause of Damage Physical Damage

Accessible Yes
Potential for Damage Low
Removed No

Planned Response Action Remove

Inspector _____

Benjamin S. Hood

State Indiana

LEA Name Greater Clark County Schools

Building Name Thomas Jefferson Elementary

HA# 03

Type of Material Thermal Material

Quantity of Material 48 Each

Material Location

Boiler room and tunnel

Material Description

Fittings

Comments

Material in tunnel is in poor condition. Entry to tunnel is restricted. No one should enter without proper training and protection. Clean up recommended. Scheduled for abatement in 2012/2013 renovation.

Does Material Contain Asbestos? Yes
Is it Friable? Yes
Original Inspection Date 6/1/1992
Current Surveillance Date 4/22/2015

Current Assessment Rating 1B Damaged TSI

Cause of Damage Physical Damage

Accessible Yes
Potential for Damage Low
Removed No

Planned Response Action Remove

Inspector _____

Benjamin S. Hood

State Indiana

LEA Name Greater Clark County Schools

Building Name Thomas Jefferson Elementary

HA# 05-A

Type of Material Miscellaneous Material

Quantity of Material Unquantified SF

Material Location

Throughout the building (classrooms, hallways & office)

Material Description

VAT-underneath carpet

Comments

Floor Tile (installed in 1994)

Does Material Contain Asbestos? Yes Is it Friable? No

Original Inspection Date 6/1/1992
Current Surveillance Date 4/22/2015

Current Assessment Rating NR Not Rated

Cause of Damage No Damage

Accessible No
Potential for Damage Low

Removed No

Planned Response Action O & M

Inspector Benjamin S. Hood

State Indiana

LEA Name Greater Clark County Schools

Building Name Thomas Jefferson Elementary

HA# 05-B

Type of Material Miscellaneous Material

Quantity of Material Unquantified SF

Material Location

Throughout the building (first aid office, cafeteria, workroom, water fountain area, office hallway, entrance, and art room)

Material Description

12" x 12" newer off-white floor tile

Comments

Minor chipping near water fountain. Overall, this material is not in poor condition.

Does Material Contain Asbestos? Yes
Is it Friable? No

Original Inspection Date 6/1/1992

Current Surveillance Date 4/22/2015

Current Assessment Rating NR Not Rated

Cause of Damage

Accessible Yes
Potential for Damage Low

Removed No

Planned Response Action O & M

Inspector

Benjamin S. Hood

State Indiana

LEA Name Greater Clark County Schools

Building Name Thomas Jefferson Elementary

HA# 05-C

Type of Material Miscellaneous Material

Quantity of Material Unquantified SF

Material Location

Throughout the building (gym and custodial closets).

Material Description

12" x 12" original floor tile

Comments

Minor chipping in closets. Overall, this material is not in poor condition.

Does Material Contain Asbestos? Yes
Is it Friable? No

Original Inspection Date 6/1/1992

Current Surveillance Date 4/22/2015

Current Assessment Rating NR Not Rated

Cause of Damage

Accessible Yes
Potential for Damage Low

Removed No

Planned Response Action O & M

Inspector Benjamin S. Hood

State Indiana
Accreditation Number 19A001039

LEA Name Greater Clark County Schools

Building Name Thomas Jefferson Elementary

HA# 05-D

Type of Material Miscellaneous Material

Quantity of Material Unquantified SF

Material Location

Throughout the building (gym)

Material Description

12" x 12" original light blue floor tile

Comments

Where visible, this material is not in poor condition.

Does Material Contain Asbestos? Yes Is it Friable? No

Original Inspection Date 6/1/1992
Current Surveillance Date 4/22/2015

Current Assessment Rating NR Not Rated

Cause of Damage

Accessible Yes
Potential for Damage Low

Removed No

Planned Response Action O & M

Inspector Benjamin S. Hood

State Indiana
Accreditation Number 19A001039

LEA Name Greater Clark County Schools
Building Name Thomas Jefferson Elementary

HA# 07

Type of Material Miscellaneous Material

Quantity of Material 33,750 SF

Material Location

Throughout the building

Material Description

Mastic

Comments

Inspector

This material was not visible to inspect.

Does Material Contain Asbestos? Assumed

Is it Friable?

Original Inspection Date 6/1/1992

Current Surveillance Date 4/22/2015

Current Assessment Rating NR Not Rated

Cause of Damage No Damage

Accessible No Potential for Damage Low

Removed No

Planned Response Action O & M

Benjamin S. Hood

State Indiana

LEA Name Greater Clark County Schools

Building Name Thomas Jefferson Elementary

HA# 11

Type of Material Miscellaneous Material

Quantity of Material 6 Each

Material Location

Boiler room (2) Gym Exterior Doors (4)

Material Description

Fire door-Metal clad

Comments

Inspector

The fire door shell is intact with no core material visible to inspect.

Does Material Contain Asbestos? Assumed

Is it Friable?

Original Inspection Date 6/1/1992

Current Surveillance Date 4/22/2015

Current Assessment Rating NR Not Rated

Cause of Damage No Damage

Accessible Yes
Potential for Damage Low

Removed No.

Planned Response Action O & M

Benjamin S. Hood

State Indiana

LEA Name Greater Clark County Schools

Building Name Thomas Jefferson Elementary

HA# 15

Type of Material Miscellaneous Material

Quantity of Material 2 Each

Material Location

Boiler room

Material Description

Boiler gaskets

Comments

Boiler doors were closed. The visible edges of this material were not in poor condition. There is some fiberglass rope visible, but also some older looking gasket material.

Does Material Contain Asbestos? Assumed

Is it Friable?

Original Inspection Date 6/1/1992

Current Surveillance Date 4/22/2015

Current Assessment Rating NR Not Rated

Cause of Damage No Damage

Accessible Yes
Potential for Damage Low

Removed No

Planned Response Action O & M

Inspector

Benjamin S. Hood

State Indiana

LEA Name Greater Clark County Schools

Building Name Thomas Jefferson Elementary

HA# A

Type of Material Miscellaneous Material

Quantity of Material Approx. 3,800 LF

Material Location

Throughout the building

Material Description

Cove base

Comments

Material is not in poor condition overall with minor signs of wear. Loose and missing in a few locations. (installed in 1994)

Does Material Contain Asbestos? Assumed

Is it Friable?

Original Inspection Date 5/31/1995
Current Surveillance Date 4/22/2015

Current Assessment Rating NR Not Rated

Cause of Damage No Damage

Accessible Yes
Potential for Damage Low

Removed No

Planned Response Action O & M

Inspector

Benjamin S. Hood

State Indiana

LEA Name Greater Clark County Schools

Building Name Thomas Jefferson Elementary

HA# B

Type of Material Miscellaneous Material

Quantity of Material Approx. 1,200 SF

Material Location

Throughout the building

Material Description

Cove base mastic

Comments

Mastic was visible to inspect at corner near custodial closet in the cafateria where cove base was missing.

Does Material Contain Asbestos? Assumed

Is it Friable?

Original Inspection Date 5/31/1995
Current Surveillance Date 4/22/2015

Current Assessment Rating NR Not Rated

Cause of Damage No Damage

Accessible No Potential for Damage Low

Removed No

Planned Response Action O & M

Inspector

Benjamin S. Hood

State Indiana

LEA Name Greater Clark County Schools

Building Name Thomas Jefferson Elementary

HA# C

Type of Material Miscellaneous Material

Quantity of Material 2 Each

Material Location

Stage Ends

Material Description

AHU Cloth Expansion Joints

Comments

These were noted during the June 2011 6 month surveillance and will remain in the management plan until properly sampled.

Does Material Contain Asbestos? Assumed

Is it Friable?

Original Inspection Date 6/27/2011

Current Surveillance Date 4/22/2015

Current Assessment Rating NA Not Applicable

Cause of Damage No Damage

Accessible Yes
Potential for Damage Low

Removed No

Planned Response Action O & M

Inspector

Benjamin S. Hood

State Indiana

LEA Name Greater Clark County Schools

Building Name Thomas Jefferson Elementary

HA# D

Type of Material Miscellaneous Material

Quantity of Material Unquantified Each

Material Location

Gym & throughout the building

Material Description

Fire Doors-Original to building (wooden)

Comments

These were noted during the June 2011 6 month surveillance and will remain in the management plan until properly sampled.

Does Material Contain Asbestos? Assumed

Is it Friable?

Original Inspection Date 6/27/2011

Current Surveillance Date 4/22/2015

Current Assessment Rating NA Not Applicable

Cause of Damage No Damage

Accessible Yes
Potential for Damage Low

Removed No

Planned Response Action O & M

Inspector Benjamin S. Hood

State Indiana

LEA Name Greater Clark County Schools

Building Name Thomas Jefferson Elementary

HA# E

Type of Material Miscellaneous Material

Quantity of Material Unquantified LF

Material Location

Classrooms, Art Room & Teachers Lounge

Material Description

Gray Sink Insulation

Comments

This was noted during the June 2011 6 month surveillance and will remain in the management plan until properly sampled.

Does Material Contain Asbestos? Assumed

Is it Friable?

Original Inspection Date 6/27/2011

Current Surveillance Date 4/22/2015

Current Assessment Rating NA Not Applicable

Cause of Damage No Damage

Accessible Yes
Potential for Damage Low

Removed No

Planned Response Action O & M

Inspector _____

Benjamin S. Hood

State Indiana

LEA Name Greater Clark County Schools

Building Name Thomas Jefferson Elementary

HA# F

Type of Material Thermal System Insulation

Quantity of Material N/A LF

Material Location

Storage Rooms Near Crawlspace Tunnel Access

Material Description

Pipe Insulation

Comments

This material was noted by the licensed inspector during the April 2015 6 month inspection. A tear (less than 1 LF) in a four inch line was noted during the inspection with a small amount of debris (less than 1 LF) was noted below the damaged pipe insulation. The debris should be cleaned up and the pipe repaired as soon as possible. Overall material is not in poor condition.

Does Material Contain Asbestos? Assumed

Is it Friable? Yes

Original Inspection Date 4/22/2015

Current Surveillance Date 4/22/2015

Current Assessment Rating 1B Damaged TSI

Cause of Damage

Accessible Yes

Potential for Damage Low

Removed No

Planned Response Action O & M

Inspector

Benjamin S. Hood

State Indiana

Greater Clark County Schools LEA Name Building Name Thomas Jefferson Elementary HA# 01 Type of Material Thermal Material 10 LF **Quantity of Material Material Location** Boiler room **Material Description** Pipe insulation Comments This material was not in poor condition along east wall near east boiler by tunnel entry. Scheduled for abatement in 2012/2013 renovation. **Does Material Contain Asbestos?** Yes Is it Friable? No 6/1/1992 **Original Inspection Date Current Surveillance Date** 10/22/2014 NR Not Rated **Current Assessment Rating Cause of Damage** No Damage **Accessible** Yes **Potential for Damage** Low Removed No **Planned Response Action** Remove

Inspector

Benjamin S. Hood

State Indiana

LEA Name Greater Clark County Schools
Building Name Thomas Jefferson Elementary

HA# 02

Type of Material Thermal Material

Quantity of Material 230 LF

Material Location
Tunnels

Material Description

Pipe insulation

Comments

Entrances to tunnels are restricted, as this material is in poor condition. There is debris all over the floor of the dirt crawl. No one should enter this area without proper training and protection. Clean up recommended. Scheduled for abatement in 2012/2013 renovation.

Does Material Contain Asbestos? Yes
Is it Friable? Yes

Original Inspection Date 6/1/1992

Current Surveillance Date 10/22/2014

Current Assessment Rating 1B Damaged TSI

Cause of Damage Physical Damage

Accessible Yes

Potential for Damage Low

Removed No.

Planned Response Action Remove

Inspector _____

Benjamin S. Hood

State Indiana

Greater Clark County Schools LEA Name Building Name Thomas Jefferson Elementary HA# 03 Type of Material Thermal Material 48 Each **Quantity of Material Material Location** Boiler room and tunnel **Material Description Fittings** Comments Material in tunnel is in poor condition. Entry to tunnel is restricted. No one should enter without proper training and protection. Clean up recommended. Scheduled for abatement in 2012/2013 renovation. **Does Material Contain Asbestos?** Yes Is it Friable? Yes **Original Inspection Date** 6/1/1992 **Current Surveillance Date** 10/22/2014 **Current Assessment Rating** 1B Damaged TSI **Cause of Damage Physical Damage** Yes **Accessible Potential for Damage** Low Removed No **Planned Response Action** Remove

Inspector Benjamin S. Hood

State Indiana

LEA Name

Building Name

Thomas Jefferson Elementary

HA#

05-A

Type of Material

Quantity of Material

Unquantified SF

Material Location

Throughout the building (classrooms, hallways & office)

Material Description

VAT-underneath carpet

Comments

Floor Tile (installed in 1994)

Does Material Contain Asbestos? Yes
Is it Friable? No

Original Inspection Date 6/1/1992
Current Surveillance Date 10/22/2014

Current Assessment Rating NR Not Rated

Cause of Damage No Damage

Accessible No
Potential for Damage Low

Removed No.

Planned Response Action O & M

Inspector Benjamin S. Hood

State Indiana
Accreditation Number 19A001039

LEA Name Greater Clark County Schools

Building Name Thomas Jefferson Elementary

HA# 05-B

Type of Material Miscellaneous Material

Quantity of Material Unquantified SF

Material Location

Throughout the building (first aid office, cafeteria, workroom, water fountain area, office hallway, entrance, and art room)

Material Description

12" x 12" newer off-white floor tile

Comments

Where visible, this material is not in poor condition.

Does Material Contain Asbestos? Yes Is it Friable? No

Original Inspection Date 6/1/1992

Current Surveillance Date 10/22/2014

Current Assessment Rating NR Not Rated

Cause of Damage

Accessible Yes
Potential for Damage Low

Removed No

Planned Response Action O & M

Inspector _____

Benjamin S. Hood

State Indiana

Greater Clark County Schools LEA Name Building Name Thomas Jefferson Elementary HA# 05-C Type of Material Miscellaneous Material **Quantity of Material** Unquantified SF **Material Location** Throughout the building (gym and custodial closets). **Material Description** 12" x 12" original floor tile Comments Where visible, this material is not in poor condition. **Does Material Contain Asbestos?** Yes Is it Friable? No 6/1/1992 **Original Inspection Date Current Surveillance Date** 10/22/2014 NR Not Rated **Current Assessment Rating Cause of Damage** Yes Accessible **Potential for Damage** Low No Removed O & M **Planned Response Action**

Inspector

Benjamin S. Hood

State Indiana
Accreditation Number 19A001039

Greater Clark County Schools LEA Name Building Name Thomas Jefferson Elementary HA# 05-D Type of Material Miscellaneous Material **Quantity of Material** Unquantified SF **Material Location** Throughout the building (gym) **Material Description** 12" x 12" original light blue floor tile Comments Where visible, this material is not in poor condition. **Does Material Contain Asbestos?** Yes Is it Friable? No 6/1/1992 **Original Inspection Date Current Surveillance Date** 10/22/2014 NR Not Rated **Current Assessment Rating Cause of Damage** Yes Accessible **Potential for Damage** Low

No

O & M

Inspector

Removed

Planned Response Action

Benjamin S. Hood

State Indiana
Accreditation Number 19A001039

Greater Clark County Schools LEA Name Building Name Thomas Jefferson Elementary HA# 07 Type of Material Miscellaneous Material **Quantity of Material** 33,750 SF **Material Location** Throughout the building **Material Description** Mastic Comments This material was not visible to inspect. **Does Material Contain Asbestos?** Assumed Is it Friable? No 6/1/1992 **Original Inspection Date Current Surveillance Date** 10/22/2014 NR Not Rated **Current Assessment Rating Cause of Damage** No Damage No **Accessible Potential for Damage** Low No Removed **Planned Response Action** O & M

Inspector

Benjamin S. Hood

LEA Name Greater Clark County Schools

Building Name Thomas Jefferson Elementary

HA# 11

Type of Material Miscellaneous Material

Quantity of Material 6 Each

Material Location

Boiler room (2) Gym Exterior Doors (4)

Material Description

Fire door-Metal clad

Comments

Inspector

The fire door shell is intact with no core material visible to inspect.

Does Material Contain Asbestos? Assumed

Is it Friable?

Original Inspection Date 6/1/1992

Current Surveillance Date 10/22/2014

Current Assessment Rating NR Not Rated

Cause of Damage No Damage

Accessible Yes

Potential for Damage Low

Removed No.

Planned Response Action O & M

Benjamin S. Hood

State Indiana

Greater Clark County Schools LEA Name Building Name Thomas Jefferson Elementary HA# 15 Type of Material Miscellaneous Material 2 Each **Quantity of Material Material Location** Boiler room **Material Description** Boiler gaskets Comments Boiler doors were closed. The visible edges of this material were not in poor condition. There is some fiberglass rope visible, but also some older looking gasket material. **Does Material Contain Asbestos?** Assumed Is it Friable? No 6/1/1992 **Original Inspection Date Current Surveillance Date** 10/22/2014 NR Not Rated **Current Assessment Rating Cause of Damage** No Damage **Accessible** Yes **Potential for Damage** Low Removed No O & M **Planned Response Action**

Benjamin S. Hood

Inspector

State Indiana

LEA Name
Greater Clark County Schools
Building Name
Thomas Jefferson Elementary
A
Type of Material
Miscellaneous Material

Approx. 3,800 LF

Quantity of Material Material Location

cation

Throughout the building

Material Description

Cove base

Comments

Material is not in poor condition overall with minor signs of wear. Loose and missing in a few locations. (installed in 1994)

a few locations. (installed in 1994)

Does Material Contain Asbestos? Assumed

Is it Friable? No

Original Inspection Date 5/31/1995

Current Surveillance Date 10/22/2014

Current Assessment Rating NR Not Rated

Cause of Damage No Damage

Accessible Yes
Potential for Damage Low

Removed No

Planned Response Action O & M

Inspector _____

Benjamin S. Hood

LEA Name Greater Clark County Schools

Building Name Thomas Jefferson Elementary

HA# B

Type of Material Miscellaneous Material

Quantity of Material Approx. 1,200 SF

Material Location

Throughout the building

Material Description

Cove base mastic

Comments

Mastic was visible to inspect at corner near custodial closet in the cafateria where cove base was missing.

Does Material Contain Asbestos? Assumed

Is it Friable?

Original Inspection Date 5/31/1995

Current Surveillance Date 10/22/2014

Current Assessment Rating NR Not Rated

Cause of Damage No Damage

Accessible No
Potential for Damage Low

Removed No

Planned Response Action O & M

Inspector

Benjamin S. Hood

State Indiana

LEA Name Greater Clark County Schools

Building Name Thomas Jefferson Elementary

HA# C

Type of Material Miscellaneous Material

Quantity of Material 2 Each

Material Location

Stage Ends

Material Description

AHU Cloth Expansion Joints

Comments

These were noted during the June 2011 6 month surveillance and will remain in the management plan until properly sampled.

Does Material Contain Asbestos? Assumed

Is it Friable?

Original Inspection Date 6/27/2011

Current Surveillance Date 10/22/2014

Current Assessment Rating NA Not Applicable

Cause of Damage No Damage

Accessible Yes
Potential for Damage Low

Removed No

Planned Response Action O & M

Inspector _____

Benjamin S. Hood

State Indiana

LEA Name Greater Clark County Schools

Building Name Thomas Jefferson Elementary

HA# D

Type of Material Miscellaneous Material

Quantity of Material Unquantified Each

Material Location

Gym & throughout the building

Material Description

Fire Doors-Original to building (wooden)

Comments

These were noted during the June 2011 6 month surveillance and will remain in the management plan until properly sampled.

Does Material Contain Asbestos? Assumed

Is it Friable?

Original Inspection Date 6/27/2011

Current Surveillance Date 10/22/2014

Current Assessment Rating NA Not Applicable

Cause of Damage No Damage

Accessible Yes
Potential for Damage Low

Removed No

Planned Response Action O & M

Inspector _____

Benjamin S. Hood

State Indiana

LEA Name Greater Clark County Schools

Building Name Thomas Jefferson Elementary

HA# E

Type of Material Miscellaneous Material

Quantity of Material Unquantified LF

Material Location

Classrooms, Art Room & Teachers Lounge

Material Description

Gray Sink Insulation

Comments

This was noted during the June 2011 6 month surveillance and will remain in the management plan until properly sampled.

Does Material Contain Asbestos? Assumed

Is it Friable?

Original Inspection Date 6/27/2011

Current Surveillance Date 10/22/2014

Current Assessment Rating NA Not Applicable

Cause of Damage No Damage

Accessible Yes

Potential for Damage Low

Removed No

Planned Response Action O & M

Inspector

Benjamin S. Hood

State Indiana

LEA Name Greater Clark County Schools

Building Name Thomas Jefferson Elementary

HA# 01

Type of Material Thermal Material

Quantity of Material 10 LF

Material Location

Boiler room

Material Description

Pipe insulation

Comments

This material was not in poor condition along east wall near east boiler by tunnel entry. Scheduled for abatement in 2012/2013 renovation.

Does Material Contain Asbestos? Yes

Is it Friable?

Original Inspection Date 6/1/1992

Current Surveillance Date 4/21/2014

Current Assessment Rating NR Not Rated

Cause of Damage No Damage

Accessible Yes
Potential for Damage Low
Removed No

Planned Response Action Remove

Inspector

Jeffrey P. Rechtin

State Indiana

Greater Clark County Schools LEA Name Building Name Thomas Jefferson Elementary

HA# 02

Type of Material Thermal Material

230 LF **Quantity of Material**

Material Location Tunnels

Material Description

Pipe insulation

Comments

Entrances to tunnels are restricted, as this material is in poor condition. There is debris all over the floor of the dirt crawl. No one should enter this area without proper training and protection. Clean up recommended. Scheduled for abatement in 2012/2013 renovation.

Does Material Contain Asbestos? Yes Is it Friable? Yes

Original Inspection Date 6/1/1992 **Current Surveillance Date** 4/21/2014

Damaged TSI **Current Assessment Rating** 1B

Cause of Damage Physical Damage

Accessible Yes **Potential for Damage** Low No Removed

Planned Response Action Remove

Inspector

Jeffrey P. Rechtin

Indiana State **Accreditation Number** 19A003594

LEA Name Greater Clark County Schools

Building Name Thomas Jefferson Elementary

HA# 03

Type of Material Thermal Material

Quantity of Material 48 Each

Material Location

Boiler room and tunnel

Material Description

Fittings

Comments

Material in tunnel is in poor condition. Entry to tunnel is restricted. No one should enter without proper training and protection. Clean up recommended. Scheduled for abatement in 2012/2013 renovation.

Does Material Contain Asbestos? Yes
Is it Friable? Yes
Original Inspection Date 6/1/1992
Current Surveillance Date 4/21/2014

Current Assessment Rating 1B Damaged TSI

Cause of Damage Physical Damage

Accessible Yes
Potential for Damage Low
Removed No

Planned Response Action Remove

Inspector

Jeffrey P. Rechtin

LEA Name Greater Clark County Schools

Building Name Thomas Jefferson Elementary

HA# 05-A

Type of Material Miscellaneous Material

Quantity of Material Unquantified SF

Material Location

Throughout the building (classrooms, hallways & office)

Material Description

VAT-underneath carpet

Comments

Inspector

Floor Tile (installed in 1994)

Does Material Contain Asbestos? Yes Is it Friable? No

Original Inspection Date 6/1/1992
Current Surveillance Date 4/21/2014

Current Assessment Rating NR Not Rated

Cause of Damage No Damage

Accessible No
Potential for Damage Low
Removed No
Planned Response Action O & M

Jeffrey P. Rechtin

Greater Clark County Schools LEA Name Building Name Thomas Jefferson Elementary

HA# 05-B

Type of Material Miscellaneous Material

Unquantified SF **Quantity of Material**

Material Location

Throughout the building (first aid office, cafeteria, workroom, water fountain area, office hallway, entrance, and art room)

Material Description

12" x 12" newer off-white floor tile

Comments

Where visible, this material is not in poor condition.

Does Material Contain Asbestos? Yes Is it Friable? No

6/1/1992 **Original Inspection Date Current Surveillance Date** 4/21/2014

Not Rated NR **Current Assessment Rating**

Cause of Damage

Accessible Yes **Potential for Damage** Low Removed No O & M

Planned Response Action

Inspector

Jeffrey P. Rechtin

Indiana State

LEA Name Greater Clark County Schools
Building Name Thomas Jefferson Elementary

HA# 05-C

Type of Material Miscellaneous Material

Quantity of Material Unquantified SF

Material Location

Throughout the building (gym and custodial closets).

Material Description

12" x 12" original floor tile

Comments

Where visible, this material is not in poor condition.

Does Material Contain Asbestos? Yes
Is it Friable? No

Original Inspection Date 6/1/1992

Current Surveillance Date 4/21/2014

Current Assessment Rating NR Not Rated

Cause of Damage

Inspector

Accessible Yes
Potential for Damage Low
Removed No
Planned Response Action O & M

Jeffrey P. Rechtin

LEA Name Greater Clark County Schools

Building Name Thomas Jefferson Elementary

HA# 05-D

Type of Material Miscellaneous Material

Quantity of Material Unquantified SF

Material Location

Throughout the building (gym)

Material Description

12" x 12" original light blue floor tile

Comments

Where visible, this material is not in poor condition.

Does Material Contain Asbestos? Yes
Is it Friable? No

Original Inspection Date 6/1/1992

Current Surveillance Date 4/21/2014

Current Assessment Rating NR Not Rated

Cause of Damage

Inspector

Accessible Yes
Potential for Damage Low
Removed No
Planned Response Action O & M

Jeffrey P. Rechtin

LEA Name Greater Clark County Schools

Building Name Thomas Jefferson Elementary

HA# 07

Type of Material Miscellaneous Material

Quantity of Material 33,750 SF

Material Location

Throughout the building

Material Description

Mastic

Comments

Inspector

This material was not visible to inspect.

Does Material Contain Asbestos? Assumed

Is it Friable?

Original Inspection Date 6/1/1992

Current Surveillance Date 4/21/2014

Current Assessment Rating NR Not Rated

Cause of Damage No Damage

Accessible No
Potential for Damage Low
Removed No
Planned Response Action O & M

Jeffrey P. Rechtin

State Indiana

LEA Name Greater Clark County Schools

Building Name Thomas Jefferson Elementary

HA# 11

Type of Material Miscellaneous Material

Quantity of Material 6 Each

Material Location

Boiler room (2) Gym Exterior Doors (4)

Material Description

Fire door-Metal clad

Comments

Inspector

The fire door shell is intact with no core material visible to inspect.

Does Material Contain Asbestos? Assumed

Is it Friable?

Original Inspection Date 6/1/1992
Current Surveillance Date 4/21/2014

Current Assessment Rating NR Not Rated

Cause of Damage No Damage

Accessible Yes
Potential for Damage Low
Removed No
Planned Response Action O & M

i lainted Nesponse Action O & W

Jeffrey P. Rechtin

LEA Name Greater Clark County Schools

Building Name Thomas Jefferson Elementary

HA# 15

Type of Material Miscellaneous Material

Quantity of Material 2 Each

Material Location

Boiler room

Material Description

Boiler gaskets

Comments

Boiler doors were closed. The visible edges of this material were not in poor condition. There is some fiberglass rope visible, but also some older looking gasket material.

Does Material Contain Asbestos? Assumed

Is it Friable?

Original Inspection Date 6/1/1992

Current Surveillance Date 4/21/2014

Current Assessment Rating NR Not Rated

Cause of Damage No Damage

Accessible Yes
Potential for Damage Low
Removed No

Planned Response Action O & M

Inspector

Jeffrey P. Rechtin

State Indiana

LEA Name Greater Clark County Schools

Building Name Thomas Jefferson Elementary

HA# A

Type of Material Miscellaneous Material

Quantity of Material Approx. 3,800 LF

Material Location

Throughout the building

Material Description

Cove base

Comments

Material is not in poor condition overall with minor signs of wear. Loose and missing in a few locations. (installed in 1994)

Does Material Contain Asbestos? Assumed

Is it Friable?

Original Inspection Date 5/31/1995
Current Surveillance Date 4/21/2014

Current Assessment Rating NR Not Rated

Cause of Damage No Damage

Accessible Yes
Potential for Damage Low
Removed No

Planned Response Action O & M

Inspector

Jeffrey P. Rechtin

State Indiana

LEA Name Greater Clark County Schools

Building Name Thomas Jefferson Elementary

HA# B

Type of Material Miscellaneous Material

Quantity of Material Approx. 1,200 SF

Material Location

Throughout the building

Material Description

Cove base mastic

Comments

Mastic was visible to inspect at corner near custodial closet in the cafateria where cove base was missing.

Does Material Contain Asbestos? Assumed

Is it Friable?

Original Inspection Date 5/31/1995
Current Surveillance Date 4/21/2014

Current Assessment Rating NR Not Rated

Cause of Damage No Damage

Accessible No
Potential for Damage Low
Removed No

Planned Response Action O & M

Inspector

Jeffrey P. Rechtin

State Indiana

LEA Name Greater Clark County Schools

Building Name Thomas Jefferson Elementary

HA# C

Type of Material Miscellaneous Material

Quantity of Material 2 Each

Material Location

Stage Ends

Material Description

AHU Cloth Expansion Joints

Comments

These were noted during the June 2011 6 month surveillance and will remain in the management plan until properly sampled.

Does Material Contain Asbestos? Assumed

Is it Friable?

Original Inspection Date 6/27/2011

Current Surveillance Date 4/21/2014

Current Assessment Rating NA Not Applicable

Cause of Damage No Damage

Accessible Yes
Potential for Damage Low
Removed No

Planned Response Action O & M

,

State Indiana

LEA Name Greater Clark County Schools

Building Name Thomas Jefferson Elementary

HA# D

Type of Material Miscellaneous Material

Quantity of Material Unquantified Each

Material Location

Gym & throughout the building

Material Description

Fire Doors-Original to building (wooden)

Comments

These were noted during the June 2011 6 month surveillance and will remain in the management plan until properly sampled.

Does Material Contain Asbestos? Assumed

Is it Friable?

Original Inspection Date 6/27/2011

Current Surveillance Date 4/21/2014

Current Assessment Rating NA Not Applicable

Cause of Damage No Damage

Accessible Yes
Potential for Damage Low
Removed No

Planned Response Action O & M

Inspector

Jeffrey P. Rechtin

LEA Name Greater Clark County Schools

Building Name Thomas Jefferson Elementary

HA# E

Type of Material Miscellaneous Material

Quantity of Material Unquantified LF

Material Location

Classrooms, Art Room & Teachers Lounge

Material Description

Gray Sink Insulation

Comments

This was noted during the June 2011 6 month surveillance and will remain in the management plan until properly sampled.

Does Material Contain Asbestos? Assumed

Is it Friable?

Original Inspection Date 6/27/2011

Current Surveillance Date 4/21/2014

Current Assessment Rating NA Not Applicable

Cause of Damage No Damage

Accessible Yes
Potential for Damage Low
Removed No

Planned Response Action O & M

Inspector _____

Jeffrey P. Rechtin

State Indiana

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

01

Type of Material

Thermal Material

Quantity of Material

10 LF

Material Location

Boiler room

Material Description

Pipe insulation

Comments

This material was not in poor condition along east wall near east boiler by tunnel entry. Scheduled for abatement in 2012/2013 renovation.

Does Material Contain Asbestos?

Yes

Is it Friable?

No

Original Inspection Date

6/1/1992

Current Surveillance Date

10/24/2013

Current Assessment Rating

NR

Not Rated

Cause of Damage

No Damage

Accessible

Yes

Potential for Damage

Low

Removed

No

Planned Response Action

Remove

inspector

Jeffrev P. Rechtin

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

02

Type of Material

Thermal Material

Quantity of Material

230 LF

Material Location

Tunnels

Material Description

Pipe insulation

Comments

Entrances to tunnels are restricted, as this material is in poor condition. There is debris all over the floor of the dirt crawl. No one should enter this area without proper training and protection. Clean up recommended. Scheduled for abatement in 2012/2013 renovation.

Does Material Contain Asbestos?

Yes

Is it Friable?

Yes

Original Inspection Date

6/1/1992

Current Surveillance Date

10/24/2013

Current Assessment Rating

1B

Damaged TSI

Cause of Damage

Physical Damage

Accessible

Yes

Potential for Damage

Low

Removed

No

Planned Response Action

Remove

Inspector

Jeffrey P. Rechtin

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

03

Type of Material

Thermal Material

Quantity of Material

48 Each

Material Location

Boiler room and tunnel

Material Description

Fittings

Comments

Material in tunnel is in poor condition. Entry to tunnel is restricted. No one should enter without proper training and protection. Clean up recommended. Scheduled for abatement in 2012/2013 renovation.

Does Material Contain Asbestos?

Yes

Is it Friable?

Yes

Original Inspection Date

6/1/1992

Current Surveillance Date

10/24/2013

Current Assessment Rating

1B

Damaged TSI

Cause of Damage

Physical Damage

Accessible

Yes

Potential for Damage

Low

Removed

No

Planned Response Action

Remove

Inspector

Jeffrey P. Rechtin

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

05-A

Type of Material

Miscellaneous Material

Quantity of Material

Unquantified SF

Material Location

Throughout the building (classrooms, hallways & office)

Material Description

VAT-underneath carpet

Comments

Floor Tile (installed in 1994)

Does Material Contain Asbestos?

Yes

Is it Friable?

No

Original Inspection Date

6/1/1992

Current Surveillance Date

10/24/2013

Current Assessment Rating

NR

Not Rated

Cause of Damage

No Damage

Accessible

No

Potential for Damage

Low

Removed

No

Planned Response Action

0 & M

Inspector

Jeffrey P. Rechtin

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

05-B

Type of Material

Miscellaneous Material

Quantity of Material

Unquantified SF

Material Location

Throughout the building (first aid office, cafeteria, workroom, water fountain area, office

hallway, entrance, and art room)

Material Description

12" x 12" newer off-white floor tile

Comments

Where visible, this material is not in poor condition.

Does Material Contain Asbestos?

Yes

Is it Friable?

No

Original Inspection Date

6/1/1992

Current Surveillance Date

10/24/2013

Current Assessment Rating

NR

Not Rated

Cause of Damage

Accessible

Yes

Potential for Damage

Low

Removed

No

Planned Response Action

O & M

Inspector

Jeffrey P. Rechtin

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

05-C

Type of Material

Miscellaneous Material

Quantity of Material

Unquantified SF

Material Location

Throughout the building (gym and custodial closets).

Material Description

12" x 12" original floor tile

Comments

Where visible, this material is not in poor condition.

Does Material Contain Asbestos?

Yes

Is it Friable?

No

Original Inspection Date

6/1/1992

Current Surveillance Date

10/24/2013

Current Assessment Rating

NR

Not Rated

Cause of Damage

Accessible

Yes

Potential for Damage

Low

Removed

No

Planned Response Action

0 & M

Inspector

Jeffrey P. Rechtin

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

05-D

Type of Material

Miscellaneous Material

Quantity of Material

Unquantified SF

Material Location

Throughout the building (gym)

Material Description

12" x 12" original light blue floor tile

Comments

Where visible, this material is not in poor condition.

Does Material Contain Asbestos?

Yes

Is it Friable?

No

Original Inspection Date

6/1/1992

Current Surveillance Date

10/24/2013

Current Assessment Rating

NR

Not Rated

Cause of Damage

Accessible

Yes

Potential for Damage

Low

Removed

No

Planned Response Action

O & M

Inspector

Jeffrey P. Rechtin

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

07

Type of Material

Miscellaneous Material

Quantity of Material

33,750 SF

Material Location

Throughout the building

Material Description

Mastic

Comments

This material was not visible to inspect.

Does Material Contain Asbestos?

Assumed

Is it Friable?

No

Original Inspection Date

6/1/1992

Current Surveillance Date

10/24/2013

Current Assessment Rating

NR

Not Rated

Cause of Damage

No Damage

Accessible

No

Potential for Damage

Low

Removed

No

Planned Response Action

O & M

Inspector

Jeffrey P. Rechtin

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

11

Type of Material

Miscellaneous Material

Quantity of Material

6 Each

Material Location

Boiler room (2) Gym Exterior Doors (4)

Material Description

Fire door-Metal clad

Comments

The fire door shell is intact with no core material visible to inspect.

Does Material Contain Asbestos?

Assumed

Is it Friable?

No

Original Inspection Date

6/1/1992

Current Surveillance Date

10/24/2013

Current Assessment Rating

NR

Not Rated

Cause of Damage

No Damage

Accessible

Yes

Potential for Damage

Low

Removed

No

Planned Response Action

O & M

Inspector

Jeffrev P. Rechtir

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

15

Type of Material

Miscellaneous Material

Quantity of Material

2 Each

Material Location

Boiler room

Material Description

Boiler gaskets

Comments

Boiler doors were closed. The visible edges of this material were not in poor condition. There is some fiberglass rope visible, but also some older looking gasket material.

Does Material Contain Asbestos?

Assumed

Is it Friable?

No

Original Inspection Date

6/1/1992

Current Surveillance Date

10/24/2013

Current Assessment Rating

NR

Not Rated

Cause of Damage

No Damage

Accessible

Yes

Potential for Damage

Low

Removed

No

Planned Response Action

0 & M

Inspector

Jeffrey P. Rechtin

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

Α

Type of Material

Miscellaneous Material

Quantity of Material

Approx. 3,800 LF

Material Location

Throughout the building

Material Description

Cove base

Comments

Material is not in poor condition overall with minor signs of wear. Loose and missing in a few locations. (installed in 1994)

Does Material Contain Asbestos?

Assumed

Is it Friable?

No

Original Inspection Date

5/31/1995

Current Surveillance Date

10/24/2013

Current Assessment Rating

NR

Not Rated

Cause of Damage

No Damage

Accessible

Yes

Potential for Damage

Low

Removed

No

Planned Response Action

0 & M

Inspector

Jeffrey P. Rechtin

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

В

Type of Material

Miscellaneous Material

Quantity of Material

Approx. 1,200 SF

Material Location

Throughout the building

Material Description

Cove base mastic

Comments

Mastic was visible to inspect at corner near custodial closet in the cafateria where cove base was missing.

Does Material Contain Asbestos?

Assumed

is it Friable?

No

Original Inspection Date

5/31/1995

Current Surveillance Date

10/24/2013

Current Assessment Rating

NR

Not Rated

Cause of Damage

No Damage

Accessible

No

Potential for Damage

Low

Removed

No

Planned Response Action

O & M

Inspector

Jeffrey P. Rechtin

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

C

Type of Material

Miscellaneous Material

Quantity of Material

2 Each

Material Location

Stage Ends

Material Description

AHU Cloth Expansion Joints

Comments

These were noted during the June 2011 6 month surveillance and will remain in the management plan until properly sampled.

Does Material Contain Asbestos?

Assumed

Is it Friable?

No

Original Inspection Date

6/27/2011

Current Surveillance Date

10/24/2013

Current Assessment Rating

NA

Not Applicable

Cause of Damage

No Damage

Accessible

Yes

Potential for Damage

Low

Removed

No

Planned Response Action

O & M

Inspector

Jeffrey P. Rechtin

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

D

Type of Material

Miscellaneous Material

Quantity of Material

Unquantified Each

Material Location

Gym & throughout the building

Material Description

Fire Doors-Original to building (wooden)

Comments

These were noted during the June 2011 6 month surveillance and will remain in the management plan until properly sampled.

Does Material Contain Asbestos?

Assumed

Is it Friable?

No

Original Inspection Date

6/27/2011

Current Surveillance Date

10/24/2013

Current Assessment Rating

NA

Not Applicable

Cause of Damage

No Damage

Accessible

Yes

Potential for Damage

Low

Removed

No

Planned Response Action

O & M

Inspector

Jeffrey P. Rechtin

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

Ε

Type of Material

Miscellaneous Material

Quantity of Material

Unquantified LF

Material Location

Classrooms, Art Room & Teachers Lounge

Material Description

Gray Sink Insulation

Comments

This was noted during the June 2011 6 month surveillance and will remain in the management plan until properly sampled.

Does Material Contain Asbestos?

Assumed

Is it Friable?

No

Original Inspection Date

6/27/2011

Current Surveillance Date

10/24/2013

No Damage

Current Assessment Rating

NA

Not Applicable

Cause of Damage

Yes

Accessible

162

Potential for Damage

Low

Removed

No

Planned Response Action

0 & M

Inspector

State

Indiana

Accreditation Number

Greater Clark County Schools LEA Name Building Name

Thomas Jefferson Elementary

HA# 01

Type of Material Thermal Material

10 LF **Quantity of Material**

Material Location

Boiler room

Material Description

Pipe insulation

Comments

This material was not in poor condition along east wall near east boiler by tunnel entry. Scheduled for abatement in 2012/2013 renovation.

Does Material Contain Asbestos? Yes

Is it Friable? No

6/1/1992 **Original Inspection Date**

Current Surveillance Date 10/24/2012

Current Assessment Rating NR Not Rated

Cause of Damage No Damage

Accessible Yes

Potential for Damage Low

No Removed

Planned Response Action Remove

Inspector

Jeffrey P. Rechtin

Indiana State

19A003594 **Accreditation Number**

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

02

Type of Material

Thermal Material

Quantity of Material

230 LF

Material Location

Tunnels

Material Description

Pipe insulation

Comments

Entrances to tunnels are restricted, as this material is in poor condition. There is debris all over the floor of the dirt crawl. No one should enter this area without proper training and protection. Clean up recommended. Scheduled for abatement in 2012/2013 renovation.

Does Material Contain Asbestos?

Yes

Is it Friable?

Yes

Original Inspection Date

6/1/1992

Current Surveillance Date

10/24/2012

Current Assessment Rating

1B

Damaged TSI

Cause of Damage

Physical Damage

Accessible

Yes

Potential for Damage

Low

Removed

No

Planned Response Action

Remove

Inspector

Jeffrey P. Rechtin

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

03

Type of Material

Thermal Material

Quantity of Material

48 Each

Material Location

Boiler room and tunnel

Material Description

Fittings

Comments

Material in tunnel is in poor condition. Entry to tunnel is restricted. No one should enter without proper training and protection. Clean up recommended. Scheduled for abatement in 2012/2013 renovation.

Does Material Contain Asbestos?

Yes

Is it Friable?

Yes

Original Inspection Date

6/1/1992

Current Surveillance Date

10/24/2012

Current Assessment Rating

1B

Damaged TSI

Cause of Damage

Physical Damage

Accessible

Yes

Potential for Damage

Low

Removed

No

Planned Response Action

Remove

Inspector

Jeffrey P. Rechtin

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

05-A

Type of Material

Miscellaneous Material

Quantity of Material

Unquantified SF

Material Location

Throughout the building (classrooms, hallways & office)

Material Description

VAT-underneath carpet

Comments

Floor Tile (installed in 1994)

Does Material Contain Asbestos?

Yes

Is it Friable?

No

Original Inspection Date

6/1/1992

Current Surveillance Date

10/24/2012

Current Assessment Rating

NR

Not Rated

Cause of Damage

No Damage

No

Potential for Damage

Low

Removed

Accessible

No

Planned Response Action

0 & M

Inspector

Jeffrey P. Rechtin

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

05-B

Type of Material

Miscellaneous Material

Quantity of Material

Unquantified SF

Material Location

Throughout the building (first aid office, cafeteria, workroom, water fountain area, office hallway, entrance, and art room)

Material Description

12" x 12" newer off-white floor tile

Comments

Where visible, this material is not in poor condition.

Does Material Contain Asbestos?

Yes

Is it Friable?

No

Original Inspection Date

6/1/1992

Current Surveillance Date

10/24/2012

Current Assessment Rating

NR

Not Rated

Cause of Damage

Accessible

Yes

Potential for Damage

Low

Removed

No

Planned Response Action

0 & M

Inspector

Jeffrey P. Rechtin

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

05-C

Type of Material

Miscellaneous Material

Quantity of Material

Unquantified SF

Material Location

Throughout the building (gym and custodial closets).

Material Description

12" x 12" original floor tile

Comments

Where visible, this material is not in poor condition.

Does Material Contain Asbestos?

Yes

Is it Friable?

No

Original Inspection Date

6/1/1992

Current Surveillance Date

10/24/2012

Current Assessment Rating

NR

Not Rated

Cause of Damage

Accessible

Yes

Potential for Damage

Low

Removed

No

Planned Response Action

O & M

Inspector

Jeffrey P. Rechtin

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

05-D

Type of Material

Miscellaneous Material

Quantity of Material

Unquantified SF

Material Location

Throughout the building (gym)

Material Description

12" x 12" original light blue floor tile

Comments

Where visible, this material is not in poor condition.

Does Material Contain Asbestos?

Yes

Is it Friable?

No

Original Inspection Date

6/1/1992

Current Surveillance Date

10/24/2012

Current Assessment Rating

NR

Not Rated

Cause of Damage

Accessible

Yes

Potential for Damage

Low

Removed

No

Planned Response Action

O & M

Inspector

Jeffrey P. Rechtin

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

07

Type of Material

Miscellaneous Material

Quantity of Material

33,750 SF

Material Location

Throughout the building

Material Description

Mastic

Comments

This material was not visible to inspect.

Does Material Contain Asbestos?

Assumed

Is it Friable?

No

Original Inspection Date

6/1/1992

Current Surveillance Date

10/24/2012

No Damage

Current Assessment Rating

NR

Not Rated

Cause of Damage

No

Potential for Damage

Low

Removed

Accessible

No

Planned Response Action

O & M

Inspector

Jeffrey P. Rechtin

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

11

Type of Material

Miscellaneous Material

Quantity of Material

6 Each

Material Location

Boiler room (2) Gym Exterior Doors (4)

Material Description

Fire door-Metal clad

Comments

The fire door shell is intact with no core material visible to inspect.

Does Material Contain Asbestos?

Assumed

Is it Friable?

No

Original Inspection Date

6/1/1992

Current Surveillance Date

10/24/2012

Current Assessment Rating

NR

Cause of Damage

No Damage

Accessible

Yes

Potential for Damage

Low

Removed

No

Planned Response Action

0 & M

Inspector

Jeffrey P. Rechtin

Not Rated

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

15

Type of Material

Miscellaneous Material

Quantity of Material

2 Each

Material Location

Boiler room

Material Description

Boiler gaskets

Comments

Boiler doors were closed. The visible edges of this material were not in poor condition. There is some fiberglass rope visible, but also some older looking gasket material.

Does Material Contain Asbestos?

Assumed

Is it Friable?

No

Original Inspection Date

6/1/1992

Current Surveillance Date

10/24/2012

Current Assessment Rating

NR

Not Rated

Cause of Damage

No Damage

Accessible

Yes

Potential for Damage

Low

Removed

No

Planned Response Action

0 & M

Inspector

Jeffrey P. Rechtin

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

Α

Type of Material

Miscellaneous Material

Quantity of Material

Approx. 3,800 LF

Material Location

Throughout the building

Material Description

Cove base

Comments

Material is not in poor condition overall with minor signs of wear. Loose and missing in a few locations. (installed in 1994)

Does Material Contain Asbestos?

Assumed

Is it Friable?

No

Original Inspection Date

5/31/1995

Current Surveillance Date

10/24/2012

Current Assessment Rating

NR

Not Rated

Cause of Damage

No Damage

Accessible

Yes

Potential for Damage

Low

Removed

No

Planned Response Action

O & M

Inspector

Jeffrey P. Rechtin

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

В

Type of Material

Miscellaneous Material

Quantity of Material

Approx. 1,200 SF

Material Location

Throughout the building

Material Description

Cove base mastic

Comments

Mastic was visible to inspect at corner near custodial closet in the cafateria where cove base was missing.

Does Material Contain Asbestos?

Assumed

Is it Friable?

No

Original Inspection Date

5/31/1995

Current Surveillance Date

10/24/2012

Current Assessment Rating

NR

Not Rated

Cause of Damage

No Damage

Accessible

No

Potential for Damage

Low

Removed

No

Planned Response Action

O & M

Inspector

Jeffrey P. Rechtin

State

Indiana

Accreditation Number

LEA Name Greater Clark County Schools

Thomas Jefferson Flamenton

Building Name Thomas Jefferson Elementary

HA#

Type of Material Miscellaneous Material

Quantity of Material 2 Each

Material Location

Stage Ends

Material Description

AHU Cloth Expansion Joints

Comments

Inspector

These were noted during the June 2011 6 month surveillance and will remain in the management plan until properly sampled.

Does Material Contain Asbestos? Assumed

Is it Friable?

Original Inspection Date 6/27/2011

Current Surveillance Date 10/24/2012

Current Assessment Rating NA Not Applicable

Cause of Damage No Damage

Accessible Yes
Potential for Damage Low
Removed No

Planned Response Action O & M

Jeffrey P. Rechtin

State Indiana

Accreditation Number 19A003594

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

D

Type of Material

Miscellaneous Material

Quantity of Material

Unquantified Each

Material Location

Gym & throughout the building

Material Description

Fire Doors-Original to building (wooden)

Comments

These were noted during the June 2011 6 month surveillance and will remain in the management plan until properly sampled.

Does Material Contain Asbestos?

Assumed

Is it Friable?

No

Original Inspection Date

6/27/2011

Current Surveillance Date

10/24/2012

Current Assessment Rating

NA

Not Applicable

Cause of Damage

No Damage

Accessible

Yes

Potential for Damage

Low

Removed

No

Planned Response Action

O&M

Inspector

Jeffrey P. Rechtin

State

Indiana

Accreditation Number

LEA Name Greater Clark County Schools

Building Name Thomas Jefferson Elementary

HA# E

Type of Material Miscellaneous Material

Quantity of Material Unquantified LF

Material Location

Classrooms, Art Room & Teachers Lounge

Material Description

Gray Sink Insulation

Comments

State

This was noted during the June 2011 6 month surveillance and will remain in the management plan until properly sampled.

Does Material Contain Asbestos? Assumed

Is it Friable?

Original Inspection Date 6/27/2011

Current Surveillance Date 10/24/2012

Current Assessment Rating NA Not Applicable

Cause of Damage No Damage

Accessible Yes
Potential for Damage Low
Removed No

Planned Response Action O & M

Indiana

·

Accreditation Number 19A003594

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

01

Type of Material

Thermal Material

Quantity of Material

10 LF

Material Location

Boiler room

Material Description

Pipe insulation

Comments

This material was not in poor condition along east wall near east boiler by tunnel entry. Scheduled for abatement in 2012/2013 renovation.

Does Material Contain Asbestos?

Yes

Is it Friable?

No

Original Inspection Date

6/1/1992

Current Surveillance Date

6/25/2012

Current Assessment Rating

NR

Not Rated

Cause of Damage

No Damage

Accessible

Yes

Potential for Damage

Low

Removed

No

Planned Response Action

Remove

Inspector

Jeffery P. Rechtin

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

02

Type of Material

Thermal Material

Quantity of Material

230 LF

Material Location

Tunnels

Material Description

Pipe insulation

Comments

Entrances to tunnels are restricted, as this material is in poor condition. There is debris all over the floor of the dirt crawl. No one should enter this area without proper training and protection. Clean up recommended. Scheduled for abatement in 2012/2013 renovation.

Does Material Contain Asbestos?

Yes

Is it Friable?

Yes

Original Inspection Date

6/1/1992

Current Surveillance Date

6/25/2012

Current Assessment Rating

1B

Damaged TSI

Cause of Damage

Physical Damage

Accessible

Yes

Potential for Damage

Low

Removed

No

Planned Response Action

Remove

Inspector

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

03

Type of Material

Thermal Material

Quantity of Material

48 Each

Material Location

Boiler room and tunnel

Material Description

Fittings

Comments

Material in tunnel is in poor condition. Entry to tunnel is restricted. No one should enter without proper training and protection. Clean up recommended. Scheduled for abatement in 2012/2013 renovation.

Does Material Contain Asbestos?

Yes

Is it Friable?

Yes

Original Inspection Date

6/1/1992

Current Surveillance Date

6/25/2012

Current Assessment Rating

1B

Damaged TSI

Cause of Damage

Physical Damage Yes

Potential for Damage

Low

Removed

Accessible

.....

No

Planned Response Action

Remove

Inspector

Jewery P. Rech

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

05-A

Type of Material

Miscellaneous Material

Quantity of Material

Unquantified SF

Material Location

Throughout the building (classrooms, hallways & office)

Material Description

VAT-underneath carpet

Comments

Floor Tile (installed in 1994)

Does Material Contain Asbestos?

Yes

Is it Friable?

Νo

Original Inspection Date

6/1/1992

Current Surveillance Date

6/25/2012

Current Assessment Rating

NR

Not Rated

Cause of Damage

No Damage

Accessible

No

Potential for Damage

Low

Removed

No

Planned Response Action

0 & M

Inspector

Jeffery F. Rechtin

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

05-B

Type of Material

Miscellaneous Material

Quantity of Material

Unquantified SF

Material Location

Throughout the building (first aid office, cafeteria, workroom, water fountain area, office hallway, entrance, and art room)

Material Description

12" x 12" newer off-white floor tile

Comments

Where visible, this material is not in poor condition.

Does Material Contain Asbestos?

Yes

Is it Friable?

No

Original Inspection Date

6/1/1992

Current Surveillance Date

6/25/2012

Current Assessment Rating

NR

Not Rated

Cause of Damage

Accessible

Yes

Potential for Damage

Low

Removed

No

Planned Response Action

O & M

Inspector

Jeffery P. Rechtin

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

05-C

Type of Material

Miscellaneous Material

Quantity of Material

Unquantified SF

Material Location

Throughout the building (gym and custodial closets).

Material Description

12" x 12" original floor tile

Comments

Where visible, this material is not in poor condition.

Does Material Contain Asbestos?

Yes

Is it Friable?

No

Original Inspection Date

6/1/1992

Current Surveillance Date

6/25/2012

Current Assessment Rating

NR

Not Rated

Cause of Damage

Accessible

Yes

Potential for Damage

Low

Removed

No

Planned Response Action

O & M

Inspector

Jeffer P. Rechtin

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

05-D

Type of Material

Miscellaneous Material

Quantity of Material

Unquantified SF

Material Location

Throughout the building (gym)

Material Description

12" x 12" original light blue floor tile

Comments

Where visible, this material is not in poor condition.

Does Material Contain Asbestos?

Yes

Is it Friable?

No

Original Inspection Date

6/1/1992

Current Surveillance Date

6/25/2012

Current Assessment Rating

NR

Not Rated

Cause of Damage

Accessible

Yes

Potential for Damage

Low

Removed

No

Planned Response Action

0 & M

Inspector

/ Jeffery P. Rechtii

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

07

Type of Material

Miscellaneous Material

Quantity of Material

33,750 SF

Material Location

Throughout the building

Material Description

Mastic

Comments

This material was not visible to inspect.

Does Material Contain Asbestos?

Assumed

Is it Friable?

No

Original Inspection Date

6/1/1992

Current Surveillance Date

6/25/2012

Current Assessment Rating

NR

Not Rated

Cause of Damage

No Damage

Accessible

No

Potential for Damage

Low

Removed

No

Planned Response Action

O & M

Inspector

deffery P/-Rechtin

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

11

Type of Material

Miscellaneous Material

Quantity of Material

6 Each

Material Location

Boiler room (2) Gym Exterior Doors (4)

Material Description

Fire door-Metal clad

Comments

The fire door shell is intact with no core material visible to inspect.

Does Material Contain Asbestos?

Assumed

Is it Friable?

No

Original Inspection Date

6/1/1992

Current Surveillance Date

6/25/2012

Current Assessment Rating

NR

Not Rated

Cause of Damage

No Damage

Accessible

Yes

Potential for Damage

Low

Removed

No

Planned Response Action

O & M

Inspector

Jeffery P. Rechtin

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

15

Type of Material

Miscellaneous Material

Quantity of Material

2 Each

Material Location

Boiler room

Material Description

Boiler gaskets

Comments

Boiler doors were closed. The visible edges of this material were not in poor condition. There is some fiberglass rope visible, but also some older looking gasket material.

Does Material Contain Asbestos?

Assumed

Is it Friable?

No

Original Inspection Date

6/1/1992

Current Surveillance Date

6/25/2012

Current Assessment Rating

NR

Not Rated

Cause of Damage

No Damage

Accessible

Yes

Potential for Damage

Low

Removed

No

Planned Response Action

O & M

Inspector

Jeffery/P. Rechtin

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

Α

Type of Material

Miscellaneous Material

Quantity of Material

Approx. 3,800 LF

Material Location

Throughout the building

Material Description

Cove base

Comments

Material is not in poor condition overall with minor signs of wear. Loose and missing in a few locations. (installed in 1994)

Does Material Contain Asbestos?

Assumed

Is it Friable?

No

Original Inspection Date

5/31/1995

Current Surveillance Date

6/25/2012

Current Assessment Rating

NR

Not Rated

Cause of Damage

No Damage

Accessible

Yes

Potential for Damage

Low

Removed

No

Planned Response Action

O & M

Inspector

Jeffery P. Rechtin

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

В

Type of Material

Miscellaneous Material

Quantity of Material

Approx. 1,200 SF

Material Location

Throughout the building

Material Description

Cove base mastic

Comments

Mastic was visible to inspect at corner near custodial closet in the cafateria where cove base was missing.

Does Material Contain Asbestos?

Assumed

Is it Friable?

No

Original Inspection Date

5/31/1995

Current Surveillance Date

6/25/2012

Current Assessment Rating

NR

Not Rated

Cause of Damage

No Damage

Accessible

No

Potential for Damage

Low

Removed

No

Planned Response Action

O & M

Inspector

Jeffery P. Rechtin

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

C

Type of Material

Miscellaneous Material

Quantity of Material

2 Each

Material Location

Stage Ends

Material Description

AHU Cloth Expansion Joints

Comments

These were noted during the June 2011 6 month surveillance and will remain in the management plan until properly sampled.

Does Material Contain Asbestos?

Assumed

Is it Friable?

No

Original Inspection Date

6/27/2011

Current Surveillance Date

6/25/2012

Current Assessment Rating

NA

Not Applicable

Cause of Damage

No Damage

Accessible

Yes

Potential for Damage

Low

Removed

No

Planned Response Action

O & M

Inspector

Jeffery P. Rechtin

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

D

Type of Material

Miscellaneous Material

Quantity of Material

Unquantified Each

Material Location

Gym & throughout the building

Material Description

Fire Doors-Original to building (wooden)

Comments

These were noted during the June 2011 6 month surveillance and will remain in the management plan until properly sampled.

Does Material Contain Asbestos?

Assumed

Is it Friable?

No

Original Inspection Date

6/27/2011

Current Surveillance Date

6/25/2012

Current Assessment Rating

NA

Not Applicable

Cause of Damage

No Damage

Accessible

Yes

Potential for Damage

Low

Removed

No

Planned Response Action

0 & M

Inspector

Jeffery P Rechtin

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

Ε

Type of Material

Miscellaneous Material

Quantity of Material

Unquantified LF

Material Location

Classrooms, Art Room & Teachers Lounge

Material Description

Gray Sink Insulation

Comments

This was noted during the June 2011 6 month surveillance and will remain in the management plan until properly sampled.

Does Material Contain Asbestos?

Assumed

Is it Friable?

No

Original Inspection Date

6/27/2011

Current Surveillance Date

6/25/2012

Current Assessment Rating

NA

Not Applicable

Cause of Damage

No Damage

Accessible

Yes

Potential for Damage

Low

Removed

No

Planned Response Action

0 & M

Inspector

Jefferv P. Rechtin

State

Indiana

Accreditation Number

LEA Name Greater Clark County Schools Building Name

Thomas Jefferson Elementary

HA# 01

Thermal Material Type of Material

10 LF **Quantity of Material**

Material Location

Boiler room

Material Description

Pipe insulation

Comments

Inspector

This material was not in poor condition along east wall near east boiler by tunnel entry. Scheduled for abatement in 2012/2013 renovation.

Does Material Contain Asbestos? Yes

Is it Friable? No

Original Inspection Date 6/1/1992 **Current Surveillance Date** 6/27/2011

Current Assessment Rating NR Not Required

Cause of Damage No Damage

Accessible Yes **Potential for Damage** Low Removed No

Planned Response Action Remove

State Indiana

Accreditation Number 19A002323

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

02

Type of Material

Thermal Material

Quantity of Material

230 LF

Material Location

Tunnels

Material Description

Pipe insulation

Comments

Entrances to tunnels are restricted, as this material is in poor condition. There is debris all over the floor of the dirt crawl. No one should enter this area without proper training and protection. Clean up recommended. Scheduled for abatement in 2012/2013 renovation.

Does Material Contain Asbestos?

Yes

Is it Friable?

Yes

Original Inspection Date

6/1/1992

Current Surveillance Date

6/27/2011

Current Assessment Rating

1B

Damaged TSI

Cause of Damage

Physical Damage

Accessible

Yes

Potential for Damage

Low

Removed

No

Planned Response Action

Remove

Inspector

Sandra Shadlev

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

03

Type of Material

Thermal Material

Quantity of Material

48 Each

Material Location

Boiler room and tunnel

Material Description

Fittings

Comments

Material in tunnel is in poor condition. Entry to tunnel is restricted. No one should enter without proper training and protection. Clean up recommended. Scheduled for abatement in 2012/2013 renovation.

Does Material Contain Asbestos?

Yes

Is it Friable?

Yes

Original Inspection Date

6/1/1992

Current Surveillance Date

6/27/2011

Current Assessment Rating

1B

Damaged TSI

Cause of Damage

Physical Damage

Accessible

Yes

Potential for Damage

Low

Removed

No

Planned Response Action

Remove

Inspector

Sandra Shadley

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

05

Type of Material

Miscellaneous Material

Quantity of Material

33,750 SF

Material Location

Throughout the building (classrooms, hallways & office)

Material Description

VAT

Comments

Tile is underneath carpet (installed in 1994) in most areas. Where visible it is not in poor condition.

Does Material Contain Asbestos?

Yes

Is it Friable?

No

Original Inspection Date

6/1/1992

Current Surveillance Date

6/27/2011

Current Assessment Rating

NR

Not Required

Cause of Damage

No Damage

Accessible

No

Potential for Damage

Low

Removed

No

Planned Response Action

O & M

Inspector

Sandra Shadlev

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

07

Type of Material

Miscellaneous Material

Quantity of Material

33,750 SF

Material Location

Throughout the building

Material Description

Mastic

Comments

This material was not visible to inspect.

Does Material Contain Asbestos?

Assumed

is it Friable?

No

Original Inspection Date

6/1/1992

Current Surveillance Date

6/27/2011

Current Assessment Rating

NR

Cause of Damage

No Damage

Accessible

No

Potential for Damage

Low

Removed

No

Planned Response Action

O & M

Inspector

Sandra Shadley

Not Required

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

-11

Type of Material

Miscellaneous Material

Quantity of Material

6 Each

Material Location

Boiler room (2) Gym Exterior Doors (4)

Material Description

Fire door-Metal clad

Comments

The fire door shell is intact with no core material visible to inspect.

Does Material Contain Asbestos?

Assumed

Is it Friable?

Νo

Original Inspection Date

6/1/1992

Current Surveillance Date

6/27/2011

Current Assessment Rating

NR

Not Required

Cause of Damage

No Damage

Accessible

Yes

Potential for Damage

Low

Removed

No

Planned Response Action

O & M

Inspector

Sandra Shadlev

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

15

Type of Material

Miscellaneous Material

Quantity of Material

2 Each

Material Location

Boiler room

Material Description

Boiler gaskets

Comments

Boiler doors were closed. The visible edges of this material were not in poor condition. There is some fiberglass rope visible, but also some older looking gasket material.

Does Material Contain Asbestos?

Assumed

Is it Friable?

No

Original Inspection Date

6/1/1992

Current Surveillance Date

6/27/2011

Current Assessment Rating

NR

Not Required

Cause of Damage

No Damage

Accessible

Yes

Potential for Damage

Low

Removed

No

Planned Response Action

O & M

Inspector

Sandra Shadley

State

Indiana

Accreditation Number

LEA Name Greater Clark County Schools

Building Name Thomas Jefferson Elementary

HA# A

Type of Material Miscellaneous Material

Quantity of Material Approx. 3,800 LF

Material Location

Throughout the building

Material Description

Cove base

Comments

Inspector

State

Material is not in poor condition overall with minor signs of wear. Loose and missing in a few locations. (installed in 1994)

Does Material Contain Asbestos? Assumed

Is it Friable?

Original Inspection Date 5/31/1995
Current Surveillance Date 6/27/2011

Current Assessment Rating NR Not Required

Indiana

Cause of Damage No Damage

Accessible Yes
Potential for Damage Low
Removed No

Planned Response Action O & M

0

Accreditation Number 19A002323

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

В

Type of Material

Miscellaneous Material

Quantity of Material

Approx. 1,200 SF

Material Location

Throughout the building

Material Description

Cove base mastic

Comments

Mastic was visible to inspect at corner near custodial closet in the cafateria where cove base was missing.

Does Material Contain Asbestos?

Assumed

Is it Friable?

No

Original Inspection Date

5/31/1995

Current Surveillance Date

6/27/2011

Current Assessment Rating

NR

Not Required

Cause of Damage

No Damage

Accessible

No

Potential for Damage

Low

Removed

No

Planned Response Action

O & M

Inspector

Sandra Shadlev

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

C

Type of Material

Miscellaneous Material

Quantity of Material

2 Each

Material Location

Stage Ends

Material Description

AHU Cloth Expansion Joints

Comments

These were noted during the June 2011 6 month surveillance and will remain in the management plan until properly sampled.

Does Material Contain Asbestos?

Assumed

Is it Friable?

No

Original Inspection Date

6/27/2011

Current Surveillance Date

6/27/2011

Current Assessment Rating

NA

Not Applicable

Cause of Damage

No Damage

Accessible

Yes

Potential for Damage

Low

Removed

No

Planned Response Action

O & M

Inspector

Sandra Shadley

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

D

Type of Material

Miscellaneous Material

Quantity of Material

Unquantified Each

Material Location

Gym & throughout the building

Material Description

Fire Doors-Original to building (wooden)

Comments

These were noted during the June 2011 6 month surveillance and will remain in the management plan until properly sampled.

Does Material Contain Asbestos?

Assumed

Is it Friable?

No

Original Inspection Date

6/27/2011

Current Surveillance Date

6/27/2011

Current Assessment Rating

NA

Not Applicable

Cause of Damage

No Damage

Accessible

Yes

Potential for Damage

Low

Removed

No

Planned Response Action

O & M

Inspector

Sandra Shadley

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

Ε

Type of Material

Miscellaneous Material

Quantity of Material

Unquantified LF

Material Location

Classrooms, Art Room & Teachers Lounge

Material Description

Gray Sink Insulation

Comments

This was noted during the June 2011 6 month surveillance and will remain in the management plan until properly sampled.

Does Material Contain Asbestos?

Assumed

Is it Friable?

No

Original Inspection Date

6/27/2011

Current Surveillance Date

6/27/2011

Current Assessment Rating

NA

Not Applicable

Cause of Damage

No Damage

Accessible

Yes

Potential for Damage

Low

Removed

No

Planned Response Action

O & M

Inspector

Joendia Shadle

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

01

Type of Material

Thermal Material

Quantity of Material

10 LF

Material Location

Boiler room

Material Description

Pipe insulation

Comments

This material was not in poor condition along east wall near east boiler by tunnel entry.

Does Material Contain Asbestos?

Yes

Is it Friable?

No

Original Inspection Date

6/1/1992

Current Surveillance Date

12/6/2010

Current Assessment Rating

NR

Not Required

Cause of Damage

No Damage

Accessible

Yes

Potential for Damage

Low

Removed

No

Planned Response Action

O & M

Inspector

Paul W. Krick

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

02

Type of Material

Thermal Material

Quantity of Material

230 LF

Material Location

Tunnels

Material Description

Pipe insulation

Comments

Entrances to tunnels are restricted, as this material is in poor condition. There is debris all over the floor of the dirt crawl. No one should enter this area without proper training and protection. Clean up recommended.

Does Material Contain Asbestos?

Yes

Is it Friable?

Yes

Original Inspection Date

6/1/1992

Current Surveillance Date

12/6/2010

Current Assessment Rating

1B

Damaged TSI

Cause of Damage

Physical Damage

Accessible

Yes

Potential for Damage

Low

Removed

No

Planned Response Action

O & M

Inspector

Paul W. Krick

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

03

Type of Material

Thermal Material

Quantity of Material

48 Each

Material Location

Boiler room and tunnel

Material Description

Fittings

Comments

Material in tunnel is in poor condition. Entry to tunnel is restricted. No one should enter without proper training and protection. Clean up recommended.

Does Material Contain Asbestos?

Yes

Is it Friable?

Yes

Original Inspection Date

6/1/1992

Current Surveillance Date

12/6/2010

Current Assessment Rating

1B

Damaged TSI

Cause of Damage

Physical Damage

Accessible

Yes

Potential for Damage

Low

Removed

No

Planned Response Action

O & M

Inspector

Paul W. Krick

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

05

Type of Material

Miscellaneous Material

Quantity of Material

33,750 SF

Material Location

Throughout the building (classrooms, hallways & office)

Material Description

VAT

Comments

Tile is underneath carpet (installed in 1994) in most areas. Where visible it is not in poor condition.

Does Material Contain Asbestos?

Yes

Is it Friable?

No

Original Inspection Date

6/1/1992

Current Surveillance Date

12/6/2010

Current Assessment Rating

NR

Not Required

Cause of Damage

No Damage

Accessible

No

Potential for Damage

Low

Removed

No

Planned Response Action

O & M

Inspector

Paul W. Krick

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

07

Type of Material

Miscellaneous Material

Quantity of Material

33,750 SF

Material Location

Throughout the building

Material Description

Mastic

Comments

This material was not visible to inspect.

Does Material Contain Asbestos?

Assumed

Is it Friable?

No

Original Inspection Date

6/1/1992

Current Surveillance Date

12/6/2010

Current Assessment Rating

NR

Not Required

Cause of Damage

No Damage

Accessible

No

Potential for Damage

Low

Removed

No

Planned Response Action

O & M

Inspector

Paul W. Krick

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

11

Type of Material

Miscellaneous Material

Quantity of Material

30 SF

Material Location

Boiler room

Material Description

Fire door

Comments

The fire door shell is intact with no core material visible to inspect.

Does Material Contain Asbestos?

Assumed

Is it Friable?

Nο

Original Inspection Date

6/1/1992

Current Surveillance Date

12/6/2010

Current Assessment Rating

NR

Not Required

Cause of Damage

No Damage

Accessible

Yes

Potential for Damage

Low

Removed

No

Planned Response Action

O & M

Inspector

Paul W. Krick

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

15

Type of Material

Miscellaneous Material

Quantity of Material

2 Each

Material Location

Boiler room

Material Description

Boiler gaskets

Comments

Boiler doors were closed. The visible edges of this material were not in poor condition. There is some fiberglass rope visible, but also some older looking gasket material.

Does Material Contain Asbestos?

Assumed

Is it Friable?

No

Original Inspection Date

6/1/1992

Current Surveillance Date

12/6/2010

Current Assessment Rating

NR

Not Required

Cause of Damage

No Damage

Accessible

Yes

Potential for Damage

Low

Removed

No

Planned Response Action

O & M

Inspector

Paul W. Krick

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

Α

Type of Material

Miscellaneous Material

Quantity of Material

Approx. 3,800 LF

Material Location

Throughout the building

Material Description

Cove base

Comments

Material is not in poor condition overall with minor signs of wear. Loose and missing in a few locations. (installed in 1994)

Does Material Contain Asbestos?

Assumed

Is it Friable?

No

Original Inspection Date

5/31/1995

Current Surveillance Date

12/6/2010

Current Assessment Rating

NR

Not Required

Cause of Damage

No Damage

Accessible

Yes

Potential for Damage

Low

Removed

No

Planned Response Action

O & M

Inspector

Paul W. Krick

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

В

Type of Material

Miscellaneous Material

Quantity of Material

Approx. 1,200 SF

Material Location

Throughout the building

Material Description

Cove base mastic

Comments

Mastic was visible to inspect at corner near custodial closet in the cafateria where cove base was missing.

Does Material Contain Asbestos?

Assumed

is it Friable?

No

Original Inspection Date

5/31/1995

Current Surveillance Date

12/6/2010

Current Assessment Rating

NR

Not Required

Cause of Damage

No Damage

Accessible

No

Potential for Damage

Low

Removed

No

Planned Response Action

O & M

Inspector

Paul W. Krick

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

ilding Name

Thomas Jefferson Elementary

HA#

01

Type of Material

Thermal Material

Quantity of Material

10 LF

Material Location

Boiler room

Material Description

Pipe insulation

Comments

This material was not in poor condition.

Does Material Contain Asbestos?

Yes

Is it Friable?

No

Original Inspection Date

6/1/1992

Current Surveillance Date

12/4/2009

Current Assessment Rating

NR

Cause of Damage

No Damage

Accessible

Yes

otential for Damage

Low

Removed

No

Planned Response Action

O & M

Inspector

George William Ogle

Not Required

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

ilding Name

Thomas Jefferson Elementary

HA#

02

Type of Material

Thermal Material

Quantity of Material

230 LF

Material Location

Tunnels

Material Description

Pipe insulation

Comments

Entrances to tunnels are restricted, as this material is in poor condition. There is debris all over the floor of the dirt crawl. No one should enter this area without proper training and protection. Clean up recommended.

Does Material Contain Asbestos?

Yes

Is it Friable?

Yes

Original Inspection Date

6/1/1992

Current Surveillance Date

12/4/2009

Current Assessment Rating

1B

Damaged TSI

Cause of Damage

Physical Damage

ccessible

Yes

Potential for Damage

Low

Removed

No

Planned Response Action

O & M

Inspector

George William Ogle

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

silding Name

Thomas Jefferson Elementary

HA#

03

Type of Material

Thermal Material

Quantity of Material

48 Each

Material Location

Boiler room and tunnel

Material Description

Fittings

Comments

Material in tunnel is in poor condition. Entry to tunnel is restricted. No one should enter without proper training and protection. Clean up recommended.

Does Material Contain Asbestos?

Yes

Is it Friable?

Yes

Original Inspection Date

6/1/1992

Current Surveillance Date

12/4/2009

Current Assessment Rating

1B

Damaged TSI

Cause of Damage

Physical Damage

ccessible

Yes

rotential for Damage

Low

Removed

No

Planned Response Action

O & M

Inspector

0

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

ilding Name

Thomas Jefferson Elementary

HA#

05

Type of Material

Miscellaneous Material

Quantity of Material

33,750 SF

Material Location

Throughout the building (classrooms, hallways & office)

Material Description

VAT

Comments

Tile is underneath carpet in most areas. Where visible it is not in poor condition.

Does Material Contain Asbestos?

Yes

Is it Friable?

No

Original Inspection Date

6/1/1992

Current Surveillance Date

12/4/2009

Current Assessment Rating

NR

Not Required

Cause of Damage

No Damage

Accessible

No

otential for Damage

Low

Removed

No

Planned Response Action

O & M

Inspector

George William Ogle

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

ilding Name

Thomas Jefferson Elementary

HA#

07

Type of Material

Miscellaneous Material

Quantity of Material

33,750 SF

Material Location

Throughout the building

Material Description

Mastic

Comments

This material was not visible to inspect.

Does Material Contain Asbestos?

Assumed

Is it Friable?

No

Original Inspection Date

6/1/1992

Current Surveillance Date

12/4/2009

Current Assessment Rating

NR

Not Required

Cause of Damage

No Damage

Accessible

No

otential for Damage

Low

Removed

No

Planned Response Action

O & M

Inspector

George William Ogle

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

tilding Name

Thomas Jefferson Elementary

HA#

11

Type of Material

Miscellaneous Material

Quantity of Material

30 SF

Material Location

Boiler room

Material Description

Fire door

Comments

The fire door shell is intact with no core material visible to inspect.

Does Material Contain Asbestos?

Assumed

Is it Friable?

No

Original Inspection Date

6/1/1992

Current Surveillance Date

12/4/2009

Current Assessment Rating

NR

Not Required

Cause of Damage

No Damage

Accessible

Yes

otential for Damage

Low

Removed

No

Planned Response Action

0 & M

Inspector

George William Ogle

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Jilding Name

Thomas Jefferson Elementary

HA#

15

Type of Material

Miscellaneous Material

Quantity of Material

2 Each

Material Location

Boiler room

Material Description

Boiler gaskets

Comments

Boiler doors were closed. The visible edges of this material were not in poor condition. There is some fiberglass rope visible, but also some older looking gasket material.

Does Material Contain Asbestos?

Assumed

Is it Friable?

No

Original Inspection Date

6/1/1992

Current Surveillance Date

12/4/2009

Current Assessment Rating

NR

Not Required

Cause of Damage

No Damage

ccessible

Yes

Potential for Damage

Low

Removed

No

Planned Response Action

O & M

Inspector

George William Ogle

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

ilding Name

Thomas Jefferson Elementary

HA#

Α

Type of Material

Miscellaneous Material

Quantity of Material

Approx. 3,800 LF

Material Location

Throughout the building

Material Description

Cove base

Comments

Material is not in poor condition overall with minor signs of wear.

Does Material Contain Asbestos?

Assumed

Is it Friable?

No

Original Inspection Date

5/31/1995

Current Surveillance Date

12/4/2009

Current Assessment Rating

NR

Cause of Damage

No Damage

Accessible

Yes

otential for Damage

Low

Removed

No

Planned Response Action

M&O

Inspector

George William Ogle

Not Required

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

illding Name

Thomas Jefferson Elementary

HA#

В

Type of Material

Miscellaneous Material

Quantity of Material

Approx. 1,200 SF

Material Location

Throughout the building

Material Description

Cove base mastic

Comments

No mastic was visible to inspect.

Does Material Contain Asbestos?

Assumed

Is it Friable?

No

Original Inspection Date

5/31/1995

Current Surveillance Date

12/4/2009

Current Assessment Rating

NR

Not Required

Cause of Damage

No Damage

Accessible

No

otential for Damage

Low

Removed

No

Planned Response Action

O&M

Inspector

seorge William Ogle

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

uilding Name

Thomas Jefferson Elementary

HA#

01

Type of Material

Thermal Material

Quantity of Material

10 LF

Material Location

Boiler room

Material Description

Pipe insulation

Comments

This material was not in poor condition.

Does Material Contain Asbestos?

Yes

Is it Friable?

No

Original Inspection Date

6/1/1992

Current Surveillance Date

6/11/2009

Current Assessment Rating

NR

Not Required

Cause of Damage

No Damage

Accessible

Yes

otential for Damage

Low

Removed

No

Planned Response Action

O&M

Inspector

George William Ogle

State

IN

Accreditation Number

LEA Name

Greater Clark County Schools

3uilding Name

Thomas Jefferson Elementary

HA#

02

Type of Material

Thermal Material

Quantity of Material

230 LF

Material Location

Tunnels

Material Description

Pipe insulation

Comments

Entrances to tunnels are restricted, as this material is in poor condition. There is debris all over the floor of the dirt crawl. No one should enter this area without proper training and protection. Clean up recommended.

Does Material Contain Asbestos?

Yes

Is it Friable?

Yes

Original Inspection Date

6/1/1992

Current Surveillance Date

6/11/2009

Current Assessment Rating

1B

Damaged TSI

Cause of Damage

Physical Damage

Accessible

Yes

Potential for Damage

Low

Removed

No

Planned Response Action

0 & M

Inspector

George William Ogle

State

IN

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

03

Type of Material

Thermal Material

Quantity of Material

48 Each

Material Location

Boiler room and tunnel

Material Description

Fittings

Comments

Material in tunnel is in poor condition. Entry to tunnel is restricted. No one should enter without proper training and protection. Clean up recommended.

Does Material Contain Asbestos?

Yes

Is it Friable?

Yes

Original Inspection Date

6/1/1992

Current Surveillance Date

6/11/2009

Current Assessment Rating

1B

Damaged TSI

Cause of Damage

Physical Damage

Accessible

Yes

Potential for Damage

Low

Removed

No

Planned Response Action

0 & M

Inspector

eorge William Øgle

State

IN

Accreditation Number

LEA Name

Greater Clark County Schools

uilding Name

Thomas Jefferson Elementary

HA#

05

Type of Material

Miscellaneous Material

Quantity of Material

33,750 SF

Material Location

Throughout the building (classrooms, hallways & office)

Material Description

VAT

Comments

Tile is underneath carpet in most areas. Where visible it is not in poor condition.

Does Material Contain Asbestos?

Yes

is it Friable?

Nο

Original Inspection Date

6/1/1992

Current Surveillance Date

6/11/2009

Current Assessment Rating

NR

Not Required

Cause of Damage

No Damage

Accessible

No

otential for Damage

Low

Removed

No

Planned Response Action

O & M

Inspector

State

IN

Accreditation Number

LEA Name

Greater Clark County Schools

uilding Name

Thomas Jefferson Elementary

HA#

07

Type of Material

Miscellaneous Material

Quantity of Material

33,750 SF

Material Location

Throughout the building

Material Description

Mastic

Comments

This material was not visible to inspect.

Does Material Contain Asbestos?

Assumed

Is it Friable?

No

Original Inspection Date

6/1/1992

Current Surveillance Date

6/11/2009

Current Assessment Rating

NR

Not Required

Cause of Damage

No Damage

Accessible

No

otential for Damage

Low

Removed

No

Planned Response Action

O & M

Inspector

George William Ogle

State

IN

Accreditation Number

LEA Name

Greater Clark County Schools

uilding Name

Thomas Jefferson Elementary

HA#

11

Type of Material

Miscellaneous Material

Quantity of Material

30 SF

Material Location

Boiler room

Material Description

Fire door

Comments

The fire door shell is intact with no core material visible to inspect.

Does Material Contain Asbestos?

Assumed

Is it Friable?

No

Original Inspection Date

6/1/1992

Current Surveillance Date

6/11/2009

Current Assessment Rating

NR

Not Required

Cause of Damage

No Damage

Accessible

Yes

otential for Damage

Low

Removed

No

Planned Response Action

O & M

Inspector

George William Ogle

State

IN

Accreditation Number

LEA Name

Greater Clark County Schools

uilding Name

Thomas Jefferson Elementary

HA#

15

Type of Material

Miscellaneous Material

Quantity of Material

2 Each

Material Location

Boiler room

Material Description

Boiler gaskets

Comments

Boiler doors were closed. The visible edges of this material were not in poor condition. There is some fiberglass rope visible, but also some older looking gasket material.

Does Material Contain Asbestos?

Assumed

Is it Friable?

No

Original Inspection Date

6/1/1992

Current Surveillance Date

6/11/2009

Current Assessment Rating

NR

Not Required

Cause of Damage

No Damage

Accessible

Yes

Potential for Damage

Low

Removed

No

Planned Response Action

O & M

Inspector

Charge William C

State

IN

Accreditation Number

LEA Name

Greater Clark County Schools

uilding Name

Thomas Jefferson Elementary

HA#

Α

Type of Material

Miscellaneous Material

Quantity of Material

Approx. 3,800 LF

Material Location

Throughout the building

Material Description

Cove base

Comments

Material is not in poor condition overall with minor signs of wear.

Does Material Contain Asbestos?

Assumed

is it Friable?

No

Original Inspection Date

5/31/1995

Current Surveillance Date

6/11/2009

Current Assessment Rating

NR

Not Required

Cause of Damage

No Damage

Accessible

Yes

'otential for Damage

Low

Removed

No

Planned Response Action

O & M

Inspector

George William Ogle

State

!N

Accreditation Number

LEA Name

Greater Clark County Schools

uilding Name

Thomas Jefferson Elementary

HA#

В

Type of Material

Miscellaneous Material

Quantity of Material

Approx. 1,200 SF

Material Location

Throughout the building

Material Description

Cove base mastic

Comments

No mastic was visible to inspect.

Does Material Contain Asbestos?

Assumed

Is it Friable?

Nο

Original Inspection Date

5/31/1995

Current Surveillance Date

6/11/2009

Current Assessment Rating

NR

Not Required

Cause of Damage

No Damage

Accessible

No

'otential for Damage

Low

Removed

No

Planned Response Action

O & M

Inspector

George William Ogle

State

IN

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

01

Type of Material

Thermal Material

Quantity of Material

10 LF

Material Location

Boiler room

Material Description

Pipe insulation

Comments

This material was not in poor condition.

Does Material Contain Asbestos?

Yes

Is it Friable?

No

Original Inspection Date

6/1/1992

Current Surveillance Date

12/10/2008

Current Assessment Rating

NR

Not Required

Cause of Damage

No Damage

Accessible

Yes

Potential for Damage

Low

Removed

No

Planned Response Action

O & M

Inspector

George William Øgle

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

02

Type of Material

Thermal Material

Quantity of Material

230 LF

Material Location

Tunnels

Material Description

Pipe insulation

Comments

Entrances to tunnels are restricted, as this material is in poor condition. There is debris all over the floor of the dirt crawl. No one should enter this area without proper training and protection. Clean up recommended.

Does Material Contain Asbestos?

Yes

Is it Friable?

Yes

Original Inspection Date

6/1/1992

Current Surveillance Date

12/10/2008

Current Assessment Rating

1B

Damaged TSI

Cause of Damage

Physical Damage

Accessible

Yes

Potential for Damage

Low

Removed

No

Planned Response Action

O & M

Inspector

George William Ogle

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

03

Type of Material

Thermal Material

Quantity of Material

48 Each

Material Location

Boiler room and tunnel

Material Description

Fittings

Comments

Material in tunnel is in poor condition. Entry to tunnel is restricted. No one should enter without proper training and protection. Clean up recommended.

Does Material Contain Asbestos?

Yes

is it Friable?

Yes

Original Inspection Date

6/1/1992

Current Surveillance Date

12/10/2008

Current Assessment Rating

1B

Damaged TSI

Cause of Damage

Physical Damage

Accessible

Yes

Potential for Damage

Low

Removed

No

Planned Response Action

O & M

Inspector

Aprile William Ogle

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

05

Type of Material

Miscellaneous Material

Quantity of Material

33,750 SF

Material Location

Throughout the building (classrooms, hallways & office)

Material Description

VAT

Comments

Tile is underneath carpet in most areas. Where visible it is not in poor condition.

Does Material Contain Asbestos?

Yes

Is it Friable?

No

Original Inspection Date

6/1/1992

Current Surveillance Date

12/10/2008

Current Assessment Rating

NR

Not Required

Cause of Damage

No Damage

Accessible

No

Potential for Damage

Low

Removed

No

Planned Response Action

0 & M

Inspector

George William Ogle

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

07

Type of Material

Miscellaneous Material

Quantity of Material

33,750 SF

Material Location

Throughout the building

Material Description

Mastic

Comments

This material was not visible to inspect.

Does Material Contain Asbestos?

Assumed

Is it Friable?

No

Original Inspection Date

6/1/1992

Current Surveillance Date

12/10/2008

Current Assessment Rating

NR

Not Required

Cause of Damage

No Damage

Accessible

No

Potential for Damage

Low

Removed

No

Planned Response Action

O & M

Inspector

George William Ogle

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

11

Type of Material

Miscellaneous Material

Quantity of Material

30 SF

Material Location

Boiler room

Material Description

Fire door

Comments

The fire door shell is intact with no core material visible to inspect.

Does Material Contain Asbestos?

Assumed

Is it Friable?

No

Original Inspection Date

6/1/1992

Current Surveillance Date

12/10/2008

Current Assessment Rating

NR

Not Required

Cause of Damage

No Damage

Accessible

Yes

Potential for Damage

Low

Removed

No

Planned Response Action

0 & M

Inspector

eorge William Ogle

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

15

Type of Material

Miscellaneous Material

Quantity of Material

2 Each

Material Location

Boiler room

Material Description

Boiler gaskets

Comments

Boiler doors were closed. The visible edges of this material were not in poor condition. There is some fiberglass rope visible, but also some older looking gasket material.

Does Material Contain Asbestos?

Assumed

Is it Friable?

No

Original Inspection Date

6/1/1992

Current Surveillance Date

12/10/2008

Current Assessment Rating

NR

Not Required

Cause of Damage

No Damage

Accessible

Yes

Potential for Damage

Low

Removed

No

Planned Response Action

O & M

Inspector

George William Øgle

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

Α

Type of Material

Miscellaneous Material

Quantity of Material

Approx. 3,800 LF

Material Location

Throughout the building

Material Description

Cove base

Comments

Material is not in poor condition overall with minor signs of wear.

Does Material Contain Asbestos?

Assumed

Is it Friable?

No

Original Inspection Date

5/31/1995

Current Surveillance Date

12/10/2008

Current Assessment Rating

NR

Not Required

Cause of Damage

No Damage

Accessible

Yes

Potential for Damage

Low

Removed

No

Planned Response Action

O & M

Inspector

George William Ogle

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

В

Type of Material

Miscellaneous Material

Quantity of Material

Approx. 1,200 SF

Material Location

Throughout the building

Material Description

Cove base mastic

Comments

No mastic was visible to inspect.

Does Material Contain Asbestos?

Assumed

Is it Friable?

No

Original Inspection Date

5/31/1995

Current Surveillance Date

12/10/2008

Current Assessment Rating

NR

Not Required

Cause of Damage

No Damage

Accessible

No

Potential for Damage

Low

Removed

No

Planned Response Action

O & M

Inspector

George William Ogle

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

01

Type of Material

Thermal Material

Quantity of Material

10 LF

Material Location

Boiler room

Material Description

Pipe insulation

Comments

This material was not in poor condition.

Does Material Contain Asbestos?

Yes

Is it Friable?

No

Original Inspection Date

6/1/1992

Current Surveillance Date

6/30/2008

Current Assessment Rating

NR

Not Required

Cause of Damage

No Damage

Accessible

Yes

Potential for Damage

Low

Removed

No

Planned Response Action

0 & M

Inspector

George William Ogle

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

02

Type of Material

Thermal Material

Quantity of Material

230 LF

Material Location

Tunnels

Material Description

Pipe insulation

Comments

Entrances to tunnels are restricted, as this material is in poor condition. There is debris all over the floor of the dirt crawl. No one should enter this area without proper training and protection. Clean up recommended.

Does Material Contain Asbestos?

Yes

Is it Friable?

Yes

Original Inspection Date

6/1/1992

Current Surveillance Date

6/30/2008

Current Assessment Rating

1B

Damaged TSI

Cause of Damage

Physical Damage

Accessible

Yes

Potential for Damage

Low

Removed

No

Planned Response Action

O & M

Inspector

George William Øgle

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

03

Type of Material

Thermal Material

Quantity of Material

48 Each

Material Location

Boiler room and tunnel

Material Description

Fittings

Comments

Material in tunnel is in poor condition. Entry to tunnel is restricted. No one should enter without proper training and protection. Clean up recommended.

Does Material Contain Asbestos?

Yes

Is it Friable?

Yes

Original Inspection Date

6/1/1992

Current Surveillance Date

6/30/2008

Current Assessment Rating

1B

Damaged TSI

Cause of Damage

Physical Damage

Accessible

Yes

Potential for Damage

Low

Removed

No

Planned Response Action

O & M

Inspector

George William (

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

05

Type of Material

Miscellaneous Material

Quantity of Material

33,750 SF

Material Location

Throughout the building (classrooms, hallways & office)

Material Description

VAT

Comments

Tile is underneath carpet in most areas. Where visible it is not in poor condition.

Does Material Contain Asbestos?

Yes

Is it Friable?

No

Original Inspection Date

6/1/1992

Current Surveillance Date

6/30/2008

Current Assessment Rating

NR

Not Required

Cause of Damage

No Damage

Accessible

No

Potential for Damage

Low

Removed

No

Planned Response Action

O & M

Inspector

eorge William Øgle

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

07

Type of Material

Miscellaneous Material

Quantity of Material

33,750 SF

Material Location

Throughout the building

Material Description

Mastic

Comments

This material was not visible to inspect.

Does Material Contain Asbestos?

Assumed

Is it Friable?

No

Original Inspection Date

6/1/1992

Current Surveillance Date

6/30/2008

Current Assessment Rating

NR

Not Required

Cause of Damage

No Damage

Accessible

No

Potential for Damage

Low

Removed

Nο

Planned Response Action

O & M

Inspector

George William Ogle

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

11

Type of Material

Miscellaneous Material

Quantity of Material

30 SF

Material Location

Boiler room

Material Description

Fire door

Comments

The fire door shell is intact with no core material visible to inspect.

Does Material Contain Asbestos?

Assumed

ls it Friable?

No

Original Inspection Date

6/1/1992

Current Surveillance Date

6/30/2008

Current Assessment Rating

NR

Not Required

Cause of Damage

No Damage

Accessible

Yes

Potential for Damage

Low

Removed

No

Planned Response Action

O & M

Inspector

George William Og

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

15

Type of Material

Miscellaneous Material

Quantity of Material

2 Each

Material Location

Boiler room

Material Description

Boiler gaskets

Comments

Boiler doors were closed. The visible edges of this material were not in poor condition. There is some fiberglass rope visible, but also some older looking gasket material.

Does Material Contain Asbestos?

Assumed

Is it Friable?

No

Original Inspection Date

6/1/1992

Current Surveillance Date

6/30/2008

Current Assessment Rating

NR

Not Required

Cause of Damage

No Damage

Yes

Potential for Damage

Low

Removed

Accessible

No

Planned Response Action

O & M

Inspector

Georάe William Oαle

State

Indiana

Accreditation Number

_EA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

Α

Type of Material

Miscellaneous Material

Quantity of Material

Approx. 3,800 LF

Material Location

Throughout the building

Material Description

Cove base

Comments

Material is not in poor condition overall with minor signs of wear.

Does Material Contain Asbestos?

Assumed

Is it Friable?

Nο

Original Inspection Date

5/31/1995

Current Surveillance Date

6/30/2008

Current Assessment Rating

NR

Not Required

Cause of Damage

No Damage

Accessible

Yes

Potential for Damage

Low

Removed

No

Planned Response Action

O & M

Inspector

George William Øgle

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

В

Type of Material

Miscellaneous Material

Quantity of Material

Approx. 1,200 SF

Material Location

Throughout the building

Material Description

Cove base mastic

Comments

No mastic was visible to inspect.

Does Material Contain Asbestos?

Assumed

Is it Friable?

No

Original Inspection Date

5/31/1995

Current Surveillance Date

6/30/2008

Current Assessment Rating

NR

Not Required

Cause of Damage

No Damage

Accessible

No

Potential for Damage

Low

Removed

No

Planned Response Action

0 & M

Inspector

George William Og

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

01

Type of Material

Thermal Material

Quantity of Material

10 LF

Material Location

Boiler room

Material Description

Pipe insulation

Comments

This material was not in poor condition.

Does Material Contain Asbestos?

Yes

Is it Friable?

No

Original Inspection Date

6/1/1992

Current Surveillance Date

12/7/2007

Current Assessment Rating

NR

Not Required

Cause of Damage

No Damage

Accessible

Yes

Potential for Damage

Low

Removed

No

Planned Response Action

O & M

Inspector

George William Ogle

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

02

Type of Material

Thermal Material

Quantity of Material

230 LF

Material Location

Tunnels

Material Description

Pipe insulation

Comments

Entrances to tunnels are restricted, as this material is in poor condition. There is debris all over the floor of the dirt crawl. No one should enter this area without proper training and protection. Clean up recommended.

Does Material Contain Asbestos?

Yes

Is it Friable?

Yes

Original Inspection Date

6/1/1992

Current Surveillance Date

12/7/2007

Current Assessment Rating

1B

Damaged TSI

Cause of Damage

Physical Damage

Accessible

Yes

Potential for Damage

Low

Removed

No

Planned Response Action

O & M

Inspector

George William Ogle

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

03

Type of Material

Thermal Material

Quantity of Material

48 Each

Material Location

Boiler room and tunnel

Material Description

Fittings

Comments

Material in tunnel is in poor condition. Entry to tunnel is restricted. No one should enter without proper training and protection. Clean up recommended.

Does Material Contain Asbestos?

Yes

Is it Friable?

Yes

Original Inspection Date

6/1/1992

Current Surveillance Date

12/7/2007

Current Assessment Rating

1B

Damaged TSI

Cause of Damage

Physical Damage

Accessible

Yes

Potential for Damage

Low

Removed

No

Planned Response Action

O & M

Inspector

eorge William Ogle

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

05

Type of Material

Miscellaneous Material

Quantity of Material

33,750 SF

Material Location

Throughout the building (classrooms, hallways & office)

Material Description

VAT

Comments

Tile is underneath carpet in most areas. Where visible it is not in poor condition.

Does Material Contain Asbestos?

Yes

Is it Friable?

No

Original Inspection Date

6/1/1992

Current Surveillance Date

12/7/2007

Current Assessment Rating

NR

Not Required

Cause of Damage

No Damage

Accessible

No

Potential for Damage

Low

Removed

No

Planned Response Action

0 & M

Inspector

George William Ogle

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

07

Type of Material

Miscellaneous Material

Quantity of Material

33,750 SF

Material Location

Throughout the building

Material Description

Mastic

Comments

This material was not visible to inspect.

Does Material Contain Asbestos?

Assumed

Is it Friable?

No

Original Inspection Date

6/1/1992

Current Surveillance Date

12/7/2007

Current Assessment Rating

NR

Not Required

Cause of Damage

No Damage

Accessible

No

Potential for Damage

Low

Removed

No

Planned Response Action

O & M

Inspector

George William Ogle

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

11

Type of Material

Miscellaneous Material

Quantity of Material

30 SF

Material Location

Boiler room

Material Description

Fire door

Comments

The fire door shell is intact with no core material visible to inspect.

Does Material Contain Asbestos?

Assumed

Is it Friable?

No

Original Inspection Date

6/1/1992

Current Surveillance Date

12/7/2007

Current Assessment Rating

NR

Not Required

Cause of Damage

No Damage

Accessible

Yes

Potential for Damage

Low

Removed

No

Planned Response Action

O & M

Inspector

george/william

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

15

Type of Material

Miscellaneous Material

Quantity of Material

2 Each

Material Location

Boiler room

Material Description

Boiler gaskets

Comments

Boiler doors were closed. The visible edges of this material were not in poor condition. There is some fiberglass rope visible, but also some older looking gasket material.

Does Material Contain Asbestos?

Assumed

Is it Friable?

Nο

Original Inspection Date

6/1/1992

Current Surveillance Date

12/7/2007

Current Assessment Rating

NR

Not Required

Cause of Damage

No Damage

Accessible

Yes

Potential for Damage

Low

Removed

No

Planned Response Action

O & M

Inspector

George William Ogle

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

Α

Type of Material

Miscellaneous Material

Quantity of Material

Approx. 3,800 LF

Material Location

Throughout the building

Material Description

Cove base

Comments

Material is not in poor condition overall with minor signs of wear.

Does Material Contain Asbestos?

Assumed

Is it Friable?

No

Original Inspection Date

5/31/1995

Current Surveillance Date

12/7/2007

Current Assessment Rating

NR

Not Required

Cause of Damage

No Damage

Accessible

Yes

Potential for Damage

Low

Removed

No

Planned Response Action

O & M

Inspector

George William Øg

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

В

Type of Material

Miscellaneous Material

Quantity of Material

Approx. 1,200 SF

Material Location

Throughout the building

Material Description

Cove base mastic

Comments

No mastic was visible to inspect.

Does Material Contain Asbestos?

Assumed

Is it Friable?

No

Original Inspection Date

5/31/1995

Current Surveillance Date

12/7/2007

Current Assessment Rating

NR

Not Required

Cause of Damage

No Damage

Accessible

No

Potential for Damage

Low

Removed

No

Planned Response Action

0 & M

Inspector

Seorge William Ogle

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

01

Type of Material

Thermal Material

Quantity of Material

10 LF

Material Location

Boiler room

Material Description

Pipe insulation

Comments

This material was not in poor condition.

Does Material Contain Asbestos?

Yes

Is it Friable?

No

Original Inspection Date

6/1/1992

Current Surveillance Date

7/9/2007

Current Assessment Rating

NR

Not Required

Cause of Damage

No Damage

Accessible

Yes

Potential for Damage

Low

Removed

No

Planned Response Action

0 & M

Inspector

George William Ogl

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

02

Type of Material

Thermal Material

Quantity of Material

230 LF

Material Location

Tunnels

Material Description

Pipe insulation

Comments

Entrances to tunnels are restricted, as this material is in poor condition. There is debris all over the floor of the dirt crawl. No one should enter this area without proper training and protection. Clean up recommended.

Does Material Contain Asbestos?

Yes

Is it Friable?

Yes

Original Inspection Date

6/1/1992

Current Surveillance Date

7/9/2007

Current Assessment Rating

1B

Damaged TSI

Cause of Damage

Physical Damage

Accessible

Yes

Potential for Damage

Low

Removed

No

Planned Response Action

O & M

Inspector

George William Ogl

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

03

Type of Material

Thermal Material

Quantity of Material

48 Each

Material Location

Boiler room and tunnel

Material Description

Fittings

Comments

Material in tunnel is in poor condition. Entry to tunnel is restricted. No one should enter without proper training and protection. Clean up recommended.

Does Material Contain Asbestos?

Yes

Is it Friable?

Yes

Original Inspection Date

6/1/1992

Current Surveillance Date

7/9/2007

Current Assessment Rating

1B

Damaged TSI

Cause of Damage

Physical Damage

Accessible

Yes

Potential for Damage

Low

Removed

No

Planned Response Action

0 & M

Inspector

George William Ogle

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

05

Type of Material

Miscellaneous Material

Quantity of Material

33,750 SF

Material Location

Throughout the building (classrooms, hallways & office)

Material Description

VAT

Comments

Tile is underneath carpet in most areas. Where visible it is not in poor condition.

Does Material Contain Asbestos?

Yes

Is it Friable?

No

Original Inspection Date

6/1/1992

Current Surveillance Date

7/9/2007

Current Assessment Rating

NR

Not Required

Cause of Damage

No Damage

Accessible

No

Potential for Damage

Low

Removed

No

Planned Response Action

O & M

Inspector

George vvilliam ogi

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

07

Type of Material

Miscellaneous Material

Quantity of Material

33,750 SF

Material Location

Throughout the building

Material Description

Mastic

Comments

This material was not visible to inspect.

Does Material Contain Asbestos?

Assumed

Is it Friable?

No

Original Inspection Date

6/1/1992

Current Surveillance Date

7/9/2007

Current Assessment Rating

NR

Not Required

Cause of Damage

No Damage

Accessible

No

Potential for Damage

Low

Removed

No

Planned Response Action

O & M

Inspector

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

11

Type of Material

Miscellaneous Material

Quantity of Material

30 SF

Material Location

Boiler room

Material Description

Fire door

Comments

The fire door shell is intact with no core material visible to inspect.

Does Material Contain Asbestos?

Assumed

is it Friable?

No

Original Inspection Date

6/1/1992

Current Surveillance Date

7/9/2007

Current Assessment Rating

NR

Not Required

Cause of Damage

No Damage

Accessible

Yes

Potential for Damage

Low

Removed

No

Planned Response Action

0 & M

Inspector

seorge William Ogle

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

15

Type of Material

Miscellaneous Material

Quantity of Material

2 Each

Material Location

Boiler room

Material Description

Boiler gaskets

Comments

Boiler doors were closed. The visible edges of this material were not in poor condition. There is some fiberglass rope visible, but also some older looking gasket material.

Does Material Contain Asbestos?

Assumed

Is it Friable?

No

Original Inspection Date

6/1/1992

Current Surveillance Date

7/9/2007

Current Assessment Rating

NR

Not Required

Cause of Damage

No Damage

Accessible

Yes

Potential for Damage

Low

Removed

No

Planned Response Action

O & M

Inspector

George William Ogle

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

Α

Type of Material

Miscellaneous Material

Quantity of Material

Approx. 3,800 LF

Material Location

Throughout the building

Material Description

Cove base

Comments

Material is not in poor condition overall with minor signs of wear.

Does Material Contain Asbestos?

Assumed

Is it Friable?

No

Original Inspection Date

5/31/1995

Current Surveillance Date

7/9/2007

Current Assessment Rating

NR

Not Required

Cause of Damage

No Damage

Accessible

Yes

Potential for Damage

Low

Removed

No

Planned Response Action

O & M

Inspector

eorge William C

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

В

Type of Material

Miscellaneous Material

Quantity of Material

Approx. 1,200 SF

Material Location

Throughout the building

Material Description

Cove base mastic

Comments

No mastic was visible to inspect.

Does Material Contain Asbestos?

Assumed

Is it Friable?

No

Original Inspection Date

5/31/1995

Current Surveillance Date

7/9/2007

Current Assessment Rating

NR

Not Required

Cause of Damage

No Damage

Accessible

No

Potential for Damage

Low

Removed

No

Planned Response Action

O & M

Inspector

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

01

Type of Material

Thermal Material

Quantity of Material

10 LF

Material Location

Boiler room

Material Description

Pipe insulation

Comments

This material was not in poor condition.

Does Material Contain Asbestos?

Yes

Is it Friable?

No

Original Inspection Date

6/1/1992

Current Surveillance Date

12/19/2006

Current Assessment Rating

NR No Damage Not Required

Cause of Damage

Yes

Accessible

103

Potential for Damage

Low

Removed

No

Planned Response Action

0 & M

Inspector

George William Ogle

State

Indiana

Accreditation Number

Greater Clark County Schools LEA Name

Thomas Jefferson Elementary **Building Name**

HA# 02

Thermal Material Type of Material

230 LF Quantity of Material

Material Location

Tunnels

Material Description

Pipe insulation

Comments

Inspector

Entrances to tunnels are restricted, as this material is in poor condition. There is debris all over the floor of the dirt crawl. No one should enter this area without proper training and protection. Clean up recommended.

Yes **Does Material Contain Asbestos?**

Yes Is it Friable?

6/1/1992 **Original Inspection Date**

12/19/2006 **Current Surveillance Date**

Damaged TSI 1B **Current Assessment Rating**

Physical Damage **Cause of Damage**

Yes Accessible

Low **Potential for Damage**

No Removed

O & M Planned Response Action

Indiana State

191003027 **Accreditation Number**

LEA Name Greater Clark County Schools

Building Name Thomas Jefferson Elementary

HA# 03

Type of Material Thermal Material

Quantity of Material 48 Each

Material Location

Boiler room and tunnel

Material Description

Fittings

Comments

Material in tunnel is in poor condition. Entry to tunnel is restricted. No one should enter without proper training and protection. Clean up recommended.

Does Material Contain Asbestos? Yes
Is it Friable? Yes

Original Inspection Date 6/1/1992

Current Surveillance Date 12/19/2006

Current Assessment Rating 1B Damaged TSI

Cause of Damage Physical Damage

Accessible Yes
Potential for Damage Low
Removed No

Planned Response Action O & M

Inspector george William Ogle

State Indiana

Accreditation Number 191003027

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

05

Type of Material

Miscellaneous Material

Quantity of Material

33,750 SF

Material Location

Throughout the building (classrooms, hallways & office)

Material Description

VAT

Comments

Tile is underneath carpet in most areas. Where visible it is not in poor condition.

Does Material Contain Asbestos?

Yes

Is it Friable?

No

Original Inspection Date

6/1/1992

Current Surveillance Date

12/19/2006

Current Assessment Rating

NR

Not Required

Cause of Damage

No Damage

Accessible

No

Potential for Damage

Low

Removed

No

Planned Response Action

O & M

Inspector

George William Ogle

State

Indiana

Accreditation Number

LEA Name Greater Clark County Schools

Thomas Inffersor Elementary

Building Name Thomas Jefferson Elementary

HA# 07

Type of Material Miscellaneous Material

Quantity of Material 33,750 SF

Material Location

Throughout the building

Material Description

Mastic

Comments

This material was not visible to inspect.

Does Material Contain Asbestos? Assumed

Is it Friable?

Original Inspection Date 6/1/1992

Current Surveillance Date 12/19/2006

Current Assessment Rating NR Not Required

Cause of Damage No Damage

Accessible No

Potential for Damage Low

Removed No

Planned Response Action O & M

Inspector <u>George William Ogle</u>

State Indiana

Accreditation Number 191003027

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

11

Type of Material

Miscellaneous Material

Quantity of Material

30 SF

Material Location

Boiler room

Material Description

Fire door

Comments

The fire door shell is intact with no core material visible to inspect.

Does Material Contain Asbestos?

Assumed

Is it Friable?

No

Original Inspection Date

6/1/1992

Current Surveillance Date

12/19/2006

Current Assessment Rating

NR

Cause of Damage

No Damage

Accessible

Yes

Potential for Damage

Low

Removed

No

Planned Response Action

O & M

Inspector

George William Ogle

Not Required

State

Indiana

Accreditation Number

Greater Clark County Schools LEA Name

Thomas Jefferson Elementary **Building Name**

HA# 15

Miscellaneous Material Type of Material

2 Each **Quantity of Material**

Material Location

Boiler room

Material Description

Boiler gaskets

Comments

Boiler doors were closed. The visible edges of this material were not in poor condition. There is some fiberglass rope visible, but also some older looking gasket material.

Does Material Contain Asbestos? Assumed

No is it Friable?

6/1/1992 **Original Inspection Date**

12/19/2006 **Current Surveillance Date**

Not Required NR **Current Assessment Rating**

No Damage **Cause of Damage**

Yes **Accessible** Low **Potential for Damage**

No

Removed

O & M **Planned Response Action**

Inspector

Indiana State

191003027 **Accreditation Number**

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

Δ

Type of Material

Miscellaneous Material

Quantity of Material

Approx. 3,800 LF

Material Location

Throughout the building

Material Description

Cove base

Comments

Material is not in poor condition overall with minor signs of wear.

Does Material Contain Asbestos?

Assumed

Is it Friable?

No

Original Inspection Date

5/31/1995

Current Surveillance Date

12/19/2006

No Damage

Current Assessment Rating

NR

Not Required

Cause of Damage

Yes

Accessible

res

Potential for Damage

Low

Removed

No

Planned Response Action

O & M

Inspector

eorge William Ø

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

R

Type of Material

Miscellaneous Material

Quantity of Material

Approx. 1,200 SF

Material Location

Throughout the building

Material Description

Cove base mastic

Comments

No mastic was visible to inspect.

Does Material Contain Asbestos?

Assumed

Is it Friable?

No

Original Inspection Date

5/31/1995

Current Surveillance Date

12/19/2006

No Damage

Current Assessment Rating

NR

Not Required

Cause of Damage

No

Potential for Damage

Low

Removed

Accessible

Nο

Planned Response Action

O & M

Inspector

/deorge/William

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

01

Type of Material

Thermal Material

Quantity of Material

10 LF

Material Location

Boiler room

Material Description

Pipe insulation

Comments

This material was not in poor condition.

Does Material Contain Asbestos?

Yes

Is it Friable?

Yes

Original Inspection Date

6/1/1992

Current Surveillance Date

6/28/2006

Current Assessment Rating

5

ACBM with Potential for Damage

Cause of Damage

No Damage

Accessible

Yes

Potential for Damage

Low

Removed

Νo

Planned Response Action

O & M

Inspector

Christopher Ames

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

02

Type of Material

Thermal Material

Quantity of Material

230 LF

Material Location

Tunnels

Material Description

Pipe insulation

Comments

Entrances to tunnels are restricted, as this material is in poor condition. There is debris all over the floor of the dirt crawl. No one should enter this area without proper training and protection. Clean up recommended.

Does Material Contain Asbestos?

Yes

Is it Friable?

Yes

Original Inspection Date

6/1/1992

Current Surveillance Date

6/28/2006

Current Assessment Rating

1B

Damaged TSI

Cause of Damage

Physical Damage

Accessible

Yes

Potential for Damage

Low

Removed

No

Planned Response Action

O & M

Inspector

Christopher Ames

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

03

Type of Material

Thermal Material

Quantity of Material

48 Each

Material Location

Boiler room and tunnel

Material Description

Fittings

Comments

Material in tunnel is in poor condition. Entry to tunnel is restricted. No one should enter without proper training and protection. Clean up recommended.

Does Material Contain Asbestos?

Yes

Is it Friable?

Yes

Original Inspection Date

6/1/1992

Current Surveillance Date

6/28/2006

Current Assessment Rating

1B

Damaged TSI

Cause of Damage

Physical Damage

Accessible

Yes

Potential for Damage

Low

Removed

No

Planned Response Action

O & M

Inspector

Christopher Ames

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

05

Type of Material

Miscellaneous Material

Quantity of Material

33,750 SF

Material Location

Throughout the building (classrooms, hallways & office)

Material Description

VAT

Comments

Tile is underneath carpet in most areas. Where visible it is not in poor condition.

Does Material Contain Asbestos?

Yes

Is it Friable?

No

Original Inspection Date

6/1/1992

Current Surveillance Date

6/28/2006

Current Assessment Rating

NR

Not Required

Cause of Damage

No Damage

Accessible

No

Potential for Damage

Low

Removed

No

Planned Response Action

O & M

Inspector

Christopher Ames

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

07

Type of Material

Miscellaneous Material

Quantity of Material

33,750 SF

Material Location

Throughout the building

Material Description

Mastic

Comments

This material was not visible to inspect.

Does Material Contain Asbestos?

Assumed

Is it Friable?

No

Original Inspection Date

6/1/1992

Current Surveillance Date

6/28/2006

Current Assessment Rating

NR

Not Required

Cause of Damage

No Damage

Accessible

No

Potential for Damage

Low

Removed

No

Planned Response Action

O & M

Inspector

Christopher Ames

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

11

Type of Material

Miscellaneous Material

Quantity of Material

30 SF

Material Location

Boiler room

Material Description

Fire door

Comments

The fire door shell is intact with no core material visible to inspect.

Does Material Contain Asbestos?

Assumed

Is it Friable?

No

Original Inspection Date

6/1/1992

Current Surveillance Date

6/28/2006

Current Assessment Rating

NR

Not Required

Cause of Damage

No Damage

Accessible

Yes

Potential for Damage

Low

Removed

No

Planned Response Action

O & M

Inspector

Christopher Ames

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

15

Type of Material

Miscellaneous Material

Quantity of Material

2 Each

Material Location

Boiler room

Material Description

Boiler gaskets

Comments

Boiler doors were closed. The visible edges of this material were not in poor condition. There is some fiberglass rope visible, but also some older looking gasket material.

Does Material Contain Asbestos?

Assumed

Is it Friable?

No

Original Inspection Date

6/1/1992

Current Surveillance Date

6/28/2006

Current Assessment Rating

NR

Not Required

Cause of Damage

No Damage

Accessible

Yes

Potential for Damage

Low

Removed

No

Planned Response Action

O & M

Inspector

Christopher Ames

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

Α

Type of Material

Miscellaneous Material

Quantity of Material

Approx. 3,800 LF

Material Location

Throughout the building

Material Description

Cove base

Comments

Material is not in poor condition overall with minor signs of wear.

Does Material Contain Asbestos?

Assumed

ls it Friable?

No

Original Inspection Date

5/31/1995

Current Surveillance Date

6/28/2006

No Damage

Current Assessment Rating

NR

Not Required

Cause of Damage

Yes

Potential for Damage

Low

Removed

Accessible

No

Planned Response Action

O & M

Inspector

Christopher Ames

State

Indiana

Accreditation Number

'_EA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

В

Type of Material

Miscellaneous Material

Quantity of Material

Approx. 1,200 SF

Material Location

Throughout the building

Material Description

Cove base mastic

Comments

No mastic was visible to inspect.

Does Material Contain Asbestos?

Assumed

Is it Friable?

No

Original Inspection Date

5/31/1995

Current Surveillance Date

6/28/2006

Current Assessment Rating

NR

Not Required

Cause of Damage

No Damage

Accessible

No

Potential for Damage

Low

Removed

No

Planned Response Action

O & M

Inspector

Christopher Ames

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

01

Type of Material

Thermal Material

Quantity of Material

10 LF

Material Location

Boiler room

Material Description

Pipe insulation

Comments

This material was not in poor condition.

Does Material Contain Asbestos?

Yes

Is it Friable?

Yes

Original Inspection Date

6/1/1992

Current Surveillance Date

1/23/2006

Current Assessment Rating

5

ACBM with Potential for Damage

Cause of Damage

No Damage

Accessible

Yes

Potential for Damage

Low

Removed

No

Planned Response Action

O & M

Inspector

eorge/William Ogle

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

02

Type of Material

Thermal Material

Quantity of Material

230 LF

Material Location

Tunnels

Material Description

Pipe insulation

Comments

Entrances to tunnels are restricted, as this material is in poor condition. There is debris all over the floor of the dirt crawl. No one should enter this area without proper training and protection. Clean up recommended.

Does Material Contain Asbestos?

Yes

Is it Friable?

Yes

Original Inspection Date

6/1/1992

Current Surveillance Date

1/23/2006

Current Assessment Rating

1B

Damaged TSI

Cause of Damage

Physical Damage

Accessible

Yes

Potential for Damage

Low

Removed

No

Planned Response Action

O & M

Inspector

eorge William Ogle

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

03

Type of Material

Thermal Material

Quantity of Material

48 Each

Material Location

Boiler room and tunnel

Material Description

Fittings

Comments

Material in tunnel is in poor condition. Entry to tunnel is restricted. No one should enter without proper training and protection. Clean up recommended.

Does Material Contain Asbestos?

Yes

Is it Friable?

Yes

Original Inspection Date

6/1/1992

Current Surveillance Date

1/23/2006

Current Assessment Rating

1B

Damaged TSI

Cause of Damage

Physical Damage

Accessible

Yes

Potential for Damage

Low

Removed

No

Planned Response Action

O & M

Inspector

ebrge William Ogle

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

05

Type of Material

Miscellaneous Material

Quantity of Material

33,750 SF

Material Location

Throughout the building (classrooms, hallways & office)

Material Description

VAT

Comments

This material was not in poor condition overall.

Does Material Contain Asbestos?

Yes

Is it Friable?

No

Original Inspection Date

6/1/1992

Current Surveillance Date

1/23/2006

Current Assessment Rating

NR

Not Required

Cause of Damage

No Damage

Accessible

No

Potential for Damage

Low

Removed

No

Planned Response Action

O & M

Inspector

eorge William Ogle

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

07

Type of Material

Miscellaneous Material

Quantity of Material

33,750 SF

Material Location

Throughout the building

Material Description

Mastic

Comments

This material was not visible to inspect.

Does Material Contain Asbestos?

Assumed

Is it Friable?

No

Original Inspection Date

6/1/1992

Current Surveillance Date

1/23/2006

Current Assessment Rating

NR

Not Required

Cause of Damage

No Damage

Accessible

No

Potential for Damage

Low

Removed

No

Planned Response Action

O & M

Inspector

Seorge William Ogle

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

11

Type of Material

Miscellaneous Material

Quantity of Material

30 SF

Material Location

Boiler room

Material Description

Fire door

Comments

The fire door shell is intact with no core material visible to inspect.

Does Material Contain Asbestos?

Assumed

Is it Friable?

No

Original Inspection Date

6/1/1992

Current Surveillance Date

1/23/2006

Current Assessment Rating

NR

Not Required

Cause of Damage

No Damage

Accessible

Yes

Potential for Damage

Low

Removed

No

Planned Response Action

0 & M

Inspector

e∕orge XV*i*lliam Ogle

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

15

Type of Material

Miscellaneous Material

Quantity of Material

2 Each

Material Location

Boiler room

Material Description

Boiler gaskets

Comments

Boiler doors were closed. The visible edges of this material were not in poor condition. There is some fiberglass rope visible, but also some older looking gasket material.

Does Material Contain Asbestos?

Assumed

Is it Friable?

No

Original Inspection Date

6/1/1992

Current Surveillance Date

1/23/2006

Current Assessment Rating

NR

Not Required

Cause of Damage

No Damage

Accessible

Yes

Potential for Damage

Low

Removed

No

Planned Response Action

O & M

Inspector

eorge William Ogle

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

Α

Type of Material

Miscellaneous Material

Quantity of Material

Approx. 3,800 LF

Material Location

Throughout the building

Material Description

Cove base

Comments

Material is not in poor condition overall with minor signs of wear.

Does Material Contain Asbestos?

Assumed

Is it Friable?

No

Original Inspection Date

5/31/1995

Current Surveillance Date

1/23/2006

Current Assessment Rating

NR

Not Required

Cause of Damage

No Damage

Accessible

Yes

Potential for Damage

Low

Removed

No

Planned Response Action

0 & M

Inspector

ebrge William Ogle

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

В

Type of Material

Miscellaneous Material

Quantity of Material

Approx. 1,200 SF

Material Location

Throughout the building

Material Description

Cove base mastic

Comments

No mastic was visible to inspect.

Does Material Contain Asbestos?

Assumed

Is it Friable?

No

Original Inspection Date

5/31/1995

Current Surveillance Date

1/23/2006

Current Assessment Rating

NR

Not Required

Cause of Damage

No Damage

Accessible

No

Potential for Damage

Low

Removed

No

Planned Response Action

O & M


Inspector

George William Ogle

State

Indiana

Accreditation Number



Greater Clark County Schools LEA Name Thomas Jefferson Elementary

01

Building Name

Thermal Material Type of Material

10 LF **Quantity of Material**

Material Location

Boiler room

Material Description

Pipe insulation

Comments

Inspector

State

HA#

There is a 10 ' run of mag left in the boiler room. It is not in poor condition.

Does Material Contain Asbestos? Yes

Yes Is it Friable?

6/1/1992 **Original Inspection Date** 7/20/2005 **Current Surveillance Date**

ACBM with Potential for Damage **Current Assessment Rating**

Indiana

No Damage Cause of Damage

Accessible Yes Low Potential for Damage No Removed

0 & M **Planned Response Action**

191523030 **Accreditation Number**

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

02

Type of Material

Thermal Material

Quantity of Material

230 LF

Material Location

Tunnels

Material Description

Pipe insulation

Comments

Entrances to tunnels are restricted, as this material is in poor condition. There is debris all over the floor of the dirt crawl. No one should enter this area without proper training and protection. Clean up recommended.

Does Material Contain Asbestos?

Yes

Is it Friable?

Yes

Original Inspection Date

6/1/1992

Current Surveillance Date

7/20/2005

Current Assessment Rating

1B

Damaged TSI

Cause of Damage

Physical Damage

Accessible

Yes

Potential for Damage

Low

Removed

No

Planned Response Action

O & M

Inspector

George William Øgl

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

03

Type of Material

Thermal Material

Quantity of Material

48 Each

Material Location

Boiler room and tunnel

Material Description

Fittings

Comments

Material in tunnel is in poor condition. Entry to tunnel is restricted. No one should enter without proper training and protection. Clean up recommended.

Does Material Contain Asbestos?

Yes

Is it Friable?

Yes

Original Inspection Date

6/1/1992

Current Surveillance Date

7/20/2005

Current Assessment Rating

1B

Damaged TSI

Cause of Damage

Physical Damage

Accessible

Yes

Potential for Damage

Low

Removed

No

Planned Response Action

M&O

Inspector

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

05

Type of Material

Miscellaneous Material

Quantity of Material

33,750 SF

Material Location

Throughout the building (classrooms, hallways & office)

Material Description

VAT

Comments

The only suspect material that was visible to inspect was in the gymnasium. It has a center area of light brown 12" X 12" with a newer looking light blue 12" X 12" around the perimeter of the basketball playing area. All other tile found is the new white 12" X 12". Two samples of gymnasium floor tile were takwn 7/6/1988. They were negative for asbestos content.

Does Material Contain Asbestos?

Yes

Is it Friable?

No

Original Inspection Date

6/1/1992

Current Surveillance Date

7/20/2005

Current Assessment Rating

NR

Not Required

Cause of Damage

No Damage

Accessible

No

Potential for Damage

Low

Removed

No

Planned Response Action

0 & M

Inspector

George William Ogle

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

07

Type of Material

Miscellaneous Material

Quantity of Material

33,750 SF

Material Location

Throughout the building

Material Description

Mastic

Comments

This material was not visible to inspect.

Does Material Contain Asbestos?

Assumed

Is it Friable?

No

Original Inspection Date

6/1/1992

Current Surveillance Date

7/20/2005

Current Assessment Rating

NR

Not Required

Cause of Damage

No Damage

Accessible

No

Potential for Damage

Low

Removed

No

Planned Response Action

0 & M

Inspector

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

11

Type of Material

Miscellaneous Material

Quantity of Material

30 SF

Material Location

Boiler room

Material Description

Fire door

Comments

The fire door is not in poor condition with no core material visible to inspect.

Does Material Contain Asbestos?

Assumed

Is it Friable?

No

Original Inspection Date

6/1/1992

Current Surveillance Date

7/20/2005

Current Assessment Rating

NR

Not Required

Cause of Damage

No Damage

Accessible

Yes

Potential for Damage

Low

Removed

Nο

Planned Response Action

O & M

Inspector

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

15

Type of Material

Miscellaneous Material

Quantity of Material

2 Each

Material Location

Boiler room

Material Description

Boiler gaskets

Comments

Boiler doors were closed. The visible edges of this material were not in poor condition. There is some fiberglass rope visible, but also some older looking gasket material.

Does Material Contain Asbestos?

Assumed

Is it Friable?

No

Original Inspection Date

6/1/1992

Current Surveillance Date

7/20/2005

Current Assessment Rating

NR

Not Required

Cause of Damage

No Damage

Accessible

Yes

Potential for Damage

Low

Removed

No

Planned Response Action

0 & M

Inspector

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

Α

Type of Material

Miscellaneous Material

Quantity of Material

Approx. 3,800 LF

Material Location

Throughout the building

Material Description

Cove base

Comments

Material is not in poor condition overall with minor signs of wear. The pieces coming off the wall by the boys' restroom near the main entrance and in the cafeteria have been reglued.

Does Material Contain Asbestos?

Assumed

Is it Friable?

No

Original Inspection Date

5/31/1995

Current Surveillance Date

7/20/2005

Current Assessment Rating

NR

Not Required

Cause of Damage

No Damage

Accessible

Yes

Potential for Damage

Low

Removed

No

Planned Response Action

0 & M

Inspector

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

В

Type of Material

Miscellaneous Material

Quantity of Material

Approx. 1,200 SF

Material Location

Throughout the building

Material Description

Cove base mastic

Comments

No mastic was visible to inspect.

Does Material Contain Asbestos?

Assumed

Is it Friable?

No

Original Inspection Date

5/31/1995

Current Surveillance Date

7/20/2005

Current Assessment Rating

NR

Not Required

Cause of Damage

No Damage

Accessible

No

Potential for Damage

Low

Removed

No

Planned Response Action


0 & M

Inspector

State

Indiana

Accreditation Number



LEA Name Greater Clark County Schools

Building Name Thomas Jefferson Elementary

HA# 01

Type of Material Thermal Material

Quantity of Material 10 LF

Material Location

Boiler room

Material Description

Pipe insulation

Comments

There is a 10 ' run of mag left in the boiler room. It is not in poor condition.

Does Material Contain Asbestos? Yes

Is it Friable? Yes

Original Inspection Date 6/1/1992
Current Surveillance Date 12/9/2004

Current Assessment Rating 5 ACBM with Potential for Damage

Cause of Damage No Damage

Accessible Yes
Potential for Damage Low
Removed No

Planned Response Action 0 & M

Inspector Christiaan Sparks

State Indiana

Accreditation Number 190804103

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

02

Type of Material

Thermal Material

Quantity of Material

230 LF

Material Location

Tunnels

Material Description

Pipe insulation

Comments

Entrances to tunnels are restricted, as this material is in poor condition. There is debris all over the floor of the dirt crawl. No one should enter this area without proper training and protection. Clean up recommended.

Does Material Contain Asbestos?

Yes

Is it Friable?

Yes

Original Inspection Date

6/1/1992

Current Surveillance Date

12/9/2004

Current Assessment Rating

1B

Damaged TSI

Cause of Damage

Physical Damage

Accessible

Yes

Potential for Damage

Low

Removed

No

Planned Response Action

0 & M

Inspector

Christiaan Sparks

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

03

Type of Material

Thermal Material

Quantity of Material

48 Each

Material Location

Boiler room and tunnel

Material Description

Fittings

Comments

The minor damage in the boiler room has been repaired. Material in tunnel is in poor condition. Entry to tunnel is restricted. No one should enter without proper training and protection. Clean up recommended.

Does Material Contain Asbestos?

Yes

Is it Friable?

Yes

Original Inspection Date

6/1/1992

Current Surveillance Date

12/9/2004

Current Assessment Rating

1B

Damaged TSI

Cause of Damage

Physical Damage

Accessible

Yes

Potential for Damage

Low

Removed

No

Planned Response Action

0 & M

Inspector

Christiaan Sparks

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

05

Type of Material

Miscellaneous Material

Quantity of Material

33,750 SF

Material Location

Throughout the building (classrooms, hallways & office)

Material Description

VAT

Comments

All areas seen during this surveillance were found to either be carpeted or have a newer 12" X 12" white and gray streaked floor tile. No suspect material was visible to inspect.

Does Material Contain Asbestos?

Yes

Is it Friable?

No

Original Inspection Date

6/1/1992

Current Surveillance Date

12/9/2004

Current Assessment Rating

NR

Not Required

Cause of Damage

No Damage

Accessible

No

Potential for Damage

Low

Removed

No

Planned Response Action

0 & M

Inspector

Christiaan Sparks

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

07

Type of Material

Miscellaneous Material

Quantity of Material

33,750 SF

Material Location

Throughout the building

Material Description

Mastic

Comments

This material was not visible to inspect.

Does Material Contain Asbestos?

Assumed

Is it Friable?

No

Original Inspection Date

6/1/1992

Current Surveillance Date

12/9/2004

Current Assessment Rating

NR

Not Required

Cause of Damage

No Damage

Accessible

Νo

Potential for Damage

Low

Removed

No

Planned Response Action

0 & M

Inspector

Christiaan Sparks

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

11

Type of Material

Miscellaneous Material

Quantity of Material

30 SF

Material Location

Boiler room

Material Description

Fire door

Comments

The fire door is not in poor condition with no core material visible to inspect.

Does Material Contain Asbestos?

Assumed

Is it Friable?

No

Original Inspection Date

6/1/1992

Current Surveillance Date

12/9/2004

Current Assessment Rating

NR

Not Required

Cause of Damage

Potential for Damage

No Damage Yes

Accessible

Low

Removed

No

Planned Response Action

0 & M

Inspector

Christiaan Sparks

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

15

Type of Material

Miscellaneous Material

Quantity of Material

2 Each

Material Location

Boiler room

Material Description

Boiler gaskets

Comments

Boiler doors were closed. The visible edges of this material were not in poor condition.

Does Material Contain Asbestos?

Assumed

Is it Friable?

Nο

Original Inspection Date

6/1/1992

Current Surveillance Date

12/9/2004

Current Assessment Rating

NR

Not Required

Cause of Damage

No Damage

Accessible

Yes

Potential for Damage

Low

Removed

No

Planned Response Action

0 & M

Inspector

Christiaan Sparks

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

Type of Material

Miscellaneous Material

Quantity of Material

Approx. 3,800 LF

Material Location

Throughout the building

Material Description

Cove base

Comments

Material is not in poor condition overall with minor signs of wear. Pieces are coming off the wall by the boys' restroom near the main entrance and in the cafeteria.

Does Material Contain Asbestos?

Assumed

Is it Friable?

No

Original Inspection Date

5/31/1995

Current Surveillance Date

12/9/2004

Current Assessment Rating

NR

Not Required

Cause of Damage

No Damage

Accessible

Yes

Potential for Damage

Low

Removed

No

Planned Response Action

O & M

Inspector

Christiaan Sparks

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

В

Type of Material

Miscellaneous Material

Quantity of Material

Approx. 1,200 SF

Material Location

Throughout the building

Material Description

Cove base mastic

Comments

Where visible, this material was not in poor condition.

Does Material Contain Asbestos?

Assumed

Is it Friable?

No

Original Inspection Date

5/31/1995

Current Surveillance Date

12/9/2004

Current Assessment Rating

NR

Not Required

Cause of Damage

No Damage

Accessible

No

Potential for Damage

Low

Removed

No

Planned Response Action

O & M


Inspector

Christiaan Sparks

State

Indiana

Accreditation Number



LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

01

Type of Material

Thermal Material

Quantity of Material

10 LF

Material Location

Boiler room

Material Description

Pipe insulation

Comments

There is a 10 ' run of mag left in the boiler room. It is not in poor condition.

Does Material Contain Asbestos?

Yes

Is it Friable?

Yes

Original Inspection Date

06/01/1992

Current Surveillance Date

12/09/2003

Current Assessment Rating

5

ACBM with Potential for Damage

Cause of Damage

No Damage

Accessible

Yes

Potential for Damage

Low

Removed

No

Planned Response Action

M & O

Inspector

Christiaan Sparks

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

02

Type of Material

Thermal Material

Quantity of Material

230 LF

Material Location

Tunnels

Material Description

Pipe insulation

Comments

Entrances to tunnels are restricted, as this material is in poor condition. There is debris all over the floor of the dirt crawl. No one should enter this area without proper training and protection. Clean up recommended.

Does Material Contain Asbestos?

Yes

Is it Friable?

Yes

Original Inspection Date

06/01/1992

Current Surveillance Date

12/09/2003

Current Assessment Rating

1B

Damaged TSI

Cause of Damage

Physical Damage

Accessible

Yes

Potential for Damage

Low

Removed

No

Planned Response Action

0 & M

Inspector

Christiaan Sparks

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

03

Type of Material

Thermal Material

Quantity of Material

48 Each

Material Location

Boiler room and tunnel

Material Description

Fittings

Comments

The minor damage in the boiler room has been repaired. Material in tunnel is in poor condition. Entry to tunnel is restricted. No one should enter without proper training and protection. Clean up recommended.

Does Material Contain Asbestos?

Yes

Is it Friable?

Yes

Original Inspection Date

06/01/1992

Current Surveillance Date

12/09/2003

Current Assessment Rating

1B

Damaged TSI

Cause of Damage

Physical Damage

Accessible

Yes

Potential for Damage

Low

Removed

No

Planned Response Action

O & M

Inspector

Christiaan Sparks

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

05

Type of Material

Miscellaneous Material

Quantity of Material

33,750 SF

Material Location

Throughout the building (classrooms, hallways & office)

Material Description

VAT

Comments

All areas seen during this surveillance were found to either be carpeted or have a newer 12" X 12" white and gray streaked floor tile. No suspect material was visible to inspect.

Does Material Contain Asbestos?

Yes

Is it Friable?

No

Original Inspection Date

06/01/1992

Current Surveillance Date

12/09/2003

Current Assessment Rating

NR

Not Required

Cause of Damage

No Damage

Accessible

No

Potential for Damage

Low

Removed

No

Planned Response Action

O & M

Inspector

Christiaan Sparks

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

07

Type of Material

Miscellaneous Material

Quantity of Material

33,750 SF

Material Location

Throughout the building

Material Description

Mastic

Comments

This material was not visible to inspect.

Does Material Contain Asbestos?

Assumed

Is it Friable?

No

Original Inspection Date

06/01/1992

Current Surveillance Date

12/09/2003

No Damage

Current Assessment Rating

NR

Not Required

Cause of Damage

No

Accessible

Potential for Damage

Low

Removed

No

Planned Response Action

O & M

Inspector

Christiaan Sparks

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

11

Type of Material

Miscellaneous Material

Quantity of Material

30 SF

Material Location

Boiler room

Material Description

Fire door

Comments

The fire door is not in poor condition with no core material visible to inspect.

Does Material Contain Asbestos?

Assumed

Is it Friable?

No

Original Inspection Date

06/01/1992

Current Surveillance Date

12/09/2003

Current Assessment Rating

NR

Not Required

Cause of Damage

No Damage

Accessible

Yes

Potential for Damage

Low

Removed

No

Planned Response Action

0 & M

Inspector

Christiaan Sparks

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

15

Type of Material

Miscellaneous Material

Quantity of Material

2 Each

Material Location

Boiler room

Material Description

Boiler gaskets

Comments

Boiler doors were closed. The visible edges of this material were not in poor condition.

Does Material Contain Asbestos?

Assumed

Is it Friable?

No

Original Inspection Date

06/01/1992

Current Surveillance Date

12/09/2003

Current Assessment Rating

NR

Not Required

Cause of Damage

No Damage

Accessible

Yes

Potential for Damage

Low

Removed

No

Planned Response Action

O & M

Inspector

Christiaan Sparks

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

Α

Type of Material

Miscellaneous Material

Quantity of Material

Approx. 3,800 LF

Material Location

Throughout the building

Material Description

Cove base

Comments

Material is not in poor condition overall with minor signs of wear. Pieces are coming off the wall by the boys' restroom near the main entrance and in the cafeteria.

Does Material Contain Asbestos?

Assumed

Is it Friable?

No

Original Inspection Date

05/31/1995

Current Surveillance Date

12/09/2003

Current Assessment Rating

NR

Not Required

Cause of Damage

No Damage

Accessible

Yes

Potential for Damage

Low

Removed

No

Planned Response Action

0 & M

Inspector

Christiaan Sparks

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

8

Type of Material

Miscellaneous Material

Quantity of Material

Approx. 1,200 SF

Material Location

Throughout the building

Material Description

Cove base mastic

Comments

Where visible, this material was not in poor condition.

Does Material Contain Asbestos?

Assumed

Is it Friable?

No

Original Inspection Date

05/31/1995

Current Surveillance Date

12/09/2003

Current Assessment Rating

NR

Not Required

Cause of Damage

No Damage

Accessible

No

Potential for Damage

Low

Removed

No

Planned Response Action

0 & M


Inspector

Christiaan Sparks

State

Indiana

Accreditation Number



LEA Name Greater Clark County Schools

Building Name Thomas Jefferson Elementary

HA# 01

Type of Material Thermal Material

Quantity of Material 90 LF

Material Location

Tunnels and boiler room

Material Description

Pipe insulation - mag Debris (40 square feet)

Comments

Inspector

State

There is a 10 ' run of mag left in the boiler room. It is not in poor condition. Ceiling in tunnel is woven mag and it is delaminating. All other material has been removed and replaced with fiberglass. Entrances to tunnels have limited access. There is debris on the floor at the entrance to the tunnel and throughout the crawl areas. O & M is needed. (Homogeneous area designation "04" covering debris in the tunnel is now included in this homogeneous area designation.)

íristiaan Sparks

Does Material Contain Asbestos? Yes

Is it Friable?

Original Inspection Date 06/01/1992
Current Surveillance Date 06/12/2003

Current Assessment Rating 1B Damaged TSI

Indiana

Cause of Damage Delamination

Accessible Yes
Potential for Damage Low
Removed No

Planned Response Action O & M

Accreditation Number 190804103

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

02

Type of Material

Thermal Material

Quantity of Material

150 LF

Material Location

Tunnels and boiler room

Material Description

Pipe insulation - air cell

Comments

Entrances to tunnels are restricted, as this material is in poor condition. No air cell found in boiler room. Dirt crawl area is only place it was found. There is debris all over the floor of the dirt crawl. No one should enter this area without proper training and protection. Clean up recommended.

Does Material Contain Asbestos?

Yes

Is it Friable?

Yes

Original Inspection Date

06/01/1992

Current Surveillance Date

06/12/2003

Current Assessment Rating

1B

Damaged TSI

Cause of Damage

Physical Damage

Accessible

Yes

Potential for Damage

Low

Removed

No

Planned Response Action

0 & M

Inspector

Christiaan Sparks

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

03

Type of Material

Thermal Material

Quantity of Material

48 Each

Material Location

Boiler room and tunnel

Material Description

Fittings

Comments

The minor damage in the boiler room has been repaired. Material in tunnel is in poor condition. Entry to tunnel is restricted. No one should enter without proper training and protection. Clean up recommended.

Does Material Contain Asbestos?

Yes

Is it Friable?

Yes

Original Inspection Date

06/01/1992

Current Surveillance Date

06/12/2003

Current Assessment Rating

1B

Damaged TSI

Cause of Damage

Physical Damage

Accessible

Yes

Potential for Damage

Low

Removed

No

Planned Response Action

0 & M

Inspector

Christiaan Sparks

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

04

Type of Material

Thermal Material

Quantity of Material

40 SF

Material Location

Tunnel

Material Description

Debris

Comments

This homogeneous area designation has been included with homogeneous area designation "01". Homogeneous area designation "04" will be removed from the Management Plan.

Does Material Contain Asbestos?

No

Is it Friable?

No

Original Inspection Date

06/01/1992

Current Surveillance Date

06/12/2003

Current Assessment Rating

NA

Not Applicable

Cause of Damage

Not Applicable

Accessible

Yes

Potential for Damage

NA

Removed

No

Planned Response Action

None

Inspector

Christiaan Sparks

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

05

Type of Material

Miscellaneous Material

Quantity of Material

33,750 SF

Material Location

Throughout the building (classrooms, hallways & office)

Material Description

VAT

Comments

All areas seen during this surveillance were found to either be carpeted or have a newer 12" X 12" white and gray streaked floor tile. No suspect material was visible to inspect.

Does Material Contain Asbestos?

Yes

Is it Friable?

No

Original Inspection Date

06/01/1992

Current Surveillance Date

06/12/2003

Current Assessment Rating

NR

Not Required

Cause of Damage

No Damage

Accessible

No

Potential for Damage

Low

Removed

No

Planned Response Action

0 & M

Inspector

Christiaan Sparks

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

07

Type of Material

Miscellaneous Material

Quantity of Material

33,750 SF

Material Location

Throughout the building

Material Description

Mastic

Comments

This material was not visible to inspect.

Does Material Contain Asbestos?

Assumed

Is it Friable?

No

Original Inspection Date

06/01/1992

Current Surveillance Date

06/12/2003

Current Assessment Rating

NR

Not Required

Cause of Damage

No Damage

Accessible

No

Potential for Damage

Low

Removed

No

Planned Response Action

O & M

Inspector

Christiaan Sparks

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

11

Type of Material

Miscellaneous Material

Quantity of Material

30 SF

Material Location

Boiler room

Material Description

Fire door

Comments

The fire door is not in poor condition with no core material visible to inspect.

Does Material Contain Asbestos?

Assumed

Is it Friable?

No

Original Inspection Date

06/01/1992

Current Surveillance Date

06/12/2003

Current Assessment Rating

NR

Not Required

Cause of Damage

No Damage

Accessible

Yes

Potential for Damage

Low

Removed

No

Planned Response Action

0 & M

Inspector

Christiaan Sparks

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

15

Type of Material

Miscellaneous Material

Quantity of Material

2 Each

Material Location

Boiler room

Material Description

Boiler gaskets

Comments

Boiler doors were closed. The visible edges of this material were not in poor condition.

Does Material Contain Asbestos?

Assumed

Is it Friable?

No

Original Inspection Date

06/01/1992

Current Surveillance Date

06/12/2003

Current Assessment Rating

NR

Not Required

Cause of Damage

No Damage

Accessible

Yes

Potential for Damage

Low

Removed

No

Planned Response Action

O & M

Inspector

Christiaan Sparks

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

Α

Type of Material

Miscellaneous Material

Quantity of Material

Approx. 3,800 LF

Material Location

Throughout the building

Material Description

Cove base

Comments

Material is not in poor condition overall with minor signs of wear. Pieces are coming off the wall by the boys' restroom near the main entrance and in the cafeteria.

Does Material Contain Asbestos?

Assumed

Is it Friable?

No

Original Inspection Date

05/31/1995

Current Surveillance Date

06/12/2003

Current Assessment Rating

NR

Not Required

Cause of Damage

No Damage

Accessible

Yes

Potential for Damage

Low

Removed

No

Planned Response Action

0 & M

Inspector

Christiaan Snarks

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

В

Type of Material

Miscellaneous Material

Quantity of Material

Approx. 1,200 SF

Material Location

Throughout the building

Material Description

Cove base mastic

Comments

Where visible, this material was not in poor condition.

Does Material Contain Asbestos?

Assumed

Is it Friable?

No

Original Inspection Date

05/31/1995

Current Surveillance Date

06/12/2003

Current Assessment Rating

NR

Not Required

Cause of Damage

No Damage

Accessible

No

Potential for Damage

Low

Removed

No

Planned Response Action

0 & M

Inspector

Christiaan Sparks

State

Indiana

Accreditation Number



LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

01

Type of Material

Thermal Material

Quantity of Material

90 LF

Material Location

Tunnels and boiler room

Material Description

Pipe insulation - mag

Comments

There is a 10 ' run of mag left in the boiler room. It is not in poor condition. Ceiling in tunnel is woven mag and it is delaminating. All other material has been removed and replaced with fiberglass. Entrances to tunnels have limited access. There is also some debris on the floor at the entrance to the tunnel.

Does Material Contain Asbestos?

Yes

Is it Friable?

Yes

Original Inspection Date

06/01/1992

Current Surveillance Date

12/17/2002

Current Assessment Rating

1B

Damaged TSI

Cause of Damage

Delamination

Accessible

Yes

Potential for Damage

Low

Removed

No

Planned Response Action

0 & M

Inspector

Christiaan Sparks

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

02

Type of Material

Thermal Material

Quantity of Material

150 LF

Material Location

Tunnels and boiler room

Material Description

Pipe insulation - air cell

Comments

Entrances to tunnels are restricted, as this material is in poor condition. No air cell found in boiler room. Dirt crawl area is only place it was found. There is debris all over the floor of the dirt crawl. No one should enter this area without proper training and protection. Clean up recommended.

Does Material Contain Asbestos?

Yes

Is it Friable?

Yes

Original Inspection Date

06/01/1992

Current Surveillance Date

12/17/2002

Current Assessment Rating

1B

Damaged TSI

Cause of Damage

Physical Damage

Accessible

Yes

Potential for Damage

Low

Removed

No

Planned Response Action

O & M

inspector

Christiaan Sparks

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

03

Type of Material

Thermal Material

Quantity of Material

48 Each

Material Location

Boiler room and tunnel

Material Description

Fittings

Comments

The minor damage in the boiler room has been repaired. Material in tunnel is in poor condition. Entry to tunnel is restricted. No one should enter without proper training and protection. Clean up recommended.

Does Material Contain Asbestos?

Yes

Is it Friable?

Yes

Original Inspection Date

06/01/1992

Current Surveillance Date

12/17/2002

Current Assessment Rating

1B

Damaged TSI

Cause of Damage

Physical Damage

Accessible

Yes

Potential for Damage

Low

Removed

No

Planned Response Action

O & M

Inspector

Christiaan Sparks

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

04

Type of Material

Thermal Material

Quantity of Material

40 SF

Material Location

Tunnel

Material Description

Debris

Comments

It seems that a much larger area than 40 square feet is littered with air cell and mag insulation in all dirt crawl areas, but unable to quantify an exact area. Access to tunnel is restricted. O & M cleanup is needed. No one should enter without proper training and protection.

Does Material Contain Asbestos?

Yes

Is it Friable?

Yes

Original Inspection Date

06/01/1992

Current Surveillance Date

12/17/2002

Current Assessment Rating

1B

Damaged TSI

Cause of Damage

Physical Damage

Accessible

Yes

Potential for Damage

High

Removed

No

Planned Response Action

0 & M

Inspector

Christiaan Sparks

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

05

Type of Material

Miscellaneous Material

Quantity of Material

33,750 SF

Material Location

Throughout the building (classrooms, hallways & office)

Material Description

VAT

Comments

All areas seen during this surveillance were found to either be carpeted or have a newer 12" X 12" white and gray streaked floor tile. No suspect material was visible to inspect.

Does Material Contain Asbestos?

Yes

Is it Friable?

No

Original Inspection Date

06/01/1992

Current Surveillance Date

12/17/2002

Current Assessment Rating

NR

Not Required

Cause of Damage

No Damage

Accessible

No

Potential for Damage

Low

Removed

No

Planned Response Action

O & M

Inspector

Christiaan Sparks

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

07

Type of Material

Miscellaneous Material

Quantity of Material

33,750 SF

Material Location

Throughout the building

Material Description

Mastic

Comments

This material was not visible to inspect.

Does Material Contain Asbestos?

Assumed

Is it Friable?

No

Original Inspection Date

06/01/1992

Current Surveillance Date

12/17/2002

Current Assessment Rating

NR

Not Required

Cause of Damage

No Damage

Accessible

No

Potential for Damage

Low

Removed

No

Planned Response Action

0 & M

Inspector

Christiaan Sparks

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

11

Type of Material

Miscellaneous Material

Quantity of Material

30 SF

Material Location

Boiler room

Material Description

Fire door

Comments

The fire door is not in poor condition with no core material visible to inspect.

Does Material Contain Asbestos?

Assumed

Is it Friable?

No

Original Inspection Date

06/01/1992

Current Surveillance Date

12/17/2002

Current Assessment Rating

NR

Not Required

Cause of Damage

No Damage

Accessible

Yes

Potential for Damage

Low

Removed

No

Planned Response Action

O & M

Inspector

Christiaan Sparks

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

15

Type of Material

Miscellaneous Material

Quantity of Material

2 Each

Material Location

Boiler room

Material Description

Boiler gaskets

Comments

Boiler doors were closed. The visible edges of this material were not in poor condition.

Does Material Contain Asbestos?

Assumed

Is it Friable?

No

Original Inspection Date

06/01/1992

Current Surveillance Date

12/17/2002

Current Assessment Rating

NR

Not Required

Cause of Damage

No Damage

Accessible

Yes

Potential for Damage

Low

Removed

No

Planned Response Action

O & M

Inspector

Christiaan Sparks

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

Α

Type of Material

Miscellaneous Material

Quantity of Material

Approx. 3,800 LF

Material Location

Throughout the building

Material Description

Cove base

Comments

Material is not in poor condition overall with minor signs of wear. Pieces are coming off the wall by the boys' restroom off the main entrance.

Does Material Contain Asbestos?

Assumed

Is it Friable?

No

Original Inspection Date

05/31/1995

Current Surveillance Date

12/17/2002

Current Assessment Rating

NR

Not Required

Cause of Damage

No Damage

Accessible

Yes

Potential for Damage

Low

Removed

No

Planned Response Action

0 & M

Inspector

Christiaan Sparks

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

В

Type of Material

Miscellaneous Material

Quantity of Material

Approx. 1,200 SF

Material Location

Throughout the building

Material Description

Cove base mastic

Comments

Where visible, this material was not in poor condition.

Does Material Contain Asbestos?

Assumed

Is it Friable?

No

Original Inspection Date

05/31/1995

Current Surveillance Date

12/17/2002

Current Assessment Rating

NR

Not Required

Cause of Damage

No Damage

Accessible

No

Potential for Damage

Low

Removed

No

Planned Response Action

0 & M

Inspector

Christiaan Sparks

State

Indiana

Accreditation Number



LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

01

Type of Material

Thermal Material

Quantity of Material

90 LF

Material Location

Tunnels

Material Description

Pipe insulation - mag

Comments

There is a 10 ' run of mag left in the boiler room. It is not in poor condition. Ceiling in tunnel is woven mag and it is delaminating. All other material has been removed and replaced with fiberglass. Entrances to tunnels have limited access. There is also some debris on the floor at the entrance to the tunnel.

Does Material Contain Asbestos?

Yes

Is it Friable?

Yes

Original Inspection Date

06/01/1992

Current Surveillance Date

06/19/2002

Current Assessment Rating

1B

Damaged TSI

Cause of Damage

Delamination

Accessible

Yes

Potential for Damage

Low

Removed

No

Planned Response Action

0 & M

Inspector

Richard D. Wort

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

02

Type of Material

Thermal Material

Quantity of Material

150 LF

Material Location

Tunnels and boiler room

Material Description

Pipe insulation - air cell

Comments

Entrances to tunnels are restricted, as this material is in bad condition. No air cell found in boiler room. Dirt crawl area is only place it was found. There is debris all over the floor of the dirt crawl. No one should enter this area without proper training and protection.

Does Material Contain Asbestos?

Yes

Is it Friable?

Yes

Original Inspection Date

06/01/1992

Current Surveillance Date

06/19/2002

Current Assessment Rating

1B

Damaged TSI

Cause of Damage

Physical Damage

Accessible

Yes

Potential for Damage

Low

Removed

No

Planned Response Action

0 & M

Inspector

Richard D. Calvert

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

03

Type of Material

Thermal Material

Quantity of Material

48 Each

Material Location

Boiler room and tunnel

Material Description

Fittings

Comments

The minor damage in the boiler room has been repaired. Material in tunnel is in bad condition. Entry to tunnel is restricted. No one should enter without proper training and protection.

Does Material Contain Asbestos?

Yes

Is it Friable?

Yes

Original Inspection Date

06/01/1992

Current Surveillance Date

06/19/2002

Current Assessment Rating

1B

Damaged TSI

Cause of Damage

Physical Damage

Accessible

Yes

Potential for Damage

Low

Removed

No

Planned Response Action

O & M

Inspector

Richard D. Calvert

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

04

Type of Material

Thermal Material

Quantity of Material

40 SF

Material Location

Tunnel

Material Description

Debris

Comments

It seems that a much larger area than 40 square feet is littered with air cell and mag insulation in all dirt crawl areas. Access to tunnel is restricted. O & M cleanup is needed. No one should enter without proper training and protection.

Does Material Contain Asbestos?

Yes

Is it Friable?

Yes

Original Inspection Date

06/01/1992

Current Surveillance Date

06/19/2002

Current Assessment Rating

1B

Damaged TSI

Cause of Damage

Physical Damage

Accessible

Yes

Potential for Damage

High

Removed

No

Planned Response Action

O & M

Inspector

Richard D. Calvert

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

05

Type of Material

Miscellaneous Material

Quantity of Material

33,750 SF

Material Location

Throughout the building (classrooms, hallways & office)

Material Description

VAT

Comments

Most areas are now covered with carpet which is glued down. Cannot verify presence of tile beneath without risk of damaging carpet. Where visible in rooms 14, 17 and 19 the floor tile is not in poor condition. Four pieces are coming up by the food service exit. Basement areas and landing on stairs to basement has newer 12" X 12" white with gray streaks floor tile.

Does Material Contain Asbestos?

Yes

Is it Friable?

No

Original Inspection Date

06/01/1992

Current Surveillance Date

06/19/2002

Current Assessment Rating

NR

Not Required

Cause of Damage

No Damage

Accessible

Yes

Potential for Damage

Low

Removed

No

Planned Response Action

0 & M

Inspector

Richard D. Calvert

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

07

Type of Material

Miscellaneous Material

Quantity of Material

33,750 SF

Material Location

Throughout the building

Material Description

Mastic

Comments

Material was not visible to inspect.

Does Material Contain Asbestos?

Assumed

Is it Friable?

No

Original Inspection Date

06/01/1992

Current Surveillance Date

06/19/2002

Current Assessment Rating

NR

Not Required

Cause of Damage

No Damage

Accessible

No

Potential for Damage

Low

Removed

No

Planned Response Action

0 & M

Inspector

Richard D. Calvert

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

11

Type of Material

Miscellaneous Material

Quantity of Material

30 SF

Material Location

Boiler room

Material Description

Fire door

Comments

The fire door is not in poor condition with no core material visible to inspect.

Does Material Contain Asbestos?

Assumed

Is it Friable?

No

Original Inspection Date

06/01/1992

Current Surveillance Date

06/19/2002

Current Assessment Rating

NR

Not Required

Cause of Damage

No Damage

Accessible

Yes

Potential for Damage

Low

Removed

No

Planned Response Action

0 & M

Inspector

Richard D. Calvert

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

15

Type of Material

Miscellaneous Material

Quantity of Material

2 Each

Material Location

Boiler room

Material Description

Boiler gaskets

Comments

The boilers were off and open in order to have a good visual look at this material. It is mostly fiberglass except fot the small sections between the door halves. I am unable to sample the material without causing damage. All material appears to be not in poor condition.

Does Material Contain Asbestos?

Assumed

Is it Friable?

No

Original Inspection Date

06/01/1992

Current Surveillance Date

06/19/2002

Current Assessment Rating

NR

Not Required

Cause of Damage

No Damage

Accessible

Yes

Potential for Damage

Low

Removed

No

Planned Response Action

0 & M

Inspector

Pichard D. Calvart

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

Α

Type of Material

Miscellaneous Material

Quantity of Material

Approx. 3,800 LF

Material Location

Throughout the building

Material Description

Cove base

Comments

Material is not in poor condition overall with minor signs of wear. Pieces are coming off the wall by the boys' restroom off the main entrance.

Does Material Contain Asbestos?

Assumed

Is it Friable?

No

Original Inspection Date

05/31/1995

Current Surveillance Date

06/19/2002

Current Assessment Rating

NR

Not Required

Cause of Damage

No Damage

Accessible

Yes

Potential for Damage

Low

Removed

No

Planned Response Action

0 & M

Inspector

Richard D. Calvert

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

В

Type of Material

Miscellaneous Material

Quantity of Material

Approx. 1,200 SF

Material Location

Throughout the building

Material Description

Cove base mastic

Comments

Material is not exposed to inspect.

Does Material Contain Asbestos?

Assumed

Is it Friable?

Nο

Original Inspection Date

05/31/1995

Current Surveillance Date

06/19/2002

Current Assessment Rating

NR

Not Required

Cause of Damage

No Damage

Accessible

No

Potential for Damage

Low

Removed

No

Planned Response Action

0 & M

Inspector

Richard D. Calvert

State

Indiana

Accreditation Number



LEA Name Greater Clark County Schools

Building Name Thomas Jefferson Elementary

HA# 01

Type of Material Thermal Material

Quantity of Material 90 LF

Material Location

Tunnels

Material Description

Pipe insulation - mag

Comments

There is a 10 ' run of mag left in the boiler room. It is not in poor condition. Ceiling in tunnel is woven mag and it is delaminating. All other material has been removed and replaced with fiberglass. Entrances to tunnels have limited access. There is also some debris on the floor at the entrance to the tunnel.

Does Material Contain Asbestos? Yes

Is it Friable? Yes

Original Inspection Date 06/01/1992

Current Surveillance Date 12/10/2002

Current Assessment Rating 1B Damaged TSI

Cause of Damage Delamination

Accessible Yes

Potential for Damage Low

Removed No

Planned Response Action O & M

Inspector

State Indiana

Accreditation Number 191914122

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

02

Type of Material

Thermal Material

Quantity of Material

150 LF

Material Location

Tunnels and boiler room

Material Description

Pipe insulation - air cell

Comments

Entrances to tunnels are restricted, as this material is in bad condition. No air cell found in boiler room. Dirt crawl area is only place it was found. There is debris all over the floor of the dirt crawl. No one should enter this area without proper training and protection.

Does Material Contain Asbestos?

Yes

Is it Friable?

Yes

Original Inspection Date

06/01/1992

Current Surveillance Date

12/10/2002

Current Assessment Rating

1B

Damaged TSI

Cause of Damage

Physical Damage

Accessible

Yes

Potential for Damage

Low

Removed

No

Planned Response Action

O & M

Inspector

tanhan Kimbrough

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

03

Type of Material

Thermal Material

Quantity of Material

48 Each

Material Location

Boiler room and tunnel

Material Description

Fittings

Comments

The minor damage in the boiler room has been repaired. Material in tunnel is in bad condition. Entry to tunnel is restricted. No one should enter without proper training and protection.

Does Material Contain Asbestos?

Yes

Is it Friable?

Yes

Original Inspection Date

06/01/1992

Current Surveillance Date

12/10/2002

Current Assessment Rating

1B

Damaged TSI

Cause of Damage

Physical Damage

Accessible

Yes

Potential for Damage

Low

Removed

No

Planned Response Action

O & M

Inspector

Stephen Kimbrough

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

04

Type of Material

Thermal Material

Quantity of Material

40 SF

Material Location

Tunnel

Material Description

Debris

Comments

It seems that a much larger area than 40 square feet is littered with air cell and mag insulation in all dirt crawl areas. Access to tunnel is restricted. O & M cleanup is needed. No one should enter without proper training and protection.

Does Material Contain Asbestos?

Yes

Is it Friable?

Yes

Original Inspection Date

06/01/1992

Current Surveillance Date

12/10/2002

Current Assessment Rating

1B

Damaged TSI

Cause of Damage

Physical Damage

Accessible

Yes

Potential for Damage

High

Removed

No

Planned Response Action

O & M

Inspector

Stephen Kimbrough

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

05

Type of Material

Miscellaneous Material

Quantity of Material

33,750 SF

Material Location

Throughout the building (classrooms, hallways & office)

Material Description

VAT

Comments

Most areas are now covered with carpet which is glued down. Cannot verify presence of tile beneath without risk of damaging carpet. Where visible in rooms 14, 17 and 19 the floor tile is not in poor condition. Basement areas and landing on stairs to basement has newer 12" X 12" white with gray streaks floor tile.

Does Material Contain Asbestos?

Yes

Is it Friable?

No

Original Inspection Date

06/01/1992

Current Surveillance Date

12/10/2002

Current Assessment Rating

NR

Not Required

Cause of Damage

No Damage

Accessible

Yes

Potential for Damage

Low

Removed

No

Planned Response Action

0 & M

Inspector

tenhen Kimbrough

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

07

Type of Material

Miscellaneous Material

Quantity of Material

33,750 SF

Material Location

Throughout the building

Material Description

Mastic

Comments

Material was not visible to inspect.

Does Material Contain Asbestos?

Assumed

Is it Friable?

No

Original Inspection Date

06/01/1992

Current Surveillance Date

12/10/2002

Current Assessment Rating

NR

Not Required

Cause of Damage

No Damage

Accessible

No

Potential for Damage

Low

Removed

No

Planned Response Action

O & M

Inspector

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

11

Type of Material

Miscellaneous Material

Quantity of Material

30 SF

Material Location

Boiler room

Material Description

Fire door

Comments

The fire door is not in poor condition with no core material visible to inspect.

Does Material Contain Asbestos?

Assumed

Is it Friable?

No

Original Inspection Date

06/01/1992

Current Surveillance Date

12/10/2002

Current Assessment Rating

NR

Not Required

Cause of Damage

No Damage

Accessible

Yes

Potential for Damage

Low

Removed

. .

Hemovea

No

Planned Response Action

O & M

Inspector

Stephen Kimbrough

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

15

Type of Material

Miscellaneous Material

Quantity of Material

2 Each

Material Location

Boiler room

Material Description

Boiler gaskets

Comments

The boilers were off and open in order to have a good visual look at this material. It is mostly fiberglass except fot the small sections between the door halves. I am unable to sample the material without causing damage. All material appears to be not in poor condition.

Does Material Contain Asbestos?

Assumed

Is it Friable?

No

Original Inspection Date

06/01/1992

Current Surveillance Date

12/10/2002

Current Assessment Rating

NR

Not Required

Cause of Damage

No Damage

Accessible

Yes

Potential for Damage

Low

Removed

No

Planned Response Action

0 & M

Inspector

Stephen Kimprough

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

Α

Type of Material

Miscellaneous Material

Quantity of Material

Approx. 3,800 LF

Material Location

Throughout the building

Material Description

Cove base

Comments

Material is not in poor condition overall with minor signs of wear.

Does Material Contain Asbestos?

Assumed

Is it Friable?

No

Original Inspection Date

05/31/1995

Current Surveillance Date

12/10/2002

Current Assessment Rating

NR

Not Required

Cause of Damage

No Damage

Accessible

Yes

Potential for Damage

Low

Removed

No

Planned Response Action

0 & M

Inspector

Stephen Kimbrough

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

В

Type of Material

Miscellaneous Material

Quantity of Material

Approx. 1,200 SF

Material Location

Throughout the building

Material Description

Cove base mastic

Does Material Contain Asbestos?

Comments

Material is not exposed to inspect.

Assumed

Is it Friable?

Nο

Original Inspection Date

05/31/1995

Current Surveillance Date

12/10/2002

Current Assessment Rating

NR

Not Required

Cause of Damage

No Damage

Accessible

No

Potential for Damage

Low

Removed

No

Planned Response Action

0 & M


Inspector

Stenher Kimbrough

State

Indiana

Accreditation Number



LEA Name Greater Clark County Schools

Building Name Thomas Jefferson Elementary

HA# 01

Type of Material Thermal Material

Quantity of Material 90 LF

Material Location

Tunnels

Material Description

Pipe insulation - mag

Comments

There was a 10 ' run of mag left in the boiler room. It is in good condition. Ceiling in tunnel is woven mag and it is delaminating. All other material has been removed and replaced with fiberglass. Entrances to tunnels have limited access.

Does Material Contain Asbestos? Yes

Is it Friable? Yes

Original Inspection Date 06/01/1992

Current Surveillance Date 01/11/2001

Current Assessment Rating 1B Damaged TSI

Cause of Damage Delamination

Accessible Yes
Potential for Damage Low

Removed No

Planned Response Action 0 & M

Inspector Value 4. Wilson

State Indiana

Accreditation Number 190824065

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

02

Type of Material

Thermal Material

Quantity of Material

150 LF

Material Location

Tunnels and boiler room

Material Description

Pipe insulation - air cell

Comments

Entrances to tunnels are restricted, as this material is in bad condition. No air cell found in boiler room. Dirt crawl area is only place it was found. There is debris all over the floor of the dirt crawl.

Does Material Contain Asbestos?

Yes

Is it Friable?

Yes

Original Inspection Date

06/01/1992

Current Surveillance Date

01/11/2001

Current Assessment Rating

1B

Damaged TSI

Cause of Damage

Physical Damage

Accessible

Yes

Potential for Damage

Low

Removed

No

Planned Response Action

0 & M

Inspector

Patrick E. Wilson

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

03

Type of Material

Thermal Material

Quantity of Material

48 Each

Material Location

Boiler room and tunnel

Material Description

Fittings

Comments

The minor damage in the boiler room has been repaired. Material in tunnel is in bad condition. Entry to tunnel is restricted.

Does Material Contain Asbestos?

Yes

Is it Friable?

Yes

Original Inspection Date

06/01/1992

Current Surveillance Date

01/11/2001

Current Assessment Rating

1B

Damaged TSI

Cause of Damage

Physical Damage

Accessible

Yes

Potential for Damage

Low

Removed

No

Planned Response Action

0 & M

Inspector

Patrick E. Wilson

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

04

Type of Material

Thermal Material

Quantity of Material

40 SF

Material Location

Tunnel

Material Description

Debris

Comments

It seems that a much larger area than 40 square feet is littered with air cell and mag insulation in all dirt crawl areas. Access to tunnel is restricted. O & M cleanup is needed before anyone goes in there.

Does Material Contain Asbestos?

Yes

Is it Friable?

Yes

Original Inspection Date

06/01/1992

Current Surveillance Date

01/11/2001

Current Assessment Rating

1B

Damaged TSI

Cause of Damage

Physical Damage

Accessible

Yes

Potential for Damage

High

Removed

No

Planned Response Action

0 & M

Inspector

Patrick E Wilson

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

05

Type of Material

Miscellaneous Material

Quantity of Material

33,750 SF

Material Location

Throughout the building (classrooms, hallways & office)

Material Description

VAT

Comments

Most areas are now covered with carpet which is glued down. Cannot verify presence of tile beneath without risk of damaging carpet. Where visible in rooms 14, 17 and 19 the floor tile is in good condition.

Does Material Contain Asbestos?

Yes

Is it Friable?

Nο

Original Inspection Date

06/01/1992

Current Surveillance Date

01/11/2001

Current Assessment Rating

NR

Not Required

Cause of Damage

No Damage

Accessible

Yes

Potential for Damage

Low

Removed

Νo

Planned Response Action

0 & M

Inspector

Patrick F. Wilson

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

07

Type of Material

Miscellaneous Material

Quantity of Material

33,750 SF

Material Location

Throughout the building

Material Description

Mastic

Comments

Material was not visible to inspect.

Does Material Contain Asbestos?

Assumed

Is it Friable?

No

Original Inspection Date

06/01/1992

Current Surveillance Date

01/11/2001

Current Assessment Rating

NR

Cause of Damage

No Damage

Accessible

No

Potential for Damage

Low

Removed

No

Planned Response Action

0 & M

Inspector

Patrick F. Wilson

Not Required

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

11

Type of Material

Miscellaneous Material

Quantity of Material

30 SF

Material Location

Boiler room

Material Description

Fire door

Comments

The fire door is in good condition and no core material was visible to inspect.

Does Material Contain Asbestos?

Assumed

Is it Friable?

No

Original Inspection Date

06/01/1992

Current Surveillance Date

01/11/2001

Current Assessment Rating

NR

Not Required

Cause of Damage

No Damage

Accessible

Yes

Potential for Damage

Low

Removed

No

Planned Response Action

0 & M

Inspector

Patrick E. Wilson

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

15

Type of Material

Miscellaneous Material

Quantity of Material

2 Each

Material Location

Boiler room

Material Description

Boiler gaskets

Comments

Gasketing material appears to be fiberglass rope. Only a couple of small pads appear to be suspect material. All material appears to be in good condition. The boilers are in operation.

Does Material Contain Asbestos?

Assumed

Is it Friable?

No

Original Inspection Date

06/01/1992

Current Surveillance Date

01/11/2001

Current Assessment Rating

NR

Not Required

Cause of Damage

No Damage

Accessible

Yes

Potential for Damage

Low

Removed

No

Planned Response Action

O & M

Inspector

Patrick F. Wilson

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

Α

Type of Material

Miscellaneous Material

Quantity of Material

Approx. 3,800 LF

Material Location

Throughout the building

Material Description

Cove base

Comments

Material is in good condition overall with minor signs of wear.

Does Material Contain Asbestos?

Assumed

Is it Friable?

No

Original Inspection Date

05/31/1995

Current Surveillance Date

01/11/2001

Current Assessment Rating

NR

Not Required

Cause of Damage

No Damage

Accessible

Yes

Potential for Damage

Low

Removed

No

Planned Response Action

O & M

Inspector

Patrick E. Wilson

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

В

Type of Material

Miscellaneous Material

Quantity of Material

Approx. 1,200 SF

Material Location

Throughout the building

Material Description

Cove base mastic

Comments

Material is not exposed to inspect.

Does Material Contain Asbestos?

Assumed

Is it Friable?

No

Original Inspection Date

05/31/1995

Current Surveillance Date

01/11/2001

Current Assessment Rating

NR

Not Required

Cause of Damage

No Damage

Accessible

No

Potential for Damage

Low

Removed

No

Planned Response Action

0 & M


Inspector

Patrick F. Wilson

State

Indiana

Accreditation Number



LEA Name Greater Clark County Schools

Building Name Thomas Jefferson Elementary

HA# 01

Type of Material Thermal Material

Quantity of Material 90 LF

Material Location Tunnels

Material Description

Pipe Insulation - Mag

Comments

Inspector

State

There was a 10 ' run of mag left in the boiler room. It is in good condition. Ceiling in tunnel is woven mag and it is delaminating. All other material has been removed and replaced with fiberglass. Entrances to tunnels need to be restricted.

Does Material Contain Asbestos? Yes Is it Friable? Yes

Original Inspection Date 06/01/1992

Current Surveillance Date 06/28/2000

Current Assessment Rating 1B Damaged TSI

Indiana

Cause of Damage Delamination

Accessible Yes
Potential for Damage Low
Removed No
Planned Response Action O & M

Accreditation Number 191523030

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

02

Type of Material

Thermal Material

Quantity of Material

150 LF

Material Location

Tunnels and Boiler Room

Material Description

Pipe Insulation - Air Cell

Comments

Entrances to tunnels need to be kept restricted as this material is in bad condition. No air cell found in boiler room. Dirt crawl area is only place I found it. There is debris all over the place.

Does Material Contain Asbestos?

Yes

Is it Friable?

Yes

Original Inspection Date

06/01/1992

Current Surveillance Date

06/28/2000

Current Assessment Rating

1B

Damaged TSI

Cause of Damage

Physical Damage

Accessible

Yes

Potential for Damage

Low

Removed

No

Planned Response Action

M & O

Inspector

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

03

Type of Material

Thermal Material

Quantity of Material

48 Each

Material Location

Boiler Room and Tunnel

Material Description

Fittings

Comments

The minor damage in the boiler room has been repaired. Material in tunnel is in bad condition. Entry to tunnel needs to be restricted.

Does Material Contain Asbestos?

Yes

Is it Friable?

Yes

Original Inspection Date

06/01/1992

Current Surveillance Date

06/28/2000

Current Assessment Rating

1B

Damaged TSI

Cause of Damage

Physical Damage

Accessible

Yes

Potential for Damage

Low

Removed

No

Planned Response Action

0 & M

Inspector

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

04

Type of Material

Thermal Material

Quantity of Material

40 SF

Material Location

Tunnel

Material Description

Debris

Comments

It seems that a much larger area than 40 square feet is littered with air cell and mag insulation in all dirt crawl areas. Access to tunnel needs to be kept restricted. O & M clleanup is needed before anyone goes in there.

Does Material Contain Asbestos?

Yes

Is it Friable?

Yes

Original Inspection Date

06/01/1992

Current Surveillance Date

06/28/2000

Current Assessment Rating

1B

Damaged TSI

Cause of Damage

Physical Damage

Accessible

Yes

Potential for Damage

High

Removed

No

Planned Response Action

0 & M

Inspector

/ Geo/g≱ Willian

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

05

Type of Material

Miscellaneous Material

Quantity of Material

33,750 SF

Material Location

Throughout the building (classrooms, hallways & office)

Material Description

VAT

Comments

Most areas are now covered with carpet which is glued down. Cannot verify presence of tile beneath without risk of damaging carpet. Where visible in rooms 14, 17 and 19 the floor tile is in good condition.

Does Material Contain Asbestos?

Yes

Is it Friable?

No

Original Inspection Date

06/01/1992

Current Surveillance Date

06/28/2000

Current Assessment Rating

NR

Not Required

Cause of Damage

No Damage

Accessible

Yes

Potential for Damage

Low

Removed

No

Planned Response Action

O & M

Indiana

Inspector

State

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

07

Type of Material

Miscellaneous Material

Quantity of Material

33750 SF

Material Location

Throughout the building

Material Description

Mastic

Comments

Material was not visible to inspect.

Does Material Contain Asbestos?

Assumed

Is it Friable?

No

Original Inspection Date

06/01/1992

Current Surveillance Date

06/28/2000

Current Assessment Rating

NR

Not Required

Cause of Damage

No Damage

Accessible

No

Potential for Damage

Low

Removed

No

Planned Response Action

O & M

Inspector

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

11

Type of Material

Miscellaneous Material

Quantity of Material

30 SF

Material Location

Boiler Room

Material Description

Fire Door

Comments

The fire door is in good condition and no core material was visible to inspect.

Does Material Contain Asbestos?

Assumed

Is it Friable?

No

Original Inspection Date

06/01/1992

Current Surveillance Date

06/28/2000

Current Assessment Rating

NR

Not Required

Cause of Damage

No Damage

Accessible

Yes

Potential for Damage

Low

Removed

No

Planned Response Action

0 & M

Inspector

9

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

15

Type of Material

Miscellaneous Material

Quantity of Material

2 Each

Material Location

Boiler Room

Material Description

Boiler Gaskets

Comments

Most gasketing material is fiberglass rope. Only a couple of small pads appear to be suspect material. All material is in good condition overall.

Does Material Contain Asbestos?

Assumed

Is it Friable?

No

Original Inspection Date

06/01/1992

Current Surveillance Date

06/28/2000

Current Assessment Rating

NR

Not Required

Cause of Damage

No Damage

Accessible

Yes

Potential for Damage

Low

Removed

No

Planned Response Action

O & M

Inspector

George Williai

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

Α

Type of Material

Miscellaneous Material

Quantity of Material

Unquantified LF

Material Location

Throughout the building

Material Description

Cove Base

Comments

Material is in good condition overall.

Does Material Contain Asbestos?

Assumed

Is it Friable?

No

Original Inspection Date

05/31/1995

Current Surveillance Date

06/28/2000

Current Assessment Rating

NR

Not Required

Cause of Damage

No Damage

Accessible

Yes

Potential for Damage

Low

Removed

No

Planned Response Action

O & M

Inspector

U

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

В

Type of Material

Miscellaneous Material

Quantity of Material

Unquantified LF

Material Location

Throughout Building

Material Description

Cove Base Mastic

Comments

Material is not exposed to inspect.

Does Material Contain Asbestos?

Assumed

Is it Friable?

No

Original Inspection Date

05/31/1995

Current Surveillance Date

06/28/2000

Current Assessment Rating

NR

Not Required

Jase (J. Cyle Seo(de William Ogle

Cause of Damage

No Damage

Accessible

No

Potential for Damage

Low

Removed

No

Planned Response Action

O & M


Inspector

U

State

Indiana

Accreditation Number



LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

01

Type of Material

Thermal Material

Quantity of Material

90 LF

Material Location

Tunnels

Material Description

Pipe Insulation - Mag

Comments

There was a 10 ' run of mag left in the boiler room. Ceiling in tunnel is woven mag and it is delaminating. All other material has been removed and replaced with fiberglass. Entrances to tunnels need to be restricted.

Does Material Contain Asbestos?

Yes

Is it Friable?

Yes

Original Inspection Date

06/01/1992

Current Surveillance Date

12/08/1999

Current Assessment Rating

1B

Damaged TSI

Cause of Damage

Physical Damage

Accessible

Yes

Potential for Damage

Low

Removed

No

Planned Response Action

0 & M

Inspector

Matthew Wallace

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

02

Type of Material

Thermal Material

Quantity of Material

150 LF

Material Location

Tunnels and Boiler Room

Material Description

Pipe Insulation - Air Cell

Comments

Entrances to tunnels need to be restricted as this material is in bad condition.

Does Material Contain Asbestos?

Yes

Is it Friable?

Yes

Original Inspection Date

06/01/1992

Current Surveillance Date

12/08/1999

Current Assessment Rating

1B

Damaged TSI

Cause of Damage

Physical Damage

Accessible

Yes

Potential for Damage

Low

Removed

No

Planned Response Action

O & M

Inspector

Matthew Wallace

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

03

Type of Material

Thermal Material

Quantity of Material

48 Each

Material Location

Boiler Room and Tunnel

Material Description

Fittings

Comments

There is some minor damage in the boiler room. Material in tunnel is in bad condition.

Entry to tunnel needs to be restricted.

Does Material Contain Asbestos?

Yes

Is it Friable?

Yes

Original Inspection Date

06/01/1992

Current Surveillance Date

12/08/1999

Current Assessment Rating

1B

Damaged TSI

Cause of Damage

Physical Damage

Accessible

Yes

Potential for Damage

Low

Removed

No

Planned Response Action

0 & M

Inspector

Matthew Wallace

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

04

Type of Material

Thermal Material

Quantity of Material

40 SF

Material Location

Tunnel

Material Description

Debris

Comments

Access to tunnel needs to be restricted. There is debris on the floor of the tunnel. O & M needed.

Does Material Contain Asbestos?

Yes

Is it Friable?

Yes

Original Inspection Date

06/01/1992

Current Surveillance Date

12/08/1999

Current Assessment Rating

1B

Damaged TSI

Cause of Damage

Physical Damage

Accessible

Yes

Potential for Damage

High

Removed

No

Planned Response Action

O & M

Inspector

Matthow Wallace

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

05

Type of Material

Miscellaneous Material

Quantity of Material

33750 SF

Material Location

Throughout the building (classrooms, hallways & office)

Material Description

VAT

Comments

Material is positive everywhere except the gymnasium. VAT was removed in the cafeteria during the summer of '95.

Does Material Contain Asbestos?

Yes

Is it Friable?

No

Original Inspection Date

06/01/1992

Current Surveillance Date

12/08/1999

No Damage

Current Assessment Rating

NR

Not Required

Cause of Damage

. .

Accessible

Yes

Potential for Damage

Low

Removed

No

Planned Response Action

0 & M

Inspector

Matthew Wallace

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

07

Type of Material

Miscellaneous Material

Quantity of Material

33750 SF

Material Location

Throughout the building

Material Description

Mastic

Comments

Material is assumed to be in good condition.

Does Material Contain Asbestos?

Assumed

Is it Friable?

No

Original Inspection Date

06/01/1992

Current Surveillance Date

12/08/1999

Current Assessment Rating

NR

Not Required

Cause of Damage

No Damage

Accessible

No

Potential for Damage

Low

Removed

No

Planned Response Action

0 & M

Inspector

Matthew Wallace

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

11

Type of Material

Miscellaneous Material

Quantity of Material

30 SF

Material Location

Boiler Room

Material Description

Fire Door

Comments

Material is assumed to be in good condition.

Does Material Contain Asbestos?

Assumed

Is it Friable?

No

Original Inspection Date

06/01/1992

Current Surveillance Date

12/08/1999

Current Assessment Rating

NR

Not Required

Cause of Damage

No Damage

Accessible

Yes

Potential for Damage

Low

Removed

No

Planned Response Action

0 & M

Inspector

Matthew Wallace

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

15

Type of Material

Miscellaneous Material

Quantity of Material

2 Each

Material Location

Boiler Room

Material Description

Boiler Gaskets

Comments

Material is in good condition.

Does Material Contain Asbestos?

Assumed

Is it Friable?

No

Original Inspection Date

06/01/1992

Current Surveillance Date

12/08/1999

Current Assessment Rating

NR

Not Required

Cause of Damage

No Damage

Accessible

Yes

Potential for Damage

Low

Removed

No

Planned Response Action

0 & M

Inspector

Matthew Wallace

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

Α

Type of Material

Miscellaneous Material

Quantity of Material

Unquantified LF

Material Location

Throughout the building

Material Description

Cove Base

Comments

Material is in good condition.

Does Material Contain Asbestos?

Assumed

Is it Friable?

No

Original Inspection Date

05/31/1995

Current Surveillance Date

12/08/1999

No Damage

Current Assessment Rating

NR

Not Required

Cause of Damage

Accessible

Yes

Potential for Damage

Low

Removed

No

Planned Response Action

0 & M

Inspector

Matthew Wallace

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

В

Type of Material

Miscellaneous Material

Quantity of Material

Unquantified LF

Material Location

Throughout Building

Material Description

Cove Base Mastic

Comments

Material is assumed to be in good condition.

Does Material Contain Asbestos?

Assumed

Is it Friable?

No

Original Inspection Date

05/31/1995

Current Surveillance Date

12/08/1999

Current Assessment Rating

NR

Not Required

Cause of Damage

No Damage

Accessible

No

Potential for Damage

Low

Removed

No

Planned Response Action

0 & M

Inspector

Matthew Wallace

State

Indiana

Accreditation Number



LEA Name Greater Clark County Schools

Building Name Thomas Jefferson Elementary

HA# 01

Type of Material Thermal Material

Quantity of Material 90 LF

Material Location

Tunnels

Material Description

Pipe Insulation - Mag

Comments

Inspector

There was a 10 ' run of damaged mag left in the boiler room. Material has been repaired. Ceiling in tunnel is woven mag. All other material has been removed and replaced with fiberglass. Entrances to tunnels need to be restricted.

Matthew Wallace

Does Material Contain Asbestos? Yes

Is it Friable? Yes

Original Inspection Date 06/01/1992
Current Surveillance Date 06/24/1999

Current Assessment Rating 1B Damaged TSI

Cause of Damage Physical Damage

Accessible Yes
Potential for Damage Low
Removed No

Planned Response Action O & M

State Indiana

Accreditation Number 191219020

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

02

Type of Material

Thermal Material

Quantity of Material

150 LF

Material Location

Tunnels and Boiler Room

Material Description

Pipe Insulation - Air Cell

Comments

Entrances to tunnels need to be restricted. There was damage to the pipe near boiler #1.

O & M has been completed.

Does Material Contain Asbestos?

Yes

Is it Friable?

Yes

Original Inspection Date

06/01/1992

Current Surveillance Date

06/24/1999

Current Assessment Rating

1B

Damaged TSI

Cause of Damage

Physical Damage

Accessible

Yes

Potential for Damage

Low

Removed

No

Planned Response Action

0 & M

Inspector

Matthew Wallace

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

03

Type of Material

Thermal Material

Quantity of Material

48 Each

Material Location

Boiler Room and Tunnel

Material Description

Fittings

Comments

There is some minor damage in the boiler room. Entry to tunnel needs to be restricted.

Does Material Contain Asbestos?

Yes

Is it Friable?

Yes

Original Inspection Date

06/01/1992

Current Surveillance Date

06/24/1999

Current Assessment Rating

1B

Damaged TSI

Cause of Damage

Physical Damage

Accessible

Yes

Potential for Damage

Low

Removed

No

Planned Response Action

0 & M

Inspector

Matthew Wallace

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

04

Type of Material

Thermal Material

Quantity of Material

40 SF

Material Location

Tunnel

Material Description

Debris

Comments

Access to tunnel needs to be restricted. There is debris on the floor of the tunnel. O & M

needed.

Does Material Contain Asbestos?

Yes

Is it Friable?

Yes

Original Inspection Date

06/01/1992

Current Surveillance Date

06/24/1999

Current Assessment Rating

1B

Damaged TSI

Cause of Damage

Physical Damage

Accessible

Yes

Potential for Damage

High

Removed

Nο

Planned Response Action

0 & M

Inspector

Matthew Wallace

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

05

Type of Material

Miscellaneous Material

Quantity of Material

33750 SF

Material Location

Throughout Building (Classrooms, Halls & Office)

Material Description

VAT

Comments

Material is positive everywhere except the gymnasium. VAT was removed in the cafeteria over the summer of '95.

Does Material Contain Asbestos?

Yes

Is it Friable?

No

Original Inspection Date

06/01/1992

Current Surveillance Date

06/24/1999

Current Assessment Rating

NR

Not Required

Cause of Damage

No Damage

Accessible

Yes

Potential for Damage

Low

Removed

No

Planned Response Action

0 & M

Inspector

Matthew Wallace

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

07

Type of Material

Miscellaneous Material

Quantity of Material

33750 SF

Material Location

Throughout Building

Material Description

Mastic

Comments

Material is assumed to be in good condition.

Does Material Contain Asbestos?

Assumed

Is it Friable?

No

Original Inspection Date

06/01/1992

Current Surveillance Date

06/24/1999

Current Assessment Rating

NR

Not Required

Cause of Damage

No Damage

Accessible

No

Potential for Damage

Low

Removed

No

Planned Response Action

0 & M

Inspector

Matthew Wallace

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

11

Type of Material

Miscellaneous Material

Quantity of Material

30 SF

Material Location

Boiler Room

Material Description

Fire Door

Comments

Material is assumed to be in good condition.

Does Material Contain Asbestos?

Assumed

Is it Friable?

No

Original Inspection Date

06/01/1992

Current Surveillance Date

06/24/1999

Current Assessment Rating

NR

Not Required

Cause of Damage

No Damage

Accessible

Yes

Potential for Damage

Low

Removed

No

Planned Response Action

0 & M

Inspector

Matthew Wallace

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

15

Type of Material

Miscellaneous Material

Quantity of Material

2 Each

Material Location

Boiler Room

Material Description

Boiler Gaskets

Comments

Material is in good condition.

Does Material Contain Asbestos?

Assumed

Is it Friable?

No

Original Inspection Date

06/01/1992

Current Surveillance Date

06/24/1999

Current Assessment Rating

NR

Not Required

Cause of Damage

No Damage

Accessible

Yes

Potential for Damage

Low

Removed

No

Planned Response Action

O & M

Inspector

Vatthew Wallace

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

Α

Type of Material

Miscellaneous Material

Quantity of Material

Unquantified LF

Material Location

Throughout the building

Material Description

Cove Base

Comments

Material is in good condition.

Does Material Contain Asbestos?

Assumed

Is it Friable?

No

Original Inspection Date

05/31/1995

Current Surveillance Date

06/24/1999

Current Assessment Rating

NR

Not Required

Cause of Damage

No Damage

Accessible

Yes

Potential for Damage

Low

Removed

No

Planned Response Action

0 & M

Inspector

Matthew Wallace

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

В

Type of Material

Miscellaneous Material

Quantity of Material

Unquantified LF

Material Location

Throughout Building

Material Description

Cove Base Mastic

Comments

Material is assumed to be in good condition.

Does Material Contain Asbestos?

Assumed

Is it Friable?

No

Original Inspection Date

05/31/1995

Current Surveillance Date

06/24/1999

Current Assessment Rating

NR

Not Required

Cause of Damage

No Damage

Accessible

No

Potential for Damage

Low

Removed

No

Planned Response Action

O & M

Inspector

Matthew Wallace

State

Indiana

Accreditation Number



LEA Name Greater Clark County Schools

Building Name Thomas Jefferson Elementary

HA# 01

Type of Material Thermal Material

Quantity of Material

90 LF

Material Location

Tunnels

Material Description

Pipe Insulation - Mag

Comments

There was a 10 ' run of damaged mag left in the boiler room. Material has been repaired. Ceiling in tunnel is woven mag. All other material has been removed and replaced with fiberglass. Entrances to tunnels need to be restricted.

Clint Yates

Does Material Contain Asbestos? Yes Is it Friable? Yes

Original Inspection Date 06/01/1992
Current Surveillance Date 12/29/1998

Current Assessment Rating 1B Damaged TSI
Cause of Damage Physical Damage

Accessible Yes
Potential for Damage Low
Removed No
Planned Response Action O & M

Inspector

State Indiana

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

02

Type of Material

Thermal Material

Quantity of Material

150 LF

Material Location

Tunnels and Boiler Room

Material Description

Pipe Insulation - Air Cell

Comments

Entrances to tunnels need to be restricted. There was damage to the pipe near boiler #1. O & M has been completed.

Does Material Contain Asbestos?

Yes

Is it Friable?

Yes

Original Inspection Date

06/01/1992

Current Surveillance Date

12/29/1998

Current Assessment Rating

1B Damaged TSI

Cause of Damage

Physical Damage

Accessible

Yes

Potential for Damage

Low

Removed

No

Planned Response Action

0 & M

Inspector

Clint Yates

State

Indiana

Accreditation Number

LEA Name Greater Clark County Schools

Building Name Thomas Jefferson Elementary

HA# 03

Type of Material Thermal Material

Quantity of Material 48 Each

Material Location

Boiler Room and Tunnel

Material Description

Fittings

Comments

There is some minor damage in the boiler room. Entry to tunnel is restricted.

Clint Yates

Does Material Contain Asbestos? Yes

Is it Friable? Yes

Original Inspection Date 06/01/1992
Current Surveillance Date 12/29/1998

Current Assessment Rating 1B Damaged TSI
Cause of Damage Physical Damage

Accessible Yes
Potential for Damage Low
Removed No

Planned Response Action O & M

Inspector

State Indiana

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

04

Type of Material

Thermal Material

Quantity of Material

40 SF

Material Location

Tunnel

Material Description

Debris

Comments

Access to tunnel restricted. Do not know if there. Could not access tunnel.

Does Material Contain Asbestos?

Yes

Is it Friable?

Yes

Original Inspection Date

06/01/1992

Current Surveillance Date

12/29/1998

Current Assessment Rating

1B Damaged TSI

Cause of Damage

Physical Damage

Accessible

Yes

Potential for Damage

High

Removed

No

Planned Response Action

O & M

Inspector

Clint Xates

State

Indiana

Accreditation Number

LEA Name Greater Clark County Schools

Building Name Thomas Jefferson Elementary

HA# 05

Type of Material Miscellaneous Material

Quantity of Material 33750 SF

Material Location

Throughout Building (Classrooms, Halls & Office)

Material Description

VAT

Comments

Material is positive everywhere except the gymnasium. VAT was removed in the cafeteria over the summer of '95.

Clint Yates

Does Material Contain Asbestos? Yes

Is it Friable? No

Original Inspection Date 06/01/1992
Current Surveillance Date 12/29/1998

Current Assessment Rating NR Not Required

Cause of Damage No Damage

Accessible Yes
Potential for Damage Low
Removed No
Planned Response Action O & M

Inspector

State Indiana

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

07

Type of Material

Miscellaneous Material

Quantity of Material

33750 SF

Material Location

Throughout Building

Material Description

Mastic

Comments

Material is assumed to be in good condition.

Does Material Contain Asbestos?

Assumed

Is it Friable?

No

Original Inspection Date

06/01/1992

Current Surveillance Date

12/29/1998

Current Assessment Rating

NR Not Required

Cause of Damage

No Damage

Accessible

No

Potential for Damage

Low

Removed

No

Planned Response Action

O & M

Inspector

Clint/Yates

State

Indiana

Accreditation Number

LEA Name Greater Clark County Schools

Building Name Thomas Jefferson Elementary

HA# 11

Miscellaneous Material Type of Material

30 SF **Quantity of Material**

Material Location

Boiler Room

Material Description

Fire Door

Comments

Material is assumed to be in good condition.

Does Material Contain Asbestos? Assumed

Is it Friable? No

Original Inspection Date 06/01/1992 **Current Surveillance Date** 12/29/1998

Current Assessment Rating NR Not Required

Cause of Damage No Damage

Accessible Yes Potential for Damage Low No Removed O & M Planned Response Action

Inspector

Indiana State

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

15

Type of Material

Miscellaneous Material

Quantity of Material

2 Each

Material Location

Boiler Room

Material Description

Boiler Gaskets

Comments

Material is in good condition.

Does Material Contain Asbestos?

Assumed

Is it Friable?

No

Original Inspection Date

06/01/1992

Current Surveillance Date

12/29/1998

Current Assessment Rating

NR Not Required

Cause of Damage

No Damage

Accessible

Yes

Potential for Damage

Low

Removed

No

Planned Response Action

O&M

Inspector

Clint Yates

State

Accreditation Number

Indiana

Clint/Yates

LEA Name Greater Clark County Schools

Building Name Thomas Jefferson Elementary

HA# A

Type of Material Miscellaneous Material

Quantity of Material Unquantified LF

Material Location

Throughout the building

Material Description

Cove Base

Comments

Material is in good condition.

Does Material Contain Asbestos? Assumed

Is it Friable?

Original Inspection Date 05/31/1995
Current Surveillance Date 12/29/1998

Current Assessment Rating NR Not Required

Cause of Damage No Damage

Accessible Yes
Potential for Damage Low
Removed No
Planned Response Action O & M

Inspector

State Indiana

Clipt Yates

LEA Name Greater Clark County Schools

Building Name Thomas Jefferson Elementary

HA# B

Type of Material Miscellaneous Material

Quantity of Material Unquantified LF

Material Location

Throughout Building

Material Description

Cove Base Mastic

Comments

Material is assumed to be in good condition.

Does Material Contain Asbestos? Assumed

Is it Friable?

Original Inspection Date 05/31/1995
Current Surveillance Date 12/29/1998


Current Assessment Rating NR Not Required

Cause of Damage No Damage

Accessible No
Potential for Damage Low
Removed No
Planned Response Action O & M

Inspector

State Indiana



LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

01

90

Type of Material

Thermal Material

Quantity of Material

LF

Material Location

Tunnels

Material Description

Pipe Insulation - Mag

Comments

There is a 10 ' run of damaged mag left in the boiler room. Material is in poor condition. Ceiling in tunnel is woven mag. All other material has been removed and replaced with fiberglass. Entrances to tunnels need to be restricted.

Does Material Contain Asbestos?

Yes

Is it Friable?

Yes

Original Inspection Date

6/ 1/92

Current Surveillance Date

1/14/98

Current Assessment Rating

1B Damaged TSI

Cause of Damage

Physical Damage

Accessible

Yes

Potential for Damage

Low

Removed

No

Planned Response Action

O & M

Inspector

Karen Foxx

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

02

Type of Material

Thermal Material

Quantity of Material

LF

150

Material Location

Tunnels and Boiler Room

Material Description

Pipe Insulation - Air Cell

Comments

Entrances to tunnels need to be restricted. There is damage to the pipe near boiler #1. O & M is needed.

Does Material Contain Asbestos?

Yes

Is it Friable?

Yes

Original Inspection Date

6/ 1/92

Current Surveillance Date

1/14/98

Current Assessment Rating

1B Damaged TSI

Cause of Damage

Physical Damage

Accessible

Yes

Potential for Damage

Low

Removed

No

Planned Response Action

O & M

Inspector

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

03

Type of Material

Thermal Material

Quantity of Material

48

Each

Material Location

Boiler Room and Tunnel

Material Description

Fittings

Comments

There is some minor damage in the boiler room. Entry to tunnel is restricted.

Does Material Contain Asbestos?

Yes

Is it Friable?

Yes

Original Inspection Date

6/ 1/92

Current Surveillance Date

1/14/98

Current Assessment Rating

1B Damaged TSi

Cause of Damage

Physical Damage

Accessible

Yes

Potential for Damage

Low

Removed

No

Planned Response Action

0 & M

Inspector

Karen Foxx

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

04

40

Type of Material

Thermal Material

Quantity of Material

SF

Material Location

Tunnel

Material Description

Debris

Comments

Access to tunnel restricted. Do not know if there. Could not access tunnel.

Does Material Contain Asbestos?

Yes

Is it Friable?

Yes

Original Inspection Date

6/ 1/92

Current Surveillance Date

1/14/98

Current Assessment Rating

1B Damaged TSI

Cause of Damage

Physical Damage

Accessible

Yes

Potential for Damage

High

Removed

No

Planned Response Action

O & M

Inspector

Karen Foxx

State

Indiana

Accreditation Number

LEA Name Greater Clark County Schools

Building Name Thomas Jefferson Elementary

HA# 05

Type of Material Miscellaneous Material

Quantity of Material 33,750 SF

Material Location

Throughout Building (Classrooms, Halls & Office)

Material Description

VAT

Comments

Material is positive everywhere except the gymnasium. VAT was removed in the cafeteria over the summer of '95.

Does Material Contain Asbestos? Yes

Is it Friable?

Original Inspection Date 6/ 1/92
Current Surveillance Date 1/14/98

Current Assessment Rating NR Not Required

Cause of Damage No Damage

Accessible Yes
Potential for Damage Low

Removed No

Planned Response Action O & M

Inspector Kasen John

State Indiana

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

07

Type of Material

Miscellaneous Material

Quantity of Material

33,750 SF

Material Location

Throughout Building

Material Description

Mastic

Comments

Material is assumed to be in good condition.

Does Material Contain Asbestos?

Assumed

Is it Friable?

No

Original Inspection Date

6/ 1/92

Current Surveillance Date

1/14/98

Current Assessment Rating

NR Not Required

Cause of Damage

No Damage

Accessible

No

Potential for Damage

Low

Removed

No

Planned Response Action

O & M

Inspector

Karen Foxx

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

11

Type of Material

Miscellaneous Material

Quantity of Material

30 SF

Material Location

Boiler Room

Material Description

Fire Door

Comments

Material is assumed to be in good condition.

Does Material Contain Asbestos?

Assumed

Is it Friable?

No

Original Inspection Date

6/ 1/92

Current Surveillance Date

1/14/98

Current Assessment Rating

NR Not Required

Cause of Damage

No Damage

Accessible

Yes

Potential for Damage

Low

Removed

No

Planned Response Action

O & M

Inspector

Karen Foxx

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

15

2

Type of Material

Miscellaneous Material

Quantity of Material

Each

Material Location

Boiler Room

Material Description

Boiler Gaskets

Comments

Material is in good condition.

Does Material Contain Asbestos?

Assumed

Is it Friable?

No

Original Inspection Date

6/ 1/92

Current Surveillance Date

1/14/98

Current Assessment Rating

NR Not Required

Cause of Damage

No Damage

Accessible

Yes

Potential for Damage

Low

Removed

No

Planned Response Action

M&O

Inspector

Karen Foxx

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

Α

Type of Material

Miscellaneous Material

Quantity of Material

LF

Material Location

Throughout the building

Material Description

Cove Base

Comments

Material is in good condition.

Does Material Contain Asbestos?

Assumed

Is it Friable?

No

Original Inspection Date

5/31/95

Current Surveillance Date

1/14/98

Current Assessment Rating

NR Not Required

Cause of Damage

No Damage

Accessible

Yes

Potential for Damage

Low

Removed

No

Planned Response Action

O & M

Inspector

Karen Foxx

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

В

Type of Material

Miscellaneous Material

Quantity of Material

LF

Material Location

Throughout Building

Material Description

Cove Base Mastic

Comments

Material is assumed to be in good condition.

Does Material Contain Asbestos?

Assumed

Is it Friable?

No

Original Inspection Date

5/31/95

Current Surveillance Date

1/14/98

Current Assessment Rating

NR Not Required

Cause of Damage

No Damage

Accessible

No

Potential for Damage

Low

Removed

No

Planned Response Action

O & M


Inspector

Karen Foxx

State

Indiana

Accreditation Number



LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

1

90

Type of Material

Thermal Material

Quantity of Material

LF

Material Location

Tunnels

Material Description

Pipe Insulation - Mag

Comments

Entry to tunnel is restricted. Material is in poor condition.

Does Material Contain Asbestos?

Yes

Is it Friable?

Yes

Original Inspection Date

6/ 1/92

Current Surveillance Date

7/ 3/97

Current Assessment Rating

1B Damaged TSI

Cause of Damage

Physical Damage

Accessible

Yes

Potential for Damage

Low

Removed

No

Planned Response Action

0 & M

Inspector

Karen Foxx

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

11

Type of Material

Miscellaneous Material

Quantity of Material

30 SF

Material Location

Boiler Room

Material Description

Fire Door

Comments

Material is assumed to be in good condition.

Does Material Contain Asbestos?

Assumed

Is it Friable?

No

Original Inspection Date

6/ 1/92

Current Surveillance Date

7/3/97

Current Assessment Rating

NR Not Required

Cause of Damage

No Damage

Accessible

Yes

Potential for Damage

Low

Removed

No

Planned Response Action

0 & M

Inspector

Karen Foyy

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

15

2

Type of Material

Miscellaneous Material

Each

Quantity of Material

Material Location

Boiler Room

Material Description

Boiler Gaskets

Comments

Material is in good condition.

Does Material Contain Asbestos?

Assumed

Is it Friable?

No

Original Inspection Date

6/ 1/92

Current Surveillance Date

7/ 3/97

Current Assessment Rating

NR Not Required

Cause of Damage

No Damage

Accessible

Yes

Potential for Damage

Low

Removed

No

Planned Response Action

0 & M

Inspector

Karen Foxx

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

2

Type of Material

Thermal Material

Quantity of Material

150

LF

Material Location

Tunnels and Boiler Room

Material Description

Pipe Insulation - Air Cell

Comments

Restricted entry to tunnel. There is damage to the pipe near boiler #1. O & M is

needed.

Does Material Contain Asbestos?

Yes

Is it Friable?

Yes

Original Inspection Date

6/ 1/92

Current Surveillance Date

7/ 3/97

Current Assessment Rating

1B Damaged TSI

Cause of Damage

Physical Damage

Accessible

Yes

Potential for Damage

Low

Removed

No

Planned Response Action

O & M

Inspector

Karen Foyy

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

3

48

Type of Material

Thermal Material

Quantity of Material

Each

Material Location

Boiler Room and Tunnel

Material Description

Fittings

Comments

There is some minor damage in the boiler room. Entry to tunnel is restricted.

Does Material Contain Asbestos?

Yes

Is it Friable?

Yes

Original Inspection Date

6/ 1/92

Current Surveillance Date

7/3/97

Current Assessment Rating

1B Damaged TSI

Cause of Damage

Physical Damage

Accessible

Yes

Potential for Damage

Low

Removed

No

Planned Response Action

O&M

Inspector

Karen Foxx

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

4

Type of Material

Thermal Material

Quantity of Material

40 SF

Material Location

Tunnel

Material Description

Debris

Comments

Access to tunnel restricted. Do not know if there. Could not access tunnel.

Does Material Contain Asbestos?

Yes

Is it Friable?

Yes

Original Inspection Date

6/ 1/92

Current Surveillance Date

7/ 3/97

Current Assessment Rating

1B Damaged TSI

Cause of Damage

Physical Damage

Accessible

Yes

Potential for Damage

High

Removed

No

Planned Response Action

O & M

Inspector

Karen Foxx

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

5

Type of Material

Miscellaneous Material

Quantity of Material

33,750 SF

Material Location

Throughout Building (Classrooms, Halls & Office)

Material Description

VAT

Comments

Material is positive everywhere except the gymnasium. VAT was removed in the cafeteria over the summer of '95.

Does Material Contain Asbestos?

Yes

Is it Friable?

No

Original Inspection Date

6/ 1/92

Current Surveillance Date

7/ 3/97

Current Assessment Rating

NR Not Required

Karin

Cause of Damage

No Damage

Accessible

Yes

Potential for Damage

Low

Removed

No

Planned Response Action

0 & M

Inspector

Caren Foxy

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

7

Type of Material

Miscellaneous Material

Quantity of Material

33,750 SF

Material Location

Throughout Building

Material Description

Mastic

Comments

Material is assumed to be in good condition.

Does Material Contain Asbestos?

Assumed

Is it Friable?

No

Original Inspection Date

6/ 1/92

Current Surveillance Date

7/ 3/97

Current Assessment Rating

NR Not Required

Cause of Damage

No Damage

Accessible

No

Potential for Damage

Low

Removed

No

Planned Response Action

0 & M

Inspector

Karen Foxx

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

Α

Type of Material

Miscellaneous Material

Quantity of Material

LF

Material Location

Throughout the building

Material Description

Cove Base

Comments

Material is in good condition.

Does Material Contain Asbestos?

Assumed

Is it Friable?

No

Original Inspection Date

5/31/95

Current Surveillance Date

7/ 3/97

Current Assessment Rating

NR Not Required

Cause of Damage

No Damage

Accessible

Yes

Potential for Damage

Low

Removed

No

Planned Response Action

M&O

Inspector

Karen Foxx

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

В

Type of Material

Miscellaneous Material

Quantity of Material

LF

Material Location

Throughout Building

Material Description

Cove Base Mastic

Comments

Material is assumed to be in good condition.

Does Material Contain Asbestos?

Assumed

Is it Friable?

No

Original Inspection Date

5/31/95

Current Surveillance Date

7/ 3/97

Current Assessment Rating

NR Not Required

Cause of Damage

No Damage

Accessible

No

Potential for Damage

Low

Removed

No

Planned Response Action

O & M


Inspector

Karen Foxx

State

Indiana

Accreditation Number



LEA Name Greater Clark County Schools

Building Name Thomas Jefferson Elementary

HA# 1

Type of Material Thermal Material

Quantity of Material 90 LF

Material Location

Tunnels

Material Description

Pipe Insulation - Mag

Comments

Entry to tunnel is restricted. Material is in poor condition.

Does Material Contain Asbestos? Yes
Is it Friable? Yes
Original Inspection Date 6/ 1/92
Current Surveillance Date 12/16/96

Current Assessment Rating 1B Damaged TSI
Cause of Damage Physical Damage

Accessible Yes
Potential for Damage Low
Removed No
Planned Response Action O & M

inspector

State Indiana

Clint Yates

LEA Name Greater Clark County Schools

Building Name Thomas Jefferson Elementary

HA# 11

Type of Material Miscellaneous Material

Quantity of Material 30 SF

Material Location

Boiler Room

Material Description

Fire Door

Comments

Material is assumed to be asbestos containing.

Does Material Contain Asbestos? Assumed

Is it Friable?

Original Inspection Date 6/ 1/92
Current Surveillance Date 12/16/96

Current Assessment Rating NR Not Required

Cause of Damage No Damage

Accessible Yes
Potential for Damage Low
Removed No
Planned Response Action O & M

Inspector

State Indiana
Accreditation Number 193804035

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

15

Type of Material

Miscellaneous Material

Quantity of Material

2

Each

Material Location

Boiler Room

Material Description

Boiler Gaskets

Comments

Material is assumed to be asbestos containing.

Does Material Contain Asbestos?

Assumed

Is it Friable?

No

Original Inspection Date

6/ 1/92

Current Surveillance Date

12/16/96

Current Assessment Rating

NR Not Required

Cause of Damage

No Damage

Accessible

Yes

Potential for Damage

Low

Removed

No

Planned Response Action

O & M

Inspector

Clint Yates

State

Indiana

Accreditation Number

LEA Name Greater Clark County Schools

Building Name Thomas Jefferson Elementary

HA# 2

Type of Material Thermal Material

Quantity of Material 150 LF

Material Location

Tunnels and Boiler Room

Material Description

Pipe Insulation - Air Cell

Comments

Restricted entry to tunnel. Material is known to be asbestos containing. There is damage to the pipe near boiler #1. O & M is needed. No change.

Does Material Contain Asbestos? Yes Is it Friable? Yes

Original Inspection Date 6/ 1/92
Current Surveillance Date 12/16/96

Current Assessment Rating 1B Damaged TSI
Cause of Damage Physical Damage

Accessible Yes
Potential for Damage Low
Removed No
Planned Response Action O & M

Inspector

State

Indiana

Accreditation Number 193804035

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

3

48

Type of Material

Thermal Material

Quantity of Material

Each

Material Location

Boiler Room and Tunnel

Material Description

Fittings

Comments

Material is known to be asbestos containing. There is some minor damage in the boiler room. Entry to tunnel is not restricted.

Does Material Contain Asbestos?

Yes

Is it Friable?

Yes

Original Inspection Date

6/ 1/92

Current Surveillance Date

12/16/96

Current Assessment Rating

1B Damaged TSI

Cause of Damage

Physical Damage

Accessible

Yes

Potential for Damage

Low

Removed

No

Planned Response Action

O & M

Inspector

Clint Yates

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

4

Type of Material

Thermal Material

Quantity of Material

40 SF

Material Location

Tunnel

Material Description

Debris

Comments

Material is known to be asbestos containing. Access to tunnel is not restricted.

Does Material Contain Asbestos?

Yes

Is it Friable?

Yes

Original Inspection Date

6/ 1/92

Current Surveillance Date

12/16/96

Current Assessment Rating

1B Damaged TSI

Cause of Damage

Physical Damage

Accessible

Yes

Potential for Damage

High

Removed

No

Planned Response Action

O & M

inspector

Clint Yates

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

5

Type of Material

Miscellaneous Material

Quantity of Material

33,750 SF

Material Location

Throughout Building (Classrooms, Halls & Office)

Material Description

VAT

Comments

VAT was removed in entire building during the summer of 1995.

Does Material Contain Asbestos?

Yes

Is it Friable?

No

Original Inspection Date

6/ 1/92

Current Surveillance Date

12/16/96

Current Assessment Rating

NR Not Required

Cause of Damage

No Damage

Accessible

Yes

Potential for Damage

Low

Removed

No

Planned Response Action

M & O

Inspector

Clint Yates

State

Indiana

Accreditation Number

Clint Yates

LEA Name Greater Clark County Schools

Thomas Jefferson Flamentania

Building Name Thomas Jefferson Elementary

HA# 7

Type of Material Miscellaneous Material

Quantity of Material 33,750 SF

Material Location

Throughout Building

Material Description

Mastic

Comments

Material is assumed to be asbestos containing.

Does Material Contain Asbestos? Assumed

Is it Friable? No

Original Inspection Date 6/ 1/92
Current Surveillance Date 12/16/96

Current Assessment Rating NR Not Required

Cause of Damage No Damage

Accessible No
Potential for Damage Low
Removed No
Planned Response Action O & M

Inspector

State Indiana

Accreditation Number 193804035

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

Α

Type of Material

Miscellaneous Material

Quantity of Material

LF

Material Location

Throughout the building

Material Description

Cove Base

Comments

Material is assumed to be positive and will be treated as ACM until it is sampled. Material is in good condition.

Does Material Contain Asbestos?

Assumed

Is it Friable?

No

Original Inspection Date

5/31/95

Current Surveillance Date

12/16/96

Current Assessment Rating

NR Not Required

Cause of Damage

No Damage

Accessible

Yes

Potential for Damage

Low

Removed

No

Planned Response Action

0 & M

Inspector

Clipt Yates

State

Indiana

Accreditation Number

LEA Name Greater Clark County Schools
Building Name Thomas Jefferson Elementary

HA# B

Type of Material Miscellaneous Material

Quantity of Material LF

Material Location

Throughout Building

Material Description

Cove Base Mastic

Comments

Material is assumed to be positive and will be treated as ACM until it is sampled. Material is in good condition.

Does Material Contain Asbestos? Assumed

Is it Friable?

Original Inspection Date 5/31/95
Current Surveillance Date 12/16/96

Current Assessment Rating NR Not Required


Cause of Damage No Damage

Accessible No
Potential for Damage Low
Removed No
Planned Response Action O & M

Inspector

Clipt Yates Indiana

State Indiana
Accreditation Number 193804035



LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

1

90

Type of Material

Thermal Material

Quantity of Material

LF

Material Location

Tunnels

Material Description

Pipe Insulation - Mag

Comments

Entry to tunnel is restricted. Material is known to be asbestos containing. No change.

Does Material Contain Asbestos?

Yes

Is it Friable?

Yes

Original Inspection Date

6/ 1/92

Current Surveillance Date

6/24/96

Current Assessment Rating

1B Damaged TSI

Cause of Damage

Physical Damage

Accessible

Yes

Potential for Damage

Low

Removed

No

Planned Response Action

0 & M

Inspector

Rex Gaddis

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

11

30

Type of Material

Miscellaneous Material

Quantity of Material

SF

Material Location

Boiler Room

Material Description

Fire Door

Comments

Material is assumed to be asbestos containing.

Does Material Contain Asbestos?

Assumed

Is it Friable?

No

Original Inspection Date

6/ 1/92

Current Surveillance Date

6/24/96

Current Assessment Rating

NR Not Required

Cause of Damage

No Damage

Accessible

Yes

Potential for Damage

Low

Removed

No

Planned Response Action

O & M

Inspector

Rex Gaddis

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

15

Type of Material

Miscellaneous Material

Quantity of Material

2

Each

Material Location

Boiler Room

Material Description

Boiler Gaskets

Comments

Material is assumed to be asbestos containing.

Does Material Contain Asbestos?

Assumed

Is it Friable?

No

Original Inspection Date

6/ 1/92

Current Surveillance Date

6/24/96

Current Assessment Rating

NR Not Required

Cause of Damage

No Damage

Accessible

Yes

Potential for Damage

Low

Removed

No

Planned Response Action

0 & M

Inspector

Rex Gaddis

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

2

150

Type of Material

Thermal Material

Quantity of Material

LF

Material Location

Tunnels and Boiler Room

Material Description

Pipe Insulation - Air Cell

Comments

Restricted entry to tunnel. Material is known to be asbestos containing. There is damage to the pipe near boiler #1. O & M is needed. No change.

Does Material Contain Asbestos?

Yes

Is it Friable?

Yes

Original Inspection Date

6/ 1/92

Current Surveillance Date

6/24/96

Current Assessment Rating

1B Damaged TSI

Cause of Damage

Physical Damage

Accessible

Yes

Potential for Damage

Low

Removed

No

Planned Response Action

0 & M

Inspector

Rex Gaddis

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

3

Type of Material

Thermal Material

Quantity of Material

48

Each

Material Location

Boiler Room and Tunnel

Material Description

Fittings

Comments

Material is known to be asbestos containing. There is some minor damage in the boiler room. Entry to tunnel is restricted.

Does Material Contain Asbestos?

Yes

Is it Friable?

Yes

Original Inspection Date

6/ 1/92

Current Surveillance Date

6/24/96

Current Assessment Rating

1B Damaged TSI

Cause of Damage

Physical Damage

Accessible

Yes

Potential for Damage

Low

Removed

No

Planned Response Action

O & M

Inspector

Rex Gaddis

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

4

40

Type of Material

Thermal Material

Quantity of Material

SF

Material Location

Tunnel

Material Description

Debris

Comments

Material is known to be asbestos containing. Access to tunnel is restricted. Do not know if there. Could not access tunnel.

Does Material Contain Asbestos?

Yes

Is it Friable?

Yes

Original Inspection Date

6/ 1/92

Current Surveillance Date

6/24/96

Current Assessment Rating

1B Damaged TSI

Cause of Damage

Physical Damage

Accessible

Yes

Potential for Damage

High

Removed

No

Planned Response Action

O & M

Inspector

Rex Gaddis

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

- 5

Type of Material

Miscellaneous Material

Quantity of Material

33,750 SF

Material Location

Throughout Building (Classrooms, Halls & Office)

Material Description

VAT

Comments

Material is positive everywhere except the gymnasium. VAT was removed in the cafeteria over the summer of '95.

Does Material Contain Asbestos?

Yes

Is it Friable?

'No

Original Inspection Date

6/ 1/92

Current Surveillance Date

6/24/96

Current Assessment Rating

NR Not Required

Cause of Damage

No Damage

Accessible

Yes

Potential for Damage

Low

Removed

No

Planned Response Action

O & M

Inspector

Rex Gaddis

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

7

Type of Material

Miscellaneous Material

Quantity of Material

33,750 SF

Material Location

Throughout Building

Material Description

Mastic

Comments

Material is assumed to be asbestos containing.

Does Material Contain Asbestos?

Assumed

Is it Friable?

No

Original Inspection Date

6/ 1/92

Current Surveillance Date

6/24/96

Current Assessment Rating

NR Not Required

Cause of Damage

No Damage

Accessible

No

Potential for Damage

Low

Removed

No

Planned Response Action

O & M

Inspector

Rev Gaddis

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

Α

Type of Material

Miscellaneous Material

Quantity of Material

LF

Material Location

Throughout the building

Material Description

Cove Base

Comments

Material is assumed to be positive and will be treated as ACM until it is sampled. Material is in good condition.

Does Material Contain Asbestos?

Assumed

Is it Friable?

No

Original Inspection Date

5/31/95

Current Surveillance Date

6/24/96

Current Assessment Rating

NR Not Required

Cause of Damage

No Damage

Accessible

Yes

Potential for Damage

Low

Removed

No

Planned Response Action

0 & M

Inspector

Rex Gaddis

State

Indiana

Accreditation Number

LEA Name Greater Clark County Schools

Building Name Thomas Jefferson Elementary

HA#

Type of Material Miscellaneous Material

Quantity of Material LF

Material Location

Throughout Building

Material Description

Cove Base Mastic

Comments

Material is assumed to be positive and will be treated as ACM until it is sampled. Material is in good condition.

Rex Gaddis

Does Material Contain Asbestos? Assumed

Is it Friable?

Original Inspection Date 5/31/95
Current Surveillance Date 6/24/96

Current Assessment Rating NR Not Required


Cause of Damage No Damage

Accessible No
Potential for Damage Low
Removed No
Planned Response Action O & M

Inspector ________

State Indiana

Accreditation Number 190908032



LEA NAME:

Greater Clark County Schools

BUILDING NAME:

Thomas Jefferson Elementary

HA#:

1

TYPE OF MATERIAL:

Thermal Material

QUANTITY OF MATERIAL:

90LF

MATERIAL LOCATION:

Tunnels

MATERIAL DESCRIPTION:

Pipe Insulation - Mag

COMMENTS:

Entry to tunnel is restricted. Material is known to be asbestos containing.

IS MATERIAL FRIABLE?

YES

ORIGINAL INSPECTION DATE:

06/01/92

CURRENT SURVEILLANCE DATE:

12/07/95

CURRENT ASSESSMENT RATING:

1B Damaged TSI

CAUSE OF DAMAGE:

Physical Damage

ACCESSIBLE:

YES

POTENTIAL FOR DAMAGE:

Low

REMOVED:

NO

STATE:

Indiana

INSPECTOR NAME:

Clint Yates

LEA NAME:

Greater Clark County Schools

BUILDING NAME:

Thomas Jefferson Elementary

HA#:

11

TYPE OF MATERIAL: Miscellaneous Material

QUANTITY OF MATERIAL:

30SF

MATERIAL LOCATION:

Boiler Room

MATERIAL DESCRIPTION:

Fire Door

COMMENTS:

Material is assumed to be asbestos containing.

IS MATERIAL FRIABLE?

NO

ORIGINAL INSPECTION DATE: 06/01/92

CURRENT SURVEILLANCE DATE:

12/07/95

CURRENT ASSESSMENT RATING:

NR Not Required

CAUSE OF DAMAGE:

No Damage

ACCESSIBLE:

YES

POTENTIAL FOR DAMAGE:

Low

REMOVED:

NO

STATE:

Indiana

INSPECTOR NAME:

LEA NAME:

Greater Clark County Schools

BUILDING NAME: Thomas Jefferson Elementary

HA#:

15

TYPE OF MATERIAL: Miscellaneous Material

QUANTITY OF MATERIAL:

2

MATERIAL LOCATION:

Boiler Room

MATERIAL DESCRIPTION:

Boiler Gaskets

COMMENTS:

Material is assumed to be asbestos containing.

IS MATERIAL FRIABLE?

NO

ORIGINAL INSPECTION DATE:

06/01/92

CURRENT SURVEILLANCE DATE:

12/07/95

CURRENT ASSESSMENT RATING: NR Not Required

CAUSE OF DAMAGE:

No Damage

ACCESSIBLE:

YES

POTENTIAL FOR DAMAGE:

Low

REMOVED:

NO

STATE:

Indiana

INSPECTOR NAME:

int Yates

LEA NAME:

Greater Clark County Schools

BUILDING NAME:

Thomas Jefferson Elementary

HA#:

2

TYPE OF MATERIAL:

Thermal Material

QUANTITY OF MATERIAL:

150LF

MATERIAL LOCATION:

Tunnels and Boiler Room

MATERIAL DESCRIPTION:

Pipe Insulation - Air Cell

COMMENTS:

Restricted entry to tunnel. Material is known to be asbestos containing. There is damage to the pipe near boiler #1. 0 & M is needed.

IS MATERIAL FRIABLE?

ORIGINAL INSPECTION DATE:

06/01/92

YES

CURRENT SURVEILLANCE DATE:

12/07/95

CURRENT ASSESSMENT RATING:

1B Damaged TSI

CAUSE OF DAMAGE:

Physical Damage

ACCESSIBLE:

YES

POTENTIAL FOR DAMAGE:

Low

REMOVED:

NO

STATE:

Indiana

INSPECTOR NAME:

Clint Yates

LEA NAME:

Greater Clark County Schools

BUILDING NAME:

Thomas Jefferson Elementary

HA#:

3

TYPE OF MATERIAL:

Thermal Material

QUANTITY OF MATERIAL:

48

MATERIAL LOCATION:

Boiler Room and Tunnel

MATERIAL DESCRIPTION:

Fittings

COMMENTS:

Material is known to be asbestos containing. There is some damage in the boiler room. Entry to tunnel is restricted.

IS MATERIAL FRIABLE?

YES

ORIGINAL INSPECTION DATE:

06/01/92

CURRENT SURVEILLANCE DATE:

12/07/95

CURRENT ASSESSMENT RATING:

1B Damaged TSI

CAUSE OF DAMAGE:

Physical Damage

ACCESSIBLE:

YES

POTENTIAL FOR DAMAGE:

Low

REMOVED:

NO

STATE:

Indiana

INSPECTOR NAME:

Clint/Yates

LEA NAME:

Greater Clark County Schools

BUILDING NAME:

Thomas Jefferson Elementary

HA#:

4

TYPE OF MATERIAL:

Thermal Material

QUANTITY OF MATERIAL:

40SF

MATERIAL LOCATION:

Tunnel

MATERIAL DESCRIPTION:

Debris

COMMENTS:

Material is located on tunnel floor. It is known to be asbestos containing. Access to tunnel is restricted.

IS MATERIAL FRIABLE?

YES

ORIGINAL INSPECTION DATE:

06/01/92

CURRENT SURVEILLANCE DATE:

12/07/95

CURRENT ASSESSMENT RATING:

1B Damaged TSI

CAUSE OF DAMAGE:

Physical Damage

ACCESSIBLE:

YES

POTENTIAL FOR DAMAGE:

High

REMOVED:

NO

STATE:

Indiana

INSPECTOR NAME:

Clint Yates

LEA NAME:

Greater Clark County Schools

BUILDING NAME:

Thomas Jefferson Elementary

HA#:

5

TYPE OF MATERIAL:

Miscellaneous Material

QUANTITY OF MATERIAL:

33,750

MATERIAL LOCATION:

Throughout Building (Classrooms, Halls & Office)

MATERIAL DESCRIPTION:

VAT

COMMENTS:

Material is positive everywhere except the gymnasium. VAT was removed in the cafeteria over the summer of '95.

IS MATERIAL FRIABLE?

NO

ORIGINAL INSPECTION DATE:

06/01/92

CURRENT SURVEILLANCE DATE:

12/07/95

CURRENT ASSESSMENT RATING:

NR

R Not Required

CAUSE OF DAMAGE:

No Damage

ACCESSIBLE:

YES

POTENTIAL FOR DAMAGE:

Low

REMOVED:

NO

STATE:

Indiana

INSPECTOR NAME:

Clint Yaxes

LEA NAME:

Greater Clark County Schools

BUILDING NAME: Thomas Jefferson Elementary

HA#:

7

TYPE OF MATERIAL: Miscellaneous Material

QUANTITY OF MATERIAL:

33,750

MATERIAL LOCATION:

Throughout Building

MATERIAL DESCRIPTION:

Mastic

COMMENTS:

Material is assumed to be asbestos containing.

IS MATERIAL FRIABLE?

NO

ORIGINAL INSPECTION DATE:

06/01/92

CURRENT SURVEILLANCE DATE:

12/07/95

CURRENT ASSESSMENT RATING: NR Not Required

CAUSE OF DAMAGE:

No Damage

ACCESSIBLE:

NO

POTENTIAL FOR DAMAGE:

Low

REMOVED:

NO

STATE:

Indiana

INSPECTOR NAME:

LEA NAME:

Greater Clark County Schools

BUILDING NAME:

Thomas Jefferson Elementary

HA#:

A

TYPE OF MATERIAL:

Miscellaneous Material

QUANTITY OF MATERIAL:

MATERIAL LOCATION:

Throughout Building

MATERIAL DESCRIPTION:

Cove Base

COMMENTS:

This material was not addressed in the original inspection. It is assumed to be positive and will be treated as ACM until it is sampled. Material is in good condition and is non-friable and does not need as assessment rating at this time.

IS MATERIAL FRIABLE?

NO

ORIGINAL INSPECTION DATE:

CURRENT SURVEILLANCE DATE:

12/07/95

CURRENT ASSESSMENT RATING:

NR Not Required

CAUSE OF DAMAGE:

No Damage

ACCESSIBLE:

YES

POTENTIAL FOR DAMAGE:

Low

REMOVED:

NO

STATE:

Indiana

INSPECTOR NAME:

Clint Yates

LEA NAME:

Greater Clark County Schools

BUILDING NAME:

Thomas Jefferson Elementary

HA#:

В

TYPE OF MATERIAL:

Miscellaneous Material

QUANTITY OF MATERIAL:

MATERIAL LOCATION:

Throughout Building

MATERIAL DESCRIPTION:

Cove Base Mastic

COMMENTS:

This material was not addressed in the original inspection. It is assumed to be positive and will be treated as ACM until it is sampled. Material is in good condition and is non-friable and does not need an assessment rating at this time.

IS MATERIAL FRIABLE?

NO

ORIGINAL INSPECTION DATE:

CURRENT SURVEILLANCE DATE:

12/07/95

CURRENT ASSESSMENT RATING:

NR Not Required

CAUSE OF DAMAGE:

No Damage

ACCESSIBLE:

NO

POTENTIAL FOR DAMAGE:

Low

REMOVED:

NO

STATE:

Indiana

INSPECTOR NAME:

Wint Yates

THIRD YEAR REINSPECTIONS

REINSPECTION PLAN

GREATER CLARK COUNTY SCHOOLS

Reinspection by an accredited building inspector will be scheduled to be performed not more than three years from the date of the original inspection. The reinspection report will then be made a permanent part of this Management Plan. Reinspections will be performed every three years for as long as the building contains ACBM, and will be reinspected once within three years from the date that all ACBM has been removed.

Records of each reinspection should be maintained in this binder.

DATE PLANNED	DATE COMPLETED	COMPLETED BY
JUNE 2007	July 2007	Bill Ogle
JUNE 2010	ala and	Sandy Stadley
JUNE 2013	April 2013	Jeff hechtin
JUNE 2016	April 2016	Porjain (to)
	May 2019	
JUNE 2022		
JUNE 2025		

REINSPECTION PLAN

GREATER CLARK COUNTY SCHOOLS JEFFERSON ELEMENTARY SCHOOL

The ACBM in this building shall be reinspected every three years to determine any change in the condition of the materials for as long they remain in the building. This reinspection will be conducted tri-annually by an accredited inspector.

The following table outlines the dates on which these inspections should take place in this school building.

REINSPECTION SCHEDULE

DATE PLANNED	DATE COMPLETED	COMPLETED BY
JUNE 1992	JUNE 1992	ASBESTECH
JUNE 1995	June '95	alliance
JUNE 1998	June '98	alleance
JUNE 2001	July '01	4. Wilson
JUNE 2004	July '04	C. Spanks

Triennial Reinspection

LEA Name Greater Clark County School Corporation

Building Name Thomas Jefferson Elementary School

Building Number 03

HA ID 01

HA Description Pipe Insulation

HA Type Thermal System Insulation (TSI)

HA Location Boiler room

Quantity 10 LF

Comments This material was not in poor condition along east wall near east boiler by

tunnel entry.

Scheduled for abatement in 2012/2013 renovation.

Asbestos Known

Friable No

Original Inspection 6/1/1992

Current Inspection 5/16/2019

Material Assessment

Assessment Rating 5 ACBM with potential for damage

Damage Assessment and Potential for Damage

Percent Damaged % Good Condition

Physical ContactVibrationAirLow/NoneLow/NoneLow/None

Planned Response Action O&M

Inspector

Sean Stults

State IN

Accreditation Number 19A007184

Triennial Reinspection

LEA Name Greater Clark County School Corporation

Thomas Jefferson Elementary School **Building Name**

Building Number 03

HAID 02

HA Description Pipe Insulation

HA Type Thermal System Insulation (TSI)

Tunnels **HA Location**

LF Quantity 230

Comments Entrances to tunnels are restricted, as this material is in poor condition. There is

all over the floor of the dirt crawl. No one should enter this area without proper

training

and protection. Clean up recommended. Scheduled for abatement in 2012/2013

renovation.

Asbestos Known

Friable Yes

Original Inspection 6/1/1992 **Current Inspection** 5/16/2019

Material Assessment

Assessment Rating 1 Damaged or significantly damaged thermal syste

Damage Assessment and Potential for Damage

Percent Damaged % Damanged - Localized

> **Physical Contact** Vibration <u>Air</u> High

Low/None Low/None

Planned Response Action Patch and Repair

Inspector

Sean Stults

State IN Accreditation Number 19A007184

LEA Name Greater Clark County School Corporation

Thomas Jefferson Elementary School **Building Name**

Building Number 03

HAID 03

HA Description Fittings

HA Type Thermal System Insulation (TSI)

Boiler room and tunnel **HA Location**

Quantity 48 Unit(s)

Comments Material in tunnel is in poor condition. Entry to tunnel is restricted. No one

should enter

without proper training and protection. Clean up recommended. Scheduled for

abatement in 2012/2013 renovation.

Asbestos Known

Friable Yes

Original Inspection 6/1/1992 **Current Inspection** 5/16/2019

Material Assessment

Assessment Rating 1 Damaged or significantly damaged thermal syste

Damage Assessment and Potential for Damage

Percent Damaged % Damanged - Localized

> **Physical Contact Vibration** <u>Air</u> High

Low/None Low/None

Planned Response Action 0&M

Sean Stults

State IN

Accreditation Number 19A007184

Inspector

LEA Name Greater Clark County School Corporation

Building Name Thomas Jefferson Elementary School

Building Number 03

HA ID 05-A

HA Type VAT-underneath carpet Miscellaneous Material

HA Location Throughout the building (classrooms, hallways & office)

Quantity Unquantified SF

Comments Floor Tile (installed in 1994)

Asbestos Known

Friable No

Original Inspection 6/1/1992

Current Inspection 5/16/2019

Material Assessment

Assessment Rating 5 ACBM with potential for damage

Damage Assessment and Potential for Damage

Percent Damaged % Good Condition

Physical ContactVibrationAirLow/NoneLow/NoneLow/None

Planned Response Action O&M

Inspector

Sean Stults

State IN

LEA Name Greater Clark County School Corporation

Building Name Thomas Jefferson Elementary School

Building Number 03

HA ID 05-B

HA Description 12" x 12" newer off-white floor tile

HA Type Miscellaneous Material

HA Location Throughout the building (first aid office, cafeteria, workroom, water fountain

area, office

hallway, entrance, and art room)

Quantity Unquantified

Comments Minor chipping near water fountain. Overall, this material is not in poor

condition.

Asbestos Known

Friable No

Original Inspection 6/1/1992

Current Inspection 5/16/2019

Material Assessment

Assessment Rating 5 ACBM with potential for damage

Damage Assessment and Potential for Damage

Percent Damaged % Good Condition

<u>Physical Contact</u> <u>Vibration</u> <u>Air</u>

Low/None Low/None Low/None

Planned Response Action O&M

Inspector

Sean Stults

State IN

LEA Name Greater Clark County School Corporation

Building Name Thomas Jefferson Elementary School

Building Number 03

HA ID 05-C

HA Description 12" x 12" original floor tileHA Type Miscellaneous Material

HA Location Throughout the building (gym and custodial closets).

Quantity Unquantified SF

Comments Minor chipping in closets. Overall, this material is not in poor condition.

Asbestos Known

Friable No

Original Inspection 6/1/1992

Current Inspection 5/16/2019

Material Assessment

Assessment Rating 5 ACBM with potential for damage

Damage Assessment and Potential for Damage

Percent Damaged % Good Condition

Physical ContactVibrationAirLow/NoneLow/NoneLow/None

Planned Response Action O&M

Inspector

Sean Stults

State IN

LEA Name Greater Clark County School Corporation

Building Name Thomas Jefferson Elementary School

Building Number 03

HA ID 05-D

HA Description 12" x 12" original light blue floor tile

HA Type Miscellaneous Material

HA Location Throughout the building (gym)

Quantity Unquantified SF

Comments Where visible, this material is not in poor condition.

Asbestos Known

Friable No

Original Inspection 6/1/1992

Current Inspection 5/16/2019

Material Assessment

Assessment Rating 5 ACBM with potential for damage

Damage Assessment and Potential for Damage

Percent Damaged % Good Condition

Physical ContactVibrationAirLow/NoneLow/NoneLow/None

Planned Response Action O&M

Inspector

Sean Stults

State IN

LEA Name Greater Clark County School Corporation

Building Name Thomas Jefferson Elementary School

Building Number 03

HA ID 07

HA Description Mastic

HA Type Miscellaneous Material

HA Location Throughout the building

Quantity 33750 SF

Comments This material was not visible to inspect.

Asbestos Assumed

Friable No

Original Inspection 6/1/1992

Current Inspection 5/16/2019

Material Assessment

Assessment Rating 5 ACBM with potential for damage

Damage Assessment and Potential for Damage

Percent Damaged % Good Condition

Physical ContactVibrationAirLow/NoneLow/NoneLow/None

Planned Response Action O&M

Inspector

Sean Stults

State IN

LEA Name Greater Clark County School Corporation

Building Name Thomas Jefferson Elementary School

Building Number 03

HA ID 11

HA Type Fire door-Metal clad Miscellaneous Material

HA Location Boiler room (2) Gym Exterior Doors (4)

Quantity 6 Unit(s)

Comments The fire door shell is intact with no core material visible to inspect.

Asbestos Assumed

Friable No

Original Inspection 6/1/1992

Current Inspection 5/16/2019

Material Assessment

Assessment Rating 5 ACBM with potential for damage

Damage Assessment and Potential for Damage

Percent Damaged % Good Condition

Physical ContactVibrationAirLow/NoneLow/NoneLow/None

Planned Response Action O&M

Inspector

Sean Stults

State IN

LEA Name Greater Clark County School Corporation

Building Name Thomas Jefferson Elementary School

Building Number 03

HA ID 15

HA Description Boiler gaskets

HA Type Miscellaneous Material

HA Location Boiler room

Quantity 2 Unit(s)

Comments Boiler doors were closed. The visible edges of this material were not in poor

condition.

There is some fiberglass rope visible, but also some older looking gasket

material.

Asbestos Assumed

Friable No

Original Inspection 6/1/1992

Current Inspection 5/16/2019

Material Assessment

Assessment Rating 5 ACBM with potential for damage

Damage Assessment and Potential for Damage

Percent Damaged % Good Condition

Physical ContactVibrationAirLow/NoneLow/NoneLow/None

Planned Response Action O&M

-

State IN

Inspector

Sean Stults

LEA Name Greater Clark County School Corporation

Building Name Thomas Jefferson Elementary School

Building Number 03

HAID Α

HA Location

HA Description Cove Base

HA Type Miscellaneous Material Throughout the building

Quantity Approx. 3800 LF

Comments Material is not in poor condition overall with minor signs of wear. Loose and

missing in

a few locations. (installed in 1994)

Asbestos Assumed

Friable No

Original Inspection 5/31/1995 **Current Inspection** 5/16/2019

Material Assessment

Assessment Rating 5 ACBM with potential for damage

Damage Assessment and Potential for Damage

Percent Damaged % **Good Condition**

> **Physical Contact Vibration** <u>Air</u> Low/None Low/None Low/None

Planned Response Action 0&M

Inspector

Sean Stults

State IN

LEA Name Greater Clark County School Corporation

Building Name Thomas Jefferson Elementary School

Building Number 03

HA ID B

HA Description Cove base mastic

HA Type Miscellaneous Material

HA Location Throughout the building

Quantity Approx. 1200 SF

Comments Mastic was visible to inspect at corner near custodial closet in the cafateria

where cove

base was missing.

Asbestos Assumed

Friable No

Original Inspection 5/31/1995

Current Inspection 5/16/2019

Material Assessment

Assessment Rating 5 ACBM with potential for damage

Damage Assessment and Potential for Damage

Percent Damaged % Good Condition

Physical ContactVibrationAirLow/NoneLow/NoneLow/None

Planned Response Action O&M

Inspector

Sean Stults

State IN

LEA Name Greater Clark County School Corporation

Building Name Thomas Jefferson Elementary School

Building Number 03

HA ID C

HA Description AHU Cloth Expansion Joints

HA Type Miscellaneous Material

HA Location Stage ends

Quantity 2 Unit(s)

Comments These were noted during the June 2011 6 month surveillance and will remain in

the

management plan until properly sampled.

Asbestos Assumed

Friable No

Original Inspection 6/27/2011

Current Inspection 5/16/2019

Material Assessment

Assessment Rating 5 ACBM with potential for damage

Damage Assessment and Potential for Damage

Percent Damaged % Good Condition

Physical Contact Vibration Air

Low/None Low/None Low/None

Planned Response Action O&M

Sean Stults

State IN

Accreditation Number 19A007184

Inspector

LEA Name Greater Clark County School Corporation

Building Name Thomas Jefferson Elementary School

Building Number 03

HA ID D

HA Description Fire Doors-Original to building (wooden)

HA Type Miscellaneous Material

HA Location Gym & throughout the building

Quantity Unquantified Unit(s)

Comments These were noted during the June 2011 6 month surveillance and will remain in

the

management plan until properly sampled.

Asbestos Assumed

Friable No

Original Inspection 6/27/2011

Current Inspection 5/16/2019

Material Assessment

Assessment Rating 5 ACBM with potential for damage

Damage Assessment and Potential for Damage

Percent Damaged % Good Condition

Physical ContactVibrationAirLow/NoneLow/NoneLow/None

Planned Response Action O&M

Inspector

Sean Stults

State IN

LEA Name Greater Clark County School Corporation

Building Name Thomas Jefferson Elementary School

Building Number 03

HA ID E

HA Description Gray Sink InsulationHA Type Miscellaneous Material

HA Location Classrooms, Art Room & Teachers Lounge

Quantity Unquantified LF

Comments This was noted during the June 2011 6 month surveillance and will remain in the

management plan until properly sampled.

Asbestos Assumed

Friable No

Original Inspection 6/27/2011

Current Inspection 5/16/2019

Material Assessment

Assessment Rating 5 ACBM with potential for damage

Damage Assessment and Potential for Damage

Percent Damaged % Good Condition

Physical ContactVibrationAirLow/NoneLow/NoneLow/None

Planned Response Action O&M

Inspector

Sean Stults

State IN

LEA Name Greater Clark County School Corporation

Building Name Thomas Jefferson Elementary School

Building Number 03

HAID F

HA Description Pipe Insulation

HA Type Thermal System Insulation (TSI)

HA Location Storage Rooms Near Crawlspace Tunnel Access

Quantity N/A LF

Comments This material was noted by the licensed inspector during the April 2015 6 month

inspection. A tear (less than 1 LF) in a four inch line was noted during the

inspection

with a small amount of debris (less than 1 LF) was noted below the damaged

pipe

insulation. The debris should be cleaned up and the pipe repaired as soon as

possible. Multiple open exposed spots on the line with damage.

Overall material is not in poor condition.

Asbestos Assumed

Friable Yes

Original Inspection 4/22/2015

Current Inspection 5/16/2019

Material Assessment

<u>Assessment Rating</u> 1 Damaged or significantly damaged thermal syste

Damage Assessment and Potential for Damage

Percent Damaged % Damanged - Localized

Physical ContactVibrationAirMediumLow/NoneLow/None

<u>Planned Response Action</u> Patch and Repair

Inspector

Sean Stults

State IN Accreditation Number 19A007184

LEA Name Greater Clark County School Corporation

Building Name Thomas Jefferson Elementary School

Building Number 03

HA ID 01

HA Description Pipe Insulation

HA Type Thermal System Insulation (TSI)

HA Location Boiler room

Quantity 10 LF

Comments This material was not in poor condition along east wall near east boiler by

tunnel entry.

Scheduled for abatement in 2012/2013 renovation.

Asbestos Known

Friable No

Original Inspection 6/1/1992

Current Inspection 4/27/2016

Material Assessment

Assessment Rating 5 ACBM with potential for damage

Damage Assessment and Potential for Damage

Percent Damaged % Good Condition

Physical Contact Vibration Air

Low/None Low/None Low/None

Planned Response Action O&M

Inspector

Benjamin S. Hood

State IN

LEA Name Greater Clark County School Corporation

Building Name Thomas Jefferson Elementary School

Building Number 03

HA ID 02

HA Description Pipe Insulation

HA Type Thermal System Insulation (TSI)

HA Location Tunnels

Quantity 230 LF

Comments Entrances to tunnels are restricted, as this material is in poor condition. There is

debris

all over the floor of the dirt crawl. No one should enter this area without proper

training

and protection. Clean up recommended. Scheduled for abatement in 2012/2013

renovation.

Asbestos Known

Friable Yes

Original Inspection 6/1/1992

Current Inspection 4/27/2016

Material Assessment

Assessment Rating 1 Damaged or significantly damaged thermal syste

Damage Assessment and Potential for Damage

<u>Percent Damaged</u> % Damanged - Localized

<u>Physical Contact</u> <u>Vibration</u> <u>Air</u>

High Low/None Low/None

Planned Response Action Patch and Repair

Inspector

Benjamin S. Hood

State IN Accreditation Number 19A001039

LEA Name Greater Clark County School Corporation

Building Name Thomas Jefferson Elementary School

Building Number 03

HA ID 03

HA Description Fittings

HA Type Thermal System Insulation (TSI)

HA Location Boiler room and tunnel

Quantity 48 Unit(s)

Comments Material in tunnel is in poor condition. Entry to tunnel is restricted. No one

should enter

without proper training and protection. Clean up recommended. Scheduled for

abatement in 2012/2013 renovation.

Asbestos Known

Friable Yes

Original Inspection 6/1/1992

Current Inspection 4/27/2016

Material Assessment

Assessment Rating 1 Damaged or significantly damaged thermal syste

Damage Assessment and Potential for Damage

Percent Damaged % Damanged - Localized

Physical ContactVibrationAirHighLow/NoneLow/None

Planned Response Action O&M

A1.

Benjamin S. Hood

State IN

Accreditation Number 19A001039

Inspector

LEA Name Greater Clark County School Corporation

Building Name Thomas Jefferson Elementary School

Building Number 03

HA ID 05-A

HA TypeVAT-underneath carpet
Miscellaneous Material

HA Location Throughout the building (classrooms, hallways & office)

Quantity Unquantified SF

Comments Floor Tile (installed in 1994)

Asbestos Known

Friable No

Original Inspection 6/1/1992

Current Inspection 4/27/2016

Material Assessment

Assessment Rating 5 ACBM with potential for damage

Damage Assessment and Potential for Damage

Percent Damaged % Good Condition

Physical ContactVibrationAirLow/NoneLow/NoneLow/None

Planned Response Action O&M

Inspector

Benjamin S. Hood

State IN

LEA Name Greater Clark County School Corporation

Building Name Thomas Jefferson Elementary School

Building Number 03

HA ID 05-B

HA Description 12" x 12" newer off-white floor tile

HA Type Miscellaneous Material

HA Location Throughout the building (first aid office, cafeteria, workroom, water fountain

SF

area, office

hallway, entrance, and art room)

Quantity Unquantified

Comments Minor chipping near water fountain. Overall, this material is not in poor

condition.

Asbestos Known

Friable No

Original Inspection 6/1/1992

Current Inspection 4/27/2016

Material Assessment

Assessment Rating 5 ACBM with potential for damage

Damage Assessment and Potential for Damage

Percent Damaged % Good Condition

Physical ContactVibrationAirLow/NoneLow/NoneLow/None

Planned Response Action O&M

Inspector

Benjamin S. Hood

State IN

LEA Name Greater Clark County School Corporation

Building Name Thomas Jefferson Elementary School

Building Number 03

HA ID 05-C

HA Description 12" x 12" original floor tileHA Type Miscellaneous Material

HA Location Throughout the building (gym and custodial closets).

Quantity Unquantified SF

Comments Minor chipping in closets. Overall, this material is not in poor condition.

Asbestos Known

Friable No

Original Inspection 6/1/1992

Current Inspection 4/27/2016

Material Assessment

Assessment Rating 5 ACBM with potential for damage

Damage Assessment and Potential for Damage

Percent Damaged % Good Condition

Physical ContactVibrationAirLow/NoneLow/NoneLow/None

Planned Response Action O&M

Benjamin S. Hood

State IN

Accreditation Number 19A001039

Inspector

LEA Name Greater Clark County School Corporation

Building Name Thomas Jefferson Elementary School

Building Number 03

HA ID 05-D

HA Description 12" x 12" original light blue floor tile

HA Type Miscellaneous Material

HA Location Throughout the building (gym)

Quantity Unquantified SF

Comments Where visible, this material is not in poor condition.

Asbestos Known

Friable No

Original Inspection 6/1/1992

Current Inspection 4/27/2016

Material Assessment

Assessment Rating 5 ACBM with potential for damage

Damage Assessment and Potential for Damage

Percent Damaged % Good Condition

Physical ContactVibrationAirLow/NoneLow/NoneLow/None

Planned Response Action O&M

Inspector

Benjamin S. Hood

State IN

LEA Name Greater Clark County School Corporation

Building Name Thomas Jefferson Elementary School

Building Number 03

HA ID 07

HA Description Mastic

HA Type Miscellaneous Material

HA Location Throughout the building

Quantity 33750 SF

Comments This material was not visible to inspect.

Asbestos Assumed

Friable No

Original Inspection 6/1/1992

Current Inspection 4/27/2016

Material Assessment

Assessment Rating 5 ACBM with potential for damage

Damage Assessment and Potential for Damage

Percent Damaged % Good Condition

Physical ContactVibrationAirLow/NoneLow/NoneLow/None

Planned Response Action O&M

Inspector

Benjamin S. Hood

State IN

LEA Name Greater Clark County School Corporation

Building Name Thomas Jefferson Elementary School

Building Number 03

HA ID 11

HA Description Fire door-Metal cladHA Type Miscellaneous Material

HA Location Boiler room (2) Gym Exterior Doors (4)

Quantity 6 Unit(s)

Comments The fire door shell is intact with no core material visible to inspect.

Asbestos Assumed

Friable No

Original Inspection 6/1/1992

Current Inspection 4/27/2016

Material Assessment

Assessment Rating 5 ACBM with potential for damage

Damage Assessment and Potential for Damage

Percent Damaged % Good Condition

Physical ContactVibrationAirLow/NoneLow/NoneLow/None

Planned Response Action O&M

Inspector

Benjamin S. Hood

State IN

LEA Name Greater Clark County School Corporation

Building Name Thomas Jefferson Elementary School

Building Number 03

HA ID 15

HA Description Boiler gaskets

HA Type Miscellaneous Material

HA Location Boiler room

Quantity 2 Unit(s)

Comments Boiler doors were closed. The visible edges of this material were not in poor

condition.

There is some fiberglass rope visible, but also some older looking gasket

material.

Asbestos Assumed

Friable No

Original Inspection 6/1/1992

Current Inspection 4/27/2016

Material Assessment

Assessment Rating 5 ACBM with potential for damage

Damage Assessment and Potential for Damage

Percent Damaged % Good Condition

Physical ContactVibrationAirLow/NoneLow/NoneLow/None

Planned Response Action O&M

Inspector

Benjamin S. Hood

State IN

Greater Clark County School Corporation

Building Name Thomas Jefferson Elementary School **Building Number** 03 **HAID** Α **HA Description** Cove Base **HA Type** Miscellaneous Material Throughout the building **HA Location** Quantity Approx. 3800 LF Comments Material is not in poor condition overall with minor signs of wear. Loose and missing in a few locations. (installed in 1994) **Asbestos** Assumed Friable No **Original Inspection** 5/31/1995 **Current Inspection** 4/27/2016 **Material Assessment Assessment Rating** 5 ACBM with potential for damage **Damage Assessment and Potential for Damage Good Condition Percent Damaged** % **Physical Contact** Vibration <u>Air</u> Low/None Low/None Low/None **Planned Response Action 0&M** Inspector

State IN

Benjamin S. Hood

Accreditation Number 19A001039

LEA Name

LEA Name Greater Clark County School Corporation

Building Name Thomas Jefferson Elementary School

Building Number 03

HA ID B

HA Description Cove base mastic

HA Type Miscellaneous Material

HA Location Throughout the building

Quantity Approx. 1200 SF

Comments Mastic was visible to inspect at corner near custodial closet in the cafateria

where cove

base was missing.

Asbestos Assumed

Friable No

Original Inspection 5/31/1995

Current Inspection 4/27/2016

Material Assessment

Assessment Rating 5 ACBM with potential for damage

Damage Assessment and Potential for Damage

Percent Damaged % Good Condition

Physical ContactVibrationAirLow/NoneLow/NoneLow/None

Planned Response Action O&M

Inspector

Benjamin S. Hood

State IN

LEA Name Greater Clark County School Corporation

Building Name Thomas Jefferson Elementary School

Building Number 03

HA ID C

HA Description AHU Cloth Expansion Joints

HA Type Miscellaneous Material

HA Location Stage ends

Quantity 2 Unit(s)

Comments These were noted during the June 2011 6 month surveillance and will remain in

the

management plan until properly sampled.

Asbestos Assumed

Friable No

Original Inspection 6/27/2011

Current Inspection 4/27/2016

Material Assessment

Assessment Rating 5 ACBM with potential for damage

Damage Assessment and Potential for Damage

Percent Damaged % Good Condition

 Physical Contact
 Vibration
 Air

 Low/None
 Low/None
 Low/None

Planned Response Action O&M

Inspector

Benjamin S. Hood

State IN

LEA Name Greater Clark County School Corporation

Building Name Thomas Jefferson Elementary School

Building Number 03

HA ID D

HA Description Fire Doors-Original to building (wooden)

HA Type Miscellaneous Material

HA Location Gym & throughout the building

Quantity Unquantified Unit(s)

Comments These were noted during the June 2011 6 month surveillance and will remain in

the

management plan until properly sampled.

Asbestos Assumed

Friable No

Original Inspection 6/27/2011

Current Inspection 4/27/2016

Material Assessment

<u>Assessment Rating</u> 5 ACBM with potential for damage

Damage Assessment and Potential for Damage

Percent Damaged % Good Condition

Physical ContactVibrationAirLow/NoneLow/NoneLow/None

Planned Response Action O&M

Inspector

Benjamin S. Hood

State IN

LEA Name Greater Clark County School Corporation

Building Name Thomas Jefferson Elementary School

Building Number 03

HA ID E

HA Description Gray Sink InsulationHA Type Miscellaneous Material

HA Location Classrooms, Art Room & Teachers Lounge

Quantity Unquantified LF

Comments This was noted during the June 2011 6 month surveillance and will remain in the

management plan until properly sampled.

Asbestos Assumed

Friable No

Original Inspection 6/27/2011

Current Inspection 4/27/2016

Material Assessment

Assessment Rating 5 ACBM with potential for damage

Damage Assessment and Potential for Damage

Percent Damaged % Good Condition

Physical ContactVibrationAirLow/NoneLow/NoneLow/None

Planned Response Action O&M

Inspector

Benjamin S. Hood

State IN

Greater Clark County School Corporation LEA Name Building Name Thomas Jefferson Elementary School **Building Number** 03 HA ID **HA Description Pipe Insulation HA Type** Thermal System Insulation (TSI) Storage Rooms Near Crawlspace Tunnel Access **HA Location** Quantity N/A LF Comments This material was noted by the licensed inspector during the April 2015 6 month inspection. A tear (less than 1 LF) in a four inch line was noted during the inspection with a small amount of debris (less than 1 LF) was noted below the damaged insulation. The debris should be cleaned up and the pipe repaired as soon as possible. Multiple open exposed spots on the line with damage. Overall material is not in poor condition. Asbestos Assumed Friable Yes Original Inspection 4/22/2015 **Current Inspection** 4/27/2016 **Material Assessment** 1 Damaged or significantly damaged thermal syste **Assessment Rating Damage Assessment and Potential for Damage Percent Damaged** % Damanged - Localized **Physical Contact** Vibration Air Low/None Medium Low/None **Planned Response Action** Patch and Repair

Inspector

Benjamin S. Hood

State IN

THIRD YEAR REINSPECTION REPORT

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

01

Type of Material

Thermal Material

Quantity of Material

10 LF

Material Location

Boiler room

Material Description

Pipe insulation

Comments

This material was not in poor condition along east wall near east boiler by tunnel entry. Scheduled for abatement in 2012/2013 renovation.

Does Material Contain Asbestos?

Yes

Is it Friable?

No

Original Inspection Date

6/1/1992

Current Reinspection Date

4/24/2013

Current Assessment Rating

NR

Not Rated

Cause of Damage

No Damage Yes

Low

Potential for Damage

Removed

Accessible

No

Planned Response Action

Remove

Inspector

Jeffrey P. Rechtin

State

Indiana

Accreditation Number

19A003594

THIRD YEAR REINSPECTION REPORT

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

02

Type of Material

Thermal Material

Quantity of Material

230 LF

Material Location

Tunnels

Material Description

Pipe insulation

Comments

Entrances to tunnels are restricted, as this material is in poor condition. There is debris all over the floor of the dirt crawl. No one should enter this area without proper training and protection. Clean up recommended. Scheduled for abatement in 2012/2013 renovation.

Does Material Contain Asbestos?

Yes

Is it Friable?

Yes

Original Inspection Date

6/1/1992

Current Reinspection Date

4/24/2013

Current Assessment Rating

1B

Damaged TSI

Cause of Damage

Physical Damage

Accessible

Yes

Potential for Damage

Low

Removed

No

Planned Response Action

Remove

Inspector

Jeffrey P. Rechtin

State

Indiana

Accreditation Number

19A003594

THIRD YEAR REINSPECTION REPORT

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

03

Type of Material

Thermal Material

Quantity of Material

48 Each

Material Location

Boiler room and tunnel

Material Description

Fittings

Comments

Material in tunnel is in poor condition. Entry to tunnel is restricted. No one should enter without proper training and protection. Clean up recommended. Scheduled for abatement in 2012/2013 renovation.

Does Material Contain Asbestos?

Yes

Is it Friable?

Yes

Original Inspection Date

6/1/1992

Current Reinspection Date

4/24/2013

Current Assessment Rating

1B

Damaged TSI

Cause of Damage

Physical Damage

Accessible

Yes

Potential for Damage

Low

Removed

No

Planned Response Action

Remove

Inspector

Jeffrey P. Rechtin

State

Indiana

Accreditation Number

19A003594

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

05-A

Type of Material

Miscellaneous Material

Quantity of Material

Unquantified SF

Material Location

Throughout the building (classrooms, hallways & office)

Material Description

VAT-underneath carpet

Comments

Floor Tile (installed in 1994)

Does Material Contain Asbestos?

Yes

Is it Friable?

No

Original Inspection Date

6/1/1992

Current Reinspection Date

4/24/2013

Current Assessment Rating

NR

Not Rated

Cause of Damage

No Damage

Accessible

No

Potential for Damage

Low

Removed

No

Planned Response Action

O & M

Inspector

Jeffrey P. Rechtin

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

05-B

Type of Material

Miscellaneous Material

Quantity of Material

Unquantified SF

Material Location

Throughout the building (first aid office, cafeteria, workroom, water fountain area, office hallway, entrance, and art room)

Material Description

12" x 12" newer off-white floor tile

Comments

Where visible, this material is not in poor condition.

Does Material Contain Asbestos?

Yes

Is it Friable?

No

Original Inspection Date

6/1/1992

Current Reinspection Date

4/24/2013

Current Assessment Rating

NR

Not Rated

Cause of Damage

Accessible

Yes

Potential for Damage

Low

Removed

No

Planned Response Action

O&M

Inspector

Jeffrey P. Rechtin

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

05-C

Type of Material

Miscellaneous Material

Quantity of Material

Unquantified SF

Material Location

Throughout the building (gym and custodial closets).

Material Description

12" x 12" original floor tile

Comments

Where visible, this material is not in poor condition.

Does Material Contain Asbestos?

Yes

is it Friable?

No

Original Inspection Date

6/1/1992

Current Reinspection Date

4/24/2013

Current Assessment Rating

NR

Not Rated

Cause of Damage

Accessible

Yes

Potential for Damage

Low

Removed

No

Planned Response Action

0 & M

Inspector

Jeffrey P. Rechtin

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

05-D

Type of Material

Miscellaneous Material

Quantity of Material

Unquantified SF

Material Location

Throughout the building (gym)

Material Description

12" x 12" original light blue floor tile

Comments

Where visible, this material is not in poor condition.

Does Material Contain Asbestos?

Yes

Is it Friable?

Νo

Original Inspection Date

6/1/1992

Current Reinspection Date

4/24/2013

Current Assessment Rating

NR

Not Rated

Cause of Damage

Accessible

Yes

Potential for Damage

Low

Removed

No

Planned Response Action

O & M

Inspector

Jeffrey P. Rechtin

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

07

Type of Material

Miscellaneous Material

Quantity of Material

33,750 SF

Material Location

Throughout the building

Material Description

Mastic

Comments

This material was not visible to inspect.

Does Material Contain Asbestos?

Assumed

Is it Friable?

No

Original Inspection Date

6/1/1992

Current Reinspection Date

4/24/2013

Current Assessment Rating

NR

Not Rated

Cause of Damage

No Damage

Accessible

No

Potential for Damage

Low

Removed

No

Planned Response Action

O & M

Inspector

Jeffrey P. Rechtin

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

11

Type of Material

Miscellaneous Material

Quantity of Material

6 Each

Material Location

Boiler room (2) Gym Exterior Doors (4)

Material Description

Fire door-Metal clad

Comments

The fire door shell is intact with no core material visible to inspect.

Does Material Contain Asbestos?

Assumed

Is it Friable?

No

Original Inspection Date

6/1/1992

Current Reinspection Date

4/24/2013

No Damage

Current Assessment Rating

NR

Not Rated

Cause of Damage

Yes

Accessible

103

Potential for Damage

Low

Removed

No

Planned Response Action

O&M

Inspector

Jeffrey P. Rechtin

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

15

Type of Material

Miscellaneous Material

Quantity of Material

2 Each

Material Location

Boiler room

Material Description

Boiler gaskets

Comments

Boiler doors were closed. The visible edges of this material were not in poor condition. There is some fiberglass rope visible, but also some older looking gasket material.

Does Material Contain Asbestos?

Assumed

Is it Friable?

No

Original Inspection Date

6/1/1992

Current Reinspection Date

4/24/2013

Current Assessment Rating

NR

Not Rated

Cause of Damage

No Damage

Accessible

Yes

Potential for Damage

Low

Removed

No

Planned Response Action

O & M

Inspector

Jeffrey P. Rechtin

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

Α

Type of Material

Miscellaneous Material

Quantity of Material

Approx. 3,800 LF

Material Location

Throughout the building

Material Description

Cove base

Comments

Material is not in poor condition overall with minor signs of wear. Loose and missing in a few locations. (installed in 1994)

Does Material Contain Asbestos?

Assumed

Is it Friable?

No

Original Inspection Date

5/31/1995

Current Reinspection Date

4/24/2013

Current Assessment Rating

NR

Not Rated

Cause of Damage

No Damage

Accessible

Yes

Potential for Damage

Low

Removed

No

Planned Response Action

O & M

inspector

Jeffrey P. Rechtin

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

В

Type of Material

Miscellaneous Material

Quantity of Material

Approx. 1,200 SF

Material Location

Throughout the building

Material Description

Cove base mastic

Comments

Mastic was visible to inspect at corner near custodial closet in the cafateria where cove base was missing.

Does Material Contain Asbestos?

Assumed

Is it Friable?

No

Original Inspection Date

5/31/1995

Current Reinspection Date

4/24/2013

Current Assessment Rating

NR

Not Rated

Cause of Damage

No Damage

Accessible

No

Potential for Damage

Low

Removed

No

Planned Response Action

O & M

Inspector

Jeffrey P. Rechtin

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

C

Type of Material

Miscellaneous Material

Quantity of Material

2 Each

Material Location

Stage Ends

Material Description

AHU Cloth Expansion Joints

Comments

These were noted during the June 2011 6 month surveillance and will remain in the management plan until properly sampled.

Does Material Contain Asbestos?

Assumed

Is it Friable?

Nο

Original Inspection Date

6/27/2011

Current Reinspection Date

4/24/2013

No Damage

Current Assessment Rating

NA

Not Applicable

Cause of Damage

Yes

Potential for Damage

Low

Removed

Accessible

No

Planned Response Action

O & M

Inspector

Jeffrey P. Rechtin

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

D

Type of Material

Miscellaneous Material

Quantity of Material

Unquantified Each

Material Location

Gym & throughout the building

Material Description

Fire Doors-Original to building (wooden)

Comments

These were noted during the June 2011 6 month surveillance and will remain in the management plan until properly sampled.

Does Material Contain Asbestos?

Assumed

is it Friable?

No

Original Inspection Date

6/27/2011

Current Reinspection Date

4/24/2013

Current Assessment Rating

NA

Not Applicable

Cause of Damage

No Damage

Accessible

Yes

Potential for Damage

Low

Removed

No

Planned Response Action

O & M

Inspector

Jeffrey P. Rechtin

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

F

Type of Material

Miscellaneous Material

Quantity of Material

Unquantified LF

Material Location

Classrooms, Art Room & Teachers Lounge

Material Description

Gray Sink Insulation

Comments

This was noted during the June 2011 6 month surveillance and will remain in the management plan until properly sampled.

Does Material Contain Asbestos?

Assumed

Is it Friable?

No

Original Inspection Date

6/27/2011

Current Reinspection Date

4/24/2013

Current Assessment Rating

NA

Not Applicable

Cause of Damage

No Damage

Accessible

Yes

Potential for Damage

Low

Removed

No

Planned Response Action

O & M

Inspector

Jeffrey P. Rechtin

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

01

Type of Material

Thermal Material

Quantity of Material

10 LF

Material Location

Boiler room

Material Description

Pipe insulation

Comments

This material was not in poor condition along east wall near east boiler by tunnel entry.

Does Material Contain Asbestos?

Yes

Is it Friable?

No

Original Inspection Date

6/1/1992

Current Reinspection Date

6/30/2010

Current Assessment Rating

NR

Not Required

Cause of Damage

No Damage

Accessible

Yes

Potential for Damage

Low

Removed

No

Planned Response Action

O & M

Inspector

Sandra Shadle

State

ΙN

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

02

Type of Material

Thermal Material

Quantity of Material

230 LF

Material Location

Tunnels

Material Description

Pipe insulation

Comments

Entrances to tunnels are restricted, as this material is in poor condition. There is debris all over the floor of the dirt crawl. No one should enter this area without proper training and protection. Clean up recommended.

Does Material Contain Asbestos?

Yes

Is it Friable?

Yes

Original Inspection Date

6/1/1992

Current Reinspection Date

6/30/2010

Current Assessment Rating

1B

Damaged TSI

Cause of Damage

Physical Damage

Potential for Damage

Yes Low

Removed

Accessible

No

Planned Response Action

0 & M

Inspector

Sandra Shadley

State

IN

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

03

Type of Material

Thermal Material

Quantity of Material

48 Each

Material Location

Boiler room and tunnel

Material Description

Fittings

Comments

Material in tunnel is in poor condition. Entry to tunnel is restricted. No one should enter without proper training and protection. Clean up recommended.

Does Material Contain Asbestos?

Yes

Is it Friable?

Yes

Original Inspection Date

6/1/1992

Current Reinspection Date

6/30/2010

Current Assessment Rating

1B

Damaged TSI

Cause of Damage

Physical Damage

Accessible

Yes

Potential for Damage

Low

Removed

No

Planned Response Action

O & M

Inspector

Sandra Shadley

State

IN

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

05

Type of Material

Miscellaneous Material

Quantity of Material

33,750 SF

Material Location

Throughout the building (classrooms, hallways & office)

Material Description

VAT

Comments

Tile is underneath carpet (installed in 1994) in most areas. Where visible it is not in poor condition.

Does Material Contain Asbestos?

Yes

Is it Friable?

No

Original Inspection Date

6/1/1992

Current Reinspection Date

6/30/2010

Current Assessment Rating

NR

Not Required

Cause of Damage

No Damage

Accessible

No

Potential for Damage

Low

Removed

No

Planned Response Action

O & M

Inspector

Sandra Sh

State

IN

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

07

Type of Material

Miscellaneous Material

Quantity of Material

33,750 SF

Material Location

Throughout the building

Material Description

Mastic

Comments

This material was not visible to inspect.

Does Material Contain Asbestos?

Assumed

Is it Friable?

No

Original Inspection Date

6/1/1992

Current Reinspection Date

6/30/2010

Current Assessment Rating

NR

Not Required

Cause of Damage

No Damage

Accessible

No

Potential for Damage

Low

Removed

No

Planned Response Action

M & O

Inspector

Sanura Snauley

State

IN

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

11

Type of Material

Miscellaneous Material

Quantity of Material

30 SF

Material Location

Boiler room

Material Description

Fire door

Comments

The fire door shell is intact with no core material visible to inspect.

Does Material Contain Asbestos?

Assumed

Is it Friable?

No

Original Inspection Date

6/1/1992

Current Reinspection Date

6/30/2010

Current Assessment Rating

NR

Not Required

Cause of Damage

No Damage

Accessible

Yes

Potential for Damage

Low

Removed

No

Planned Response Action

O & M

Inspector

Sandra Shadley

State

IN

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

15

Type of Material

Miscellaneous Material

Quantity of Material

2 Each

Material Location

Boiler room

Material Description

Boiler gaskets

Comments

Boiler doors were closed. The visible edges of this material were not in poor condition. There is some fiberglass rope visible, but also some older looking gasket material.

Does Material Contain Asbestos?

Assumed

is it Friable?

No

Original Inspection Date

6/1/1992

Current Reinspection Date

6/30/2010

Current Assessment Rating

NR

Not Required

Cause of Damage

No Damage

Accessible

Yes

Potential for Damage

Low

Removed

No

Planned Response Action

O & M

Inspector

Sandra Shadley

State

IN

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

Α

Type of Material

Miscellaneous Material

Quantity of Material

Approx. 3,800 LF

Material Location

Throughout the building

Material Description

Cove base

Comments

Material is not in poor condition overall with minor signs of wear. Loose and missing in a few locations. (installed in 1994)

Does Material Contain Asbestos?

Assumed

Is it Friable?

No

Original Inspection Date

5/31/1995

Current Reinspection Date

6/30/2010

Current Assessment Rating

NR

Not Required

Cause of Damage

No Damage

Accessible

Yes

Potential for Damage

Low

Removed

No

Planned Response Action

O & M

Inspector

Sandra Shadley

State

IN

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

В

Type of Material

Miscellaneous Material

Quantity of Material

Approx. 1,200 SF

Material Location

Throughout the building

Material Description

Cove base mastic

Comments

Mastic was visible to inspect at corner near custodial closet in the cafateria where cove base was missing.

Does Material Contain Asbestos?

Assumed

ls it Friable?

No

Original Inspection Date

5/31/1995

Current Reinspection Date

6/30/2010

Current Assessment Rating

NR

Not Required

Cause of Damage

No Damage

Accessible

No

Potential for Damage

Low

Removed

No

Planned Response Action

O & M

Inspector

Sandra Shadley

State

IN

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

01

Type of Material

Thermal Material

Quantity of Material

10 LF

Material Location

Boiler room

Material Description

Pipe insulation

Comments

This material was not in poor condition.

Does Material Contain Asbestos?

Yes

Is it Friable?

No

Original Inspection Date

6/1/1992

Current Reinspection Date

7/9/2007

Current Assessment Rating

NR

Not Required

Cause of Damage

No Damage

Accessible

Yes

Potential for Damage

Low

Removed

Nο

Planned Response Action

O & M

Inspector

eorge/William Og

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

02

Type of Material

Thermal Material

Quantity of Material

230 LF

Material Location

Tunnels

Material Description

Pipe insulation

Comments

Entrances to tunnels are restricted, as this material is in poor condition. There is debris all over the floor of the dirt crawl. No one should enter this area without proper training and protection. Clean up recommended.

Does Material Contain Asbestos?

Yes

Is it Friable?

Yes

Original Inspection Date

6/1/1992

Current Reinspection Date

7/9/2007

Current Assessment Rating

1B

Damaged TSI

Cause of Damage

Physical Damage

Accessible

Yes

Potential for Damage

Low

Removed

No

Planned Response Action

O & M

Inspector

George William Og

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

03

Type of Material

Thermal Material

Quantity of Material

48 Each

Material Location

Boiler room and tunnel

Material Description

Fittings

Comments

Material in tunnel is in poor condition. Entry to tunnel is restricted. No one should enter without proper training and protection. Clean up recommended.

Does Material Contain Asbestos?

Yes

Is it Friable?

Yes

Original Inspection Date

6/1/1992

Current Reinspection Date

7/9/2007

Current Assessment Rating

1B

Damaged TSI

Cause of Damage

Physical Damage

_

Yes

Potential for Damage

Low

Removed

Accessible

No

Planned Response Action

O & M

Inspector

George William Og

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

05

Type of Material

Miscellaneous Material

Quantity of Material

33,750 SF

Material Location

Throughout the building (classrooms, hallways & office)

Material Description

VAT

Comments

Tile is underneath carpet in most areas. Where visible it is not in poor condition.

Does Material Contain Asbestos?

Yes

Is it Friable?

No

Original Inspection Date

6/1/1992

Current Reinspection Date

7/9/2007

Current Assessment Rating

NR

Not Required

Cause of Damage

No Damage

Accessible

No

Potential for Damage

Low

Removed

No

Planned Response Action

O & M

Inspector

George William Ogle

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

07

Type of Material

Miscellaneous Material

Quantity of Material

33,750 SF

Material Location

Throughout the building

Material Description

Mastic

Comments

This material was not visible to inspect.

Does Material Contain Asbestos?

Assumed

Is it Friable?

No

Original Inspection Date

6/1/1992

Current Reinspection Date

7/9/2007

Current Assessment Rating

NR

Not Required

Cause of Damage

No Damage

Accessible

No

Potential for Damage

Low

Removed

No

Planned Response Action

O & M

Inspector

George William Ogle

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

11

Type of Material

Miscellaneous Material

Quantity of Material

30 SF

Material Location

Boiler room

Material Description

Fire door

Comments

The fire door shell is intact with no core material visible to inspect.

Does Material Contain Asbestos?

Assumed

Is it Friable?

No

Original Inspection Date

6/1/1992

Current Reinspection Date

7/9/2007

Current Assessment Rating

NR

Not Required

Cause of Damage

No Damage

Accessible

Yes

Potential for Damage

Low

Removed

No

Planned Response Action

O & M

Inspector

George William Ogle

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

15

Type of Material

Miscellaneous Material

Quantity of Material

2 Each

Material Location

Boiler room

Material Description

Boiler gaskets

Comments

Boiler doors were closed. The visible edges of this material were not in poor condition. There is some fiberglass rope visible, but also some older looking gasket material.

Does Material Contain Asbestos?

Assumed

Is it Friable?

No

Original Inspection Date

6/1/1992

Current Reinspection Date

7/9/2007

Current Assessment Rating

NR

Not Required

Cause of Damage

No Damage

Accessible

Yes

Potential for Damage

Low

Removed

No

Planned Response Action

O & M

Inspector

Seorge William Øgle

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

Α

Type of Material

Miscellaneous Material

Quantity of Material

Approx. 3,800 LF

Material Location

Throughout the building

Material Description

Cove base

Comments

Material is not in poor condition overall with minor signs of wear.

Does Material Contain Asbestos?

Assumed

Is it Friable?

No

Original Inspection Date

5/31/1995

Current Reinspection Date

7/9/2007

Current Assessment Rating

NR

Not Required

Cause of Damage

No Damage

Accessible

Yes

Potential for Damage

Low

Removed

Nο

Planned Response Action

O & M

Inspector

George William

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

В

Type of Material

Miscellaneous Material

Quantity of Material

Approx. 1,200 SF

Material Location

Throughout the building

Material Description

Cove base mastic

Comments

No mastic was visible to inspect.

Does Material Contain Asbestos?

Assumed

Is it Friable?

Nο

Original Inspection Date

5/31/1995

Current Reinspection Date

7/9/2007

Current Assessment Rating

NR

Not Required

Cause of Damage

No Damage

Accessible

No

Potential for Damage

Low

Removed

No

Planned Response Action


0 & M

Inspector

State

Indiana

Accreditation Number



LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

01

Type of Material

Thermal Material

Quantity of Material

10 LF

Material Location

Boiler room

Material Description

Pipe insulation

Comments

There is a 10 ' run of mag left in the boiler room. It is not in poor condition.

Does Material Contain Asbestos?

Yes

Is it Friable?

Yes

Original Inspection Date

6/1/1992

Current Reinspection Date

7/2/2004

Current Assessment Rating

5

Cause of Damage

No Damage

Accessible

Yes

Potential for Damage

Low

Removed

No

Planned Response Action

0 & M

Inspector

Christiaan Sparks

ACBM with Potential for Damage

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

02

Type of Material

Thermal Material

Quantity of Material

230 LF

Material Location

Tunnels

Material Description

Pipe insulation

Comments

Entrances to tunnels are restricted, as this material is in poor condition. There is debris all over the floor of the dirt crawl. No one should enter this area without proper training and protection. Clean up recommended.

Does Material Contain Asbestos?

Yes

Is it Friable?

Yes

Original Inspection Date

6/1/1992

Current Reinspection Date

7/2/2004

Current Assessment Rating

1B

Damaged TSI

Cause of Damage

Physical Damage

Accessible

Yes

Potential for Damage

Low

Removed

No

Planned Response Action

0 & M

Inspector

Christiaan Sparks

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

03

Type of Material

Thermal Material

Quantity of Material

48 Each

Material Location

Boiler room and tunnel

Material Description

Fittings

Comments

The minor damage in the boiler room has been repaired. Material in tunnel is in poor condition. Entry to tunnel is restricted. No one should enter without proper training and protection. Clean up recommended.

Does Material Contain Asbestos?

Yes

Is it Friable?

Yes

Original Inspection Date

6/1/1992

Current Reinspection Date

7/2/2004

Current Assessment Rating

1B

Damaged TSI

Cause of Damage

Physical Damage

Accessible

Yes

Potential for Damage

Low

Removed

No

Planned Response Action

0 & M

Inspector

Christiaan Sparks

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

05

Type of Material

Miscellaneous Material

Quantity of Material

33,750 SF

Material Location

Throughout the building (classrooms, hallways & office)

Material Description

VAT

Comments

All areas seen during this surveillance were found to either be carpeted or have a newer 12" X 12" white and gray streaked floor tile. No suspect material was visible to inspect.

Does Material Contain Asbestos?

Yes

Is it Friable?

No

Original Inspection Date

6/1/1992

Current Reinspection Date

7/2/2004

Current Assessment Rating

NR

Not Required

Cause of Damage

No Damage

Accessible

No

Potential for Damage

Low

Removed

No

Planned Response Action

0 & M

Inspector

Christiaan Sparks

State

Indiana

Accreditation Number

LEA Name Greater

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

07

Type of Material

Miscellaneous Material

Quantity of Material

33,750 SF

Material Location

Throughout the building

Material Description

Mastic

Comments

This material was not visible to inspect.

Does Material Contain Asbestos?

Assumed

Is it Friable?

No

Original Inspection Date

6/1/1992

Current Reinspection Date

7/2/2004

Current Assessment Rating

NR

Not Required

Cause of Damage

No Damage

Accessible

No

Potential for Damage

Low

Removed

No

Planned Response Action

0 & M

Inspector

Christiaan Sparks

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

11

Type of Material

Miscellaneous Material

Quantity of Material

30 SF

Material Location

Boiler room

Material Description

Fire door

Comments

The fire door is not in poor condition with no core material visible to inspect.

Does Material Contain Asbestos?

Assumed

Is it Friable?

No

Original Inspection Date

6/1/1992

Current Reinspection Date

7/2/2004

Current Assessment Rating

NR

Not Required

Cause of Damage

No Damage

Accessible

Yes

Potential for Damage

Low

Removed

No

Planned Response Action

0 & M

Inspector

Christiaan Sparks

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

15

Type of Material

Miscellaneous Material

Quantity of Material

2 Each

Material Location

Boiler room

Material Description

Boiler gaskets

Comments

Boiler doors were closed. The visible edges of this material were not in poor condition.

Does Material Contain Asbestos?

Assumed

Is it Friable?

No

Original Inspection Date

6/1/1992

Current Reinspection Date

7/2/2004

Current Assessment Rating

NR

Not Required

Cause of Damage

No Damage

Accessible

Yes

Potential for Damage

Low

Removed

No

Planned Response Action

0 & M

Inspector

Christiaan Sparks

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

Α

Type of Material

Miscellaneous Material

Quantity of Material

Approx. 3,800 LF

Material Location

Throughout the building

Material Description

Cove base

Comments

Material is not in poor condition overall with minor signs of wear. Pieces are coming off the wall by the boys' restroom near the main entrance and in the cafeteria.

Does Material Contain Asbestos?

Assumed

Is it Friable?

No

Original Inspection Date

5/31/1995

Current Reinspection Date

7/2/2004

Current Assessment Rating

NR

Not Required

Cause of Damage

No Damage

Accessible

Yes

Potential for Damage

Low

Removed

No

Planned Response Action

0 & M

Inspector

Christiaan Sparks

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

R

Type of Material

Miscellaneous Material

Quantity of Material

Approx. 1,200 SF

Material Location

Throughout the building

Material Description

Cove base mastic

Comments

Where visible, this material was not in poor condition.

Does Material Contain Asbestos?

Assumed

Is it Friable?

No

Original Inspection Date

5/31/1995

Current Reinspection Date

7/2/2004

Current Assessment Rating

NR

Not Required

Cause of Damage

No Damage

Accessible

No

Potential for Damage

Low

Removed

No

Planned Response Action

0 & M


Inspector

Christiaan Sparks

State

Indiana

Accreditation Number



LEA Name Greater Clark County Schools

Building Name Thomas Jefferson Elementary

HA# 01

Type of Material Thermal Material

Quantity of Material 90 LF

Material Location

Tunnels

Material Description

Pipe insulation - mag

Comments

There is a 10 ' run of mag left in the boiler room. It is in good condition. Ceiling in tunnel is woven mag and it is delaminating. All other material has been removed and replaced with fiberglass. Entrances to tunnels have limited access. There is also some debris on the floor at the entrance to the tunnel.

Does Material Contain Asbestos? Yes Is it Friable? Yes

Original Inspection Date 06/01/1992
Current Reinspection Date 07/11/2001

Current Assessment Rating 1B Damaged TSI

Cause of Damage Delamination

Accessible Yes
Potential for Damage Low
Removed No

Planned Response Action O & M

Inspector Patrick E. Wilson

Father E. Wilson

State Indiana

LEA Name Greater Clark County Schools

Building Name Thomas Jefferson Elementary

HA# 02

Type of Material Thermal Material

Quantity of Material 150 LF

Material Location

Tunnels and boiler room

Material Description

Pipe insulation - air cell

Comments

Entrances to tunnels are restricted, as this material is in bad condition. No air cell found in boiler room. Dirt crawl area is only place it was found. There is debris all over the floor of the dirt crawl. No one should enter this area without proper training and protection.

Does Material Contain Asbestos? Yes

Is it Friable? Yes

Original Inspection Date 06/01/1992
Current Reinspection Date 07/11/2001

Current Assessment Rating 1B Damaged TSI

Cause of Damage Physical Damage

Accessible Yes
Potential for Damage Low

Removed No

Planned Response Action O & M

Inspector Patrick Wilson KW

Patrick E. Wilson

State Indiana

LEA Name Greater Clark County Schools

Building Name Thomas Jefferson Elementary

HA# 03

Type of Material Thermal Material

Quantity of Material 48 Each

Material Location

Boiler room and tunnel

Material Description

Fittings

Comments

The minor damage in the boiler room has been repaired. Material in tunnel is in bad condition. Entry to tunnel is restricted. No one should enter without proper training and protection.

Does Material Contain Asbestos? Yes Is it Friable? Yes

Original Inspection Date 06/01/1992

Current Reinspection Date 07/11/2001

Current Assessment Rating 1B Damaged TSI

Cause of Damage Physical Damage

Accessible Yes
Potential for Damage Low
Removed No

Planned Response Action O & M

Inspector Palkick Wilson Patrick E. Wilson

State Indiana

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

04

Type of Material

Thermal Material

Quantity of Material

40 SF

Material Location

Tunnel

Material Description

Debris

Comments

It seems that a much larger area than 40 square feet is littered with air cell and mag insulation in all dirt crawl areas. Access to tunnel is restricted. O & M cleanup is needed. No one should enter without proper training and protection.

Does Material Contain Asbestos?

Yes

Is it Friable?

Yes

Original Inspection Date

06/01/1992

Current Reinspection Date

07/11/2001

Current Assessment Rating

1B

Damaged TSI

Cause of Damage

Physical Damage

Accessible

Yes

Potential for Damage

High

Removed

No

Planned Response Action

0 & M

Inspector

Patrick Wilson w

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

05

Type of Material

Miscellaneous Material

Quantity of Material

33,750 SF

Material Location

Throughout the building (classrooms, hallways & office)

Material Description

VAT

Comments

Most areas are now covered with carpet which is glued down. Cannot verify presence of tile beneath without risk of damaging carpet. Where visible in rooms 14, 17 and 19 the floor tile is in good condition. Basement areas and landing on stairs to basement has newer 12" X 12" white with gray streaks floor tile.

Does Material Contain Asbestos?

Yes

Is it Friable?

No

Original Inspection Date

06/01/1992

Current Reinspection Date

07/11/2001

Current Assessment Rating

NR

Not Required

Cause of Damage

No Damage

Accessible

Yes

Potential for Damage

Low

Removed

Nο

Planned Response Action

O & M

Inspector

Patrick E Wilson

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

07

Type of Material

Miscellaneous Material

Quantity of Material

33,750 SF

Material Location

Throughout the building

Material Description

Mastic

Comments

Material was not visible to inspect.

Does Material Contain Asbestos?

Assumed

Is it Friable?

No

Original Inspection Date

06/01/1992

Current Reinspection Date

07/11/2001

Current Assessment Rating

NR

Not Required

Cause of Damage

No Damage

Accessible

No

Potential for Damage

Low

Removed

No

Planned Response Action

0 & M

Inspector

Patrick F Wilson

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

11

Type of Material

Miscellaneous Material

Quantity of Material

30 SF

Material Location

Boiler room

Material Description

Fire door

Comments

The fire door is in good condition and no core material was visible to inspect.

Does Material Contain Asbestos?

Assumed

Is it Friable?

No

Original Inspection Date

06/01/1992

Current Reinspection Date

07/11/2001

Current Assessment Rating

NR

Not Required

Cause of Damage

No Damage

Accessible

Yes

Potential for Damage

Low

Removed

No

Planned Response Action

0 & M

Inspector

Patrick Wilson Kw Patrick E. Wilson

State

Indiana

Accreditation Number

LEA Name Greate

Greater Clark County Schools

Building Name Thomas Jefferson Elementary

HA# 15

Type of Material Miscellaneous Material

Quantity of Material 2 Each

Material Location

Boiler room

Material Description

Boiler gaskets

Comments

The boilers were off and open in order to have a good visual look at this material. It is mostly fiberglass except fot the small sections between the door halves. I am unable to sample the material without causing damage. All material appears to be in good condition.

Does Material Contain Asbestos? Assumed

Is it Friable?

Original Inspection Date 06/01/1992

Current Reinspection Date 07/11/2001

Current Assessment Rating NR Not Required

Cause of Damage No Damage

Accessible Yes
Potential for Damage Low
Removed No

Planned Response Action 0 & M

Inspector Patrick Wilson Kw

Patrick E. Wilson

State Indiana

LEA Name Greater Clark County Schools

Building Name Thomas Jefferson Elementary

HA#

Type of Material Miscellaneous Material

Quantity of Material Approx. 3,800 LF

Material Location

Throughout the building

Material Description

Cove base

Comments

Material is in good condition overall with minor signs of wear.

Does Material Contain Asbestos? Assumed

Is it Friable? No

Original Inspection Date 05/31/1995 **Current Reinspection Date** 07/11/2001

Current Assessment Rating NR Not Required

Cause of Damage No Damage

Accessible Yes Potential for Damage Low Removed No

Planned Response Action 0 & M

Patrick Wilson KW Inspector

Indiana State

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

В

Type of Material

Miscellaneous Material

Quantity of Material

Approx. 1,200 SF

Material Location

Throughout the building

Material Description

Cove base mastic

Comments

Material is not exposed to inspect.

Does Material Contain Asbestos?

Assumed

Is it Friable?

No

Original Inspection Date

05/31/1995

Current Reinspection Date

07/11/2001

Current Assessment Rating

NR

Not Required

Cause of Damage

No Damage

Accessible

No

Potential for Damage

Low

Removed

No

Planned Response Action

0 & M


Inspector

Patrick Wilson NW

State

Indiana

Accreditation Number



LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

01

90

Type of Material

Thermal Material

Quantity of Material

LF

Material Location

Tunnels

Material Description

Pipe Insulation - Mag

Comments

There is a 10 ' run of damaged mag left in the boiler room. Material is in poor condition. Ceiling in tunnel is woven mag. All other material has been removed and replaced with fiberglass. Entrances to tunnels need to be restricted. Material damage brought to Mr. Meredith's attention on this date.

Does Material Contain Asbestos?

Yes

Is it Friable?

Yes

Original Inspection Date

6/ 1/92

Current Reinspection Date

6/ 1/98

Current Assessment Rating

1B Damaged TSI

Cause of Damage

Physical Damage

Accessible

Yes

Potential for Damage

Low

Removed

No

Planned Response Action

O & M

Inspector

Clint Yates

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

02

Type of Material

Thermal Material

LF

Quantity of Material

150

Material Location

Tunnels and Boiler Room

Material Description

Pipe Insulation - Air Cell

Comments

Entrances to tunnels need to be restricted. There is damage to the pipe near boiler

#1. O & M is needed.

Does Material Contain Asbestos?

Yes

Is it Friable?

Yes

Original Inspection Date

6/ 1/92

Current Reinspection Date

6/ 1/98

Current Assessment Rating

1B Damaged TSI

Cause of Damage

Physical Damage

Accessible

Yes

Potential for Damage

Low

Removed

No

Planned Response Action

O & M

Inspector

Clint Yates

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

03

Type of Material

Thermal Material

Quantity of Material

48

Each

Material Location

Boiler Room and Tunnel

Material Description

Fittings

Comments

There is some minor damage in the boiler room. Entry to tunnel is restricted.

Does Material Contain Asbestos?

Yes

Is it Friable?

Yes

Original Inspection Date

6/ 1/92

Current Reinspection Date

6/ 1/98

Current Assessment Rating

1B Damaged TSI

Cause of Damage

Physical Damage

Accessible

Yes

Potential for Damage

Low

Removed

No

Planned Response Action

O & M

Inspector

Clint Yates

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

04

Type of Material

Thermal Material

Quantity of Material

40 SF

Material Location

Tunnel

Material Description

Debris

Comments

Access to tunnel restricted. Do not know if there. Could not access tunnel.

Does Material Contain Asbestos?

Yes

Is it Friable?

Yes

Original Inspection Date

6/ 1/92

Current Reinspection Date

6/ 1/98

Current Assessment Rating

1B Damaged TSI

Cause of Damage

Physical Damage

Accessible

Yes

Potential for Damage

High

Removed

No

Planned Response Action

O & M

Inspector

Clint Yates

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

05

Type of Material

Miscellaneous Material

Quantity of Material

33,750 SF

Material Location

Throughout Building (Classrooms, Halls & Office)

Material Description

VAT

Comments

Material is positive everywhere except the gymnasium. VAT was removed in the cafeteria over the summer of '95.

Does Material Contain Asbestos?

Yes

Is it Friable?

No

Original Inspection Date

6/ 1/92

Current Reinspection Date

6/ 1/98

Current Assessment Rating

0/ 1/90

Cause of Damage

No Damage

NR Not Required

Accessible

Yes

Potential for Damage

Low

Removed

No

Planned Response Action

O & M

Inspector

Clint Yates

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

07

Type of Material

Miscellaneous Material

Quantity of Material

33,750 SF

Material Location

Throughout Building

Material Description

Mastic

Comments

Material is assumed to be in good condition.

Does Material Contain Asbestos?

Assumed

Is it Friable?

No

Original Inspection Date

6/ 1/92

Current Reinspection Date

6/ 1/98

Current Assessment Rating

NR Not Required

Cause of Damage

No Damage

Accessible

No

Potential for Damage

Low

Removed

No

Planned Response Action

O & M

Inspector

Clint Yate

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

11

Type of Material

Miscellaneous Material

Quantity of Material

30 SF

Material Location

Boiler Room

Material Description

Fire Door

Comments

Material is assumed to be in good condition.

Does Material Contain Asbestos?

Assumed

Is it Friable?

No

Original Inspection Date

6/ 1/92

Current Reinspection Date

6/ 1/98

Current Assessment Rating

NR Not Required

Cause of Damage

No Damage

Accessible

Yes

Potential for Damage

Low

Removed

No

Planned Response Action

O & M

Inspector

Clint Yates

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

15

Type of Material

Miscellaneous Material

Each

Quantity of Material

2

Material Location

Boiler Room

Material Description

Boiler Gaskets

Comments

Material is in good condition.

Does Material Contain Asbestos?

Assumed

Is it Friable?

No

Original Inspection Date

6/ 1/92

Current Reinspection Date

6/ 1/98

Current Assessment Rating

NR Not Required

Cause of Damage

No Damage

Accessible

Yes

Potential for Damage

Low

Removed

No

Planned Response Action

O & M

Inspector

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

Α

Type of Material

Miscellaneous Material

Quantity of Material

LF

Material Location

Throughout the building

Material Description

Cove Base

Comments

Material is in good condition.

Does Material Contain Asbestos?

Assumed

Is it Friable?

No

Original Inspection Date

5/31/95

Current Reinspection Date

6/ 1/98

Current Assessment Rating

NR Not Required

Cause of Damage

No Damage

Accessible

Yes

Potential for Damage

Low

Removed

No

Planned Response Action

O & M

Inspector

Clint Yates

State

Indiana

Accreditation Number

LEA Name

Greater Clark County Schools

Building Name

Thomas Jefferson Elementary

HA#

В

Type of Material

Miscellaneous Material

Quantity of Material

LF

Material Location

Throughout Building

Material Description

Cove Base Mastic

Comments

Material is assumed to be in good condition.

Does Material Contain Asbestos?

Assumed

Is it Friable?

No

Original Inspection Date

5/31/95

Current Reinspection Date

6/ 1/98

Current Assessment Rating

NR Not Required

Cause of Damage

No Damage

Accessible

No

Potential for Damage

Low

Removed

No

Planned Response Action

O&M


Inspector

Clint Yates

State

Indiana

Accreditation Number



LEA NAME: Greater Clark County School Corp.

BUILDING NAME: Thomas Jefferson Elementary

HA#:

TYPE OF MATERIAL: Thermal Material

QUANTITY OF MATERIAL: 90LF

MATERIAL LOCATION:

Tunnels

MATERIAL DESCRIPTION:

Pipe Insulation - Mag

COMMENTS:

Entry to tunnel is restricted. Material is known to be asbestos containing.

IS MATERIAL FRIABLE? YES

ORIGINAL INSPECTION DATE: 06/01/92

CURRENT REINSPECTION DATE: 06/26/95

CURRENT ASSESSMENT RATING: 1B Damaged TSI

CAUSE OF DAMAGE: Physical Damage

ACCESSIBLE: NO

POTENTIAL FOR DAMAGE: Low

REMOVED: NO

CURRENT VIDEO TAPE:

(TAPE NO/FOOTAGE)

INSPECTOR NAME:

Rev Gaddis

STATE: Indiana

ACCREDITATION NO.: 190908032

LEA NAME:

Greater Clark County School Corp.

BUILDING NAME:

Thomas Jefferson Elementary

HA#:

11

TYPE OF MATERIAL:

Miscellaneous Material

QUANTITY OF MATERIAL:

30SF

MATERIAL LOCATION:

Boiler Room

MATERIAL DESCRIPTION:

Fire Door

COMMENTS:

Material is assumed to be asbestos containing.

IS MATERIAL FRIABLE?

NO

ORIGINAL INSPECTION DATE:

06/01/92

CURRENT REINSPECTION DATE:

06/26/95

CURRENT ASSESSMENT RATING:

NR Not Required

CAUSE OF DAMAGE:

No Damage

ACCESSIBLE:

NO

POTENTIAL FOR DAMAGE:

Low

REMOVED:

NO

CURRENT VIDEO TAPE:

(TAPE NO/FOOTAGE)

INSPECTOR NAME:

Pey Caddie

STATE:

Indiana

ACCREDITATION NO.:

LEA NAME:

Greater Clark County School Corp.

BUILDING NAME:

Thomas Jefferson Elementary

HA#:

14

TYPE OF MATERIAL:

Miscellaneous Material

QUANTITY OF MATERIAL:

MATERIAL LOCATION:

MATERIAL DESCRIPTION:

Chalkboard

COMMENTS:

Not covered under AHERA.

IS MATERIAL FRIABLE?

NO

ORIGINAL INSPECTION DATE:

CURRENT REINSPECTION DATE:

CURRENT ASSESSMENT RATING:

CAUSE OF DAMAGE:

ACCESSIBLE:

NO

POTENTIAL FOR DAMAGE:

REMOVED:

NO

CURRENT VIDEO TAPE: (TAPE NO/FOOTAGE)

INSPECTOR NAME:

Pay Caddie

STATE:

Indiana

ACCREDITATION NO.:

LEA NAME:

Greater Clark County School Corp.

BUILDING NAME:

Thomas Jefferson Elementary

HA#:

15

TYPE OF MATERIAL:

Miscellaneous Material

QUANTITY OF MATERIAL:

2

MATERIAL LOCATION:

Boiler Room

MATERIAL DESCRIPTION:

Boiler Gaskets

COMMENTS:

Material is assumed to be asbestos containing.

IS MATERIAL FRIABLE?

NO

ORIGINAL INSPECTION DATE:

06/01/92

CURRENT REINSPECTION DATE:

06/26/95

CURRENT ASSESSMENT RATING:

NR Not Required

CAUSE OF DAMAGE:

No Damage

ACCESSIBLE:

NO

POTENTIAL FOR DAMAGE:

Low

REMOVED:

NO

CURRENT VIDEO TAPE: (TAPE NO/FOOTAGE)

.

INSPECTOR NAME:

Pey Caddie

STATE:

Indiana

ACCREDITATION NO.:

LEA NAME:

Greater Clark County School Corp.

BUILDING NAME:

Thomas Jefferson Elementary

HA#:

2

TYPE OF MATERIAL:

Thermal Material

QUANTITY OF MATERIAL:

150LF

MATERIAL LOCATION:

Tunnels

MATERIAL DESCRIPTION:

Pipe Insulation - Air Cell

COMMENTS:

Restricted entry to tunnel. Material is known to be asbestos containing.

IS MATERIAL FRIABLE?

YES

ORIGINAL INSPECTION DATE:

06/01/92

CURRENT REINSPECTION DATE:

06/26/95

CURRENT ASSESSMENT RATING:

1B Damaged TSI

CAUSE OF DAMAGE:

Physical Damage

ACCESSIBLE:

NO

POTENTIAL FOR DAMAGE:

Low

REMOVED:

NO

CURRENT VIDEO TAPE:

(TAPE NO/FOOTAGE)

.....

INSPECTOR NAME:

Dan Caddia

STATE:

Indiana

ACCREDITATION NO.:

LEA NAME:

Greater Clark County School Corp.

BUILDING NAME:

Thomas Jefferson Elementary

HA#:

3

TYPE OF MATERIAL:

Thermal Material

QUANTITY OF MATERIAL:

48

MATERIAL LOCATION:

Boiler Room and Tunnel

MATERIAL DESCRIPTION:

Fittings

COMMENTS:

Material is known to be asbestos containing. There is some damage in the boiler room. Entry to tunnel is restricted.

IS MATERIAL FRIABLE?

YES

ORIGINAL INSPECTION DATE:

06/01/92

CURRENT REINSPECTION DATE:

06/26/95

CURRENT ASSESSMENT RATING:

Damaged TSI 1B

CAUSE OF DAMAGE:

Physical Damage

ACCESSIBLE:

NO

POTENTIAL FOR DAMAGE:

Low

REMOVED:

NO

CURRENT VIDEO TAPE:

(TAPE NO/FOOTAGE)

INSPECTOR NAME:

STATE:

Indiana

ACCREDITATION NO.:

LEA NAME:

Greater Clark County School Corp.

BUILDING NAME:

Thomas Jefferson Elementary

HA#:

TYPE OF MATERIAL: Thermal Material

QUANTITY OF MATERIAL:

40SF

MATERIAL LOCATION:

Tunnel

MATERIAL DESCRIPTION:

Debris

COMMENTS:

Material is located on tunnel floor. It is known to be asbestos containing. Access to tunnel is restricted.

IS MATERIAL FRIABLE?

YES

ORIGINAL INSPECTION DATE:

06/01/92

CURRENT REINSPECTION DATE:

06/26/95

CURRENT ASSESSMENT RATING:

1B Damaged TSI

CAUSE OF DAMAGE:

Physical Damage

ACCESSIBLE:

NO

POTENTIAL FOR DAMAGE:

High

REMOVED:

STATE:

NO

CURRENT VIDEO TAPE:

(TAPE NO/FOOTAGE)

INSPECTOR NAME:

Indiana

ACCREDITATION NO.:

LEA NAME:

Greater Clark County School Corp.

BUILDING NAME:

Thomas Jefferson Elementary

HA#:

TYPE OF MATERIAL: Miscellaneous Material

QUANTITY OF MATERIAL:

33,750

MATERIAL LOCATION:

Throughout Building (Classrooms, Halls & Office)

MATERIAL DESCRIPTION:

VAT

COMMENTS:

Material is positive everywhere except the gymnasium.

IS MATERIAL FRIABLE?

NO

ORIGINAL INSPECTION DATE:

06/01/92

CURRENT REINSPECTION DATE:

06/26/95

CURRENT ASSESSMENT RATING:

NR Not Required

CAUSE OF DAMAGE:

No Damage

ACCESSIBLE:

NO

POTENTIAL FOR DAMAGE:

Low

REMOVED:

NO

CURRENT VIDEO TAPE:

(TAPE NO/FOOTAGE)

INSPECTOR NAME:

STATE:

Indiana

ACCREDITATION NO.:

LEA NAME:

Greater Clark County School Corp.

BUILDING NAME:

Thomas Jefferson Elementary

HA#:

TYPE OF MATERIAL: Miscellaneous Material

QUANTITY OF MATERIAL:

33,750

MATERIAL LOCATION:

Throughout Building

MATERIAL DESCRIPTION:

Mastic

COMMENTS:

Material is assumed to be asbestos containing.

IS MATERIAL FRIABLE?

NO

ORIGINAL INSPECTION DATE:

06/01/92

CURRENT REINSPECTION DATE:

06/26/95

CURRENT ASSESSMENT RATING:

NR Not Required

CAUSE OF DAMAGE:

No Damage

ACCESSIBLE:

NO

POTENTIAL FOR DAMAGE:

Low

REMOVED:

STATE:

NO

CURRENT VIDEO TAPE:

(TAPE NO/FOOTAGE)

INSPECTOR NAME:

Indiana

ACCREDITATION NO.:

THIRD YEAR REINSPECTION REPORT

LEA NAME:

Greater Clark County School Corp.

BUILDING NAME:

Thomas Jefferson Elementary

HA#:

A

TYPE OF MATERIAL:

Miscellaneous Material

QUANTITY OF MATERIAL:

MATERIAL LOCATION:

Throughout Building

MATERIAL DESCRIPTION:

Cove Base

COMMENTS:

This material was not addressed in the original inspection. It is assumed to be positive and will be treated as ACM until it is sampled. Material is in good condition and is non-friable and does not need as assessment rating at this time.

IS MATERIAL FRIABLE?

NO

ORIGINAL INSPECTION DATE:

CURRENT REINSPECTION DATE:

06/26/95

CURRENT ASSESSMENT RATING:

NR Not Required

CAUSE OF DAMAGE:

No Damage

ACCESSIBLE:

NO

POTENTIAL FOR DAMAGE:

Low

REMOVED:

NO

CURRENT VIDEO TAPE:

(TAPE NO/FOOTAGE)

/

INSPECTOR NAME:

Pay Gaddie

STATE:

Indiana

ACCREDITATION NO.:

190908032

THIRD YEAR REINSPECTION REPORT

LEA NAME:

Greater Clark County School Corp.

BUILDING NAME:

Thomas Jefferson Elementary

HA#:

В

TYPE OF MATERIAL:

Miscellaneous Material

QUANTITY OF MATERIAL:

MATERIAL LOCATION:

Throughout Building

MATERIAL DESCRIPTION:

Cove Base Mastic

COMMENTS:

This material was not addressed in the original inspection. It is assumed to be positive and will be treated as ACM until it is sampled. Material is in good condition and is non-friable and does not need an assessment rating at this time.

IS MATERIAL FRIABLE?

NO

ORIGINAL INSPECTION DATE:

CURRENT REINSPECTION DATE:

06/26/95

CURRENT ASSESSMENT RATING:

NR Not Required

CAUSE OF DAMAGE:

No Damage

ACCESSIBLE:

NO

POTENTIAL FOR DAMAGE:

Low

REMOVED:

NO

CURRENT VIDEO TAPE:

(TAPE NO/FOOTAGE)

INSPECTOR NAME:

Pov Caddia

STATE:

Indiana

ACCREDITATION NO.:

190908032

ADDITIONAL BULK SAMPLES

ALLIANCE INDIANA, INC. 1433 Sadlier Circle West Dr. Indianapolis, IN 46239 317/351-5600 Fax 317/351-5610

Project Name-	THOMAS JEFFE	RSON ELEMENTARY
Project Location	on- TUNNEL	
City/State-	TEFFERSONVILLE	ENDIANA
		Date- 07 NOCOMBER 2000
	cted By- Blue OGC	
Samples Collec	ried by - <u>picc (roc</u>	
SAMPLE I.D. NUMBER	LOCATION OF SAMPLE	DESCRIPTION OF SAMPLE MATERIAL
WM-01	TUNNEL ENTRANCE	WHITE COATED BLACK/BROWN FIBROUS SHEET
	:	
CHAIN OF O	CUSTODY	
Sample By: BIL	_	EMC(December Day
Date: 07 1200	and the second s	Recorded By: Log#:
Signature: <u>Be</u>	Signature: Ki	ta Maales Signature:
Date Shipped:	Shipped Via:	Shipped To:

EMSL Analytical, Inc.

6330 E. 75th St., Suite 152 Indianapolis, IN 46250

Phone: (317) 570-5892

Fax: (317) 570-5894



Attn.: Bruce Wallace Alliance Indiana, Inc.

1433 Sadlier Circle West Drive Indianapolis, IN 46239

Tuesday, December 12, 2000

Ref Number: IN006082

POLARIZED LIGHT MICROSCOPY (PLM)

Performed by EPA 600/R-93/116 Method*

Project: NGR-00A02

Sample	Location	Appearance	Sample Treatment	ASB %	ESTOS Type	%	NON-AS	BEST	OS Non-Fibrous
WM-01		Black/Brown Fibrous Homogeneous	Teased		one Detected	_	Cellulose		6 Other

Comments: For all obviously heterogeneous samples easily separated into subsamples, and for layered samples, each component is analyzed separately. Also, "# of Layers" refers to number of separable subsamples.

* NY samples/analyzed by ELAP 198.1 Method.

Richard K. Harding **Analyst**

Approved Signatory

Disclaimers; PLM has been known to miss asbestos in a small percentage of samples which contain asbestos. Thus negative PLM results cannot be guaranteed. EMSL suggests that samples reported as <1% or none detected be tested with either SEM or TEM. The above test report relates only to the items tested. This report may not be reproduced, except in full, without written approval by EMSL. The above test must not be used by the client to claim product endorsement by NVLAP nor any agency of the United States Government. Laboratory is not responsible for the accuracy of results when requested to physically separate and analyze layered samples.

1

ALLIANCE INDIANA, INC. 1433 Sadlier Circle West Dr. Indianapolis, IN 46239 317/351-5600 Fax 317/351-5610

12006082

F'roject Name	- IHOMAS JEF,	FERSON ELEMENTARY
Froject Locati	ion- TUNNEL	
	JEFFERSONVICLE	= INDIANA
Project Numb	er- NGR - OOAC	2 Date- 27 NECEMBER 2000
Samples Colle	cted By- BILL O	SUE -
SAMPLE I.D. NUMBER	LOCATION OF SAMPLE	DESCRIPTION OF SAMPLE MATERIAL
WM-01	TUNNEL ENTRANCE	WHITE COATED BLACK/BROWN FIBRUUS SHEET
)		
CHAIN OF C	USTODY	
Sample By: Buc Date: 17 Decem		Récorded By: Log#:
_ignature: <u>B.O</u>	Signature:	Total Signature:
Date Shipped:	Shipped Via:	Shipped To:

ANNUAL NOTIFICATIONS
ACCREDITATIONS
TRAINING
INFORMATION

Indiana Department of Environmental Management 100 N. Senate Avenue Mail Code 61-52 IGCN 1003 Indianapolis, IN 46204-2251

April 17, 2014

RECEIVED APR 22 2014



Benjamin S. Hood Alliance Environmental Group 5340 Commerce Circle, Ste E Indianapolis IN 46237

Re: Asbestos Inspector # 19A001039

Based upon the review of your license application, the Office of Air Quality has determined that you have fulfilled the requirements of 326 IAC 18 and are eligible for licensing in the following discipline:

Asbestos Inspector

Your Asbestos Inspector license is attached below. The license is waterproof and tear resistant. Please sign your license and do not laminate or alter your license in anyway. Your license must be available for review at all times while implementing an asbestos project. This license may be revoked, pursuant to 326 IAC 18-1-7, if you:

- (1) Violate any requirements of these rules (326 IAC 18), 326 IAC 14-10, or any requirement of the Asbestos-Containing Materials in Schools Rule or any other federal, state, or local regulation pertaining to asbestos in buildings or to asbestos projects.
- (2) Falsify information on your application for licensing.
- (3) Fail to meet any qualifications specified in 326-IAC 18-1-4.
- (4) Conduct asbestos project, or related asbestos handling activity, in a manner which is hazardous to the public health.

Your license is valid effective 05/05/2014, and will expire on 05/05/2015, as indicated on your card. We suggest that you attend the required training and submit an application for license renewal early to insure your license does not lapse. NOTE: 326 IAC 18-1-4(h) and 326 IAC 18-1-6(e) require that any individual who has an eighteen (18) month lapse between any two training courses of the same discipline to attend an initial training course for the discipline in which they are seeking a license. In order to avoid re-taking the initial training course you must have attended a refresher in the discipline you are seeking a license within eighteen (18) months from the date of issuance of your last training course certificate.

Office of Air Quality, Asbestos Licensina Section (317) 233-3861



Indiana Dept. of Environmental Management

Benjamin S. Hood

Asbestos Inspector License #: 19A001039

Effective: 05/05/2014

Expiration: 05/05/2015 Gender: M

Birth Date: 04/10/1978

Gender M

Height: 6-00 Weight: 285 Eye Color: Brown Hair Color: Brown

NOTICES

NOTIFICATION LOG

GREATER CLARK COUNTY SCHOOLS

COPY IN BOOK **DATE OF NOTIFICATION** (X) **YEAR**

NOTIFICATION LOG

LEA Name - Greater Clark County Schools

Date of Notification	Copy of Notification in Supplemental Book?
1989	
1990	
<u>1991</u>	
1992	
1993	
1994	
1995	
1996	
1997	
1998	
1999	
2000	
2001	
2002	
2003	
2004	
2005	
2006	
2007	
2008	

This information is being published to comply with the requirements of 40 CFR 763, Subpart E, Asbestos Containing Materials in Schools. This regulation, commonly known as the "AHERA" rule, requires local education agencies, such as this one, to perform certain tasks in regards to the presence and control of asbestos containing materials in the buildings under the jurisdiction of the local education agency.

These include but are not limited to:

- 1. Developing an asbestos management plan which is designed to outline procedures and guidelines for the initial inspection, triennial reinspections, and 6 month periodic surveillance of asbestos-containing materials that are present in the buildings.
- 2. Provide awareness training and additional training to selected school employees.
- 3. Periodically notify all workers and occupants, or their local guardians, parent teacher organizations, and collective bargaining organizations of the availability of asbestos management plans, the location of same and the times that the plans may be reviewed.

This notification is to advise all patrons, occupants, or their legal guardians, collective bargaining organizations, and parent-teachers organizations, that the asbestos management plans required under this act are available for review upon request. The plans can be viewed by any person during normal business hours of the particular school. Interested parties wishing to inquire about the plans should contact the individual school office. Master copies of the plans for all buildings under the jurisdiction of this local education agency are available in the Auxiliary Services at River Valley Middle School, which is located at 2220 Veteran's Parkway, Jeffersonville, Indiana 47130; telephone number (812) 288-4821. Inquiries regarding any facet of the regulation or the management plans should be directed to Mr. Steve Hobgood at the above telephone number during regular business hours.

Greater Clark County Schools, school facilities, and buildings which contain asbestos-containing materials (ACMs) and must comply with the 40 CFR 763, Subpart E (AHERA) regulations include:

Jeffersonville, Charlestown and New Washington High Schools; Parkview, River Valley and Charlestown Middle Schools; Wilson, Thomas Jefferson, Northaven, New Washington, Jonathan Jennings, Bridgepoint, Maple, Spring Hill, and Parkwood Elementary Schools, Service Center, Corden Porter Storage, Auto Tech Program- Witten Property, and Corden Porter Center with Gym.

Listed is a brief description of asbestos projects currently ongoing and completed at our facilities this past school year, as well as activities currently scheduled for the 2015/2016 school year. Detailed reports of each activity will become a part of each school's asbestos management plan and may be reviewed in the school office.

- * The required triennial re-inspection will be performed in April 2016.
- * The required six month periodic surveillance was performed in October 2014.
- * The required six month periodic surveillance activities are scheduled for April and October each year.

School facilities and buildings that are asbestos free and require no surveillance or reinspection are:

This information is being published to comply with the requirements of 40 CFR 763, Subpart E, Asbestos Containing Materials in Schools. This regulation, commonly known as the "AHERA" rule, requires local education agencies, such as this one, to perform certain tasks in regards to the presence and control of asbestos containing materials in the buildings under the jurisdiction of the local education agency.

These include but are not limited to:

- 1. Developing an asbestos management plan which is designed to outline procedures and guidelines for the initial inspection, triennial reinspections, and 6 month periodic surveillance of asbestos-containing materials that are present in the buildings.
- 2. Provide awareness training and additional training to selected school employees.
- 3. Periodically notify all workers and occupants, or their local guardians, parent teacher organizations, and collective bargaining organizations of the availability of asbestos management plans, the location of same and the times that the plans may be reviewed.

This notification is to advise all patrons, occupants, or their legal guardians, collective bargaining organizations, and parent-teachers organizations, that the asbestos management plans required under this act are available for review upon request. The plans can be viewed by any person during normal business hours of the particular school. Interested parties wishing to inquire about the plans should contact the individual school office. Master copies of the plans for all buildings under the jurisdiction of this local education agency are available in the Auxiliary Services building, which is located at 2220 Veteran's Parkway, Jeffersonville, Indiana 47130; telephone number (812) 288-4821. Inquiries regarding any facet of the regulation or the management plans should be directed to Mr. Steve Hobgood at the above telephone number during regular business hours.

Greater Clark County Schools, school facilities, and buildings which contain asbestos-containing materials (ACMs) and must comply with the 40 CFR 763, Subpart E (AHERA) regulations include:

Jeffersonville, Charlestown and New Washington High Schools; Parkview, River Valley and Charlestown Middle Schools; Wilson, Thomas Jefferson, Northaven, New Washington, Jonathan Jennings, Bridgepoint, Maple, Spring Hill, and Parkwood Elementary Schools, the Auxiliary Services Building, Service Center, Corden Porter Storage, and Corden Porter Center with Gym.

Listed is a brief description of asbestos projects currently ongoing and completed at our facilities this past school year, as well as activities currently scheduled for the 2014/2015 school year. Detailed reports of each activity will become a part of each school's asbestos management plan and may be reviewed in the school office.

- * The required triennial re-inspection will be performed in April 2013.
- * The required six month periodic surveillance was performed in October 2013.
- * The required six month periodic surveillance activities are scheduled for April and October each year.

School facilities and buildings that are asbestos free and require no surveillance or reinspection are:

March 2013

AHERA ANNUAL NOTICE GREATER CLARK COUNTY SCHOOLS

This information is being published to comply with the requirements of 40 CFR 763, Subpart E, Asbestos Containing Materials in Schools. This regulation, commonly known as the "AHERA" rule, requires local education agencies, such as this one, to perform certain tasks in regards to the presence and control of asbestos containing materials in the buildings under the jurisdiction of the local education agency.

These include but are not limited to:

- Developing an asbestos management plan which is designed to outline procedures and guidelines for the initial inspection, triennial reinspections, and 6 month periodic surveillance of asbestos-containing materials that are present in the buildings.
- 2. Provide awareness training and additional training to selected school employees.
- Periodically notify all workers and occupants, or their local guardians, parent teacher organizations, and collective bargaining organizations of the availability of asbestos management plans, the location of same and the times that the plans may be reviewed.

This notification is to advise all patrons, occupants, or their legal guardians, collective bargaining organizations, and parent-teachers organizations, that the asbestos management plans required under this act are available for review upon request. The plans can be viewed by any person during normal business hours of the particular school. Interested parties wishing to inquire about the plans should contact the individual school office. Master copies of the plans for all buildings under the jurisdiction of this local education agency are available in the Auxiliary Services building, which is located at 2710 E 10th Street, Jeffersonville, Indiana 47130; telephone number (812) 288-4821. Inquiries regarding any facet of the regulation or the management plans should be directed to Mr. Steve Hobgood at the above telephone number during regular business hours.

Greater Clark County Schools, school facilities, and buildings which contain asbestos-containing materials (ACMs) and must comply with the 40 CFR 763, Subpart E (AHERA) regulations include:

Jeffersonville, Charlestown and New Washington High Schools; Parkview, River Valley and Charlestown Middle Schools; Wilson, Thomas Jefferson, Northaven, New Washington, Jonathan Jennings, Bridgepoint, Maple, Spring Hill, and Parkwood Elementary Schools, the Auxiliary Services Building, Service Center, Corden Porter Storage, and Corden Porter Center with Gym.

Listed is a brief description of asbestos projects currently ongoing and completed at our facilities this past school year, as well as activities currently scheduled for the 2013/2014 school year. Detailed reports of each activity will become a part of each school's asbestos management plan and may be reviewed in the school office.

- * The required triennial re-inspection will be performed in April 2013.
- * The required six month periodic surveillance was performed in October 2012.
- * The required six month periodic surveillance activities are scheduled for April and October each year.
- * Projects completed in 2012: Parkview Middle School.

School facilities and buildings that are asbestos free and require no surveillance or reinspection are:

This information is being published to comply with the requirements of 40 CFR 763, Subpart E, Asbestos Containing Materials in Schools. This regulation, commonly known as the "AHERA" rule, requires local education agencies, such as this one, to perform certain tasks in regards to the presence and control of asbestos containing materials in the buildings under the jurisdiction of the local education agency.

These include but are not limited to:

- Developing an asbestos management plan which is designed to outline procedures and guidelines for the initial inspection, triennial reinspections, and 6 month periodic surveillance of asbestos-containing materials that are present in the buildings.
- 2. Provide awareness training and additional training to selected school employees.
- 3. Periodically notify all workers and occupants, or their local guardians, parent teacher organizations, and collective bargaining organizations of the availability of asbestos management plans, the location of same and the times that the plans may be reviewed.

This notification is to advise all patrons, occupants, or their legal guardians, collective bargaining organizations, and parent-teachers organizations, that the asbestos management plans required under this act are available for review upon request. The plans can be viewed by any person during normal business hours of the particular school. Interested parties wishing to inquire about the plans should contact the individual school office. Master copies of the plans for all buildings under the jurisdiction of this local education agency are available in the Auxiliary Services building, which is located at 2710 E 10th Street, Jeffersonville, Indiana 47130; telephone number (812) 288-4821. Inquiries regarding any facet of the regulation or the management plans should be directed to Mr. Steve Hobgood at the above telephone number during regular business hours.

Greater Clark County Schools, school facilities, and buildings which contain asbestos-containing materials (ACMs) and must comply with the 40 CFR 763, Subpart E (AHERA) regulations include:

Jeffersonville, Charlestown and New Washington High Schools; Parkview, River Valley and Charlestown Middle Schools; Wilson, Thomas Jefferson, Northaven, New Washington, Jonathan Jennings, Bridgepoint, Maple, Spring Hill, and Parkwood Elementary Schools, the Auxiliary Services Building, Service Center, and Corden Porter Center with Gym.

Listed is a brief description of asbestos projects currently ongoing and completed at our facilities this past school year, as well as activities currently scheduled for the 2012/2013 school year. Detailed reports of each activity will become a part of each school's asbestos management plan and may be reviewed in the school office.

- * The required triennial re-inspection will be performed in June 2013.
- * The required six month periodic surveillance was performed in December 2011.
- * The required six month periodic surveillance activities are scheduled for June and December each year.
- * Projects completed in 2011: Options building and Parkwood Elementary.
- * Projects scheduled for 2012: Parkview Middle School and Bridgepoint Elementary.
- * Cordon Porter storage building was sold in 2012.

School facilities and buildings that are asbestos free and require no surveillance or reinspection are:

This information is being published to comply with the requirements of 40 CFR 763 Subpart E Asbestos Containing Materials in Schools. This regulation, commonly known as the "AHERA" rule, requires local education agencies, such as this one, to perform certain tasks in regards to the presence and control of asbestos containing materials in the buildings under the jurisdiction of the local education agency.

These include but are not limited to:

- Developing an asbestos management plan which is designed to outline procedures and guidelines for the inspection, reinspection and periodic surveillance of asbestos containing materials that are present in the buildings.
- 2. Provide awareness training and additional training to selected school employees.
- 3. Periodically notify all workers and occupants, or their local guardians, parent teacher organizations, and collective bargaining organizations of the availability of asbestos management plans, the location of same and the times that the plans may be reviewed.

This notification is to advise all patrons, occupants, or their legal guardians, collective bargaining organizations, and parent-teachers organizations, that the asbestos management plans required under this act are available for review upon request. A copy of the plans for all buildings under the jurisdiction of this local education agency are available in the Auxillary Services building, which is located at 2710 E 10th Street, Jeffersonville, Indiana 47130; telephone number (812) 288-4821. Plans for individual schools and other buildings are located in the administration office of each school. The plans can be viewed by any person during normal business hours of the particular school. Interested parties wishing to inquire about the hours and times that the plans are available should call the above number.

At this time, the management plans can provide information regarding inspections, response actions, and post-response action activities, including periodic reinspection and surveillance activities that are planned or in progress. Inquiries regarding any facet of the regulation or the management plans should be directed to Mr. Steve Hobgood at the above telephone number during regular business hours.

Listed is a brief description of asbestos work that has been completed in our schools this year. Detailed reports have become part of each school's asbestos management plan and may be reviewed in the school office.

Jeffersonville, Charlestown and New Washington High Schools; Parkview, River Valley and Charlestown Middle Schools; Wilson, Thomas Jefferson, Northaven, New Washington, Jonathan Jennings, Bridgepoint, Maple, Spring Hill, and Parkwood Elementary Schools; the former Administration Building, Service Center, Options and Corden Porter Center Buildings and Alternative School-

- * The required triennial reinspection will be performed in June 2013.
- * The required six month periodic surveillance was performed in December 2010.
- * The next scheduled activity is the required six month periodic surveillance in June 2011.
- * Charlestown High School asbestos removal project was completed in 2010.
- * Options Building is under renovation in 2011.
- * Parkwood Elementary is under renovation in 2011.

Pleasant Ridge Elementary School, Utica Elementary School and the (New) Administration Building — These buildings are asbestos free and Riverside Elementary was demolished in 2006. No surveillances or reinspections are required for these buildings.

March 2011

This information is being published to comply with the requirements of 40 CFR 763 Subpart E Asbestos Containing Materials in Schools. This regulation, commonly known as the "AHERA" rule, requires local education agencies, such as this one, to perform certain tasks in regards to the presence and control of asbestos containing materials in the buildings under the jurisdiction of the local education agency.

These include but are not limited to:

- 1. Developing an asbestos management plan which is designed to outline procedures and guidelines for the inspection, reinspection and periodic surveillance of asbestos containing materials that are present in the buildings.
- 2. Provide awareness training and additional training to selected school employees.
- 3. Periodically notify all workers and occupants, or their local guardians, parent teacher organizations, and collective bargaining organizations of the availability of asbestos management plans, the location of same and the times that the plans may be reviewed.

This notification is to advise all patrons, occupants, or their legal guardians, collective bargaining organizations, and parent-teachers organizations, that the asbestos management plans required under this act are available for review upon request. A copy of the plans for all buildings under the jurisdiction of this local education agency are available in the Auxillary Services building, which is located at 2710 E 10th Street, Jeffersonville, Indiana 47130; telephone number (812) 288-4821. Plans for individual schools and other buildings are located in the administration office of each school. The plans can be viewed by any person during normal business hours of the particular school. Interested parties wishing to inquire about the hours and times that the plans are available should call the above number.

At this time, the management plans can provide information regarding inspections, response actions, and post-response action activities, including periodic reinspection and surveillance activities that are planned or in progress. Inquiries regarding any facet of the regulation or the management plans should be directed to Mr. Steve Hobgood at the above telephone number during regular business hours.

Listed is a brief description of asbestos work that has been completed in our schools this year. Detailed reports have become part of each school's asbestos management plan and may be reviewed in the school office.

Jeffersonville, Charlestown and New Washington High Schools; Parkview, River Valley and Charlestown Middle Schools; Wilson, Thomas Jefferson, Northaven, New Washington, Jonathan Jennings, Bridgepoint, Maple, Spring Hill, and Parkwood Elementary Schools; the former Administration Building, Service Center, and Corden Porter Center Buildings -

- * The required triennial reinspection will be performed in June 2010.
- * The required six month periodic surveillance was performed in December 2009.
- * The next scheduled activity is the required six month periodic surveillance in December 2010.

 Charlestown High School is an ongoing asbestos removal project which will be complete prior to partial demolition.

Pleasant Ridge Elementary School, Utica Elementary School and the (New) Administration Building — These buildings are asbestos free and Riverside Elementary was demolished in 2006. No surveillances or reinspections are required for these buildings.

March 2010

This information is being published to comply with the requirements of 40 CFR 763 Subpart E Asbestos Containing Materials in Schools. This regulation, commonly known as the "AHERA" rule, requires local education agencies, such as this one, to perform certain tasks in regards to the presence and control of asbestos containing materials in the buildings under the jurisdiction of the local education agency.

These include but are not limited to:

- 1. Developing an asbestos management plan which is designed to outline procedures and guidelines for the inspection, reinspection and periodic surveillance of asbestos containing materials that are present in the buildings.
- 2. Provide awareness training and additional training to selected school employees.
- 3. Periodically notify all workers and occupants, or their local guardians, parent teacher organizations, and collective bargaining organizations of the availability of asbestos management plans, the location of same and the times that the plans may be reviewed.

This notification is to advise all patrons, occupants, or their legal guardians, collective bargaining organizations, and parent-teachers organizations, that the asbestos management plans required under this act are available for review upon request. A copy of the plans for all buildings under the jurisdiction of this local education agency are available in the Service Center building, which is located at 301 E. 11th Street, Jeffersonville, Indiana 47130; telephone number (812) 288-4821. Plans for individual schools and other buildings are located in the administration office of each school. The plans can be viewed by any person during normal business hours of the particular school. Interested parties wishing to inquire about the hours and times that the plans are available should call the above number.

At this time, the management plans can provide information regarding inspections, response actions, and post-response action activities, including periodic reinspection and surveillance activities that are planned or in progress. Inquiries regarding any facet of the regulation or the management plans should be directed to Mr. Steve Hobgood at the above telephone number during regular business hours.

Listed is a brief description of asbestos work that has been completed in our schools this year. Detailed reports have become part of each school's asbestos management plan and may be reviewed in the school office.

Jeffersonville, Charlestown and New Washington High Schools; Parkview, River Valley and Charlestown Middle Schools; Wilson, Thomas Jefferson, Northaven, New Washington, Jonathan Jennings, Bridgepoint, Maple, Spring Hill, and Parkwood Elementary Schools; the former Administration Building, Service Center, and Corden Porter Center Buildings -

- * The required triennial reinspection was performed in June 2007.
- * The required six month periodic surveillance was performed in December 2008.
- * The next scheduled activities are the required six month periodic surveillance in June 2009 and Dec 2009. Charlestown High School has undergone an asbestos removal project prior to partial demolition.

Pleasant Ridge Elementary School, Utica Elementary School and the (New) Administration Building – These buildings are asbestos free and Riverside Elementary was demolished in 2006. No surveillances or re-inspections are required for these buildings.

April 2009

This information is being published to comply with the requirements of 40 CFR 763 Subpart E asbestos containing materials in schools. This regulation, commonly known as the "AHERA" rule, requires local education agencies, such as this one, to perform certain tasks in regards to the presence and control of asbestos containing materials in the buildings under the jurisdiction of the local education agency.

These include but are not limited to:

- Developing an asbestos management plan which is designed to outline procedures and guidelines for the inspection, reinspection and periodic surveillance of asbestos containing materials that are present in the buildings.
- 2. Provide awareness training and additional training to selected school employees.
- Periodically notify all workers and occupants, or their local guardians, parent teacher organizations, and collective bargaining organizations of the availability of asbestos management plans, the location of same and the times that the plans may be reviewed.

This notification is to advise all patrons, occupants, or their legal guardians, collective bargaining organizations, and parent-teachers organizations, that the asbestos management plans required under this act are available for review upon request. A copy of the plans for all buildings under the jurisdiction of this local education agency are available in the Service Center building, which is located at 301 E. 11th Street, Jeffersonville, Indiana 47130; telephone number (812)288-4821. Plans for individual schools and other buildings are located in the administration office of each school. The plans can be viewed by any person during normal business hours of the particular school. Interested parties wishing to inquire about the hours and times that the plans are available should call the above number.

At this time, the management plans can provide information regarding inspections, response actions, and post-response action activities, including periodic reinspection and surveillance activities that are planned or in progress. Inquiries regarding any facet of the regulation or the management plans should be directed to Mr. Steve Hobgood at the above telephone number during regular business hours.

Listed is a brief description of asbestos work that has been completed in our schools this year. Detailed reports have become part of each school's asbestos management plan and may be reviewed in the school office.

Jeffersonville, Charlestown, and New Washington High Schools; Parkview, Charlestown, and River Valley Middle Schools; Wilson, Thomas Jefferson, Northaven, New Washington, Jonathan Jennings, Bridgepoint, Maple, Spring Hill, and Parkwood Elementary Schools; the former Administration Building, Service Center, and Corden Porter Center Buildings -

- * The required triennial reinspection was performed in June 2007.
- * The required six month periodic surveillance was performed in December 2007.
- * The next scheduled activities are the required six month periodic surveillance in June 2008 and Dec 2008.

Pleasant Ridge Elementary School, Utica Elementary School and the (New) Administration Building – These buildings are asbestos free. Riverside Elementary was Demolition in 2006. No surveillances or reinspections are required.

This information is being published to comply with the requirements of 40 CFR 763 Subpart E asbestos containing materials in schools. This regulation, commonly known as the "AHERA" rule, requires local education agencies, such as this one, to perform certain tasks in regards to the presence and control of asbestos containing materials in the buildings under the jurisdiction of the local education agency.

These include but are not limited to:

- Developing an asbestos management plan which is designed to outline procedures and guidelines for the inspection, reinspection and periodic surveillance of asbestos containing materials that are present in the buildings.
- 2. Provide awareness training and additional training to selected school employees.
- 3. Periodically notify all workers and occupants, or their local guardians, parent teacher organizations, and collective bargaining organizations of the availability of asbestos management plans, the location of same and the times that the plans may be reviewed.

This notification is to advise all patrons, occupants, or their legal guardians, collective bargaining organizations, and parent-teachers organizations, that the asbestos management plans required under this act are available for review upon request. A copy of the plans for all buildings under the jurisdiction of this local education agency are available in the Service Center building, which is located at 301 E. 11th Street, Jeffersonville, Indiana 47130; telephone number 288-4821. Plans for individual schools and other buildings are located in the administration office of each school. The plans can be viewed by any person during normal business hours of the particular school. Interested parties wishing to inquire about the hours and times that the plans are available should call the above number.

At this time, the management plans can provide information regarding inspections, response actions, and post-response action activities, including periodic reinspection and surveillance activities that are planned or in progress. Inquiries regarding any facet of the regulation or the management plans should be directed to Mr. Chuck Graves at the above telephone number during regular business hours.

Listed is a brief description of asbestos work that has been completed in our schools this year. Detailed reports have become part of each school's asbestos management plan and may be reviewed in the school office.

Jeffersonville, Charlestown, and New Washington High Schools; Parkview, Charlestown, and River Valley Middle Schools; Wilson, Thomas Jefferson, Northaven, New Washington, Jonathan Jennings, Bridgepoint, Maple, Spring Hill, and Parkwood Elementary Schools; the former Administration Building, Service Center, and Corden Porter Center Buildings -

- * The required six month periodic surveillance was performed in June 2006.
- * The required six month periodic surveillance was performed in December 2006.
- * The next scheduled activities are the required six month periodic surveillance in June 2007 and Dec 2007.

Pleasant Ridge Elementary School, Utica Elementary School and the (New) Administration Building – These buildings are asbestos free. Riverside Elementary was Demolition in 2006. No surveillances or reinspections are required.

March 2007

This information is being published to comply with the requirements of 40 CFR 763 Subpart E asbestos containing materials in schools. This regulation, commonly known as the "AHERA" rule, requires local education agencies, such as this one, to perform certain tasks in regards to the presence and control of asbestos containing materials in the buildings under the jurisdiction of the local education agency.

These include but are not limited to:

- Developing an asbestos management plan which is designed to outline procedures and guidelines for the inspection, reinspection and periodic surveillance of asbestos containing materials that are present in the buildings.
- 2. Provide awareness training and additional training to selected school employees.
- Periodically notify all workers and occupants, or their local guardians, parent teacher organizations, and collective bargaining organizations of the availability of asbestos management plans, the location of same and the times that the plans may be reviewed.

This notification is to advise all patrons, occupants, or their legal guardians, collective bargaining organizations, and parent-teachers organizations, that the asbestos management plans required under this act are available for review upon request. A copy of the plans for all buildings under the jurisdiction of this local education agency are available in the Service Center building, which is located at 301 E. 11th Street, Jeffersonville, Indiana 47130; telephone number 288-4821. Plans for individual schools and other buildings are located in the administration office of each school. The plans can be viewed by any person during normal business hours of the particular school. Interested parties wishing to inquire about the hours and times that the plans are available should call the above number.

At this time, the management plans can provide information regarding inspections, response actions, and post-response action activities, including periodic reinspection and surveillance activities that are planned or in progress. Inquiries regarding any facet of the regulation or the management plans should be directed to Mr. Chuck Graves at the above telephone number during regular business hours.

Listed is a brief description of asbestos work that has been completed in our schools this year. Detailed reports have become part of each school's asbestos management plan and may be reviewed in the school office.

Jeffersonville, Charlestown, and New Washington High Schools; Parkview, Charlestown, and River Valley Middle Schools; Wilson, Thomas Jefferson, Northaven, New Washington, Jonathan Jennings, Bridgepoint, Maple, Riverside, Spring Hill, and Parkwood Elementary Schools; the former Administration Building, Service Center, and Corden Porter Center Buildings -

- * The required triennial reinspection was performed in June 2005.
- * The required six month periodic surveillance was performed in December 2005.
- * The next scheduled activities are the required six month periodic surveillance in June 2006 and Dec 2006.

Pleasant Ridge Elementary School, Utica Elementary School and the (New) Administration Building – These buildings are asbestos free. No surveillances or reinspections are required.

March 2006

This information is being published to comply with the requirements of 40 CFR 763 Subpart E asbestos containing materials in schools. This regulation, commonly known as the "AHERA" rule, requires local education agencies, such as this one, to perform certain tasks in regards to the presence and control of asbestos containing materials in the buildings under the jurisdiction of the local education agency.

These include but are not limited to:

- 1. Developing an asbestos management plan which is designed to outline procedures and guidelines for the inspection, reinspection and periodic surveillance of asbestos containing materials that are present in the buildings.
- Provide awareness training and additional training to selected school employees.
- 3. Periodically notify all workers and occupants, or their local guardians, parent teacher organizations, and collective bargaining organizations of the availability of asbestos management plans, the location of same and the times that the plans may be reviewed.

This notification is to advise all patrons, occupants, or their legal guardians, collective bargaining organizations, and parent-teachers organizations, that the asbestos management plans required under this act are available for review upon request. A copy of the plans for all buildings under the jurisdiction of this local education agency are available in the Service Center building, which is located at 301 E. 11th Street, Jeffersonville, Indiana 47130; telephone number 288-4821. Plans for individual schools and other buildings are located in the administration office of each school. The plans can be viewed by any person during normal business hours of the particular school. Interested parties wishing to inquire about the hours and times that the plans are available should call the above number.

At this time, the management plans can provide information regarding inspections, response actions, and post-response action activities, including periodic reinspection and surveillance activities that are planned or in progress. Inquiries regarding any facet of the regulation or the management plans should be directed to Mr. Chuck Graves at the above telephone number during regular business hours.

Listed is a brief description of asbestos work that has been completed in our schools this year. Detailed reports have become part of each school's asbestos management plan and may be reviewed in the school office.

Jeffersonville, Charlestown, and New Washington High Schools; Parkview, Charlestown, and River Valley Middle Schools; Wilson, Thomas Jefferson, Northaven, New Washington, Jonathan Jennings, Bridgepoint, Maple, Riverside, Spring Hill, and Parkwood Elementary Schools; the former Administration Building, Service Center, and Corden Porter Center Buildings -

- * The required triennial reinspection was performed in June 2004.
- * The required six month periodic surveillance was performed in December 2004.
- * The next scheduled activities are the required six month periodic surveillance in June 2005 and December 2005.

Pleasant Ridge Elementary School, Utica Elementary School and the (New) Administration Building -

* These buildings are asbestos free. No surveillances or reinspections are required.

This information is being published to comply with the requirements of 40 CFR 763 Subpart E asbestos containing materials in schools. This regulation, commonly known as the "AHERA" rule, requires local education agencies, such as this one, to perform certain tasks in regards to the presence and control of asbestos containing materials in the buildings under the jurisdiction of the local education agency.

These include but are not limited to:

- 1. Developing an asbestos management plan which is designed to outline procedures and guidelines for the inspection, reinspection and periodic surveillance of asbestos containing materials that are present in the buildings.
- 2. Provide awareness training and additional training to selected school employees.
- 3. Periodically notify all workers and occupants, or their local guardians, parent teacher organizations, and collective bargaining organizations of the availability of asbestos management plans, the location of same and the times that the plans may be reviewed.

This notification is to advise all patrons, occupants, or their legal guardians, collective bargaining organizations, and parent-teachers organizations, that the asbestos management plans required under this act are available for review upon request. A copy of the plans for all buildings under the jurisdiction of this local education agency are available in the Service Center building, which is located at 301 E. 11th Street, Jeffersonville, Indiana 47130; telephone number 288-4821. Plans for individual schools and other buildings are located in the administration office of each school. The plans can be viewed by any person during normal business hours of the particular school. Interested parties wishing to inquire about the hours and times that the plans are available should call the above number.

At this time, the management plans can provide information regarding inspections, response actions, and post-response action activities, including periodic reinspection and surveillance activities that are planned or in progress. Inquiries regarding any facet of the regulation or the management plans should be directed to Mr. Tony Nauert at the above telephone number during regular business hours.

Listed is a brief description of asbestos work that has been completed in our schools this year. Detailed reports have become part of each school's asbestos management plan and may be reviewed in the school office.

Jeffersonville, Charlestown, and New Washington High Schools; Parkview, Charlestown, and River Valley Middle Schools; Wilson, Thomas Jefferson, Northaven, New Washington, Jonathan Jennings, Bridgepoint, Maple, Riverside, Spring Hill, and Parkwood Elementary Schools; the former Administration Building, Service Center, and Corden Porter Center Buildings -

- * The required six month periodic surveillance was performed in June 2003.
- * The required six month periodic surveillance was performed in December 2003.
- * The next scheduled activities are the required triennial reinspection in June 2004 and a required six month periodic surveillance in December 2004.

Pleasant Ridge Elementary School, Utica Elementary School and the (New) Administration Building -

* These buildings are asbestos free. No surveillances or reinspections are required.

This information is being published to comply with the requirements of 40 CFR 763 Subpart E asbestos containing materials in schools. This regulation, commonly known as the "AHERA" rule, requires local education agencies, such as this one, to perform certain tasks in regards to the presence and control of asbestos containing materials in the buildings under the jurisdiction of the local education agency.

These include but are not limited to:

- 1. Developing an asbestos management plan which is designed to outline procedures and guidelines for the inspection, reinspection and periodic surveillance of asbestos containing materials that are present in the buildings.
- 2. Provide awareness training and additional training to selected school employees.
- 3. Periodically notify all workers and occupants, or their local guardians, parent teacher organizations, and collective bargaining organizations of the availability of asbestos management plans, the location of same and the times that the plans may be reviewed.

This notification is to advise all patrons, occupants, or their legal guardians, collective bargaining organizations, and parent-teachers organizations, that the asbestos management plans required under this act are available for review upon request. A copy of the plans for all buildings under the jurisdiction of this local education agency are available in the Service Center building, which is located at 301 E. 11th Street, Jeffersonville, Indiana 47130; telephone number 288-4821. Plans for individual schools and other buildings are located in the administration office of each school. The plans can be viewed by any person during normal business hours of the particular school. Interested parties wishing to inquire about the hours and times that the plans are available should call the above number.

At this time, the management plans can provide information regarding inspections, response actions, and post-response action activities, including periodic reinspection and surveillance activities that are planned or in progress. Inquiries regarding any facet of the regulation or the management plans should be directed to Mr. Tony Nauert at the above telephone number during regular business hours.

Listed is a brief description of asbestos work that has been completed in our schools this year. Detailed reports have become part of each school's asbestos management plan and may be reviewed in the school office.

Jeffersonville, Charlestown, and New Washington High Schools; Parkview, Charlestown, and River Valley Middle Schools; Wilson, Thomas Jefferson, Northaven, New Washington, Jonathan Jennings, Bridgepoint, Maple, Riverside, Spring Hill, and Parkwood Elementary Schools; the former Administration Building, Service Center, and Corden Porter Center Buildings -

- * The required six month periodic surveillance was performed in June 2002.
- * The required six month periodic surveillance was performed in December 2002.
- * The next scheduled activity is the required periodic surveillance in June 2003.

Pleasant Ridge Elementary School, Utica Elementary School and the (New) Administration Building -

* These buildings are asbestos free. No surveillances or reinspections are required.

May 2003

This information is being published to comply with the requirements of 40 CFR 763 Subpart E asbestos containing materials in schools. This regulation, commonly known as the "AHERA" rule, requires local education agencies, such as this one, to perform certain tasks in regards to the presence and control of asbestos containing materials in the buildings under the jurisdiction of the local education agency.

These include but are not limited to:

- 1. Developing an asbestos management plan which is designed to outline procedures and guidelines for the inspection, reinspection and periodic surveillance of asbestos containing materials that are present in the buildings.
- 2. Provide awareness training and additional training to selected school employees.
- 3. Periodically notify all workers and occupants, or their local guardians, parent teacher organizations, and collective bargaining organizations of the availability of asbestos management plans, the location of same and the times that the plans may be reviewed.

This notification is to advise all patrons, occupants, or their legal guardians, collective bargaining organizations, and parent-teachers organizations, that the asbestos management plans required under this act are available for review upon request. A copy of the plans for all buildings under the jurisdiction of this local education agency are available in the Service Center building, which is located at 301 E. 11th Street, Jeffersonville, Indiana 47130; telephone number 288-4821. Plans for individual schools and other buildings are located in the administration office of each school. The plans can be viewed by any person during normal business hours of the particular school. Interested parties wishing to inquire about the hours and times that the plans are available should call the above number.

At this time, the management plans can provide information regarding inspections, response actions, and post-response action activities, including periodic reinspection and surveillance activities that are planned or in progress. Inquiries regarding any facet of the regulation or the management plans should be directed to Mr. Tony Nauert at the above telephone number during regular business hours.

Listed is a brief description of asbestos work that has been completed in our schools this year. Detailed reports have become part of each school's asbestos management plan and may be reviewed in the school office.

Jeffersonville, Charlestown, and New Washington High Schools; Parkview, Charlestown, and River Valley Middle Schools; Wilson, Thomas Jefferson, Northaven, New Washington, Jonathan Jennings, Bridgepoint, Maple, Riverside, Spring Hill, and Parkwood Elementary Schools; the Administration Building, Service Center, and Corden Porter Center Buildings -

- * The required triennial reinspection was performed in July 2001.
- * The required six month periodic surveillance was performed in December 2001.
- * The next scheduled activities are the required periodic surveillances in June 2002 and December 2002.

Pleasant Ridge Elementary School and (New) Utica Elementary School -

* These buildings are asbestos free. No surveillances or reinspections are required.

(Old) Utica Elementary School -

* In accordance with information collected from the GCCS this building has been deeded to the town of Utica. No further AHERA periodic surveillances or triennial reinspections will be conducted by the designated person.

This information is being published to comply with the requirements of 40 CFR 763 Subpart E asbestos containing materials in schools. This regulation, commonly known as the "AHERA" rule, requires local education agencies, such as this one, to perform certain tasks in regards to the presence and control of asbestos containing materials in the buildings under the jurisdiction of the local education agency.

These include but are not limited to:

- 1. Developing an asbestos management plan which is designed to outline procedures and guidelines for the inspection, reinspection and periodic surveillance of asbestos containing materials that are present in the buildings.
- 2. Provide awareness training and additional training to selected school employees.
- 3. Periodically notify all workers and occupants, or their local guardians, parent teacher organizations, and collective bargaining organizations of the availability of asbestos management plans, the location of same and the times that the plans may be reviewed.

This notification is to advise all patrons, occupants, or their legal guardians, collective bargaining organizations, and parent-teachers organizations, that the asbestos management plans required under this act are available for review upon request. A copy of the plans for all buildings under the jurisdiction of this local education agency are available in the Service Center building, which is located at 301 E. 11th Street, Jeffersonville, Indiana 47130; telephone number 288-4821. Plans for individual schools and other buildings are located in the administration office of each school. The plans can be viewed by any person during normal business hours of the particular school. Interested parties wishing to inquire about the hours and times that the plans are available should call the above number.

At this time, the management plans can provide information regarding inspections, response actions, and post-response action activities, including periodic reinspection and surveillance activities that are planned or in progress. Inquiries regarding any facet of the regulation or the management plans should be directed to Mr. Tony Nauert at the above telephone number during regular business hours.

Listed is a brief description of asbestos work that has been completed in our schools this year. Detailed reports have become part of each school's asbestos management plan and may be reviewed in the school office.

Jeffersonville, Charlestown, and New Washington High Schools; Parkview, Charlestown, and River Valley Middle Schools; Wilson, Thomas Jefferson, Northaven, (Old) Utica, New Washington, Jonathan Jennings, Bridgepoint, Maple, Riverside, Spring Hill, and Parkwood Elementary Schools; the Administration Building, Service Center, and Corden Porter Center -

- * The required six month periodic surveillance was performed in June 2000.
- * The required six month periodic surveillance was performed in January 2001.
- * The next scheduled activity is a required triennial reinspection in June 2001.

Pleasant Ridge Elementary School and (New) Utica Elementary School -

* This building is asbestos free. No surveillances or reinspections are required.

This information is being published to comply with the requirements of 40 CFR 763 Subpart E asbestos containing materials in schools. This regulation, commonly known as the "AHERA" rule, requires local education agencies, such as this one, to perform certain tasks in regards to the presence and control of asbestos containing materials in the buildings under the jurisdiction of the local education agency.

These include but are not limited to:

- 1. Developing an asbestos management plan which is designed to outline procedures and guidelines for the inspection, reinspection and periodic surveillance of asbestos containing materials that are present in the buildings.
- 2. Provide awareness training and additional training to selected school employees.
- 3. Periodically notify all workers and occupants, or their local guardians, parent teacher organizations, and collective bargaining organizations of the availability of asbestos management plans, the location of same and the times that the plans may be reviewed.

This notification is to advise all patrons, occupants, or their legal guardians, collective bargaining organizations, and parent-teachers organizations, that the asbestos management plans required under this act are available for review upon request. A copy of the plans for all buildings under the jurisdiction of this local education agency are available in the Service Center building, which is located at 301 E. 11th Street, Jeffersonville, Indiana 47130; telephone number 288-4821. Plans for individual schools and other buildings are located in the administration office of each school. The plans can be viewed by any person during normal business hours of the particular school. Interested parties wishing to inquire about the hours and times that the plans are available should call the above number.

At this time, the management plans can provide information regarding inspections, response actions, and post-response action activities, including periodic reinspection and surveillance activities that are planned or in progress. Inquiries regarding any facet of the regulation or the management plans should be directed to Mr. Tony Nauert at the above telephone number during regular business hours.

Listed is a brief description of asbestos work that has been completed in our schools this year. Detailed reports have become part of each school's asbestos management plan and may be reviewed in the school office.

Jeffersonville, Charlestown, and New Washington High Schools; Parkview, Charlestown, and River Valley Middle Schools; Wilson, Thomas Jefferson, Northaven, Utica, New Washington, Jonathan Jennings, Bridgepoint, Maple, Riverside, Spring Hill, and Parkwood Elementary Schools; the Administration Building, Service Center, and Corden Porter Center -

- * The required six month periodic surveillance was performed in June 2000.
- * The required six month periodic surveillance was performed in January 2001.
- * The next scheduled activity is a required triennial reinspection in June 2001.

Pleasant Ridge Elementary School -

* This building is asbestos free. No surveillances or reinspections are required.

This information is being published to comply with the requirements of 40 CFR 763 Subpart E asbestos containing materials in schools. This regulation, commonly known as the "AHERA" rule, requires local education agencies, such as this one, to perform certain tasks in regards to the presence and control of asbestos containing materials in the buildings under the jurisdiction of the local education agency.

These include but are not limited to:

- 1. Developing an asbestos management plan which is designed to outline procedures and guidelines for the inspection, reinspection and periodic surveillance of asbestos containing materials that are present in the buildings.
- 2. Provide awareness training and additional training to selected school employees.
- 3. Periodically notify all workers and occupants, or their local guardians, parent teacher organizations, and collective bargaining organizations of the availability of asbestos management plans, the location of same and the times that the plans may be reviewed.

This notification is to advise all patrons, occupants, or their legal guardians, collective bargaining organizations, and parent-teachers organizations, that the asbestos management plans required under this act are available for review upon request. A copy of the plans for all buildings under the jurisdiction of this local education agency are available in the Service Center building, which is located at 301 E. 11th Street, Jeffersonville, Indiana 47130; telephone number 288-4821. Plans for individual schools and other buildings are located in the administration office of each school. The plans can be viewed by any person during normal business hours of the particular school. Interested parties wishing to inquire about the hours and times that the plans are available should call the above number.

At this time, the management plans can provide information regarding inspections, response actions, and post-response action activities, including periodic reinspection and surveillance activities that are planned or in progress. Inquiries regarding any facet of the regulation or the management plans should be directed to Mr. Tony Nauert at the above telephone number during regular business hours.

Listed is a brief description of asbestos work that has been completed in our schools this year. Detailed reports have become part of each school's asbestos management plan and may be reviewed in the school office.

Jeffersonville, Charlestown, and New Washington High Schools; Parkview, Charlestown, and River Valley Middle Schools; Wilson, Thomas Jefferson, Northaven, Utica, New Washington, Jonathan Jennings, Bridgepoint, Maple, Riverside, Spring Hill, and Parkwood Elementary Schools; the Administration Building, Service Center, and Corden Porter Center -

- * The required six month periodic surveillance was performed in June 1999.
- * The required six month periodic surveillance was performed in December 1999.
- * The next scheduled activity is a required periodic surveillance in June 2000.

Pleasant Ridge Elementary School -

* This building is asbestos free. No surveillances or reinspections are required.

AHERA Annual Notice

This information is being published to comply with the requirements of 40 CFR 763 Subpart E asbestos containing materials in schools. This regulation, commonly known as the "AHERA" rule, requires local education agencies, such as this one, to perform certain tasks in regards to the presence and control of asbestos containing materials in the buildings under the jurisdiction of the local education agency.

These include but are not limited to:

- 1. Developing an asbestos management plan which is designed to outline procedures and guidelines for the inspection, reinspection and periodic surveillance of asbestos containing materials that are present in the buildings.
- 2. Provide awareness training and additional training to selected school employees.
- 3. Periodically notify all workers and occupants, or their local guardians, parent teacher organizations, and collective bargaining organizations of the availability of asbestos management plans, the location of same and the times that the plans may be reviewed.

This notification is to advise all patrons, occupants, or their legal guardians, collective bargaining organizations, and parent-teachers organizations, that the asbestos management plans required under this act are available for review upon request. A copy of the plans for all buildings under the jurisdiction of this local education agency are available in the Service Center building, which is located at 301 E. 11th Street, Jeffersonville, Indiana 47130; telephone number 288-4821. Plans for individual schools and other buildings are located in the administration office of each school. The plans can be viewed by any person during normal business hours of the particular school. Interested parties wishing to inquire about the hours and times that the plans are available should call the above number.

At this time, the management plans can provide information regarding inspections, response actions, and post-response action activities, including periodic reinspection and surveillance activities that are planned or in progress. Inquiries regarding any facet of the regulation or the management plans should be directed to Mr. Steve Meredith at the above telephone number during regular business hours.

Listed is a brief description of asbestos work that has been completed in our schools this year. Detailed reports have become part of each school's asbestos management plan and may be reviewed in the school office.

All school and support buildings where it is required -

- * The required six month periodic surveillance was performed in June 1998.
- * The required six month periodic surveillance was performed in December 1998.
- * The next scheduled activity is a required periodic surveillance in June 1999.

Parkwood Elementary School

* O & M was performed in the boiler room in May 1998.

AHERA Annual Notice

This information is being published to comply with the requirements of 40 CFR 763 Subpart E asbestos containing materials in schools. This regulation, commonly known as the "AHERA" rule, requires local education agencies, such as this one, to perform certain tasks in regards to the presence and control of asbestos containing materials in the buildings under the jurisdiction of the local education agency.

These include but are not limited to:

- 1. Developing an asbestos management plan which is designed to outline procedures and guidelines for the inspection, reinspection and periodic surveillance of asbestos containing materials that are present in the buildings.
- 2. Provide awareness training and additional training to selected school employees.
- 3. Periodically notify all workers and occupants, or their local guardians, parent teacher organizations, and collective bargaining organizations of the availability of asbestos management plans, the location of same and the times that the plans may be reviewed.

This notification is to advise all patrons, occupants, or their legal guardians, collective bargaining organizations, and parent-teachers organizations, that the asbestos management plans required under this act are available for review upon request. A copy of the plans for all buildings under the jurisdiction of this local education agency are available in the Service Center building, which is located at 301 E. 11th Street, Jeffersonville, Indiana 47130; telephone number 288-4821. Plans for individual schools and other buildings are located in the administration office of each school. The plans can be viewed by any person during normal business hours of the particular school. Interested parties wishing to inquire about the hours and times that the plans are available should call the above number.

At this time, the management plans can provide information regarding inspections, response actions, and post-response action activities, including periodic reinspection and surveillance activities that are planned or in progress. Inquiries regarding any facet of the regulation or the management plans should be directed to Mr. Steve Meredith at the above telephone number during regular business hours.

Listed is a brief description of asbestos work that has been completed in our schools this year. Detailed reports have become part of each school's asbestos management plan and may be reviewed in the school office.

All school and support buildings where it is required -

- * The required periodic surveillance was performed in June 1997 and December 1997.
- * Next activity scheduled activity is a required third year reinspection in June 1998.

AHERA Annual Notice

This information is being published to comply with the requirements of 40 CFR 763 Subpart E asbestos containing materials in schools. This regulation, commonly known as the "AHERA" rule, requires local education agencies, such as this one, to perform certain tasks in regards to the presence and control of asbestos containing materials in the buildings under the jurisdiction of the local education agency.

These include but are not limited to:

- 1. Developing an asbestos management plan which is designed to outline procedures and guidelines for the inspection, reinspection and periodic surveillance of asbestos containing materials that are present in the buildings.
- 2. Provide awareness training and additional training to selected school employees.
- 3. Periodically notify all workers and occupants, or their local guardians, parent teacher organizations, and collective bargaining organizations of the availability of asbestos management plans, the location of same and the times that the plans may be reviewed.

This notification is to advise all patrons, occupants, or their legal guardians, collective bargaining organizations, and parent-teachers organizations, that the asbestos management plans required under this act are available for review upon request. A copy of the plans for all buildings under the jurisdiction of this local education agency are available in the Service Center building, which is located at 301 E. 11th Street, Jeffersonville, Indiana 47130; telephone number 288-4821. Plans for individual schools and other buildings are located in the administration office of each school. The plans can be viewed by any person during normal business hours of the particular school. Interested parties wishing to inquire about the hours and times that the plans are available, should call the above number.

At this time, the management plans can provide information regarding inspections, response actions, and post-response action activities, including periodic reinspection and surveillance activities that are planned or in progress. Inquiries regarding any facet of the regulation or the management plans should be directed to Mr. Steve Meredith at the above telephone number during regular business hours.

Listed is a brief description of asbestos work that has been completed in our schools this year. Detailed reports have become part of each school's asbestos management plan and may be reviewed in the school office.

All school and support buildings where it is required -

- * The required periodic surveillance was performed in June 1996 and December 1996.
- * The next required periodic surveillance will be performed in June 1997 and December 1997.

This information is being published to comply with the requirements of 40 CFR 763 Subpart E asbestos containing materials in schools. This regulation, commonly known as the "AHERA" rule, requires local education agencies, such as this one, to perform certain tasks in regards to the presence and control of asbestos containing materials in the buildings under the jurisdiction of the local education agency.

These include but are not limited to:

- 1. Developing an asbestos management plan which is designed to outline procedures and guidelines for the inspection, reinspection and periodic surveillance of asbestos containing materials that are present in the buildings.
- 2. Provide awareness training and additional training to selected school employees.
- 3. Periodically notify all workers and occupants, or their local guardians, parent teacher organizations, and collective bargaining organizations of the availability of asbestos management plans, the location of same and the times that the plans may be reviewed.

This notification is to advise all patrons, occupants, or their legal guardians, collective bargaining organizations, and parent-teachers organizations, that the asbestos management plans required under this act are available for review upon request. A copy of the plans for all buildings under the jurisdiction of this local education agency are available in the Service Center building, which is located at 301 E. 11th Street, Jeffersonville, Indiana 47130; telephone number 288-4821. Plans for individual schools and other buildings are located in the administration office of each school. The plans can be viewed by any person during normal business hours of the particular school. The plans can be viewed by any person during normal business hours of the particular school. Interested parties wishing to inquire about the hours and times that the plans are available should call the above number.

At this time, the management plans can provide information regarding inspections, response actions, and post-response action activities, including periodic reinspection and surveillance activities that are planned or in progress. Inquiries regarding any facet of the regulation or the management plans should be directed to Mr. Denny Johanson at the above telephone number during regular business hours.

Listed is a brief description of asbestos work that has been completed in our schools this year. Detailed reports have become part of each school's asbestos management plan and may be reviewed in the school office.

All buildings where it is required -

- * The required third year reinspection was performed in June 1995.
- * The required periodic surveillance was performed in December 1995.
- * Next activity scheduled is a periodic surveillance in June 1996.

Charlestown High School -

* Transite panels were compliantly removed from the exterior of the building.

Corden Porter Building #3 -

* TSI was compliantly removed from the boiler room.

This information is being published to comply with the requirements of 40 CFR 763 Subpart E asbestos containing materials in schools. This regulation, commonly known as the "AHERA" rule, requires local education agencies, such as this one, to perform certain tasks in regards to the presence and control of asbestos containing materials in the buildings under the jurisdiction of the local education agency.

These include but are not limited to:

- 1. Developing an asbestos management plan which is designed to outline procedures and guidelines for the inspection, reinspection and periodic surveillance of asbestos containing materials that are present in the buildings.
- 2. Provide awareness training and additional training to selected school employees.
- 3. Periodically notify all workers and occupants, or their local guardians, parent teacher organizations, and collective bargaining organizations of the availability of asbestos management plans, the location of same and the times that the plans may be reviewed.

This notification is to advise all patrons, occupants, or their legal guardians, collective bargaining organizations, and parent-teachers organizations, that the asbestos management plans required under this act are available for review upon request. A copy of the plans for all buildings under the jurisdiction of this local education agency are available in the Service Center building, which is located at 301 E. 11th Street, Jeffersonville, Indiana 47130; telephone number 288-4821. Plans for individual schools and other buildings are located in the administration office of each school. The plans can be viewed by any person during normal business hours of the particular school. Interested parties wishing to inquire about the hours and times that the plans are available, should call the above number.

At this time, the management plans can provide information regarding inspections, response actions, and post-response action activities, including periodic reinspection and surveillance activities that are planned or in progress. Inquiries regarding any facet of the regulation or the management plans should be directed to Mr. Dennis Johanson at the above telephone number during regular business hours.

Listed is a brief description of asbestos work that has been completed in our schools this year. Detailed reports have become part of each school's asbestos management plan and may be reviewed in the school office.

All school and support buildings where it is required -

- * The required periodic surveillance was performed in June 1995 and December 1995.
- * The required triennial reinspection was performed in June 1995.
- * The next required periodic surveillance will be performed in June 1996 and December 1996.

ACCREDITATIONS



Environmental Management Institute

5610 Crawfordsville Road, Suite 15, Indianapolis, Indiana 46224-3714

317/248-4848 • 800/488-8842 • FAX 317/248-4846 www.envtlmgmt.org

This confirms that

Sandy Shadley

Completed the Required Initial Training for
Asbestos Accreditation Under TSCA Title II
and has
passed with a Score of 70 or Greater the Examination for

Asbestos Management Planner

Course Date
December 10 - 11, 2009

Examination Date

December 11, 2009

Jack E. Leonard, President

Certificate: MP(I) 2248

Expires: December 11, 2010

Approved by::

Illinois Department of Public Health

Indiana Department of Environmental Management

Indiana Department of Environmental Management 100 N. Senate Avenue Mail Code 61-52 IGCN 1003 **dianapolis, IN 46204-2251

January 21, 2010

RECEIVED JAN 23 2010

Sandra S. Shadley Alliance Environmental Grp 5340 Commerce Circle Ste E Indianapolis IN 46237



Re: Asbestos Management Planner # 19A002720

Based upon the review of your license application, the Office of Air Quality has determined that you have fulfilled the requirements of 326 IAC 18 and are eligible for licensing in the following discipline:

Asbestos Management Planner

Your Asbestos Management Planner Ilcense is attached below. The license is waterproof and tear resistant. Please sign your license and do not laminate or alter your license in anyway. Your license must be available for review at all times while implementing an asbestos project. This license may be revoked, pursuant to 326 IAC 18-1-7, if you:

- (1) Violate any requirements of these rules (326 IAC 18), 326 IAC 14-10, or any requirement of the Asbestos-Containing Materials in Schools Rule or any other federal, state, or local regulation pertaining to asbestos in buildings or to asbestos projects.
- (2) Falsify information on your application for licensing.
- (3) Fail to meet any qualifications specified in 326-IAC 18-1-4.
- (4) Conduct asbestos project, or related asbestos handling activity, in a manner which is hazardous to the public health.

Your license is valid effective 01/21/2010, and will expire on 01/21/2011, as indicated on your card. We suggest that you attend the required training and submit an application for license renewal early to insure your license does not lapse. NOTE: 326 IAC 18-1-4(h) and 326 IAC 18-1-6(e) require that any individual who has an eighteen (18) month lapse between any two training courses of the same discipline to attend an initial training course for the discipline in which they are seeking a license. In order to avoid re-taking the initial training course you must have attended a refresher in the discipline you are seeking a license within eighteen (18) months from the date of issuance of your last training course certificate.

Office of Air Quality, Asbestos Licensing Section (317) 233-3861



Indiana Dept. of Environmental Management-

Sandra S. Shadley

Asbestos Management Planner License #: 19A002720


Effective: 01/21/2010


Expiration: 01/21/2011

Birth Date: 04/21/1959 Height: 5-08 Gender: F


Weight: 140

Eye Color: Blue Hair Color: Brown









PATRICK E. WILSON 309 - 90 - 6909

Has Successfully Completed The Course
Required Under TSCA Title II
And Passed The Written Examination
With a Score of 70% or Better
For

ASBESTOS BUILDING INSPECTOR REFRESHER

Accredited by the Indiana Department of Environmental Management.

Certificate # ES00/BIR482

Course Dates: 11/29/2000

Test Date: 11/29/2000 Expires: 11/29/2001

Sharyn Reyes

Instructor



Environmental Management Institute

5610 Crawfordsville Road, Suite 15, Indianapolis, Indiana 46224-3714

317/248-4848 • 800/488-8842 • FAX 317/248-4846 www.spea.iupui.edu/Envtl_mgmt

This confirms that

George Wm. (Bill) Ogle

Completed the Requisite Initial Training for Asbestos Accreditation Under TSCA Title II and has
Passed with a Score of 70 or Greater the Examination for

Asbestos Management Planner

Course date March 2 - 3, 2000

Examination Date March 3, 2000


Jack E. Leonard, President

Certificate: MP(I) 2157 Expires March 3, 2001

Approved by:

Illinois Department of Public Health

Indiana Department of Environmental Management



CLINT YATES

316 - 92 - 7065

Has Successfully Completed The Course
Required Under TSCA Title II
And Passed The Written Examination
With a Score of 70% or Better
For

ASBESTOS BUILDING INSPECTOR REFRESHER

Accredited by the Indiana Department of Environmental Management.


Certificate # ES/BIR98/004.

Course Dates: 01/22/98 - 01/22/98

Test Date: 01/22/98 Expires: 01/22/99

Slaryn Reyce Sharyn Reyes

Assistant / Instructor



CHARLES OF ACCUMULATION OF ACC

1	INDIANA DEPARTMENT OF	CH
Ī	ENVIRONMENTAL MANAGEMENT	政
ı	ASSESTOS CERTIFICATE OF ACCREDITATION	*
1	CEDITION TO THE OF ACCREDITATION	Z
	CERTIFICATION DATE:	Ž
1	J90906032 3/16/96	Š
1	Rex Gaddis	Ž.
ŀ	IS CERTIFIED IN THE FOLLOWING DISCIPLINE(S)	
t	NO OCITIVICED IN THE FOLLOWING DISCIPLINE(S)	
ŀ	INSPECTOR X PLANNER DESIGNER	7
ŀ	CUPTUROSE	
	SUPERVISOR WORKER	C.
E	WASTE DISPOSAL MANAGER	
15	BIRTHDATE: 3/24/52 SEX: M EYES: BLU	
	HEIGHT. E. A. C. SEX.: M. S. EYES: BLUE	7
1-	HEIGHT: 5-10 WEIGHT: 220 HAIR: BRO	4

TRAINING

OPERATIONS AND MAINTENANCE INFORMATION

OPERATIONS AND MAINTENANCE REPORT

(Use only for O&M work less than 3 square or 3 linear feet)

L.E.A.:							
BUILD	ING:		 				
DATE	•						
The fo	llowing inform	ation is provid	ed in accordan	ce with	40 CFR 763.9	91 and 763.94.	
1.	Location:						
2.	Response:	Clean	Repair	·	Enca	psulation	
		Enclosure	Remo	val	_		
							_
3.	Work Descrip	otion:	÷ (con-				
4.	Date:	Start	<u></u>		Stop		
	Time:	Start			Stop		
5.	Material:	Surface	SF		Thermal	LF	
	Other:		SF	or		LF	
6.	Asbestos Cor	ntrol Method:	Wet Methods		_ HEPA	A Vacuum	
			Glovebag		Mini-	Enclosure	_
7.	Respiratory P	rotection:	N.A.P.R		P.A.F	P.R	
	Were all emp	lovees properl	y fit tested?	/ES	NO NO	OT APPLICABLE	

8.	Equipment Used:							
	Low Vol. Pumps FAM HEPA Vac	High AFD	Vol. Pumps		_			
	Other:							
9.	Material Used:							
	6 Mil. Disposable Bags Glovebags Duct Tape Disposable Coveralls Sponges	Poly HEPA Filters Spray Glue 3M Pads						
	Encapsulants: Penetrating _	Bridging	_					
	Other:		 					
10.	Work Personnel:							
	NAME	16 HOUR TE	RAINED - IDEM	ACCR	EDITED			
Super	rvisor:	YES	NO	YES	<u>NO</u>			
Work	er(s):	YES	NO	YES	<u>NO</u>			
		YES	NO	YES	NO			
		YES	NO	YES	NO			
		YES	NO	YES	NO			
		YES_	NO	YES	NO			
11.	ACBM Disposal: Storage: YES	NO , If yes, whe	re stored:					
	If no, where disposed: Land	łfill:						
12.	Final Visual Inspection Approved:	(LEA Designated Pe	rson - Printed N	lame)				
	(LEA Designated Person - Signature)							

REMOVAL PROJECT INFORMATION

SHORT TERM WORKER PROGRAM

Short Term Worker

Greater Clark County Schools

GREATER CLARK COUNTY SCHOOLS

SHORT-TERM WORKER SIGN OFF SHEET

This form should be signed each and every time before a "short-term worker" (telephone repair worker, utility worker, etc.) performs work that may cause him to come in contact with ACBM or suspected ACBM assumed to be ACM. One copy of this form should then be forwarded to the LEA designated person, and one copy should be maintained in the school building's copy of the supplemental binder provided by Alliance Indiana, Inc., in order to fulfill the LEA's recordkeeping requirements. The third copy should be forwarded to Alliance Indiana, Inc. for placement in its copy of the supplemental binder.

School Building Name - Thomas Jefferson Elementary School	Date
I certify that before performing any work which would possibly cause me to come in a Containing Building Materials (ACBM), I was provided with adequate information regarded ACBM and suspected ACBM assumed to be ACM in the above-mentioned school building the work.	rding the locations of
Signature -	
Company	
Description of work (including number of days on site)	
	19 19

Alliance	Indiana,	Inc.
	-	

AHERA Program

GREATER CLARK COUNTY SCHOOLS

SHORT-TERM WORKER SIGN IN LOG

ALL SHORT-TERM WORKERS MUST SIGN THIS LOG CONFIRMING THAT THEY HAVE SIGNED A "SHORT-TERM WORKER SIGN OFF SHEET"

BUILDING NAME - Thomas Jefferson Elementary School					
DATE	NAME(print)	COMPANY	SIGNATURE		
	52 10 500 - 50 0				
		<u> </u>			

		· · · · · · · · · · · · · · · · · · ·			
		<u>~</u>			
		36			
-					