



**ALLIANCE**  
Environmental Group, Inc.

THE ENVIRONMENTAL SOLUTION

---

**GREATER CLARK COUNTY SCHOOLS**

**CHARLESTOWN SENIOR HIGH SCHOOL**

**AHERA**

**ASBESTOS MANAGEMENT PLAN**

**DESIGNATED PERSON  
TRUTH AND CORRECT STATEMENT**

**Local Education Agency –** Greater Clark County Schools  
2112 Utica-Sellersburg Road  
Jeffersonville, Indiana 47130

**Designated Person -** Alliance Environmental Group, Inc.  
Sandra Shadley  
5153 Commerce Square Drive, Suite E  
Indianapolis, Indiana 46237

This Truth and Correct Statement, as outlined in 40 CFR 763.93(i), certifies that the general, local education agency responsibilities, as stipulated by 40 CFR 763.84, have been or will be met. These responsibilities include:

1. Ensure that the activities of any persons who perform inspections, reinspections, and periodic surveillance, develop and update management plans, and develop and implement response actions, including operations and maintenance, are carried out in accordance with 40 CFR 763 Subpart E.
2. Ensure all custodial and maintenance employees are properly trained as required by 40 CFR 763 Subpart E and other applicable Federal and/or State regulations (e.g., the Occupational Safety and Health Administration Asbestos Standard for Construction, the EPA Worker Protection Rule, or applicable State regulations).
3. Ensure that workers and building occupants, or their legal guardians, are informed at least once each school year about inspections, response actions, and post-response action activities, including periodic reinspection and surveillance activities that are planned or in progress.
4. Ensure that short-term workers (e.g., telephone repair workers, utility workers, or exterminators) who may come in contact with asbestos in a school are provided information regarding the locations of ACBM and suspected ACBM assumed to be ACM.
5. Ensure that warning labels are posted in accordance with Section 763.95.
6. Ensure management plans are available for inspection and notification of such availability has been provided as specified in the management plan under Section 763.93(g).
7. The undersigned person designated by the LEA pursuant to Section 763.84(g) (1) has received adequate training as stipulated in Section 763.84(g) (2).
8. The LEA has and will consider whether any conflict of interest may arise from the interrelationship among accredited personnel and whether that should influence the selection of accredited personnel to perform activities under Part 763.

Signature:  Date: November 6, 2016

Sandra S. Shadley

**ASBESTOS PROGRAM MASTER INDEX**

The following volumes are part of the Asbestos Program for the **GREATER CLARK COUNTY SCHOOLS**:

- A. Original Asbestos Management Plan for each school building.
- B. Asbestos Management Plan Supplement for each school building.
  - 1. Amendments to Management Plan
  - 2. Remaining Materials Report
  - 3. Surveillance, Reinspection and Additional Bulk Sampling Information
  - 4. Annual Notifications, Accreditations and Training Records
  - 5. Operations and Maintenance Records
  - 6. Asbestos Removal Projects
  - 7. Short Term Worker Program

Copies of both volumes are found in the respective buildings. The Administration Building also contains duplicate copies of both volumes for each building in their entirety.

GREATER CLARK COUNTY SCHOOLS  
CHARLESTOWN SENIOR HIGH SCHOOL  
TABLE OF CONTENTS

AMENDMENTS TO MANAGEMENT PLAN	1
REMAINING MATERIALS REPORT	2
SURVEILLANCE, REINSPECTION AND ADDITIONAL BULK SAMPLING INFORMATION	3
ANNUAL NOTIFICATIONS, ACCREDITATIONS, AND TRAINING	4
OPERATIONS AND MAINTENANCE RECORDS	5
ASBESTOS REMOVAL PROJECTS	6
SHORT TERM WORKER INFORMATION	7



*AMENDMENTS TO THE MANAGEMENT PLAN*

**AMENDMENT TO MANAGEMENT PLAN**


**Building Name -** Charlestown Senior High School


**Subject -** Removal of Homogeneous Area "03"

**Amendment -** There was additional pipe insulation discovered on overhead heat lines in the original gym and in inaccessible areas (pipe chases, above ceilings, and in wall cavities) throughout the entire original building. Most of the asbestos-containing pipe insulation was abated during the abatement project of 2009 through June 2010 by a licensed contractor. There was additional pipe insulation discovered on pipe buried beneath and on the sides of the tunnels. The pipes and insulation were also removed by a licensed contractor during the last phase of the 2010 demolition project.

Management Planner: Sandra Shadley

Accreditation Number: 19A002720

  
Signature

  
Date

**AMENDMENT TO MANAGEMENT PLAN**


**Building Name -** Charlestown Senior High School


**Subject -** Addition of Homogeneous Area H

**Amendment -** These fire rated doors (4) were noted by the inspector as suspect ACM.  
They will be included in the Management Plan until properly sampled.

Management Planner: Sandra Shadley

Accreditation Number: 19A002720

  
Signature

  
Date

**GREATER CLARK COUNTY SCHOOLS**  
**CHARLESTOWN HIGH SCHOOL**

**LEA RESPONSIBILITY CERTIFICATION**

LEA Designated Person - ALLIANCE INDIANA, INC.

  
Signature - Bruce Wallace, President/CEO

May 1, 1995  
Date

**ACCREDITATION STATEMENT**

The Greater Clark County Schools ensures that the following items will be carried out:

Activities of any persons who perform inspections, reinspections, and periodic surveillance, develop and update management plans, and develop and implement response actions, including operations and maintenance, are carried out in accordance with Subpart E of this part.

All custodial and maintenance employees are properly trained as required by this Subpart E and other applicable Federal and/or State regulations (e.g., the OSHA asbestos standard for construction, the EPA worker protection rule, or applicable State regulations).

Workers and building occupants, or their legal guardians, are informed at least once each school year about inspections, response actions, and post response action activities, including periodic reinspection and surveillance activities that are planned or in progress.

Short-term workers (e.g., telephone repair workers, utility workers, or exterminators) who may come in contact with asbestos in a school are provided information regarding the locations of ACBM and suspected ACBM assumed to be ACM.

Warning labels are posted in accordance with 763.95.

Management plans are available for inspection and notification of such availability has been provided as specified in the management plan under 763.93(g).

Designate a person to ensure that requirements under this section are properly implemented.

Designated person receives adequate training to perform duties assigned under this section. Such training shall provide, as necessary, basic knowledge of:

Health effects of asbestos

Detection, identification, and assessment of ACM

Options for controlling ACBM

Asbestos management programs

Relevant Federal and State regulations concerning asbestos, including those in this Subpart E and those of the OSHA, U.S. Department of Labor, the U.S. Department of Transportation and the U.S. Environmental Protection Agency.

Consider whether any conflict of interest may arise from the interrelationship among accredited personnel and whether that should influence the selection of accredited personnel to perform activities under this subpart.

**AMENDMENT TO THE MANAGEMENT PLAN**

**LEA Name -** Greater Clark County Schools

**Building -** Charlestown High School


**Subject -** LEA Designated Person Change

Effective May 1, 1995 the Designated Person for the  
Greater Clark County Schools is:

Alliance Indiana, Inc.  
1433 Sadler Circle West Drive  
Indianapolis, Indiana 46239  
(317) 351-5600

Management Planner: Rex Gaddis

Accreditation No. 192218025

  
\_\_\_\_\_  
Signature

May 1, 1995  
Date

**AMENDMENT TO THE  
AHERA MANAGEMENT PLAN**

**Building -** Charlestown High School

**Subject-** Deletion of a material

**Reference -** HA 12 Stage Light Wiring

**Original Assessment -**


**Amended Assessment -** This material is not regulated under AHERA and does not need to be included in the management plan.

Management Planner

Rex Gaddis

Indiana Department of Environmental Management Accreditation

192218025

  
Signature

  
Date

**AMENDMENT TO THE  
AHERA MANAGEMENT PLAN**

**Building -** Charlestown High School

**Subject-** New material

**Reference -** HA A Cove Base

**Original Assessment -** No assessment in original inspection.

**Amended Assessment -** The cove base in the building was not addressed in the original inspection. The material is considered to be suspect by EPA. The material will be assumed to contain asbestos and treated as such until a future renovation when it will be sampled.


---


Management Planner

Rex Gaddis

Indiana Department of Environmental Management Accreditation

192218025

  
\_\_\_\_\_  
Signature

  
\_\_\_\_\_  
Date

**AMENDMENT TO THE  
AHERA MANAGEMENT PLAN**

**Building -** Charlestown High School

**Subject-** New material

**Reference -** HA B Cove Base Mastic

**Original Assessment -** No assessment in original inspection.

**Amended Assessment -** The cove base mastic in the building was not addressed in the original inspection. The material is considered to be suspect by EPA. The material will be assumed to contain asbestos and treated as such until a future renovation when it will be sampled.


---


Management Planner

Rex Gaddis

Indiana Department of Environmental Management Accreditation

192218025

  
\_\_\_\_\_  
Signature

  
\_\_\_\_\_  
Date



**AMENDMENT TO MANAGEMENT PLAN**

**Building Name -** Charlestown Senior High School

**Subject -** Addition of Suspect Material to Management Plan

**Amendment -** Homogeneous area designation "C" has been added to the Management Plan to cover transite board with stone texturing on the exterior facia of the building. This material was not addressed during the original inspection. It is suspect for asbestos content and will be treated as ACM until it is sampled by an accredited inspector and analyzed by an accredited laboratory.


---

Management Planner: Matthew S. Wallace

Accreditation Number: 192716070

  
\_\_\_\_\_

Signature

  
\_\_\_\_\_

Date

**AMENDMENT TO MANAGEMENT PLAN**

**Building Name -** Charlestown High School

**Subject -** Addition of Suspect Material to Management Plan


**Amendment -** Homogeneous area designation "D" covering cooling tower panels, slats, and fill material has been added to the Management Plan. The fill material was analyzed by Metro Service Laboratories, Inc. in April, 1989 and found to be positive for asbestos content. The panels and slats are suspect for asbestos content and will be treated as ACM until they are sampled by an accredited inspector and analyzed by an accredited laboratory.

---

Management Planner: George Wm. Ogle

Accreditation Number: 191523030

  
\_\_\_\_\_  
Signature

  
\_\_\_\_\_  
Date



## BULK SAMPLES ASBESTOS ANALYSIS

ANALYSIS NUMBER: 912088

LABORATORY: Metro Service Laboratories, Inc.

CLIENT NAME: Greater Clark Co. Schools

ADDRESS: 6309 Fern Valley Pass

SAMPLED BY: T. Holley

Louisville, Kentucky 40228

[illegible]

ANALYST: T. Sowell

DATE OF ANALYSIS: 4-10-84

Metro Service Laboratories, Inc., has received interim accreditation for polarized light microscopy under the E.P.A. Interim Asbestos Bulk Sample Analysis Quality Assurance Program.

TESTED: Polarized Light Microscopy with Dispersion Staining as per 40 CFR Part 763 Appendix A Subpart F.

REVIEWED BY: Amy S. Howell

### Chemical Analysts and Consultants

6309 FERN VALLEY PASS  
LOUISVILLE, KENTUCKY 40228  
PHONE (502) 964-0865

7759 HIGHWAY 60 WEST  
WEST PADUCAH, KENTUCKY 42086  
PHONE (502) 443-6172

**AMENDMENT TO MANAGEMENT PLAN**

**Building Name -** Charlestown Senior High School

**Subject -** Removal of Homogeneous Area Designation from Management Plan

**Amendment -** Homogeneous area designation "D" covering the cooling tower panels, slats and fill material will be removed from the Management Plan. Upon further investigation it was determined that the current unit was misidentified as the unit that was in place at the time of the original AHERA inspection. The positive samples referred to the unit in use during the original inspection. This unit was removed non-friable when a new HVAC system was installed.

---

Management Planner: George Wm. Ogle

Accreditation Number: 191523030

  
\_\_\_\_\_  
Signature

  
\_\_\_\_\_  
Date

**AMENDMENT TO MANAGEMENT PLAN**


**Building Name -** Charlestown Senior High School


**Subject -** Removal of Non-Suspect Material from Management Plan

**Amendment -** Homogeneous area designation "C" covering transite board with stone texturing on the exterior facia will be removed from the Management Plan. This material was sampled by an accredited inspector and analyzed by an accredited laboratory. It was found to be negative for asbestos content.

Management Planner: George Wm. Ogle

Accreditation Number: 191523030

  
\_\_\_\_\_  
Signature

  
\_\_\_\_\_  
Date

**AMENDMENT TO MANAGEMENT PLAN**

**Building Name -** Charlestown Senior High School

**Subject -** Removal of Materials from Management Plan

**Amendment -** Homogeneous area designation "01" covering the water tank cover in the boiler room; and homogeneous area designation "05" covering air cell pipe insulation along the west wall in the boiler room will be removed from the Management Plan. These materials were removed by an accredited contractor during the spring of 2005.

---

Management Planner: George Wm. Ogle

Accreditation Number: 191928071

  
Signature

  
Date

**AMENDMENT TO MANAGEMENT PLAN**

**Building Name -** Charlestown Senior High School

**Subject -** Addition of Suspect Material to Management Plan

**Amendment -** Homogeneous area designation "A" covering aggregate covered transite panels on the building exterior has been added to the Management Plan. This material is suspect for asbestos content. It will be treated as ACM until it is sampled by an accredited inspector and analyzed by an accredited laboratory.

Management Planner: George Wm. Ogle

Accreditation Number: 191928071

Signature

Date

**AMENDMENT TO MANAGEMENT PLAN**

**LEA Name -** Greater Clark County Schools

**Subject -** LEA Designated Person Change

**Amendment -** Effective March 2005, the Designated Person for the Greater Clark County Schools is:

Alliance Environmental Group, Inc.  
5340 Commerce Circle, Suite E  
Indianapolis, Indiana 46237  
(317) 865-3400

Personnel contributing to this Management Plan are licensed in according with 40 CFR 763.93(e)(12).

**Management Planner:** Sandra S. Shadley

**Accreditation Number:** 19A002720

  
Signature

  
Date



**AMENDMENT TO MANAGEMENT PLAN**


**Building Name -** Charlestown Senior High School

**Subject -** Quantity Update of Homogeneous Area "03"

**Amendment -** There was additional pipe insulation discovered on overhead heat lines in the original gym and in inaccessible areas (pipe chases, above ceilings, and in wall cavities) throughout the entire original building. Most of the asbestos-containing pipe insulation was abated during the abatement project of 2009 through June 2010 by licensed contractors. The only remaining material at the time of this inspection was on pipe buried beneath and on the sides of the tunnels. This material is scheduled to be removed during the last phase of the 2010 demolition project.

Management Planner: Sandra Shadley

Accreditation Number: 19A002720

  
Signature

  
Date

**AMENDMENT TO MANAGEMENT PLAN**


**Building Name -** Charlestown Senior High School


**Subject -** Removal of Homogeneous Area "04"

**Amendment -** Boiler room stack breeching was removed by a licensed contractor in May 2010; therefore, this homogeneous area is being removed from the management plan.

Management Planner: Sandra Shadley

Accreditation Number: 19A002720

  
Signature

  
Date

**AMENDMENT TO MANAGEMENT PLAN**


**Building Name -** Charlestown Senior High School


**Subject -** Removal of Homogeneous Area "06"

**Amendment -** There was additional fitting material discovered on overhead heat lines in the original gym and in inaccessible areas (pipe chases, above ceilings, and in wall cavities) throughout the entire original building. All remaining asbestos fittings were abated during the abatement project of 2009 through June 2010 by licensed contractors. This homogeneous area is being removed from the management plan.

Management Planner: Sandra Shadley

Accreditation Number: 19A002720

  
Signature

  
Date

**AMENDMENT TO MANAGEMENT PLAN**


**Building Name -** Charlestown Senior High School


**Subject -** Removal of Homogeneous Area "08"

**Amendment -** It was reported that all of the VAT mastic was removed in a non-friable manner in 1998. The material was dropped from the management plan; however, it was not amended out of the plan. Additional sampling was performed by a licensed asbestos inspector prior to demolition in 2010. Laboratory analysis proved that some asbestos mastic was present on the first and second floor in the F (J) wing. This material was removed in a non-friable manner in accordance with NESHAP regulations. The remaining portion of the building was built in the 1970's. The VAT mastic was tested for this portion of the building and laboratory analysis proved most of it to be a non-asbestos containing material. The Home Economics area and the Choir Area room with the dark blue tile tested positive and were removed in a non-friable manner. All of the asbestos containing material was removed during demolition/renovation; therefore, it is being removed from the Management Plan.

Management Planner: Sandra Shadley

Accreditation Number: 19A002720

  
Signature

  
Date

**AMENDMENT TO MANAGEMENT PLAN**


**Building Name -** Charlestown Senior High School

**Subject -** Removal of Homogeneous Area "A"

**Amendment -** It was reported that all cove base in the building was removed and replaced with non-asbestos cove base in 1998. The material was dropped from the management plan; however, it was not amended out of the plan. If there was any remaining material left in the building after 1998, this material was removed in a non-friable manner in accordance with NESHAP regulations during demolition/renovation in 2009 and 2010; therefore, it is being removed from the Management Plan.

Management Planner: Sandra Shadley

Accreditation Number: 19A002720

  
Signature

  
Date

**AMENDMENT TO MANAGEMENT PLAN**


**Building Name -** Charlestown Senior High School


**Subject -** Removal of Homogeneous Area "B"

**Amendment -** Some of the cove base mastic was tested and laboratory analysis proved it to be a non-asbestos containing material in 1997. The material was dropped from the management plan; however, it was not amended out of the plan. Additional sampling was performed by a licensed asbestos inspector prior to demolition in 2010. Laboratory analysis proved that some asbestos mastic was present in the Math and Social Studies area. This material was removed in a non-friable manner in accordance with NESHAP regulations. The remaining portion of the building was built in the 1970's. The cove base mastic was tested for this portion of the building and laboratory analysis proved it to be a non-asbestos containing material in 2010. All of the asbestos containing material was removed during demolition/renovation; therefore, it is being removed from the Management Plan.

Management Planner: Sandra Shadley

Accreditation Number: 19A002720

  
Signature

  
Date

**AMENDMENT TO MANAGEMENT PLAN**


**Building Name -** Charlestown Senior High School

**Subject -** Addition and Removal of Homogeneous Area "E"

**Amendment -** Asbestos containing floor tile was identified in the Business (N) wing during the 2010 pre-demolition asbestos inspection performed by licensed asbestos inspector. All of this floor tile was located under carpet and was removed in a non-friable manner in accordance with NESHAP regulations during the 2010 demolition. This material is being removed from the Management Plan.

Management Planner: Sandra Shadley

Accreditation Number: 19A002720

  
Signature

  
Date

**AMENDMENT TO MANAGEMENT PLAN**

**Building Name -** Charlestown Senior High School

**Subject -** Addition of Homogeneous Area J

**Amendment -** Vinyl stair tread mastic was noted by the inspector during the June 2011 inspection as suspect ACM. This will be included in the Management Plan until properly sampled.

Management Planner: Sandra Shadley

Accreditation Number: 19A002720

  
Signature

  
Date



**AMENDMENT TO MANAGEMENT PLAN**


**Building Name -** Charlestown Senior High School


**Subject -** Addition of Homogeneous Area I

**Amendment -** Vinyl stair treads were noted by the inspector during the June 2011 inspection as suspect ACM. This will be included in the Management Plan until properly sampled.

Management Planner: Sandra Shadley

Accreditation Number: 19A002720

  
Signature

  
Date

*REMAINING MATERIALS*

Greater Clark County School Corporation

Remaining Materials Report

4/23/2020

HA ID	HA Description	Quantity		Asbestos	HA Location	Planned Response Action
<b><u>Charlestown Senior High School</u></b>						
F	Stage light wiring insulation	Unquantified	LF	Assumed	Auditorium-Stage light wiring, upper level lighting (material can only be viewing from above the stage/catwalk)	O&M
G	Stage fire curtain-off white	Unquantified	Unit(s)	Assumed	Auditorium stage	O&M
H	Fire rated doors	4	Unit(s)	Assumed	Auditorium above the stage	O&M
I	Vinyl Stair treads	Unquantified	SF	Assumed	Stairs to upper level - catwalk for auditorium	O&M
J	Stair tread mastic	Unquantified	SF	Assumed	Stairs to upper level - catwalk for auditorium	O&M

Greater Clark County School Corporation

Remaining Materials Report

1/14/2020

HA ID	HA Description	Quantity		Asbestos	HA Location	Planned Response Action
<b><u>Charlestown Senior High School</u></b>						
F	Stage light wiring insulation	Unquantified	LF	Assumed	Auditorium-Stage light wiring, upper level lighting (material can only be viewing from above the stage/catwalk)	O&M
G	Stage fire curtain-off white	Unquantified	Unit(s)	Assumed	Auditorium stage	O&M
H	Fire rated doors	4	Unit(s)	Assumed	Auditorium above the stage	O&M
I	Vinyl Stair treads	Unquantified	SF	Assumed	Stairs to upper level - catwalk for auditorium	O&M
J	Stair tread mastic	Unquantified	SF	Assumed	Stairs to upper level - catwalk for auditorium	O&M

**Greater Clark County School Corporation**

**Remaining Materials Report**

**5/16/2019**

HA ID	HA Description	Quantity		Asbestos	HA Location	Planned Response Action
<b><u>Charlestown Senior High School</u></b>						
F	Stage light wiring insulation	Unquantified	LF	Assumed	Auditorium-Stage light wiring, upper level lighting (material can only be viewing from above the stage/catwalk)	O&M
G	Stage fire curtain-off white	Unquantified	Unit(s)	Assumed	Auditorium stage	O&M
H	Fire rated doors	4	Unit(s)	Assumed	Auditorium above the stage	O&M
I	Vinyl Stair treads	Unquantified	SF	Assumed	Stairs to upper level - catwalk for auditorium	O&M
J	Stair tread mastic	Unquantified	SF	Assumed	Stairs to upper level - catwalk for auditorium	O&M

Greater Clark County School Corporation

Remaining Materials Report

11/14/2018

HA ID	HA Description	Quantity		Asbestos	HA Location	Planned Response Action
<b><u>Charlestown Senior High School</u></b>						
F	Stage light wiring insulation	Unquantified	LF	Assumed	Auditorium-Stage light wiring, upper level lighting (material can only be viewing from above the stage/catwalk)	O&M
G	Stage fire curtain-off white	Unquantified	Unit(s)	Assumed	Auditorium stage	O&M
H	Fire rated doors	4	Unit(s)	Assumed	Auditorium above the stage	O&M
I	Vinyl Stair treads	Unquantified	SF	Assumed	Stairs to upper level - catwalk for auditorium	O&M
J	Stair tread mastic	Unquantified	SF	Assumed	Stairs to upper level - catwalk for auditorium	O&M

Greater Clark County School Corporation

Remaining Materials Report

5/2/2018

HA ID	HA Description	Quantity		Asbestos	HA Location	Planned Response Action
<b><u>Charlestown Senior High School</u></b>						
F	Stage light wiring insulation	Unquantified	LF	Assumed	Auditorium-Stage light wiring, upper level lighting (material can only be viewing from above the stage/catwalk)	O&M
G	Stage fire curtain-off white	Unquantified	Unit(s)	Assumed	Auditorium stage	O&M
H	Fire rated doors	4	Unit(s)	Assumed	Auditorium above the stage	O&M
I	Vinyl Stair treads	Unquantified	SF	Assumed	Stairs to upper level - catwalk for auditorium	O&M
J	Stair tread mastic	Unquantified	SF	Assumed	Stairs to upper level - catwalk for auditorium	O&M

Greater Clark County School Corporation

Remaining Materials Report

10/18/2017

HA ID	HA Description	Quantity		Asbestos	HA Location	Planned Response Action
<b><u>Charlestown Senior High School</u></b>						
F	Stage light wiring insulation	Unquantified	LF	Assumed	Auditorium-Stage light wiring, upper level lighting (material can only be viewing from above the stage/catwalk)	O&M
G	Stage fire curtain-off white	Unquantified	Unit(s)	Assumed	Auditorium stage	O&M
H	Fire rated doors	4	Unit(s)	Assumed	Auditorium above the stage	O&M
I	Vinyl Stair treads	Unquantified	SF	Assumed	Stairs to upper level - catwalk for auditorium	O&M
J	Stair tread mastic	Unquantified	SF	Assumed	Stairs to upper level - catwalk for auditorium	O&M



Greater Clark County School Corporation

Remaining Materials Report

4/13/2017

HA ID	HA Description	Quantity		Asbestos	HA Location	Planned Response Action
<b><u>Charlestown Senior High School</u></b>						
F	Stage light wiring insulation	Unquantified	LF	Assumed	Auditorium-Stage light wiring, upper level lighting (material can only be viewing from above the stage/catwalk)	O&M
G	Stage fire curtain-off white	Unquantified	Unit(s)	Assumed	Auditorium stage	O&M
H	Fire rated doors	4	Unit(s)	Assumed	Auditorium above the stage	O&M
I	Vinyl Stair treads	Unquantified	SF	Assumed	Stairs to upper level - catwalk for auditorium	O&M
J	Stair tread mastic	Unquantified	SF	Assumed	Stairs to upper level - catwalk for auditorium	O&M

**Greater Clark County School Corporation**

**Remaining Materials Report**

**11/3/2016**

HA ID	HA Description	Quantity		Asbestos	HA Location	Planned Response Action
<b><u>Charlestown Senior High School</u></b>						
F	Stage light wiring insulation	Unquantified	LF	Assumed	Auditorium-Stage light wiring, upper level lighting (material can only be viewing from above the stage/catwalk)	O&M
G	Stage fire curtain-off white	Unquantified	Unit(s)	Assumed	Auditorium stage	O&M
H	Fire rated doors	4	Unit(s)	Assumed	Auditorium above the stage	O&M
I	Vinyl Stair treads	Unquantified	SF	Assumed	Stairs to upper level - catwalk for auditorium	O&M
J	Stair tread mastic	Unquantified	SF	Assumed	Stairs to upper level - catwalk for auditorium	O&M

**Greater Clark County School Corporation**

**Remaining Materials Report**

**4/28/2016**

HA ID	HA Description	Quantity		Asbestos	HA Location	Planned Response Action
<b><u>Charlestown Senior High School</u></b>						
F	Stage light wiring insulation	Unquantified	LF	Assumed	Auditorium-Stage light wiring, upper level lighting (material can only be viewing from above the stage/catwalk)	O&M
G	Stage fire curtain-off white	Unquantified	Unit(s)	Assumed	Auditorium stage	O&M
H	Fire rated doors	4	Unit(s)	Assumed	Auditorium above the stage	O&M
I	Vinyl Stair treads	Unquantified	SF	Assumed	Stairs to upper level - catwalk for auditorium	O&M
J	Stair tread mastic	Unquantified	SF	Assumed	Stairs to upper level - catwalk for auditorium	O&M

Greater Clark County School Corporation

Remaining Materials Report

10/20/2015

HA ID	HA Description	Quantity		Asbestos	HA Location	Planned Response Action
<b><u>Charlestown Senior High School</u></b>						
F	Stage light wiring insulation	Unquantified	LF	Assumed	Auditorium-Stage light wiring, upper level lighting (material can only be viewing from above the stage/catwalk)	O&M
G	Stage fire curtain-off white	Unquantified	Unit(s)	Assumed	Auditorium stage	O&M
H	Fire rated doors	4	Unit(s)	Assumed	Auditorium above the stage	O&M
I	Vinyl Stair treads	Unquantified	SF	Assumed	Stairs to upper level - catwalk for auditorium	O&M
J	Stair tread mastic	Unquantified	SF	Assumed	Stairs to upper level - catwalk for auditorium	O&M

**Greater Clark County Schools**  
**Remaining Materials Report**  
**April 22, 2015**

HA#	Material	Quantity	ACBM Y/A	Location	Planned Activities
<b><u>Charlestown Senior High School</u></b>					
F	Stage light wiring insulation	Unquantified LF	A	Auditorium-Stage light wiring, upper level lighting (material can only be viewing from above the stage/catwalk)	O & M
G	Stage fire curtain-off white	Unquantified Eac	A	Auditorium Stage	O & M
H	Fire rated doors	Each 4	A	Auditorium above the stage	O & M
I	Vinyl Stair treads	Unquantified SF	A	Stairs to upper level - catwalk for auditorium	O & M
J	Stair tread mastic	Unquantified SF	A	Stairs to upper level catwalk for auditorium.	O & M

**Greater Clark County Schools  
Remaining Materials Report  
October 22, 2014**

HA#	Material	Quantity	ACBM Y/A	Location	Planned Activities
<b><u>Charlestown Senior High School</u></b>					
F	Stage light wiring insulation	Unquantified LF	A	Auditorium-Stage light wiring, upper level lighting (material can only be viewing from above the stage/catwalk)	O & M
G	Stage fire curtain-off white	Unquantified Eac	A	Auditorium Stage	O & M
H	Fire rated doors	Each 4	A	Auditorium above the stage	O & M
I	Vinyl Stair treads	Unquantified SF	A	Stairs to upper level - catwalk for auditorium	O & M
J	Stair tread mastic	Unquantified SF	A	Stairs to upper level catwalk for auditorium.	O & M

**Greater Clark County Schools**  
**Remaining Materials Report**  
**April 21, 2014**

HA#	Material	Quantity	ACBM Y/A	Location	Planned Activities
<b><u>Charlestown Senior High School</u></b>					
F	Stage light wiring insulation	Unquantified LF	A	Auditorium-Stage light wiring, upper level lighting (material can only be viewing from above the stage/catwalk)	O & M
G	Stage fire curtain-off white	Unquantified Eac	A	Auditorium Stage	O & M
H	Fire rated doors	Each 4	A	Auditorium above the stage	O & M
I	Vinyl Stair treads	Unquantified SF	A	Stairs to upper level - catwalk for auditorium	O & M
J	Stair tread mastic	Unquantified SF	A	Stairs to upper level catwalk for auditorium.	O & M

**Greater Clark County Schools  
Remaining Materials Report  
October 24, 2013**

HA#	Material	Quantity	ACBM Y/A	Location	Planned Activities
<b><u>Charlestown Senior High School</u></b>					
F	Stage light wiring insulation	Unquantified LF	A	Auditorium-Stage light wiring, upper level lighting (material can only be viewing from above the stage/catwalk)	O & M
G	Stage fire curtain-off white	Unquantified Eac	A	Auditorium Stage	O & M
H	Fire rated doors	Each 4	A	Auditorium above the stage	O & M
I	Vinyl Stair treads	Unquantified SF	A	Stairs to upper level - catwalk for auditorium	O & M
J	Stair tread mastic	Unquantified SF	A	Stairs to upper level catwalk for auditorium.	O & M



**Greater Clark County Schools  
Remaining Materials Report  
April 24, 2013**

HA#	Material	Quantity	ACBM Y/A	Location	Planned Activities
<b><u>Charlestown Senior High School</u></b>					
F	Stage light wiring insulation	Unquantified LF	A	Auditorium-Stage light wiring, upper level lighting (material can only be viewing from above the stage/catwalk)	O & M
G	Stage fire curtain-off white	Unquantified Eac	A	Auditorium Stage	O & M
H	Fire rated doors	Each 4	A	Auditorium above the stage	O & M
I	Vinyl Stair treads	Unquantified SF	A	Stairs to upper level - catwalk for auditorium	O & M
J	Stair tread mastic	Unquantified SF	A	Stairs to upper level catwalk for auditorium.	O & M

**Greater Clark County Schools  
Remaining Materials Report  
October 24, 2012**

HA#	Material	Quantity	ACBM Y/A	Location	Planned Activities
<b><u>Charlestown Senior High School</u></b>					
F	Stage light wiring insulation	Unquantified LF	A	Auditorium-Stage light wiring, upper level lighting (material can only be viewing from above the stage/catwalk)	O & M
G	Stage fire curtain-off white	Unquantified Eac	A	Auditorium Stage	O & M
H	Fire rated doors	Each 4	A	Auditorium above the stage	O & M
I	Vinyl Stair treads	Unquantified SF	A	Stairs to upper level - catwalk for auditorium	O & M
J	Stair tread mastic	Unquantified SF	A	Stairs to upper level catwalk for auditorium.	O & M

**Greater Clark County Schools  
Remaining Materials Report  
June 25, 2012**

HA#	Material	Quantity	ACBM Y/A	Location	Planned Activities
<b><u>Charlestown Senior High School</u></b>					
F	Stage light wiring insulation	Unquantified LF	A	Auditorium-Stage light wiring, upper level lighting (material can only be viewing from above the stage/catwalk)	O & M
G	Stage fire curtain-off white	Unquantified Eac	A	Auditorium Stage	O & M
H	Fire rated doors	Each 4	A	Auditorium above the stage	O & M
I	Vinyl Stair treads	Unquantified SF	A	Stairs to upper level - catwalk for auditorium	O & M
J	Stair tread mastic	Unquantified SF	A	Stairs to upper level catwalk for auditorium.	O & M

**Greater Clark County Schools  
Remaining Materials Report  
December 15, 2011**

HA#	Material	Quantity	ACBM Y/A	Location	Planned Activities
<b><u>Charlestown Senior High School</u></b>					
F	Stage light wiring insulation	Unquantified LF	A	Auditorium-Stage light wiring, upper level lighting (material can only be viewing from above the stage/catwalk)	O & M
G	Stage fire curtain-off white	Unquantified Eac	A	Auditorium Stage	O & M
H	Fire rated doors	Each 4	A	Auditorium above the stage	O & M
I	Vinyl Stair treads	Unquantified SF	A	Stairs to upper level - catwalk for auditorium	O & M
J	Stair tread mastic	Unquantified SF	A	Stairs to upper level catwalk for auditorium.	O & M

**Greater Clark County Schools  
Remaining Materials Report  
June 27, 2011**

HA#	Material	Quantity	ACBM Y/A	Location	Planned Activities
<b><u>Charlestown Senior High School</u></b>					
F	Stage light wiring insulation	Unquantified LF	A	Auditorium-Stage light wiring, upper level lighting (material can only be viewing from above the stage/catwalk)	O & M
G	Stage fire curtain-off white	Unquantified Eac	A	Auditorium Stage	O & M
H	Fire rated doors	Each 4	A	Auditorium above the stage	O & M
I	Vinyl Stair treads	Unquantified SF	A	Staris to upper level - catwalk for auditorium	O & M
J	Stair tread mastic	Unquantified SF	A	Stairs to upper level catwalk for auditorium.	O & M

**Greater Clark County Schools  
Remaining Materials Report  
December 6, 2010**

HA#	Material	Quantity	ACBM Y/A	Location	Planned Activities
-----	----------	----------	----------	----------	--------------------

**Charlestown Senior High School**

03	Pipe insulation - on pipes buried underneath the tunnels and outside the tunnel walls	Unquantified LF	Y	Tunnel exterior	O & M
----	---	-----------------	---	-----------------	-------

Greater Clark County Schools  
Remaining Materials Report  
June 30, 2010

HA#	Material	Quantity	ACBM Y/A	Location	Planned Activities
<b><u>Charlestown Senior High School</u></b>					
03	Pipe insulation - on pipes buried underneath the tunnels and outside the tunnel walls	Unquantified LF	Y	Tunnel exterior	O & M

**Greater Clark County Schools  
Remaining Materials Report  
December 7, 2009**

HA#	Material	Quantity	ACBM Y/A	Location	Planned Activities
<b><u>Charlestown Senior High School</u></b>					
03	Pipe insulation (heat)	3,978 LF	Y	Tunnels and boiler room	O & M
04	Stack insulation (breeching)	600 SF	Y	Boiler room	O & M
06	Fittings	293 Eac	Y	Throughout the building	O & M
A	Aggregate covered transite panels	Unquantified SF	A	Building exterior	O & M



**Greater Clark County Schools  
Remaining Materials Report  
June 11, 2009**

HA#	Material	Quantity	ACBM Y/A	Location	Planned Activities
<b><u>Charlestown Senior High School</u></b>					
03	Pipe insulation (heat)	3,978 LF	Y	Tunnels and boiler room	O & M
04	Stack insulation (breeching)	600 SF	Y	Boiler room	O & M
06	Fittings	293 Eac	Y	Throughout the building	O & M
A	Aggregate covered transite panels	Unquantified SF	A	Building exterior	O & M

**Greater Clark County Schools  
Remaining Materials Report  
December 10, 2008**

HA#	Material	Quantity	ACBM Y/A	Location	Planned Activities
<b><u>Charlestown Senior High School</u></b>					
03	Pipe insulation (heat)	3,978 LF	Y	Tunnels and boiler room	O & M
04	Stack insulation (breeching)	600 SF	Y	Boiler room	O & M
06	Fittings	293 Eac	Y	Throughout the building	O & M
A	Aggregate covered transite panels	Unquantified SF	A	Building exterior	O & M

**Greater Clark County Schools  
Remaining Materials Report  
June 30, 2008**

HA#	Material	Quantity	ACBM Y/A	Location	Planned Activities
<b><u>Charlestown Senior High School</u></b>					
03	Pipe insulation (heat)	3,978 LF	Y	Tunnels and boiler room	O & M
04	Stack insulation (breeching)	600 SF	Y	Boiler room	O & M
06	Fittings	293 Eac	Y	Throughout the building	O & M
A	Aggregate covered transite panels	Unquantified SF	A	Building exterior	O & M

**Greater Clark County Schools  
Remaining Materials Report  
December 14, 2007**

HA#	Material	Quantity	ACBM Y/A	Location	Planned Activities
<b><u>Charlestown Senior High School</u></b>					
03	Pipe insulation (heat)	3,978 LF	Y	Tunnels and boiler room	O & M
04	Stack insulation (breeching)	600 SF	Y	Boiler room	O & M
06	Fittings	293 Eac	Y	Throughout the building	O & M
A	Aggregate covered transite panels	Unquantified SF	A	Building exterior	O & M

**Greater Clark County Schools  
Remaining Materials Report  
July 9, 2007**

<b>HA#</b>	<b>Material</b>	<b>Quantity</b>	<b>ACBM Y/A</b>	<b>Location</b>	<b>Planned Activities</b>
<b><u>Charlestown Senior High School</u></b>					
03	Pipe insulation (heat)	3,978 LF	Y	Tunnels and boiler room	O & M
04	Stack insulation (breeching)	600 SF	Y	Boiler room	O & M
06	Fittings	293 Eac	Y	Throughout the building	O & M
A	Aggregate covered transite panels	Unquantified SF	A	Building exterior	O & M

**Greater Clark County Schools  
Remaining Materials Report  
December 18, 2006**

HA#	Material	Quantity	ACBM Y/A	Location	Planned Activities
<b><u>Charlestown Senior High School</u></b>					
03	Pipe insulation (heat)	3,978 LF	Y	Tunnels and boiler room	O & M
04	Stack insulation (breeching)	600 SF	Y	Boiler room	O & M
06	Fittings	293 Eac	Y	Throughout the building	O & M
A	Aggregate covered transite panels	Unquantified SF	A	Building exterior	O & M

**Greater Clark County Schools  
Remaining Materials Report  
June 28, 2006**

HA#	Material	Quantity	ACBM Y/A	Location	Planned Activities
<b><u>Charlestown Senior High School</u></b>					
03	Pipe insulation (heat)	3,978 LF	Y	Tunnels and boiler room	O & M
04	Stack insulation (breaching)	600 SF	Y	Boiler room	O & M
06	Fittings	293 Eac	Y	Throughout the building	O & M
A	Aggregate covered transite panels	Unquantified SF	A	Building exterior	O & M

**Greater Clark County Schools  
Remaining Materials Report  
January 25, 2006**

HA#	Material	Quantity	ACBM Y/A	Location	Planned Activities
<b><u>Charlestown Senior High School</u></b>					
03	Pipe insulation (heat)	3,978 LF	Y	Tunnels and boiler room	O & M
04	Stack insulation (breeching)	600 SF	Y	Boiler room	O & M
06	Fittings	293 Eac	Y	Throughout the building	O & M
A	Aggregate covered transite panels	Unquantified SF	A	Building exterior	O & M



Greater Clark County Schools

Remaining Materials Report

July 19, 2005

HA#	Material	Quantity	Location	Planned Activities
<b><u>Charlestown Senior High School</u></b>				
03	Pipe insulation (heat)	3,978 LF	Tunnels and boiler room	O & M
04	Stack insulation (breeching)	600 SF	Boiler room	O & M
05	Air cell pipe insulation	250 LF	Along west wall in boiler room	O & M
06	Fittings	293 Eac	Throughout the building	O & M
A	Aggregate covered transite panels	Unquantified SF	Building exterior	O & M

Greater Clark County Schools  
Remaining Materials Report  
December 9, 2004

HA#	Material	Quantity	ACBM Y/A	Location	Planned Activities
<b><u>Charlestown Senior High School</u></b>					
01	Water tank cover	225 SF	Y	Boiler room	O & M
03	Pipe insulation (heat)	3,978 LF	Y	Tunnels and boiler room	O & M
04	Stack insulation (breeching)	600 SF	Y	Boiler room	O & M
05	Air cell pipe insulation	250 LF	Y	Along west wall in boiler room	O & M
06	Fittings	293 Each	Y	Throughout the building	O & M

**Greater Clark County Schools  
Remaining Materials Report  
July 2, 2004**

HA#	Material	Quantity	ACBM Y/A	Location	Planned Activities
<b><u>Charlestown Senior High School</u></b>					
01	Water tank cover	225 SF	Y	Boiler room	O & M
03	Pipe insulation (heat)	3,978 LF	Y	Tunnels and boiler room	O & M
04	Stack insulation (breeching)	600 SF	Y	Boiler room	O & M
05	Air cell pipe insulation	250 LF	Y	Along west wall in boiler room	O & M
06	Fittings	293 Each	Y	Throughout the building	O & M

**Greater Clark County Schools  
Remaining Materials Report  
December 9, 2003**

HA#	Material	Quantity	ACBM	Y/A	Location	Planned Activities
<b><u>Charlestown Senior High School</u></b>						
01	Water tank cover	225 SF	Y		Boiler room	O & M
03	Pipe insulation (heat)	3,978 LF	Y		Tunnels and boiler room	O & M
04	Stack insulation (breeching)	600 SF	Y		Boiler room	O & M
05	Air cell pipe insulation	250 LF	Y		Along west wall in boiler room	O & M
06	Fittings	293 Each	Y		Throughout the building	O & M

**Greater Clark County Schools  
Remaining Materials Report  
June 13, 2003**

HA#	Material	Quantity	ACBM Y/A	Location	Planned Activities
<b><u>Charlestown Senior High School</u></b>					
01	Water tank cover	225 SF	Y	Boiler room	O & M
03	Pipe insulation (heat)	3,978 LF	Y	Tunnels and boiler room	O & M
04	Stack insulation (breeching)	600 SF	Y	Boiler room	O & M
05	Air cell pipe insulation	250 LF	Y	Along west wall in boiler room	O & M
06	Fittings	293 Each	Y	Throughout the building	O & M
C	Transite board with stone texturing	Unquantified SF	A	Exterior facia board	O & M

**Greater Clark County Schools  
Remaining Materials Report  
December 18, 2003**

HA#	Material	Quantity	ACBM Y/A	Location	Planned Activities
<b><u>Charlestown Senior High School</u></b>					
01	Water tank cover	225 SF	Y	Boiler room	O & M
03	Pipe insulation (heat)	3,978 LF	Y	Tunnels and boiler room	O & M
04	Stack insulation (breeching)	600 SF	Y	Boiler room	O & M
05	Air cell pipe insulation	250 LF	Y	Along west wall in boiler room	O & M
06	Fittings	293 Each	Y	Throughout the building	O & M
C	Transite board with stone texturing	Unquantified SF	A	Exterior facia board	O & M
D	Panels, slats, and fill material	Unquantified SF	Y	Cooling tower	O & M

**Greater Clark County Schools  
Remaining Materials Report  
June 19, 2002**

HA#	Material	Quantity	ACBM Y/A	Location	Planned Activities
<b><u>Charlestown Senior High School</u></b>					
01	Water tank cover	225 SF	Y	Boiler room	O & M
03	Pipe insulation (heat)	3,978 LF	Y	Tunnels and boiler room	O & M
04	Stack insulation (breeching)	600 SF	Y	Boiler room	O & M
05	Air cell pipe insulation	250 LF	Y	Along wall in boiler room	O & M
06	Fittings	293 Each	Y	Throughout the building	O & M
C	Transite board with stone texturing	Unquantified SF	A	Exterior facia board	O & M

Greater Clark County Schools  
Remaining Materials Report  
December 12, 2001

HA#	Material	Quantity	ACBM Y/A	Location	Planned Activities
<b><u>Charlestown Senior High School</u></b>					
01	Water tank cover	225 SF	Y	Boiler room	O & M
03	Pipe insulation (heat)	3,978 LF	Y	Tunnels and boiler room	O & M
04	Stack insulation (breaching)	600 SF	Y	Boiler room	O & M
05	Air cell pipe insulation	250 LF	Y	Along wall in boiler room	O & M
06	Fittings	293 Each	Y	Throughout the building	O & M
C	Transite board with stone texturing	Unquantified SF	A	Exterior facia board	O & M



**Greater Clark County Schools  
Remaining Materials Report  
July 12, 2001**

HA#	Material	Quantity	ACBM Y/A	Location	Planned Activities
<b><u>Charlestown Senior High School</u></b>					
01	Water tank cover	225 SF	Y	Boiler room	O & M
03	Pipe insulation (heat)	3,978 LF	Y	Tunnels and boiler room	O & M
04	Stack insulation (breeching)	600 SF	Y	Boiler room	O & M
05	Air cell pipe insulation	250 LF	Y	Along wall in boiler room	O & M
06	Fittings	293 Each	Y	Throughout the building	O & M
C	Transite board with stone texturing	Unquantified SF	A	Exterior facia board	O & M

Greater Clark County Schools  
 Remaining Materials Report  
 January 11, 2001

HA#	Material	Quantity	ACBM Y/A	Location	Planned Activities
<u>Charlestown Senior High School</u>					
01	Water tank cover	225 SF	Y	Boiler room	O & M
03	Pipe insulation (heat)	3,978 LF	Y	Tunnels and boiler room	O & M
04	Stack insulation (breeching)	600 SF	Y	Boiler room	O & M
05	Air cell pipe insulation	250 LF	Y	Along wall in boiler room	O & M
06	Fittings	293 Each	Y	Throughout the building	O & M
C	Transite board with stone texturing	Unquantified SF	A	Exterior facia board	O & M

Greater Clark County Schools  
Remaining Materials Report  
June 29, 2000

HA#	Material	Quantity	ACBM Y/A	Location	Planned Activities
<b><u>Charlestown Senior High School</u></b>					
01	Water Tank Cover	225 SF	Y	Boiler Room	O & M
03	Pipe Insulation (Heat)	3978 LF	Y	Tunnels and boiler room	O & M
04	Stack Insulation (Breeching)	600 SF	Y	Boiler Room	O & M
05	Air Cell Pipe Insulation	250 LF	Y	Along Wall in Boiler Room	O & M
06	Fittings	293 Each	Y	Throughout building	O & M

Greater Clark County Schools  
Remaining Materials Report  
February 23, 2000

HA#	Material	Quantity	ACBM Y/A	Location	Planned Activities
<b><u>Charlestown Senior High School</u></b>					
01	Water Tank Cover	225 SF	Y	Boiler Room	O & M
03	Pipe Insulation (Heat)	3978 LF	Y	Tunnels and boiler room	O & M
04	Stack Insulation (Breeching)	600 SF	Y	Boiler Room	O & M
05	Air Cell Pipe Insulation	250 LF	Y	Along Wall in Boiler Room	O & M
06	Fittings	293 Each	Y	Throughout building	O & M

**Greater Clark County Schools  
Remaining Materials Report  
July 6, 1999**

HA#	Material	Quantity	ACBM Y/A	Location	Planned Activities
<b><u>Charlestown Senior High School</u></b>					
01	Water Tank Cover	225 SF	Y	Boiler Room	O & M
03	Pipe Insulation (Heat)	3978 LF	Y	Tunnels and boiler room	O & M
04	Stack Insulation (Breeching)	600 SF	Y	Boiler Room	O & M
05	Air Cell Pipe Insulation	250 LF	Y	Along Wall in Boiler Room	O & M
06	Fittings	293 Each	Y	Throughout building	O & M

*PERIODIC SURVEILLANCE  
REINSPECTION  
ADDITIONAL BULK SAMPLING  
INFORMATION*

## ASSESSMENTS FOR AHERA

1. Damaged or significantly damaged thermal systems insulation.
2. Damaged friable surfacing ACM.
3. Significantly damaged friable surfacing ACM.
4. Damaged or significantly damaged friable miscellaneous ACM.
5. ACBM with potential for damage.
6. ACBM with potential for significant damage.
7. Any remaining friable ACBM or friable suspected ACBM.

If a material is non-friable, it does not require an assessment rating under AHERA.

Due to the differences in what is required of the LEA for damaged material compared to significantly damaged material, Alliance has modified the assessment scale to the following:

- 1A. Significantly damaged thermal systems insulation.
- 1B. Damaged thermal systems insulation.
- 4A. Significantly damaged friable miscellaneous ACM.
- 4B. Damaged friable miscellaneous ACM.

*PERIODIC SURVEILLANCES*



# SURVEILLANCE INFORMATION

## PERIODIC SURVEILLANCE PLAN

### GREATER CLARK COUNTY SCHOOLS

The ACBM in this building will be periodically inspected to determine any change in the condition of the materials for as long as the material remain in the building, as required by the Asbestos Hazard Emergency Response Act (AHERA). This periodic surveillance shall be conducted on a semi-annual basis as required by law.

Records of each re-inspection will be maintained in this binder.

DATE PLANNED	DATE COMPLETED	COMPLETED BY
<u>October 2014</u>	October 22, 2014	
<u>April 2015</u>	April 22, 2015	
<u>October 2015</u>	October 20, 2016	
<u>April 2016</u>	RE-INSPECTION	
<u>October 2016</u>	November 3, 2016	
<u>April 2017</u>	April 13, 2017	
<u>October 2017</u>	October 18, 2017	
<u>April 2018</u>	May 2, 2018	
<u>October 2018</u>	November 13, 2018	
<u>April 2019</u>	RE-INSPECTION	
<u>October 2019</u>	January 14, 2020	
<u>April 2020</u>	April 23, 2020	
<u>October 2020</u>		

# **SURVEILLANCE INFORMATION**

## **PERIODIC SURVEILLANCE PLAN**

### **GREATER CLARK COUNTY SCHOOLS**

The ACBM in this building will be periodically inspected to determine any change in the condition of the materials for as long as the material remain in the building, as required by the Asbestos Hazard Emergency Response Act (AHERA). This periodic surveillance shall be conducted on a semi-annual basis as required by law.

Records of each re-inspection will be maintained in this binder.

<u>April 2021</u>	_____	_____
<u>October 2021</u>	_____	_____
<u>April 2022</u>	RE-INSPECTION	_____
<u>October 2022</u>	_____	_____
<u>April 2023</u>	_____	_____
<u>October 2023</u>	_____	_____
<u>April 2024</u>	_____	_____
<u>October 2024</u>	_____	_____
<u>April 2025</u>	RE-INSPECTION	_____
<u>October 2025</u>	_____	_____
<u>April 2026</u>	_____	_____
<u>October 2026</u>	_____	_____

## SURVEILLANCE INFORMATION

### PERIODIC SURVEILLANCE PLAN SCHEDULE

#### GREATER CLARK COUNTY SCHOOLS

The ACBM in this building will be periodically inspected to determine any change in the condition of the materials for as long as the material remain in the building, as required by the Asbestos Hazard Emergency Response Act (AHERA). This periodic surveillance shall be conducted on a semi-annual basis as required by law.

Records of each re-inspection will be maintained in this binder.

<u>DATE PLANNED</u>	<u>DATE COMPLETED</u>	<u>COMPLETED BY</u>
<u>JUNE 2009</u>	<u>JUNE 2009</u>	<u>Bill Ogle</u>
<u>DECEMBER 2009</u>	<u>December 2009</u>	<u>Bill Ogle</u>
<u>JUNE 2010</u>	<u>Reinspection</u>	<u>Sandy Shadley</u>
<u>DECEMBER 2010</u>	<u>December 2010</u>	<u>Paul Krick</u>
<u>JUNE 2011</u>	<u>June 2011</u>	<u>Sandy Shadley</u>
<u>DECEMBER 2011</u>	<u>December 2011</u>	<u>Sandy Shadley</u>
<u>JUNE 2012</u>	<u>June 2012</u>	<u>Jeff Hechtin</u>
<u>DECEMBER 2012</u>	<u>October 2012</u>	<u>Jeff Hechtin</u>
<u>JUNE 2013</u>	<u>Reinspection</u>	<u>Jeff Hechtin</u>
<u>DECEMBER 2013</u>	<u>                    </u>	<u>                    </u>

## PERIODIC SURVEILLANCE PLAN

## GREATER CLARK COUNTY SCHOOLS

The ACBM in this building will be periodically inspected to determine any change in the condition of the materials for as long as the material remain in the building, as required by the Asbestos Hazard Emergency Response Act (AHERA). This periodic surveillance shall be conducted on a semi-annual basis as required by law.

Records of each reinspection will be maintained in this binder.

<u>DATE PLANNED</u>	<u>DATE COMPLETED</u>	<u>COMPLETED BY</u>
<u>JUNE 2003</u>	<u>June '03</u>	<u>C. Sparks</u>
<u>DECEMBER 2003</u>	<u>Dec. '03</u>	<u>C. Sparks</u>
<u>JUNE 2004</u>	<u>REINSPECTION</u>	<u>C. Sparks</u>
<u>DECEMBER 2004</u>	<u>Dec. '04</u>	<u>C. Sparks</u>
<u>JUNE 2005</u>	<u>July '05</u>	<u>J. Ogle</u>
<u>DECEMBER 2005</u>	<u>Jan 06</u>	<u>Boyle</u>
<u>JUNE 2006</u>	<u>June 06</u>	<u>C. Amos</u>
<u>DECEMBER 2006</u>	<u>Dec 06</u>	<u>Boyle</u>
<u>JUNE 2007</u>	<u>July 2007</u> <u>REINSPECTION</u>	<u>Bill Ogle</u>
<u>DECEMBER 2007</u>	<u>December 2007</u>	<u>Bill Ogle</u>
<u>JUNE 2008</u>	<u>June 2008</u>	<u>Bill Ogle</u>
<u>DECEMBER 2008</u>	<u>December 2008</u>	<u>Bill Ogle</u>

**PERIODIC SURVEILLANCE PLAN****GREATER CLARK COUNTY SCHOOLS****CHARLESTOWN HIGH SCHOOL**

The ACBM in this building will be periodically inspected to determine any change in the condition of the materials for as long they remain in the building. This inspection will be conducted semi-annually.

The following table outlines the dates on which these inspections should take place in this school building.

**PERIODIC SURVEILLANCE SCHEDULE**

<u>DATE PLANNED</u>	<u>DATE COMPLETED</u>	<u>COMPLETED BY</u>
<u>DECEMBER 1995</u>	<u>12-95</u>	<u>Alliance</u>
<u>JUNE 1996</u>	<u>6-96</u>	<u>Alliance</u>
<u>DECEMBER 1996</u>	<u>12-96</u>	<u>Alliance</u>
<u>JUNE 1997</u>	<u>7-97</u>	<u>Alliance</u>
<u>DECEMBER 1997</u>	<u>1-98</u>	<u>Alliance</u>
<u>JUNE 1998</u>	<u>REINSPECTION</u>	<u>Alliance</u>
<u>DECEMBER 1998</u>	<u>12-98</u>	<u>Alliance</u>
<u>JUNE 1999</u>	<u>June '99</u>	<u>Alliance</u>
<u>DECEMBER 1999</u>	<u>Dec. '99</u>	<u>Alliance</u>
<u>JUNE 2000</u>	<u>June 2000</u>	<u>Alliance</u>
<u>DECEMBER 2000</u>	<u>Jan. '01</u>	<u>Pat Wilson</u>
<u>JUNE 2001</u>	<u>REINSPECTION</u>	<u>P. Wilson</u>
<u>DECEMBER 2001</u>	<u>Dec. '01</u>	<u>A. Kimbrough</u>
<u>JUNE 2002</u>	<u>June '02</u>	<u>R. Calvert</u>
<u>DECEMBER 2002</u>	<u>Dec. '02</u>	<u>C. Sparks</u>

# Periodic Surveillance

**LEA Name** Greater Clark County School Corporation  
**Building Name** Charlestown Senior High School  
**Building Number** 08  
**HA ID** F  
**HA Description** Stage light wiring insulation  
**HA Type** Miscellaneous Material  
**HA Location** Auditorium-Stage light wiring, upper level lighting (material can only be viewing from above the stage/catwalk)  
**Quantity** Unquantified LF  
**Comments** This material was noted by the inspector during the 12/06/2010 and will remaining in the managment plan until properly sampled. Lights all appear to be out of service/disconnected. Some are laying on the landing floor.  
**Asbestos** Assumed  
**Friable** Yes  
**Original Inspection** 12/6/2010  
**Current Inspection** 4/23/2020

## Material Assessment

**Assessment Rating** 5 ACBM with potential for damage

## Damage Assessment and Potential for Damage

**Percent Damaged** % Good Condition

**Physical Contact**

Low/None

**Vibration**

Low/None

**Air**

Low/None

**Planned Response Action** O&M

**Inspector**



Michael J. Ardis

**State** IN

**Accreditation Number** 19A007304



# Periodic Surveillance

**LEA Name** Greater Clark County School Corporation

**Building Name** Charlestown Senior High School

**Building Number** 08

**HA ID** G

**HA Description** Stage fire curtain-off white

**HA Type** Miscellaneous Material

**HA Location** Auditorium stage

**Quantity** Unquantified Unit(s)

**Comments** This was noted by the inspector during the 12/06/2010 as suspect ACM therefore it will remain in the management plan for informational purposes. Only Building materials are required to be in the AHERA Management Plan.

**Asbestos** Assumed

**Friable** No

**Original Inspection** 12/6/2010

**Current Inspection** 4/23/2020

## Material Assessment

**Assessment Rating** 5 ACBM with potential for damage

## Damage Assessment and Potential for Damage

**Percent Damaged** % Good Condition

**Physical Contact**

Low/None

**Vibration**

Low/None

**Air**

Low/None

**Planned Response Action** O&M

**Inspector**



Michael J. Ardis



**State** IN

**Accreditation Number** 19A007304

# Periodic Surveillance

**LEA Name** Greater Clark County School Corporation  
**Building Name** Charlestown Senior High School  
**Building Number** 08  
**HA ID** H  
**HA Description** Fire rated doors  
**HA Type** Miscellaneous Material  
**HA Location** Auditorium above the stage

**Quantity** 4 Unit(s)  
**Comments** The inspector noted these during the 12/06/2010 inspection as suspect ACM.  
They will remain in the management plan until properly sampled.  
**Asbestos** Assumed  
**Friable** No  
**Original Inspection** 12/6/2010  
**Current Inspection** 4/23/2020

## Material Assessment

**Assessment Rating** 5 ACBM with potential for damage

## Damage Assessment and Potential for Damage

<b><u>Percent Damaged</u></b>	%	Good Condition
<b><u>Physical Contact</u></b>	<b><u>Vibration</u></b>	<b><u>Air</u></b>
Low/None	Low/None	Low/None

**Planned Response Action** O&M

**Inspector**



Michael J. Ardis

**State** IN

**Accreditation Number** 19A007304

# Periodic Surveillance

**LEA Name** Greater Clark County School Corporation  
**Building Name** Charlestown Senior High School  
**Building Number** 08  
**HA ID** I  
**HA Description** Vinyl Stair treads  
**HA Type** Miscellaneous Material  
**HA Location** Stairs to upper level - catwalk for auditorium

**Quantity** Unquantified SF  
**Comments** This material was discovered during the June 2011 6 month surveillance and will remain in the management plan until sampled properly.  
**Asbestos** Assumed  
**Friable** No

**Original Inspection** 6/27/2011  
**Current Inspection** 4/23/2020

## Material Assessment

**Assessment Rating** 5 ACBM with potential for damage

## Damage Assessment and Potential for Damage

**Percent Damaged** % Good Condition

**Physical Contact**

Low/None

**Vibration**

Low/None

**Air**

Low/None

**Planned Response Action** O&M

**Inspector**



Michael J. Ardis

**State** IN

**Accreditation Number** 19A007304

# Periodic Surveillance

**LEA Name** Greater Clark County School Corporation  
**Building Name** Charlestown Senior High School  
**Building Number** 08  
**HA ID** J  
**HA Description** Stair tread mastic  
**HA Type** Miscellaneous Material  
**HA Location** Stairs to upper level - catwalk for auditorium

**Quantity** Unquantified SF  
**Comments** This material was discovered during the June 2011 6 month surveillance and will remain in the management plan until sampled properly.  
**Asbestos** Assumed  
**Friable** No

**Original Inspection** 6/28/2011  
**Current Inspection** 4/23/2020


## Material Assessment

**Assessment Rating** 5 ACBM with potential for damage

## Damage Assessment and Potential for Damage

<b><u>Percent Damaged</u></b>	%	Good Condition
<b><u>Physical Contact</u></b>	<b><u>Vibration</u></b>	<b><u>Air</u></b>
Low/None	Low/None	Low/None

**Planned Response Action** O&M

**Inspector**   
Michael J. Ardis

**State** IN  
**Accreditation Number** 19A007304

# Periodic Surveillance

**LEA Name** Greater Clark County School Corporation  
**Building Name** Charlestown Senior High School  
**Building Number** 08  
**HA ID** F  
**HA Description** Stage light wiring insulation  
**HA Type** Miscellaneous Material  
**HA Location** Auditorium-Stage light wiring, upper level lighting (material can only be viewing from above the stage/catwalk)  
**Quantity** Unquantified LF  
**Comments** This material was noted by the inspector during the 12/06/2010 and will remaining in the managment plan until properly sampled. Lights all appear to be out of service/disconnected. Some are laying on the landing floor.  
**Asbestos** Assumed  
**Friable** Yes  
**Original Inspection** 12/6/2010  
**Current Inspection** 1/14/2020

## Material Assessment

**Assessment Rating** 5 ACBM with potential for damage

## Damage Assessment and Potential for Damage

**Percent Damaged** % Good Condition

**Physical Contact**

Low/None

**Vibration**

Low/None

**Air**

Low/None

**Planned Response Action** O&M

**Inspector**



Michael J. Ardis

**State** IN

**Accreditation Number** 19A007304



# Periodic Surveillance

**LEA Name** Greater Clark County School Corporation

**Building Name** Charlestown Senior High School

**Building Number** 08

**HA ID** G

**HA Description** Stage fire curtain-off white

**HA Type** Miscellaneous Material

**HA Location** Auditorium stage

**Quantity** Unquantified Unit(s)

**Comments** This was noted by the inspector during the 12/06/2010 as suspect ACM therefore it will remain in the management plan for informational purposes. Only Building materials are required to be in the AHERA Management Plan.

**Asbestos** Assumed

**Friable** No

**Original Inspection** 12/6/2010

**Current Inspection** 1/14/2020

## Material Assessment

**Assessment Rating** 5 ACBM with potential for damage

## Damage Assessment and Potential for Damage

**Percent Damaged** % Good Condition

**Physical Contact**

Low/None

**Vibration**

Low/None

**Air**

Low/None

**Planned Response Action** O&M

**Inspector**



Michael J. Ardis

**State** IN

**Accreditation Number** 19A007304



# Periodic Surveillance

**LEA Name** Greater Clark County School Corporation  
**Building Name** Charlestown Senior High School  
**Building Number** 08  
**HA ID** H  
**HA Description** Fire rated doors  
**HA Type** Miscellaneous Material  
**HA Location** Auditorium above the stage

**Quantity** 4 Unit(s)  
**Comments** The inspector noted these during the 12/06/2010 inspection as suspect ACM.  
They will remain in the management plan until properly sampled.  
**Asbestos** Assumed  
**Friable** No  
**Original Inspection** 12/6/2010  
**Current Inspection** 1/14/2020

## Material Assessment

**Assessment Rating** 5 ACBM with potential for damage

## Damage Assessment and Potential for Damage

<b><u>Percent Damaged</u></b>	%	Good Condition
<b><u>Physical Contact</u></b>	<b><u>Vibration</u></b>	<b><u>Air</u></b>
Low/None	Low/None	Low/None

**Planned Response Action** O&M

**Inspector**



Michael J. Ardis

**State** IN

**Accreditation Number** 19A007304

# Periodic Surveillance

**LEA Name** Greater Clark County School Corporation  
**Building Name** Charlestown Senior High School  
**Building Number** 08  
**HA ID** I  
**HA Description** Vinyl Stair treads  
**HA Type** Miscellaneous Material  
**HA Location** Stairs to upper level - catwalk for auditorium

**Quantity** Unquantified SF  
**Comments** This material was discovered during the June 2011 6 month surveillance and will remain in the management plan until sampled properly.  
**Asbestos** Assumed  
**Friable** No

**Original Inspection** 6/27/2011  
**Current Inspection** 1/14/2020

## Material Assessment

**Assessment Rating** 5 ACBM with potential for damage

## Damage Assessment and Potential for Damage

**Percent Damaged** % Good Condition

**Physical Contact**

Low/None

**Vibration**

Low/None

**Air**

Low/None

**Planned Response Action** O&M

**Inspector**



Michael J. Ardis

**State** IN

**Accreditation Number** 19A007304

# Periodic Surveillance

**LEA Name** Greater Clark County School Corporation  
**Building Name** Charlestown Senior High School  
**Building Number** 08  
**HA ID** J  
**HA Description** Stair tread mastic  
**HA Type** Miscellaneous Material  
**HA Location** Stairs to upper level - catwalk for auditorium

**Quantity** Unquantified SF  
**Comments** This material was discovered during the June 2011 6 month surveillance and will remain in the management plan until sampled properly.  
**Asbestos** Assumed  
**Friable** No

**Original Inspection** 6/28/2011  
**Current Inspection** 1/14/2020

## Material Assessment

**Assessment Rating** 5 ACBM with potential for damage

## Damage Assessment and Potential for Damage

**Percent Damaged** % Good Condition

**Physical Contact**

Low/None

**Vibration**

Low/None

**Air**

Low/None

**Planned Response Action** O&M

**Inspector**



Michael J. Ardis

**State** IN

**Accreditation Number** 19A007304

# Periodic Surveillance

**LEA Name** Greater Clark County School Corporation  
**Building Name** Charlestown Senior High School  
**Building Number** 08  
**HA ID** F  
**HA Description** Stage light wiring insulation  
**HA Type** Miscellaneous Material  
**HA Location** Auditorium-Stage light wiring, upper level lighting (material can only be viewing from above the stage/catwalk)  
**Quantity** Unquantified LF  
**Comments** This material was noted by the inspector during the 12/06/2010 and will remaining in the managment plan until properly sampled. Lights all appear to be out of service/disconnected. Some are laying on the landing floor.  
**Asbestos** Assumed  
**Friable** Yes  
**Original Inspection** 12/6/2010  
**Current Inspection** 11/14/2018

## Material Assessment

**Assessment Rating** 5 ACBM with potential for damage

## Damage Assessment and Potential for Damage

**Percent Damaged** % Good Condition

**Physical Contact**

Low/None

**Vibration**


Low/None

**Air**

Low/None

**Planned Response Action** O&M

**Inspector**



Benjamin S. Hood

**State** IN

**Accreditation Number** 19A001039

# Periodic Surveillance

**LEA Name** Greater Clark County School Corporation

**Building Name** Charlestown Senior High School

**Building Number** 08

**HA ID** G

**HA Description** Stage fire curtain-off white

**HA Type** Miscellaneous Material

**HA Location** Auditorium stage

**Quantity** Unquantified Unit(s)

**Comments** This was noted by the inspector during the 12/06/2010 as suspect ACM therefore it will remain in the management plan for informational purposes. Only Building materials are required to be in the AHERA Management Plan.

**Asbestos** Assumed

**Friable** No

**Original Inspection** 12/6/2010

**Current Inspection** 11/14/2018

## Material Assessment

**Assessment Rating** 5 ACBM with potential for damage

## Damage Assessment and Potential for Damage

**Percent Damaged** % Good Condition

**Physical Contact**

Low/None

**Vibration**


Low/None

**Air**

Low/None

**Planned Response Action** O&M

**Inspector**



Benjamin S. Hood

**State** IN

**Accreditation Number** 19A001039

# Periodic Surveillance

**LEA Name** Greater Clark County School Corporation  
**Building Name** Charlestown Senior High School  
**Building Number** 08  
**HA ID** H  
**HA Description** Fire rated doors  
**HA Type** Miscellaneous Material  
**HA Location** Auditorium above the stage

**Quantity** 4 Unit(s)  
**Comments** The inspector noted these during the 12/06/2010 inspection as suspect ACM. They will remain in the management plan until properly sampled.  
**Asbestos** Assumed  
**Friable** No  
**Original Inspection** 12/6/2010  
**Current Inspection** 11/14/2018

## Material Assessment

**Assessment Rating** 5 ACBM with potential for damage

## Damage Assessment and Potential for Damage

<b><u>Percent Damaged</u></b>	%	Good Condition
<b><u>Physical Contact</u></b>	<b><u>Vibration</u></b>	<b><u>Air</u></b>
Low/None	Low/None	Low/None

**Planned Response Action** O&M

**Inspector**



Benjamin S. Hood

**State** IN

**Accreditation Number** 19A001039

# Periodic Surveillance

**LEA Name** Greater Clark County School Corporation  
**Building Name** Charlestown Senior High School  
**Building Number** 08  
**HA ID** I  
**HA Description** Vinyl Stair treads  
**HA Type** Miscellaneous Material  
**HA Location** Stairs to upper level - catwalk for auditorium

**Quantity** Unquantified SF  
**Comments** This material was discovered during the June 2011 6 month surveillance and will remain in the management plan until sampled properly.  
**Asbestos** Assumed  
**Friable** No

**Original Inspection** 6/27/2011  
**Current Inspection** 11/14/2018

## Material Assessment

**Assessment Rating** 5 ACBM with potential for damage

## Damage Assessment and Potential for Damage

**Percent Damaged** % Good Condition

**Physical Contact**

Low/None

**Vibration**

Low/None

**Air**

Low/None

**Planned Response Action** O&M

**Inspector**



Benjamin S. Hood

**State** IN

**Accreditation Number** 19A001039



# Periodic Surveillance

**LEA Name** Greater Clark County School Corporation  
**Building Name** Charlestown Senior High School  
**Building Number** 08  
**HA ID** J  
**HA Description** Stair tread mastic  
**HA Type** Miscellaneous Material  
**HA Location** Stairs to upper level - catwalk for auditorium

**Quantity** Unquantified SF  
**Comments** This material was discovered during the June 2011 6 month surveillance and will remain in the management plan until sampled properly.  
**Asbestos** Assumed  
**Friable** No

**Original Inspection** 6/28/2011  
**Current Inspection** 11/14/2018

## Material Assessment

**Assessment Rating** 5 ACBM with potential for damage

## Damage Assessment and Potential for Damage

**Percent Damaged** % Good Condition

**Physical Contact**

Low/None

**Vibration**

Low/None

**Air**

Low/None

**Planned Response Action** O&M

**Inspector**



Benjamin S. Hood

**State** IN

**Accreditation Number** 19A001039

# Periodic Surveillance

**LEA Name** Greater Clark County School Corporation  
**Building Name** Charlestown Senior High School  
**Building Number** 08  
**HA ID** F  
**HA Description** Stage light wiring insulation  
**HA Type** Miscellaneous Material  
**HA Location** Auditorium-Stage light wiring, upper level lighting (material can only be viewing from above the stage/catwalk)  
**Quantity** Unquantified LF  
**Comments** This material was noted by the inspector during the 12/06/2010 and will remaining in the managment plan until properly sampled. Lights all appear to be out of service/disconnected. Some are laying on the landing floor.  
**Asbestos** Assumed  
**Friable** Yes  
**Original Inspection** 12/6/2010  
**Current Inspection** 5/2/2018


## Material Assessment

**Assessment Rating** 5 ACBM with potential for damage

## Damage Assessment and Potential for Damage

<b><u>Percent Damaged</u></b>	%	Good Condition
<b><u>Physical Contact</u></b>	<b><u>Vibration</u></b>	<b><u>Air</u></b>
Low/None	Low/None	Low/None
<b><u>Planned Response Action</u></b> O&M		

**Inspector**



Benjamin S. Hood

**State** IN

**Accreditation Number** 19A001039

# Periodic Surveillance

**LEA Name** Greater Clark County School Corporation

**Building Name** Charlestown Senior High School

**Building Number** 08

**HA ID** G

**HA Description** Stage fire curtain-off white

**HA Type** Miscellaneous Material

**HA Location** Auditorium stage

**Quantity** Unquantified Unit(s)

**Comments** This was noted by the inspector during the 12/06/2010 as suspect ACM therefore it will remain in the management plan for informational purposes. Only Building materials are required to be in the AHERA Management Plan.

**Asbestos** Assumed

**Friable** No

**Original Inspection** 12/6/2010

**Current Inspection** 5/2/2018

## Material Assessment

**Assessment Rating** 5 ACBM with potential for damage

## Damage Assessment and Potential for Damage

**Percent Damaged** % Good Condition

**Physical Contact**

Low/None

**Vibration**


Low/None

**Air**

Low/None

**Planned Response Action** O&M

**Inspector**



Benjamin S. Hood

**State** IN

**Accreditation Number** 19A001039

# Periodic Surveillance

**LEA Name** Greater Clark County School Corporation

**Building Name** Charlestown Senior High School

**Building Number** 08

**HA ID** H

**HA Description** Fire rated doors

**HA Type** Miscellaneous Material

**HA Location** Auditorium above the stage

**Quantity** 4 Unit(s)

**Comments** The inspector noted these during the 12/06/2010 inspection as suspect ACM.  
They will remain in the management plan until properly sampled.

**Asbestos** Assumed

**Friable** No

**Original Inspection** 12/6/2010

**Current Inspection** 5/2/2018

## Material Assessment

**Assessment Rating** 5 ACBM with potential for damage

## Damage Assessment and Potential for Damage

**Percent Damaged** % Good Condition

**Physical Contact**

Low/None

**Vibration**

Low/None

**Air**

Low/None

**Planned Response Action** O&M

**Inspector**



Benjamin S. Hood

**State** IN

**Accreditation Number** 19A001039

# Periodic Surveillance

**LEA Name** Greater Clark County School Corporation  
**Building Name** Charlestown Senior High School  
**Building Number** 08  
**HA ID** I  
**HA Description** Vinyl Stair treads  
**HA Type** Miscellaneous Material  
**HA Location** Stairs to upper level - catwalk for auditorium

**Quantity** Unquantified SF  
**Comments** This material was discovered during the June 2011 6 month surveillance and will remain in the management plan until sampled properly.  
**Asbestos** Assumed  
**Friable** No

**Original Inspection** 6/27/2011  
**Current Inspection** 5/2/2018

## Material Assessment

**Assessment Rating** 5 ACBM with potential for damage

## Damage Assessment and Potential for Damage

**Percent Damaged** % Good Condition

**Physical Contact**

Low/None

**Vibration**

Low/None

**Air**

Low/None

**Planned Response Action** O&M

**Inspector**



Benjamin S. Hood

**State** IN

**Accreditation Number** 19A001039

# Periodic Surveillance

**LEA Name** Greater Clark County School Corporation  
**Building Name** Charlestown Senior High School  
**Building Number** 08  
**HA ID** J  
**HA Description** Stair tread mastic  
**HA Type** Miscellaneous Material  
**HA Location** Stairs to upper level - catwalk for auditorium

**Quantity** Unquantified SF  
**Comments** This material was discovered during the June 2011 6 month surveillance and will remain in the management plan until sampled properly.  
**Asbestos** Assumed  
**Friable** No

**Original Inspection** 6/28/2011  
**Current Inspection** 5/2/2018

## Material Assessment

**Assessment Rating** 5 ACBM with potential for damage

## Damage Assessment and Potential for Damage

**Percent Damaged** % Good Condition

**Physical Contact**

Low/None

**Vibration**

Low/None

**Air**

Low/None

**Planned Response Action** O&M

**Inspector**



Benjamin S. Hood

**State** IN

**Accreditation Number** 19A001039

# Periodic Surveillance

**LEA Name** Greater Clark County School Corporation  
**Building Name** Charlestown Senior High School  
**Building Number** 08  
**HA ID** F  
**HA Description** Stage light wiring insulation  
**HA Type** Miscellaneous Material  
**HA Location** Auditorium-Stage light wiring, upper level lighting (material can only be viewing from above the stage/catwalk)  
**Quantity** Unquantified LF  
**Comments** This material was noted by the inspector during the 12/06/2010 and will remaining in the managment plan until properly sampled. Lights all appear to be out of service/disconnected. Some are laying on the landing floor.  
**Asbestos** Assumed  
**Friable** Yes  
**Original Inspection** 12/6/2010  
**Current Inspection** 10/18/2017

## Material Assessment

**Assessment Rating** 5 ACBM with potential for damage

## Damage Assessment and Potential for Damage

**Percent Damaged** % Good Condition

**Physical Contact**

Low/None

**Vibration**

Low/None

**Air**

Low/None

**Planned Response Action** O&M



**Inspector**

Dustin Hawkins

**State** IN

**Accreditation Number** 19A007194



# Periodic Surveillance

**LEA Name** Greater Clark County School Corporation

**Building Name** Charlestown Senior High School

**Building Number** 08

**HA ID** G

**HA Description** Stage fire curtain-off white

**HA Type** Miscellaneous Material

**HA Location** Auditorium stage

**Quantity** Unquantified Unit(s)

**Comments** This was noted by the inspector during the 12/06/2010 as suspect ACM therefore it will remain in the management plan for informational purposes. Only Building materials are required to be in the AHERA Management Plan.

**Asbestos** Assumed

**Friable** No

**Original Inspection** 12/6/2010

**Current Inspection** 10/18/2017

## Material Assessment

**Assessment Rating** 5 ACBM with potential for damage

## Damage Assessment and Potential for Damage

**Percent Damaged** % Good Condition

**Physical Contact**

Low/None

**Vibration**

Low/None

**Air**

Low/None

**Planned Response Action** O&M



**Inspector**

Dustin Hawkins

**State** IN

**Accreditation Number** 19A007194

# Periodic Surveillance

**LEA Name** Greater Clark County School Corporation  
**Building Name** Charlestown Senior High School  
**Building Number** 08  
**HA ID** H  
**HA Description** Fire rated doors  
**HA Type** Miscellaneous Material  
**HA Location** Auditorium above the stage

**Quantity** 4 Unit(s)  
**Comments** The inspector noted these during the 12/06/2010 inspection as suspect ACM. They will remain in the management plan until properly sampled.  
**Asbestos** Assumed  
**Friable** No  
**Original Inspection** 12/6/2010  
**Current Inspection** 10/18/2017

## Material Assessment

**Assessment Rating** 5 ACBM with potential for damage

## Damage Assessment and Potential for Damage

**Percent Damaged** % Good Condition

<b><u>Physical Contact</u></b>	<b><u>Vibration</u></b>	<b><u>Air</u></b>
Low/None	Low/None	Low/None

**Planned Response Action** O&M

**Inspector**



Dustin Hawkins

**State** IN

**Accreditation Number** 19A007194

# Periodic Surveillance

**LEA Name** Greater Clark County School Corporation  
**Building Name** Charlestown Senior High School  
**Building Number** 08  
**HA ID** I  
**HA Description** Vinyl Stair treads  
**HA Type** Miscellaneous Material  
**HA Location** Stairs to upper level - catwalk for auditorium

**Quantity** Unquantified SF  
**Comments** This material was discovered during the June 2011 6 month surveillance and will remain in the management plan until sampled properly.  
**Asbestos** Assumed  
**Friable** No

**Original Inspection** 6/27/2011  
**Current Inspection** 10/18/2017

## Material Assessment

**Assessment Rating** 5 ACBM with potential for damage

## Damage Assessment and Potential for Damage

**Percent Damaged** % Good Condition

**Physical Contact**

Low/None

**Vibration**

Low/None

**Air**

Low/None

**Planned Response Action** O&M



**Inspector**

Dustin Hawkins

**State** IN

**Accreditation Number** 19A007194

# Periodic Surveillance

**LEA Name** Greater Clark County School Corporation  
**Building Name** Charlestown Senior High School  
**Building Number** 08  
**HA ID** J  
**HA Description** Stair tread mastic  
**HA Type** Miscellaneous Material  
**HA Location** Stairs to upper level - catwalk for auditorium

**Quantity** Unquantified SF  
**Comments** This material was discovered during the June 2011 6 month surveillance and will remain in the management plan until sampled properly.  
**Asbestos** Assumed  
**Friable** No

**Original Inspection** 6/28/2011  
**Current Inspection** 10/18/2017

## Material Assessment

**Assessment Rating** 5 ACBM with potential for damage

## Damage Assessment and Potential for Damage

**Percent Damaged** % Good Condition

**Physical Contact**

Low/None

**Vibration**

Low/None

**Air**

Low/None

**Planned Response Action** O&M



**Inspector**

Dustin Hawkins

**State** IN

**Accreditation Number** 19A007194

# Periodic Surveillance

**LEA Name** Greater Clark County School Corporation  
**Building Name** Charlestown Senior High School  
**Building Number** 08  
**HA ID** F  
**HA Description** Stage light wiring insulation  
**HA Type** Miscellaneous Material  
**HA Location** Auditorium-Stage light wiring, upper level lighting (material can only be viewing from above the stage/catwalk)  
**Quantity** Unquantified LF  
**Comments** This material was noted by the inspector during the 12/06/2010 and will remaining in the managment plan until properly sampled. Lights all appear to be out of service/disconnected. Some are laying on the landing floor.  
**Asbestos** Assumed  
**Friable** Yes  
**Original Inspection** 12/6/2010  
**Current Inspection** 4/13/2017

## Material Assessment

**Assessment Rating** 5 ACBM with potential for damage

## Damage Assessment and Potential for Damage

**Percent Damaged** % Good Condition

**Physical Contact**

Low/None

**Vibration**

Low/None

**Air**

Low/None

**Planned Response Action** O&M

**Inspector**

Jamie Hosier

**State** Indiana

**Accreditation Number** 19A007179

# Periodic Surveillance

**LEA Name** Greater Clark County School Corporation

**Building Name** Charlestown Senior High School

**Building Number** 08

**HA ID** G

**HA Description** Stage fire curtain-off white

**HA Type** Miscellaneous Material

**HA Location** Auditorium stage

**Quantity** Unquantified Unit(s)

**Comments** This was noted by the inspector during the 12/06/2010 as suspect ACM therefore it will remain in the management plan for informational purposes. Only Building materials are required to be in the AHERA Management Plan.

**Asbestos** Assumed

**Friable** No

**Original Inspection** 12/6/2010

**Current Inspection** 4/13/2017

## Material Assessment

**Assessment Rating** 5 ACBM with potential for damage

## Damage Assessment and Potential for Damage

**Percent Damaged** % Good Condition

**Physical Contact**

Low/None

**Vibration**

Low/None

**Air**

Low/None

**Planned Response Action** O&M



**Inspector**

Jamie Hosier

**State** Indiana

**Accreditation Number** 19A007179



# Periodic Surveillance

**LEA Name** Greater Clark County School Corporation

**Building Name** Charlestown Senior High School

**Building Number** 08

**HA ID** H

**HA Description** Fire rated doors

**HA Type** Miscellaneous Material

**HA Location** Auditorium above the stage

**Quantity** 4 Unit(s)

**Comments** The inspector noted these during the 12/06/2010 inspection as suspect ACM. They will remain in the management plan until properly sampled.

**Asbestos** Assumed

**Friable** No

**Original Inspection** 12/6/2010

**Current Inspection** 4/13/2017

## Material Assessment

**Assessment Rating** 5 ACBM with potential for damage

## Damage Assessment and Potential for Damage

**Percent Damaged** % Good Condition

**Physical Contact**

Low/None

**Vibration**

Low/None

**Air**

Low/None

**Planned Response Action** O&M

**Inspector**



Jamie Hosier

**State** Indiana

**Accreditation Number** 19A007179

# Periodic Surveillance

**LEA Name** Greater Clark County School Corporation  
**Building Name** Charlestown Senior High School  
**Building Number** 08  
**HA ID** I  
**HA Description** Vinyl Stair treads  
**HA Type** Miscellaneous Material  
**HA Location** Stairs to upper level - catwalk for auditorium

**Quantity** Unquantified SF  
**Comments** This material was discovered during the June 2011 6 month surveillance and will remain in the management plan until sampled properly.  
**Asbestos** Assumed  
**Friable** No

**Original Inspection** 6/27/2011  
**Current Inspection** 4/13/2017


## Material Assessment

**Assessment Rating** 5 ACBM with potential for damage

## Damage Assessment and Potential for Damage

<b><u>Percent Damaged</u></b>	%	Good Condition	
<b><u>Physical Contact</u></b>		<b><u>Vibration</u></b>	<b><u>Air</u></b>
Low/None		Low/None	Low/None
<b><u>Planned Response Action</u></b>	O&M		

**Inspector**

  
\_\_\_\_\_  
Jamie Hosier

**State** Indiana

**Accreditation Number** 19A007179

# Periodic Surveillance

**LEA Name** Greater Clark County School Corporation  
**Building Name** Charlestown Senior High School  
**Building Number** 08  
**HA ID** J  
**HA Description** Stair tread mastic  
**HA Type** Miscellaneous Material  
**HA Location** Stairs to upper level - catwalk for auditorium

**Quantity** Unquantified SF  
**Comments** This material was discovered during the June 2011 6 month surveillance and will remain in the management plan until sampled properly.  
**Asbestos** Assumed  
**Friable** No

**Original Inspection** 6/28/2011  
**Current Inspection** 4/13/2017


## Material Assessment

**Assessment Rating** 5 ACBM with potential for damage

## Damage Assessment and Potential for Damage

<b><u>Percent Damaged</u></b>	%	Good Condition	
<b><u>Physical Contact</u></b>		<b><u>Vibration</u></b>	<b><u>Air</u></b>
Low/None		Low/None	Low/None
<b><u>Planned Response Action</u></b>	O&M		

**Inspector**

  
\_\_\_\_\_  
Jamie Hosier

**State** Indiana

**Accreditation Number** 19A007179

# Periodic Surveillance

**LEA Name** Greater Clark County School Corporation  
**Building Name** Charlestown Senior High School  
**Building Number** 08  
**HA ID** F  
**HA Description** Stage light wiring insulation  
**HA Type** Miscellaneous Material  
**HA Location** Auditorium-Stage light wiring, upper level lighting (material can only be viewing from above the stage/catwalk)  
**Quantity** Unquantified LF  
**Comments** This material was noted by the inspector during the 12/06/2010 and will remaining in the managment plan until properly sampled. Lights all appear to be out of service/disconnected. Some are laying on the landing floor.  
**Asbestos** Assumed  
**Friable** Yes  
**Original Inspection** 12/6/2010  
**Current Inspection** 11/3/2016

## Material Assessment

**Assessment Rating** 5 ACBM with potential for damage

## Damage Assessment and Potential for Damage

**Percent Damaged** % Good Condition

**Physical Contact**

Low/None

**Vibration**

Low/None

**Air**

Low/None

**Planned Response Action** O&M



**Inspector**

Dustin Hawkins

**State** IN

**Accreditation Number** 19A007194

# Periodic Surveillance

**LEA Name** Greater Clark County School Corporation

**Building Name** Charlestown Senior High School

**Building Number** 08

**HA ID** G

**HA Description** Stage fire curtain-off white

**HA Type** Miscellaneous Material

**HA Location** Auditorium stage

**Quantity** Unquantified Unit(s)

**Comments** This was noted by the inspector during the 12/06/2010 as suspect ACM therefore it will remain in the management plan for informational purposes. Only Building materials are required to be in the AHERA Management Plan.

**Asbestos** Assumed

**Friable** No

**Original Inspection** 12/6/2010

**Current Inspection** 11/3/2016

## Material Assessment

**Assessment Rating** 5 ACBM with potential for damage

## Damage Assessment and Potential for Damage

**Percent Damaged** % Good Condition

**Physical Contact**

Low/None

**Vibration**

Low/None

**Air**

Low/None

**Planned Response Action** O&M



**Inspector**

Dustin Hawkins

**State** IN

**Accreditation Number** 19A007194

# Periodic Surveillance

**LEA Name** Greater Clark County School Corporation  
**Building Name** Charlestown Senior High School  
**Building Number** 08  
**HA ID** H  
**HA Description** Fire rated doors  
**HA Type** Miscellaneous Material  
**HA Location** Auditorium above the stage

**Quantity** 4 Unit(s)  
**Comments** The inspector noted these during the 12/06/2010 inspection as suspect ACM. They will remain in the management plan until properly sampled.  
**Asbestos** Assumed  
**Friable** No  
**Original Inspection** 12/6/2010  
**Current Inspection** 11/3/2016

## Material Assessment

**Assessment Rating** 5 ACBM with potential for damage

## Damage Assessment and Potential for Damage

**Percent Damaged** % Good Condition

**Physical Contact**

Low/None

**Vibration**

Low/None

**Air**

Low/None

**Planned Response Action** O&M



**Inspector**

Dustin Hawkins

**State** IN

**Accreditation Number** 19A007194

# Periodic Surveillance

**LEA Name** Greater Clark County School Corporation  
**Building Name** Charlestown Senior High School  
**Building Number** 08  
**HA ID** I  
**HA Description** Vinyl Stair treads  
**HA Type** Miscellaneous Material  
**HA Location** Stairs to upper level - catwalk for auditorium

**Quantity** Unquantified SF  
**Comments** This material was discovered during the June 2011 6 month surveillance and will remain in the management plan until sampled properly.  
**Asbestos** Assumed  
**Friable** No

**Original Inspection** 6/27/2011  
**Current Inspection** 11/3/2016

## Material Assessment

**Assessment Rating** 5 ACBM with potential for damage

## Damage Assessment and Potential for Damage

**Percent Damaged** % Good Condition

**Physical Contact**

Low/None

**Vibration**

Low/None

**Air**

Low/None

**Planned Response Action** O&M



**Inspector**

Dustin Hawkins

**State** IN

**Accreditation Number** 19A007194



# Periodic Surveillance

**LEA Name** Greater Clark County School Corporation  
**Building Name** Charlestown Senior High School  
**Building Number** 08  
**HA ID** J  
**HA Description** Stair tread mastic  
**HA Type** Miscellaneous Material  
**HA Location** Stairs to upper level - catwalk for auditorium

**Quantity** Unquantified SF  
**Comments** This material was discovered during the June 2011 6 month surveillance and will remain in the management plan until sampled properly.  
**Asbestos** Assumed  
**Friable** No

**Original Inspection** 6/28/2011  
**Current Inspection** 11/3/2016

## Material Assessment

**Assessment Rating** 5 ACBM with potential for damage

## Damage Assessment and Potential for Damage

**Percent Damaged** % Good Condition

**Physical Contact**

Low/None

**Vibration**

Low/None

**Air**

Low/None

**Planned Response Action** O&M



**Inspector**

Dustin Hawkins

**State** IN

**Accreditation Number** 19A007194

# Periodic Surveillance

**LEA Name** Greater Clark County School Corporation  
**Building Name** Charlestown Senior High School  
**Building Number** 08  
**HA ID** F  
**HA Description** Stage light wiring insulation  
**HA Type** Miscellaneous Material  
**HA Location** Auditorium-Stage light wiring, upper level lighting (material can only be viewing from above the stage/catwalk)  
**Quantity** Unquantified LF  
**Comments** This material was noted by the inspector during the 12/06/2010 and will remaining in the managment plan until properly sampled. Lights all appear to be out of service/disconnected. Some are laying on the landing floor.  
**Asbestos** Assumed  
**Friable** Yes  
**Original Inspection** 12/6/2010  
**Current Inspection** 10/20/2015

## Material Assessment

**Assessment Rating** 5 ACBM with potential for damage

## Damage Assessment and Potential for Damage

**Percent Damaged** % Good Condition

**Physical Contact**

Low/None

**Vibration**

Low/None

**Air**

Low/None

**Planned Response Action** O&M

**Inspector**



Benjamin S. Hood

**State** IN

**Accreditation Number** 19A001039

# Periodic Surveillance

**LEA Name** Greater Clark County School Corporation

**Building Name** Charlestown Senior High School

**Building Number** 08

**HA ID** G

**HA Description** Stage fire curtain-off white

**HA Type** Miscellaneous Material

**HA Location** Auditorium stage

**Quantity** Unquantified Unit(s)

**Comments** This was noted by the inspector during the 12/06/2010 as suspect ACM therefore it will remain in the management plan for informational purposes. Only Building materials are required to be in the AHERA Management Plan.

**Asbestos** Assumed

**Friable** No

**Original Inspection** 12/6/2010

**Current Inspection** 10/20/2015

## Material Assessment

**Assessment Rating** 5 ACBM with potential for damage

## Damage Assessment and Potential for Damage

**Percent Damaged** % Good Condition

**Physical Contact**

Low/None

**Vibration**


Low/None

**Air**

Low/None

**Planned Response Action** O&M

**Inspector**



Benjamin S. Hood

**State** IN

**Accreditation Number** 19A001039

# Periodic Surveillance

**LEA Name** Greater Clark County School Corporation  
**Building Name** Charlestown Senior High School  
**Building Number** 08  
**HA ID** H  
**HA Description** Fire rated doors  
**HA Type** Miscellaneous Material  
**HA Location** Auditorium above the stage

**Quantity** 4 Unit(s)  
**Comments** The inspector noted these during the 12/06/2010 inspection as suspect ACM. They will remain in the management plan until properly sampled.  
**Asbestos** Assumed  
**Friable** No  
**Original Inspection** 12/6/2010  
**Current Inspection** 10/20/2015

## Material Assessment

**Assessment Rating** 5 ACBM with potential for damage

## Damage Assessment and Potential for Damage

<b><u>Percent Damaged</u></b>	%	Good Condition
<b><u>Physical Contact</u></b>	<b><u>Vibration</u></b>	<b><u>Air</u></b>
Low/None	Low/None	Low/None

**Planned Response Action** O&M

**Inspector**



Benjamin S. Hood

**State** IN

**Accreditation Number** 19A001039

# Periodic Surveillance

**LEA Name** Greater Clark County School Corporation  
**Building Name** Charlestown Senior High School  
**Building Number** 08  
**HA ID** I  
**HA Description** Vinyl Stair treads  
**HA Type** Miscellaneous Material  
**HA Location** Stairs to upper level - catwalk for auditorium

**Quantity** Unquantified SF  
**Comments** This material was discovered during the June 2011 6 month surveillance and will remain in the management plan until sampled properly.  
**Asbestos** Assumed  
**Friable** No

**Original Inspection** 6/27/2011  
**Current Inspection** 10/20/2015

## Material Assessment

**Assessment Rating** 5 ACBM with potential for damage

## Damage Assessment and Potential for Damage

<b><u>Percent Damaged</u></b>	%	Good Condition
<b><u>Physical Contact</u></b>	<b><u>Vibration</u></b>	<b><u>Air</u></b>
Low/None	Low/None	Low/None

**Planned Response Action** O&M

**Inspector**



Benjamin S. Hood

**State** IN

**Accreditation Number** 19A001039

# Periodic Surveillance

**LEA Name** Greater Clark County School Corporation  
**Building Name** Charlestown Senior High School  
**Building Number** 08  
**HA ID** J  
**HA Description** Stair tread mastic  
**HA Type** Miscellaneous Material  
**HA Location** Stairs to upper level - catwalk for auditorium

**Quantity** Unquantified SF  
**Comments** This material was discovered during the June 2011 6 month surveillance and will remain in the management plan until sampled properly.  
**Asbestos** Assumed  
**Friable** No

**Original Inspection** 6/28/2011  
**Current Inspection** 10/20/2015

## Material Assessment

**Assessment Rating** 5 ACBM with potential for damage

## Damage Assessment and Potential for Damage

<b><u>Percent Damaged</u></b>	%	Good Condition	
<b><u>Physical Contact</u></b>	<b><u>Vibration</u></b>	<b><u>Air</u></b>	
Low/None	Low/None	Low/None	

**Planned Response Action** O&M

**Inspector**



Benjamin S. Hood

**State** IN

**Accreditation Number** 19A001039

# PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Charlestown Senior High School  
**HA#** F  
**Type of Material** Miscellaneous Material  
**Quantity of Material** Unquantified LF

**Material Location**

Auditorium-Stage light wiring, upper level lighting (material can only be viewing from above the stage/catwalk)


**Material Description**

Stage light wiring insulation

**Comments**

This material was noted by the inspector during the 12/06/2010 and will remaining in the managment plan until properly sampled. Lights all appear to be out of service/disconnected. Some are laying on the landing floor.

**Does Material Contain Asbestos?** Assumed  
**Is it Friable?** Yes  
**Original Inspection Date** 12/6/2010  
**Current Surveillance Date** 4/22/2015  
**Current Assessment Rating** NR Not Rated  
**Cause of Damage**  
**Accessible** Yes  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M



**Inspector**

---

Benjamin S. Hood

**State** Indiana  
**Accreditation Number** 19A001039



## PERIODIC SURVEILLANCE REPORT


**LEA Name** Greater Clark County Schools  
**Building Name** Charlestown Senior High School  
**HA#** G  
**Type of Material** Miscellaneous Material  
**Quantity of Material** Unquantified Each  
**Material Location**  
Auditorium Stage

**Material Description**  
Stage fire curtain-off white

**Comments**

This was noted by the inspector during the 12/06/2010 as suspect ACM therefore it will remain in the management plan for informational purposes. Only Building materials are required to be in the AHERA Management Plan.

**Does Material Contain Asbestos?** Assumed  
**Is it Friable?** No  
**Original Inspection Date** 12/6/2010  
**Current Surveillance Date** 4/22/2015  
**Current Assessment Rating** NR Not Rated  
**Cause of Damage**  
**Accessible** Yes  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M



**Inspector**

---

Benjamin S. Hood

**State** Indiana  
**Accreditation Number** 19A001039

## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Charlestown Senior High School  
**HA#** H  
**Type of Material** Miscellaneous Material  
**Quantity of Material** Each 4

**Material Location**

Auditorium above the stage

**Material Description**

Fire rated doors

**Comments**

The inspector noted these during the 12/06/2010 inspection as suspect ACM. They will remain in the management plan until properly sampled.

**Does Material Contain Asbestos?** Assumed  
**Is it Friable?** No  
**Original Inspection Date** 12/6/2010  
**Current Surveillance Date** 4/22/2015  
**Current Assessment Rating** NR Not Rated  
**Cause of Damage**  
**Accessible** Yes  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M



**Inspector**

---

Benjamin S. Hood

**State** Indiana  
**Accreditation Number** 19A001039

## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Charlestown Senior High School  
**HA#** I  
**Type of Material** Miscellaneous Material  
**Quantity of Material** Unquantified SF

**Material Location**

Stairs to upper level - catwalk for auditorium


**Material Description**

Vinyl Stair treads

**Comments**

This material was discovered during the June 2011 6 month surveillance and will remain in the management plan until sampled properly.

**Does Material Contain Asbestos?** Assumed  
**Is it Friable?** No  
**Original Inspection Date** 6/27/2011  
**Current Surveillance Date** 4/22/2015  
**Current Assessment Rating** NA Not Applicable  
**Cause of Damage** No Damage  
**Accessible** Yes  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M



**Inspector**

---

Benjamin S. Hood

**State** Indiana  
**Accreditation Number** 19A001039

## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Charlestown Senior High School  
**HA#** J  
**Type of Material** Miscellaneous Material  
**Quantity of Material** Unquantified SF

**Material Location**

Stairs to upper level catwalk for auditorium.


**Material Description**

Stair tread mastic

**Comments**

This material was discovered during the June 2011 6 month surveillance and will remain in the management plan until sampled properly.

**Does Material Contain Asbestos?** Assumed  
**Is it Friable?** No  
**Original Inspection Date** 6/28/2011  
**Current Surveillance Date** 4/22/2015  
**Current Assessment Rating** NA Not Applicable  
**Cause of Damage** No Damage  
**Accessible** No  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M



**Inspector**

---

Benjamin S. Hood

**State** Indiana  
**Accreditation Number** 19A001039

## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Charlestown Senior High School  
**HA#** F  
**Type of Material** Miscellaneous Material  
**Quantity of Material** Unquantified LF

**Material Location**

Auditorium-Stage light wiring, upper level lighting (material can only be viewing from above the stage/catwalk)


**Material Description**

Stage light wiring insulation

**Comments**

This material was noted by the inspector during the 12/06/2010 and will remaining in the managment plan until properly sampled. Lights all appear to be out of service/disconnected. Some are laying on the landing floor.

**Does Material Contain Asbestos?** Assumed  
**Is it Friable?** Yes  
**Original Inspection Date** 12/6/2010  
**Current Surveillance Date** 10/22/2014  
**Current Assessment Rating** NR Not Rated  
**Cause of Damage**  
**Accessible** No  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M



**Inspector**

---

Benjamin S. Hood

**State** Indiana  
**Accreditation Number** 19A001039

## PERIODIC SURVEILLANCE REPORT


**LEA Name** Greater Clark County Schools  
**Building Name** Charlestown Senior High School  
**HA#** G  
**Type of Material** Miscellaneous Material  
**Quantity of Material** Unquantified Each  
**Material Location**  
Auditorium Stage

**Material Description**  
Stage fire curtain-off white

**Comments**

This was noted by the inspector during the 12/06/2010 as suspect ACM therefore it will remain in the management plan for informational purposes. Only Building materials are required to be in the AHERA Management Plan.

**Does Material Contain Asbestos?** Assumed  
**Is it Friable?** No  
**Original Inspection Date** 12/6/2010  
**Current Surveillance Date** 10/22/2014  
**Current Assessment Rating** NR Not Rated  
**Cause of Damage**  
**Accessible** Yes  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M



**Inspector**

---

Benjamin S. Hood

**State** Indiana  
**Accreditation Number** 19A001039

## PERIODIC SURVEILLANCE REPORT


**LEA Name** Greater Clark County Schools  
**Building Name** Charlestown Senior High School  
**HA#** H  
**Type of Material** Miscellaneous Material  
**Quantity of Material** Each 4

**Material Location**  
Auditorium above the stage

**Material Description**  
Fire rated doors

**Comments**  
The inspector noted these during the 12/06/2010 inspection as suspect ACM. They will remain in the management plan until properly sampled.

**Does Material Contain Asbestos?** Assumed  
**Is it Friable?** No  
**Original Inspection Date** 12/6/2010  
**Current Surveillance Date** 10/22/2014  
**Current Assessment Rating** NR Not Rated  
**Cause of Damage**  
**Accessible** Yes  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M



**Inspector**

---

Benjamin S. Hood

**State** Indiana  
**Accreditation Number** 19A001039

## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Charlestown Senior High School  
**HA#** I  
**Type of Material** Miscellaneous Material  
**Quantity of Material** Unquantified SF

**Material Location**

Stairs to upper level - catwalk for auditorium

**Material Description**

Vinyl Stair treads

**Comments**

This material was discovered during the June 2011 6 month surveillance and will remain in the management plan until sampled properly.

**Does Material Contain Asbestos?** Assumed  
**Is it Friable?** No  
**Original Inspection Date** 6/27/2011  
**Current Surveillance Date** 10/22/2014  
**Current Assessment Rating** NA Not Applicable  
**Cause of Damage** No Damage  
**Accessible** Yes  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M



**Inspector**

---

Benjamin S. Hood

**State** Indiana  
**Accreditation Number** 19A001039



## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Charlestown Senior High School  
**HA#** J  
**Type of Material** Miscellaneous Material  
**Quantity of Material** Unquantified SF

**Material Location**

Stairs to upper level catwalk for auditorium.


**Material Description**

Stair tread mastic

**Comments**

This material was discovered during the June 2011 6 month surveillance and will remain in the management plan until sampled properly.

**Does Material Contain Asbestos?** Assumed  
**Is it Friable?** No  
**Original Inspection Date** 6/28/2011  
**Current Surveillance Date** 10/22/2014  
**Current Assessment Rating** NA Not Applicable  
**Cause of Damage** No Damage  
**Accessible** No  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M



**Inspector**

---

Benjamin S. Hood

**State** Indiana  
**Accreditation Number** 19A001039

# PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Charlestown Senior High School  
**HA#** F  
**Type of Material** Miscellaneous Material  
**Quantity of Material** Unquantified LF

**Material Location**

Auditorium-Stage light wiring, upper level lighting (material can only be viewing from above the stage/catwalk)

**Material Description**

Stage light wiring insulation

**Comments**

This material was noted by the inspector during the 12/06/2010 and will remaining in the managment plan until properly sampled. Lights all appear to be out of service/disconnected. Some are laying on the landing floor.

**Does Material Contain Asbestos?** Assumed  
**Is it Friable?** Yes  
**Original Inspection Date** 12/6/2010  
**Current Surveillance Date** 4/21/2014  
**Current Assessment Rating** NR Not Rated  
**Cause of Damage**  
**Accessible** No  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M

**Inspector**



---

Jeffrey P. Rechten

**State** Indiana  
**Accreditation Number** 19A003594

## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Charlestown Senior High School  
**HA#** G  
**Type of Material** Miscellaneous Material  
**Quantity of Material** Unquantified Each  
**Material Location**  
Auditorium Stage

**Material Description**  
Stage fire curtain-off white

**Comments**

This was noted by the inspector during the 12/06/2010 as suspect ACM therefore it will remain in the management plan for informational purposes. Only Building materials are required to be in the AHERA Management Plan.

**Does Material Contain Asbestos?** Assumed  
**Is it Friable?** No  
**Original Inspection Date** 12/6/2010  
**Current Surveillance Date** 4/21/2014  
**Current Assessment Rating** NR Not Rated  
**Cause of Damage**  
**Accessible** Yes  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M

**Inspector**



---

Jeffrey P. Rechten

**State** Indiana  
**Accreditation Number** 19A003594

## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Charlestown Senior High School  
**HA#** H  
**Type of Material** Miscellaneous Material  
**Quantity of Material** Each 4

**Material Location**  
Auditorium above the stage

**Material Description**  
Fire rated doors

**Comments**  
The inspector noted these during the 12/06/2010 inspection as suspect ACM. They will remain in the management plan until properly sampled.

**Does Material Contain Asbestos?** Assumed  
**Is it Friable?** No  
**Original Inspection Date** 12/6/2010  
**Current Surveillance Date** 4/21/2014  
**Current Assessment Rating** NR Not Rated  
**Cause of Damage**  
**Accessible** Yes  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M

**Inspector**



---

Jeffrey P. Rechtin

**State** Indiana  
**Accreditation Number** 19A003594

## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Charlestown Senior High School  
**HA#** I  
**Type of Material** Miscellaneous Material  
**Quantity of Material** Unquantified SF

**Material Location**

Stairs to upper level - catwalk for auditorium

**Material Description**

Vinyl Stair treads

**Comments**

This material was discovered during the June 2011 6 month surveillance and will remain in the management plan until sampled properly.

**Does Material Contain Asbestos?** Assumed  
**Is it Friable?** No  
**Original Inspection Date** 6/27/2011  
**Current Surveillance Date** 4/21/2014  
**Current Assessment Rating** NA Not Applicable  
**Cause of Damage** No Damage  
**Accessible** Yes  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M

**Inspector**



---

Jeffrey P. Rechten

**State** Indiana  
**Accreditation Number** 19A003594

## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Charlestown Senior High School  
**HA#** J  
**Type of Material** Miscellaneous Material  
**Quantity of Material** Unquantified SF

**Material Location**

Stairs to upper level catwalk for auditorium.

**Material Description**

Stair tread mastic

**Comments**

This material was discovered during the June 2011 6 month surveillance and will remain in the management plan until sampled properly.

**Does Material Contain Asbestos?** Assumed  
**Is it Friable?** No  
**Original Inspection Date** 6/28/2011  
**Current Surveillance Date** 4/21/2014  
**Current Assessment Rating** NA Not Applicable  
**Cause of Damage** No Damage  
**Accessible** No  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M

**Inspector**



---

Jeffrey P. Rechlin

**State** Indiana  
**Accreditation Number** 19A003594

## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Charlestown Senior High School  
**HA#** F

**Type of Material** Miscellaneous Material

**Quantity of Material** Unquantified LF

**Material Location**

Auditorium-Stage light wiring, upper level lighting (material can only be viewing from above the stage/catwalk)

**Material Description**

Stage light wiring insulation

**Comments**

This material was noted by the inspector during the 12/06/2010 and will remaining in the managment plan until properly sampled. Lights all appear to be out of service/disconnected. Some are laying on the landing floor.

**Does Material Contain Asbestos?** Assumed

**Is It Friable?** Yes

**Original Inspection Date** 12/6/2010

**Current Surveillance Date** 10/24/2013

**Current Assessment Rating** NR Not Rated

**Cause of Damage**


**Accessible** No

**Potential for Damage** Low

**Removed** No

**Planned Response Action** O & M

**Inspector**



Jeffrey P. Rechtin

**State** Indiana

**Accreditation Number** 19A003594

## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Charlestown Senior High School  
**HA#** G  
**Type of Material** Miscellaneous Material  
**Quantity of Material** Unquantified Each  
**Material Location**

Auditorium Stage

**Material Description**


Stage fire curtain-off white

**Comments**

This was noted by the inspector during the 12/06/2010 as suspect ACM therefore it will remain in the management plan for informational purposes. Only Building materials are required to be in the AHERA Management Plan.

**Does Material Contain Asbestos?** Assumed  
**Is It Friable?** No  
**Original Inspection Date** 12/6/2010  
**Current Surveillance Date** 10/24/2013  
**Current Assessment Rating** NR Not Rated  
**Cause of Damage**  
**Accessible** Yes  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M

**Inspector**



Jeffrey P. Rechten

**State** Indiana  
**Accreditation Number** 19A003594



## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Charlestown Senior High School  
**HA#** H  
**Type of Material** Miscellaneous Material  
**Quantity of Material** Each 4  
**Material Location**

Auditorium above the stage

**Material Description**

Fire rated doors

**Comments**

The inspector noted these during the 12/06/2010 inspection as suspect ACM. They will remain in the management plan until properly sampled.

**Does Material Contain Asbestos?** Assumed  
**Is it Friable?** No  
**Original Inspection Date** 12/6/2010  
**Current Surveillance Date** 10/24/2013  
**Current Assessment Rating** NR Not Rated  
**Cause of Damage**  
**Accessible** Yes  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M

**Inspector**



---

Jeffrey P. Rechten

**State** Indiana  
**Accreditation Number** 19A003594

## PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools  
Building Name Charlestown Senior High School  
HA# I

Type of Material Miscellaneous Material

Quantity of Material Unquantified SF

**Material Location**

Stairs to upper level - catwalk for auditorium

**Material Description**

Vinyl Stair treads

**Comments**

This material was discovered during the June 2011 6 month surveillance and will remain in the management plan until sampled properly.

Does Material Contain Asbestos? Assumed

Is it Friable? No

Original Inspection Date 6/27/2011

Current Surveillance Date 10/24/2013

Current Assessment Rating NA Not Applicable

Cause of Damage No Damage


Accessible Yes

Potential for Damage Low

Removed No

Planned Response Action O & M

Inspector



Jeffrey P. Rechten

State Indiana

Accreditation Number 19A003594

## PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools  
Building Name Charlestown Senior High School  
HA# J

Type of Material Miscellaneous Material

Quantity of Material Unquantified SF

**Material Location**

Stairs to upper level catwalk for auditorium.

**Material Description**

Stair tread mastic

**Comments**

This material was discovered during the June 2011 6 month surveillance and will remain in the management plan until sampled properly.

Does Material Contain Asbestos? Assumed

Is it Friable? No

Original Inspection Date 6/28/2011

Current Surveillance Date 10/24/2013

Current Assessment Rating NA Not Applicable

Cause of Damage No Damage


Accessible No

Potential for Damage Low

Removed No

Planned Response Action O & M

Inspector



Jeffrey P. Rechten

State Indiana

Accreditation Number 19A003594

## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Charlestown Senior High School  
**HA#** F  
**Type of Material** Miscellaneous Material  
**Quantity of Material** Unquantified LF

**Material Location**

Auditorium-Stage light wiring, upper level lighting (material can only be viewing from above the stage/catwalk)

**Material Description**

Stage light wiring insulation

**Comments**

This material was noted by the inspector during the 12/06/2010 and will remaining in the managment plan until properly sampled. Lights all appear to be out of service/disconnected. Some are laying on the landing floor.

**Does Material Contain Asbestos?** Assumed  
**Is it Friable?** Yes  
**Original Inspection Date** 12/6/2010  
**Current Surveillance Date** 10/24/2012  
**Current Assessment Rating** NR Not Rated  
**Cause of Damage**  
**Accessible** No  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M

**Inspector**

  
\_\_\_\_\_  
Jeffrey P. Rehtin

**State** Indiana  
**Accreditation Number** 19A003594

## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Charlestown Senior High School  
**HA#** G  
**Type of Material** Miscellaneous Material  
**Quantity of Material** Unquantified Each  
**Material Location**

Auditorium Stage

**Material Description**

Stage fire curtain-off white

**Comments**

This was noted by the inspector during the 12/06/2010 as suspect ACM therefore it will remain in the management plan for informational purposes. Only Building materials are required to be in the AHERA Mangagement Plan.

**Does Material Contain Asbestos?** Assumed  
**Is it Friable?** No  
**Original Inspection Date** 12/6/2010  
**Current Surveillance Date** 10/24/2012  
**Current Assessment Rating** NR Not Rated  
**Cause of Damage**  
**Accessible** Yes  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M

**Inspector**

  
\_\_\_\_\_  
Jeffrey P. Rehtin

**State** Indiana  
**Accreditation Number** 19A003594

## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Charlestown Senior High School  
**HA#** H  
**Type of Material** Miscellaneous Material  
**Quantity of Material** Each 4  
**Material Location**

Auditorium above the stage

**Material Description**

Fire rated doors

**Comments**

The inspector noted these during the 12/06/2010 inspection as suspect ACM. They will remain in the management plan until properly sampled.

**Does Material Contain Asbestos?** Assumed  
**Is it Friable?** No  
**Original Inspection Date** 12/6/2010  
**Current Surveillance Date** 10/24/2012  
**Current Assessment Rating** NR Not Rated  
**Cause of Damage**  
**Accessible** Yes  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M

**Inspector**

  
\_\_\_\_\_  
Jeffrey P. Rehtin

**State** Indiana  
**Accreditation Number** 19A003594

## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Charlestown Senior High School  
**HA#** I

**Type of Material** Miscellaneous Material

**Quantity of Material** Unquantified SF

**Material Location**

Stairs to upper level - catwalk for auditorium

**Material Description**

Vinyl Stair treads

**Comments**

This material was discovered during the June 2011 6 month surveillance and will remain in the management plan until sampled properly.

**Does Material Contain Asbestos?** Assumed

**Is it Friable?** No

**Original Inspection Date** 6/27/2011

**Current Surveillance Date** 10/24/2012

**Current Assessment Rating** NA Not Applicable

**Cause of Damage** No Damage

**Accessible** Yes

**Potential for Damage** Low

**Removed** No

**Planned Response Action** O & M

**Inspector**

  
\_\_\_\_\_  
Jeffrey P. Rechten

**State** Indiana

**Accreditation Number** 19A003594

## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Charlestown Senior High School  
**HA#** J  
**Type of Material** Miscellaneous Material  
**Quantity of Material** Unquantified SF  
**Material Location**

Stairs to upper level catwalk for auditorium.

**Material Description**

Stair tread mastic

**Comments**

This material was discovered during the June 2011 6 month surveillance and will remain in the management plan until sampled properly.

**Does Material Contain Asbestos?** Assumed  
**Is it Friable?** No  
**Original Inspection Date** 6/28/2011  
**Current Surveillance Date** 10/24/2012  
**Current Assessment Rating** NA Not Applicable  
**Cause of Damage** No Damage  
**Accessible** No  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M

**Inspector**



---

Jeffrey P. Rechtin

**State** Indiana  
**Accreditation Number** 19A003594



## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Charlestown Senior High School  
**HA#** F  
**Type of Material** Miscellaneous Material  
**Quantity of Material** Unquantified LF

**Material Location**

Auditorium-Stage light wiring, upper level lighting (material can only be viewing from above the stage/catwalk)

**Material Description**

Stage light wiring insulation

**Comments**

This material was noted by the inspector during the 12/06/2010 and will remaining in the managment plan until properly sampled. Lights all appear to be out of service/disconnected. Some are laying on the landing floor.

**Does Material Contain Asbestos?** Assumed  
**Is it Friable?** Yes  
**Original Inspection Date** 12/6/2010  
**Current Surveillance Date** 6/25/2012  
**Current Assessment Rating** NR Not Rated  
**Cause of Damage**  
**Accessible** No  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M

**Inspector**

  
Jeffery P. Rechten

**State** Indiana  
**Accreditation Number** 19A003594

## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Charlestown Senior High School  
**HA#** G  
**Type of Material** Miscellaneous Material  
**Quantity of Material** Unquantified Each  
**Material Location**

Auditorium Stage

**Material Description**

Stage fire curtain-off white

**Comments**

This was noted by the inspector during the 12/06/2010 as suspect ACM therefore it will remain in the management plan for informational purposes. Only Building materials are required to be in the AHERA Management Plan.

**Does Material Contain Asbestos?** Assumed  
**Is it Friable?** No  
**Original Inspection Date** 12/6/2010  
**Current Surveillance Date** 6/25/2012  
**Current Assessment Rating** NR Not Rated  
**Cause of Damage**  
**Accessible** Yes  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M

**Inspector**

  
Jeffery P. Rehtin

**State** Indiana  
**Accreditation Number** 19A003594

## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Charlestown Senior High School  
**HA#** H  
**Type of Material** Miscellaneous Material  
**Quantity of Material** Each 4

**Material Location**  
Auditorium above the stage


**Material Description**  
Fire rated doors

**Comments**

The inspector noted these during the 12/06/2010 inspection as suspect ACM. They will remain in the management plan until properly sampled.

**Does Material Contain Asbestos?** Assumed  
**Is it Friable?** No  
**Original Inspection Date** 12/6/2010  
**Current Surveillance Date** 6/25/2012  
**Current Assessment Rating** NR Not Rated  
**Cause of Damage**  
**Accessible** Yes  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M

**Inspector**

  
Jeffery P. Rehtin

**State** Indiana  
**Accreditation Number** 19A003594

## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Charlestown Senior High School  
**HA#** I

**Type of Material** Miscellaneous Material

**Quantity of Material** Unquantified SF

**Material Location**

Stairs to upper level - catwalk for auditorium

**Material Description**

Vinyl Stair treads

**Comments**

This material was discovered during the June 2011 6 month surveillance and will remain in the management plan until sampled properly.

**Does Material Contain Asbestos?** Assumed

**Is it Friable?** No

**Original Inspection Date** 6/27/2011

**Current Surveillance Date** 6/25/2012

**Current Assessment Rating** NA Not Applicable

**Cause of Damage** No Damage


**Accessible** Yes

**Potential for Damage** Low

**Removed** No

**Planned Response Action** O & M

**Inspector**

  
Jeffery P. Rechten

**State** Indiana

**Accreditation Number** 19A003594

## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Charlestown Senior High School  
**HA#** J  
**Type of Material** Miscellaneous Material  
**Quantity of Material** Unquantified SF


**Material Location**  
Stairs to upper level catwalk for auditorium.

**Material Description**  
Stair tread mastic

**Comments**  
This material was discovered during the June 2011 6 month surveillance and will remain in the management plan until sampled properly.

**Does Material Contain Asbestos?** Assumed  
**Is it Friable?** No  
**Original Inspection Date** 6/28/2011  
**Current Surveillance Date** 6/25/2012  
**Current Assessment Rating** NA Not Applicable  
**Cause of Damage** No Damage  
**Accessible** No  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M

**Inspector**

  
Jeffery P. Reecht

**State** Indiana  
**Accreditation Number** 19A003594

## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Charlestown Senior High School  
**HA#** F  
**Type of Material** Miscellaneous Material  
**Quantity of Material** Unquantified LF

**Material Location**

Auditorium-Stage light wiring, upper level lighting (material can only be viewing from above the stage/catwalk)

**Material Description**

Stage light wiring insulation

**Comments**

This material was noted by the inspector during the 12/06/2010 and will remaining in the managment plan until properly sampled. Lights all appear to be out of service/disconnected. Some are laying on the landing floor.

**Does Material Contain Asbestos?** Assumed  
**Is it Friable?** Yes  
**Original Inspection Date** 12/6/2010  
**Current Surveillance Date** 12/15/2011  
**Current Assessment Rating** NR Not Required  
**Cause of Damage**  
**Accessible** No  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M

**Inspector**

  
Sandra Shadley

**State** Indiana  
**Accreditation Number** 19A002323

## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Charlestown Senior High School  
**HA#** G  
**Type of Material** Miscellaneous Material  
**Quantity of Material** Unquantified Each

**Material Location**

Auditorium Stage

**Material Description**

Stage fire curtain-off white

**Comments**

This was noted by the inspector during the 12/06/2010 as suspect ACM therefore it will remain in the management plan for informational purposes. Only Building materials are required to be in the AHERA Management Plan.

**Does Material Contain Asbestos?** Assumed  
**Is it Friable?** No  
**Original Inspection Date** 12/6/2010  
**Current Surveillance Date** 12/15/2011  
**Current Assessment Rating** NR Not Required  
**Cause of Damage**  
**Accessible** Yes  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M

**Inspector**

  
Sandra Shadley

**State** Indiana  
**Accreditation Number** 19A002323

## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Charlestown Senior High School  
**HA#** H  
**Type of Material** Miscellaneous Material  
**Quantity of Material** Each 4

**Material Location**  
Auditorium above the stage


**Material Description**  
Fire rated doors

**Comments**

The inspector noted these during the 12/06/2010 inspection as suspect ACM. They will remain in the management plan until properly sampled.

**Does Material Contain Asbestos?** Assumed  
**Is it Friable?** No  
**Original Inspection Date** 12/6/2010  
**Current Surveillance Date** 12/15/2011  
**Current Assessment Rating** NR Not Required  
**Cause of Damage**  
**Accessible** Yes  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M

**Inspector**

  
Sandra Shadley

**State** Indiana  
**Accreditation Number** 19A002323



## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Charlestown Senior High School  
**HA#** 1  
**Type of Material** Miscellaneous Material  
**Quantity of Material** Unquantified SF

**Material Location**  
Stairs to upper level - catwalk for auditorium

**Material Description**  
Vinyl Stair treads

**Comments**  
This material was discovered during the June 2011 6 month surveillance and will remain in the management plan until sampled properly.

**Does Material Contain Asbestos?** Assumed  
**Is it Friable?** No  
**Original Inspection Date** 6/27/2011  
**Current Surveillance Date** 12/15/2011  
**Current Assessment Rating** NA Not Applicable  
**Cause of Damage** No Damage  
**Accessible** Yes  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M

**Inspector**

  
Sandra Shadley

**State** Indiana  
**Accreditation Number** 19A002323

## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Charlestown Senior High School  
**HA#** J  
**Type of Material** Miscellaneous Material  
**Quantity of Material** Unquantified SF

**Material Location**

Stairs to upper level catwalk for auditorium.

**Material Description**

Stair tread mastic

**Comments**

This material was discovered during the June 2011 6 month surveillance and will remain in the management plan until sampled properly.

**Does Material Contain Asbestos?** Assumed  
**Is it Friable?** No  
**Original Inspection Date** 6/28/2011  
**Current Surveillance Date** 12/15/2011  
**Current Assessment Rating** NA Not Applicable  
**Cause of Damage** No Damage  
**Accessible** No  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M

**Inspector**

  
Sandra Shadley

**State** Indiana  
**Accreditation Number** 19A002323

## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools

**Building Name** Charlestown Middle School

**HA#** L

**Type of Material** Thermal System Insulation

**Quantity of Material** Unquantified LF

**Material Location**

Kiln insulation in D206 (33 year old Kiln)

**Material Description**

Kiln insulation

**Comments**

This material was not assessed in the original inspection and will be added to the management plan until properly sampled.

**Does Material Contain Asbestos?** Assumed

**Is it Friable?** No

**Original Inspection Date** 12/15/2011

**Current Surveillance Date** 12/15/2011

**Current Assessment Rating** NR Not Required

**Cause of Damage** No Damage


**Accessible** Yes

**Potential for Damage** Low

**Removed** No

**Planned Response Action** O & M

**Inspector**

  
Sandra Shadley

**State** Indiana

**Accreditation Number** 19A002323

## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools

**Building Name** Charlestown Middle School

**HA#** B

**Type of Material** Miscellaneous Material

**Quantity of Material** Approx. 1,370 SF

**Material Location**

Throughout the building

**Material Description**

Cove base mastic

**Comments**

This material was not exposed to inspect except for one column post at doorway of room D-127. The mastic has been painted over.

**Does Material Contain Asbestos?** Assumed

**Is it Friable?** No

**Original Inspection Date** 5/31/1995

**Current Surveillance Date** 12/15/2011

**Current Assessment Rating** NR Not Required

**Cause of Damage** No Damage


**Accessible** No

**Potential for Damage** Low

**Removed** No

**Planned Response Action** O & M

**Inspector**

  
Sandra Shadley


**State** Indiana

**Accreditation Number** 19A002323

## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Charlestown Middle School  
**HA#** 03  
**Type of Material** Miscellaneous Material  
**Quantity of Material** 2,229 SF  
**Material Location**  
Throughout the building  
**Material Description**  
Floor tile mastic  
**Comments**  
This material was not exposed to inspect.  
**Does Material Contain Asbestos?** Assumed  
**Is it Friable?** No  
**Original Inspection Date** 6/1/1988  
**Current Surveillance Date** 12/15/2011  
**Current Assessment Rating** NR Not Required  
**Cause of Damage** No Damage  
**Accessible** No  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M

**Inspector**

  
Sandra Shadley

**State** Indiana  
**Accreditation Number** 19A002323

## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools

**Building Name** Charlestown Middle School

**HA#** A

**Type of Material** Miscellaneous Material

**Quantity of Material** Approx. 4,100 LF

**Material Location**

Throughout the building, some classrooms, library and mechanical area and upper gym.

**Material Description**

Cove base molding (color other than black)

**Comments**

The black color base has been recently installed to replace sections of the old molding that were missing. This material was not in poor condition overall.

**Does Material Contain Asbestos?** Assumed

**Is it Friable?** No

**Original Inspection Date** 5/31/1995

**Current Surveillance Date** 12/15/2011

**Current Assessment Rating** NR Not Required

**Cause of Damage** No Damage


**Accessible** Yes

**Potential for Damage** Low

**Removed** No

**Planned Response Action** O & M

**Inspector**



Sandra Shadley

**State** Indiana

**Accreditation Number** 19A002323

## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools

**Building Name** Charlestown Middle School

**HA#** D

**Type of Material** Miscellaneous Material

**Quantity of Material** Unquantified Each

**Material Location**

Mechanical wing, kitchen area, gym wing and throughout the building.

**Material Description**

Fire Doors-Metal clad

**Comments**

Fire doors were not assessed in the original inspection and are suspect for asbestos.  
These will be assumed to be ACM until properly sampled.

**Does Material Contain Asbestos?** Assumed

**Is it Friable?** No

**Original Inspection Date** 6/30/2010

**Current Surveillance Date** 12/15/2011

**Current Assessment Rating** NR Not Required

**Cause of Damage**

**Accessible** Yes

**Potential for Damage** Low

**Removed** No

**Planned Response Action** O & M

**Inspector**

  
Sandra Shadley

**State** Indiana

**Accreditation Number** 19A002323

## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools

**Building Name** Charlestown Middle School

**HA#** E

**Type of Material** Miscellaneous Material

**Quantity of Material** 11 EA

**Material Location**

Stage

**Material Description**

Stage light wiring

**Comments**

This material was discovered during the June surveillance and will remain in the management plan until properly tested.

**Does Material Contain Asbestos?** Assumed

**Is it Friable?** No

**Original Inspection Date** 6/27/2011

**Current Surveillance Date** 12/15/2011

**Current Assessment Rating** 7 Any Remaining Friable ACBM or Friable Suspected ACBM

**Cause of Damage** No Damage


**Accessible** Yes

**Potential for Damage** Low

**Removed** No

**Planned Response Action** O & M

**Inspector**


  
Sandra Shadley

**State** Indiana

**Accreditation Number** 19A002323



## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Charlestown Middle School  
**HA#** F  
**Type of Material** Miscellaneous Material  
**Quantity of Material** Unquantified SF  
**Material Location**  
Stairs near gym  
**Material Description**  
Orange vinyl stair treads  
**Comments**  
Some treads are cracked and chipped around the edges, but still remain in tact.  
**Does Material Contain Asbestos?** Assumed  
**Is it Friable?** No  
**Original Inspection Date** 6/27/2011  
**Current Surveillance Date** 12/15/2011  
**Current Assessment Rating** NR Not Required  
**Cause of Damage** Deterioration & Physical Contact  
**Accessible** Yes  
**Potential for Damage** L  
**Removed** No  
**Planned Response Action** O & M  
  
**Inspector**   
Sandra Shadley  
  
**State** Indiana  
**Accreditation Number** 19A002323

## PERIODIC SURVEILLANCE REPORT

<b>LEA Name</b>	Greater Clark County Schools	
<b>Building Name</b>	Charlestown Middle School	
<b>HA#</b>	G	
<b>Type of Material</b>	Miscellaneous Material	
<b>Quantity of Material</b>	Unquantified LF	
<b>Material Location</b>	Stairs near gym	
<b>Material Description</b>	Stair tread mastic	
<b>Comments</b>	This material was not visible to inspect.	
<b>Does Material Contain Asbestos?</b>	Assumed	
<b>Is it Friable?</b>	No	
<b>Original Inspection Date</b>	6/27/2011	
<b>Current Surveillance Date</b>	12/15/2011	
<b>Current Assessment Rating</b>	NR	Not Required
<b>Cause of Damage</b>		
<b>Accessible</b>	No	
<b>Potential for Damage</b>	Low	
<b>Removed</b>	No	
<b>Planned Response Action</b>	O & M	

**Inspector**

  
Sandra Shadley

<b>State</b>	Indiana
<b>Accreditation Number</b>	19A002323

## PERIODIC SURVEILLANCE REPORT


**LEA Name** Greater Clark County Schools  
**Building Name** Charlestown Middle School  
**HA#** H  
**Type of Material** Miscellaneous Material  
**Quantity of Material** Unquantified Each  
**Material Location**  
On older ductwork (painted green) above gym & upper gym  
**Material Description**  
AHU expansion joints

**Comments**

This material was not accessible.

**Does Material Contain Asbestos?** Assumed  
**Is it Friable?** No  
**Original Inspection Date** 6/27/2011  
**Current Surveillance Date** 12/15/2011  
**Current Assessment Rating** NR Not Required  
**Cause of Damage** No Damage  
**Accessible** Yes  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M

**Inspector**

  
Sandra Shadley

**State** Indiana  
**Accreditation Number** 19A002323

## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools

**Building Name** Charlestown Middle School

**HA#** I

**Type of Material** Miscellaneous Material

**Quantity of Material** Unquantified EA

**Material Location**

Science lab

**Material Description**

Black sink insulation

**Comments**

This material was not noted in the original inspection and is suspect material; therefore is added to the Management Plan until properly tested.

**Does Material Contain Asbestos?** Assumed

**Is it Friable?** No

**Original Inspection Date** 6/27/2011

**Current Surveillance Date** 12/15/2011

**Current Assessment Rating** NR Not Required

**Cause of Damage** No Damage

**Accessible** Yes

**Potential for Damage** Low

**Removed** No

**Planned Response Action** O & M

**Inspector**

  
Sandra Shadley

**State** Indiana

**Accreditation Number** 19A002323

## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools

**Building Name** Charlestown Middle School

**HA#** J

**Type of Material** Miscellaneous Material

**Quantity of Material** Unquantified Each

**Material Location**  
Science lab

**Material Description**  
Sink tops

**Comments**

This material was not noted in the original inspection and is suspect material; therefore is added to the Management Plan until properly tested. KILN Insulation in D206. (33 yrold kiln) Assumed 12-15-11

**Does Material Contain Asbestos?** Assumed

**Is it Friable?** No

**Original Inspection Date** 6/27/2011

**Current Surveillance Date** 12/15/2011

**Current Assessment Rating** NR Not Required

**Cause of Damage** No Damage


**Accessible** Yes

**Potential for Damage** Low

**Removed** No

**Planned Response Action** O & M

**Inspector**

  
Sandra Shadley

**State** Indiana

**Accreditation Number** 19A002323

## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools

**Building Name** Charlestown Middle School

**HA#** K

**Type of Material** Miscellaneous Material

**Quantity of Material** Unquantified Each

**Material Location**

Science lab

**Material Description**

Fume hood bases

**Comments**

This material was not noted in the original inspection and is suspect material; therefore is added to the Management Plan until properly tested.

**Does Material Contain Asbestos?** Assumed

**Is it Friable?** No

**Original Inspection Date** 6/27/2011

**Current Surveillance Date** 12/15/2011

**Current Assessment Rating** NR Not Required

**Cause of Damage** No Damage


**Accessible** Yes

**Potential for Damage** Low

**Removed** No

**Planned Response Action** O & M

**Inspector**

  
Sandra Shadley

**State** Indiana

**Accreditation Number** 19A002323

## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools

**Building Name** Charlestown Middle School

**HA#** M

**Type of Material** Miscellaneous Material

**Quantity of Material** Unquantified SF

**Material Location**

Painted green in upper gym mechanical areas

**Material Description**

Duct wrap/tape

**Comments**

This material was not assessed in the original inspection and will be added to the management plan until properly sampled.

**Does Material Contain Asbestos?** Assumed

**Is it Friable?** No

**Original Inspection Date** 12/15/2011

**Current Surveillance Date** 12/15/2011

**Current Assessment Rating** 7 Any Remaining Friable ACBM or Friable Suspected ACBM

**Cause of Damage** No Damage


**Accessible** Yes

**Potential for Damage** Low

**Removed** No

**Planned Response Action** O & M

**Inspector**



Sandra Shadley

**State** Indiana

**Accreditation Number** 19A002323

**Greater Clark County Schools**  
**Remaining Materials Report**  
**December 15, 2011**

HA#	Material	Quantity	ACBM Y/A	Location	Planned Activities
<b><u>Charlestown Middle School</u></b>					
03	Floor tile mastic	2,229 SF	A	Throughout the building	O & M
A	Cove base molding (color other than black)	Approx. 4,100 LF	A	Throughout the building, some classrooms, library and mechanical area and upper gym.	O & M
B	Cove base mastic	Approx. 1,370 SF	A	Throughout the building	O & M
D	Fire Doors-Metal clad	Unquantified Eac	A	Mechanical wing, kitchen area, gym wing and throughout the building.	O & M
E	Stage light wiring	11 EA	A	Stage	O & M
F	Orange vinyl stair treads	Unquantified SF	A	Stairs near gym	O & M
G	Stair tread mastic	Unquantified LF	A	Stairs near gym	O & M
H	AHU expansion joints	Unquantified Eac	A	On older ductwork painted green above gym & upper gym	O & M
I	Black sink insulation	Unquantified EA	A	Science lab	O & M
J	Sink tops	Unquantified Eac	A	Science lab	O & M
K	Fume hood bases	Unquantified Eac	A	Science lab	O & M
L	Kiln insulation	Unquantified LF	A	Kiln insulation in D206 (33 year old Kiln)	O & M
M	Duct wrap/tape	Unquantified SF	A	Painted green in upper gym mechanical areas	O & M



**AMENDMENT TO MANAGEMENT PLAN**


**Building Name -** Charlestown Middle School

**Subject -** Addition of Homogeneous Area M

**Amendment -** Duct wrap/tape in the upper gym mechanical area was noted during the December 2011 surveillance and was not included in the original inspection. This material is suspect to contain asbestos; therefore, it is being added to the management plan until properly sampled.

Management Planner: Sandra Shadley

Accreditation Number: 19A002720

  
Signature

  
Date

**AMENDMENT TO MANAGEMENT PLAN**


**Building Name -** Charlestown Middle School


**Subject -** Addition of Homogeneous Area L

**Amendment -** Kiln insulation in D206 was noted during the December 2011 surveillance and was not included in the original inspection. This material is suspect to contain asbestos; therefore, it is being added to the management plan until properly sampled.


Management Planner: Sandra Shadley

Accreditation Number: 19A002720

  
Signature

  
Date

## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Charlestown Senior High School  
**HA#** F  
**Type of Material** Miscellaneous Material  
**Quantity of Material** Unquantified LF  
**Material Location**  
Auditorium-Stage light wiring, upper level lighting (material can only be viewing from above the stage/catwalk)  
**Material Description**  
Stage light wiring insulation  
**Comments**  
This material was noted by the inspector during the 12/06/2010 and will remaining in the managment plan until properly sampled.  
**Does Material Contain Asbestos?** Assumed  
**Is it Friable?** Yes  
**Original Inspection Date** 12/6/2010  
**Current Surveillance Date** 6/27/2011  
**Current Assessment Rating** NR Not Required  
**Cause of Damage**  
**Accessible** No  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M  
**Inspector**  
  
Sandra Shadley  
**State** Indiana  
**Accreditation Number** 19A002323

## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Charlestown Senior High School  
**HA#** G  
**Type of Material** Miscellaneous Material  
**Quantity of Material** Unquantified Each

**Material Location**

Auditorium Stage

**Material Description**


Stage fire curtain-off white

**Comments**

This was noted by the inspector during the 12/06/2010 as suspect ACM therefore it will remain in the management plan.

**Does Material Contain Asbestos?** Assumed  
**Is it Friable?** No  
**Original Inspection Date** 12/6/2010  
**Current Surveillance Date** 6/27/2011  
**Current Assessment Rating** NR Not Required  
**Cause of Damage**  
**Accessible** Yes  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M

**Inspector**

  
Sandra Shadley

**State** Indiana  
**Accreditation Number** 19A002323

## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Charlestown Senior High School  
**HA#** H  
**Type of Material** Miscellaneous Material  
**Quantity of Material** Each 4

**Material Location**  
Auditorium above the stage

**Material Description**  
Fire rated doors

**Comments**

The inspector noted these during the 12/06/2010 inspection as suspect ACM. They will remain in the management plan until properly sampled.

**Does Material Contain Asbestos?** Assumed  
**Is it Friable?** No  
**Original Inspection Date** 12/6/2010  
**Current Surveillance Date** 6/27/2011  
**Current Assessment Rating** NR Not Required  
**Cause of Damage**  
**Accessible** Yes  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M

**Inspector**

  
Sandra Shadley

**State** Indiana  
**Accreditation Number** 19A002323

## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Charlestown Senior High School  
**HA#** I  
**Type of Material** Miscellaneous Material  
**Quantity of Material** Unquantified SF

**Material Location**

Stairs to upper level - catwalk for auditorium

**Material Description**


Vinyl Stair treads

**Comments**

This material was discovered during the June 2011 6 month surveillance and will remain in the management plan until sampled properly.

**Does Material Contain Asbestos?** Assumed  
**Is it Friable?** No  
**Original Inspection Date** 6/27/2011  
**Current Surveillance Date** 6/27/2011  
**Current Assessment Rating** NA Not Applicable  
**Cause of Damage** No Damage  
**Accessible** Yes  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M

**Inspector**

  
Sandra Shadley

**State** Indiana  
**Accreditation Number** 19A002323

## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Charlestown Senior High School  
**HA#** J  
**Type of Material** Miscellaneous Material  
**Quantity of Material** Unquantified SF

**Material Location**  
Stairs to upper level catwalk for auditorium.

**Material Description**  
Stair tread mastic

**Comments**

This material was discovered during the June 2011 6 month surveillance and will remain in the management plan until sampled properly.

**Does Material Contain Asbestos?** Assumed  
**Is it Friable?** No  
**Original Inspection Date** 6/28/2011  
**Current Surveillance Date** 6/28/2011  
**Current Assessment Rating** NA Not Applicable  
**Cause of Damage** No Damage  
**Accessible** No  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M

**Inspector**

  
Sandra Shadley

**State** Indiana  
**Accreditation Number** 19A002323

## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Charlestown Senior High School  
**HA#** 03  
**Type of Material** Thermal Material  
**Quantity of Material** Unquantified LF  
**Material Location**

Tunnel exterior

**Material Description**


Pipe insulation - on pipes buried underneath the tunnels and outside the tunnel walls

**Comments**

There was additional pipe insulation discovered on overhead heat lines in the original gym and in inaccessible areas (pipe chases, above ceilings, and in wall cavities) throughout the entire original building. Most of the asbestos-containing pipe insulation was abated during the abatement project of 2009 through June 2010 by licensed contractors. The only remaining material at the time of this inspection was on pipe buried beneath and on the sides of the tunnels. This material is scheduled to be removed during the last phase of the 2010 demolition project.

**Does Material Contain Asbestos?** Yes  
**Is it Friable?** No  
**Original Inspection Date** 6/1/1992  
**Current Surveillance Date** 12/6/2010  
**Current Assessment Rating** NR Not Required  
**Cause of Damage** No Damage  
**Accessible** No  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M

**Inspector**

  
Paul W. Krick

**State** Indiana  
**Accreditation Number** 197812124



## PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools  
Building Name Charlestown Senior High School

HA# 03

Type of Material Thermal Material

Quantity of Material 3,978 LF

Material Location

Tunnels and boiler room

Material Description

Pipe insulation (heat)

Comments

The tunnels are restricted. Overall, this material was not in poor condition. There is also suspect pipe insulation in the gym.

Does Material Contain Asbestos? Yes

Is it Friable? No

Original Inspection Date 6/1/1992

Current Surveillance Date 12/3/2009

Current Assessment Rating NR Not Required

Cause of Damage No Damage


Accessible Yes

Potential for Damage Low

Removed No

Planned Response Action O & M

Inspector

  
George William Ogle


State

Indiana

Accreditation Number

191003027

## PERIODIC SURVEILLANCE REPORT

LEA Name	Greater Clark County Schools	
Building Name	Charlestown Senior High School	
HA#	04	
Type of Material	Thermal Material	
Quantity of Material	600 SF	
Material Location	Boiler room	
Material Description	Stack insulation (breeching)	
Comments	The insulation is not in poor condition.	
Does Material Contain Asbestos?	Yes	
Is it Friable?	No	
Original Inspection Date	6/1/1992	
Current Surveillance Date	12/3/2009	
Current Assessment Rating	NR	Not Required
Cause of Damage	No Damage	
Accessible	Yes	
Potential for Damage	Med	
Removed	No	
Planned Response Action	O & M	
Inspector	 George William Ogle	
State	Indiana	
Accreditation Number	191003027	

## PERIODIC SURVEILLANCE REPORT

LEA Name	Greater Clark County Schools	
Building Name	Charlestown Senior High School	
HA#	06	
Type of Material	Thermal Material	
Quantity of Material	293 Each	
Material Location	Throughout the building	
Material Description	Fittings	
Comments	Fittings are not in poor condition overall.	
Does Material Contain Asbestos?	Yes	
Is it Friable?	No	
Original Inspection Date	6/1/1992	
Current Surveillance Date	12/3/2009	
Current Assessment Rating	NR	Not Required
Cause of Damage	No Damage	
Accessible	Yes	
Potential for Damage	Med	
Removed	No	
Planned Response Action	O & M	

Inspector

  
George William Ogle


State

Indiana

Accreditation Number

191003027

## PERIODIC SURVEILLANCE REPORT

LEA Name	Greater Clark County Schools	
Building Name	Charlestown Senior High School	
HA#	A	
Type of Material	Miscellaneous Material	
Quantity of Material	Unquantified SF	
Material Location	Building exterior	
Material Description	Aggregate covered transite panels	
Comments	The panels are not in poor condition overall.	
Does Material Contain Asbestos?	Assumed	
Is it Friable?	No	
Original Inspection Date	7/19/2005	
Current Surveillance Date	12/3/2009	
Current Assessment Rating	NR	Not Required
Cause of Damage	No Damage	
Accessible	Yes	
Potential for Damage	Low	
Removed	No	
Planned Response Action	O & M	
Inspector	 George William Oggle	
State	Indiana	
Accreditation Number	191003027	

## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Charlestown Senior High School  
**HA#** 03  
**Type of Material** Thermal Material  
**Quantity of Material** 3,978 LF  
**Material Location**

Tunnels and boiler room

**Material Description**

Pipe insulation (heat)

**Comments**

The tunnels are restricted. Overall, this material was not in poor condition.

**Does Material Contain Asbestos?** Yes  
**Is it Friable?** No  
**Original Inspection Date** 6/1/1992  
**Current Surveillance Date** 6/11/2009  
**Current Assessment Rating** NR Not Required  
**Cause of Damage** No Damage  
**Accessible** Yes  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M

**Inspector**

  
George William Ogle

**State** IN  
**Accreditation Number** 191003027

## PERIODIC SURVEILLANCE REPORT

LEA Name	Greater Clark County Schools	
Building Name	Charlestown Senior High School	
HA#	04	
Type of Material	Thermal Material	
Quantity of Material	600 SF	
Material Location	Boiler room	
Material Description	Stack insulation (breaching)	
Comments	The insulation is not in poor condition.	
Does Material Contain Asbestos?	Yes	
Is It Friable?	No	
Original Inspection Date	6/1/1992	
Current Surveillance Date	6/11/2009	
Current Assessment Rating	NR	Not Required
Cause of Damage	No Damage	
Accessible	Yes	
Potential for Damage	Med	
Removed	No	
Planned Response Action	O & M	
Inspector	 George William Ogle	
State	IN	
Accreditation Number	191003027	

## PERIODIC SURVEILLANCE REPORT

LEA Name	Greater Clark County Schools
Building Name	Charlestown Senior High School
HA#	06
Type of Material	Thermal Material
Quantity of Material	293 Each
Material Location	Throughout the building
Material Description	Fittings
Comments	Fittings are not in poor condition overall.
Does Material Contain Asbestos?	Yes
Is It Friable?	No
Original Inspection Date	6/1/1992
Current Surveillance Date	6/11/2009
Current Assessment Rating	NR Not Required
Cause of Damage	No Damage
Accessible	Yes
Potential for Damage	Med
Removed	No
Planned Response Action	O & M

Inspector

  
George William Ogle

State

IN

Accreditation Number

191003027

## PERIODIC SURVEILLANCE REPORT

LEA Name	Greater Clark County Schools	
Building Name	Charlestown Senior High School	
HA#	A	
Type of Material	Miscellaneous Material	
Quantity of Material	Unquantified SF	
Material Location		
Building exterior		
Material Description		
Aggregate covered transite panels		
Comments		
The panels are not in poor condition overall.		
Does Material Contain Asbestos?	Assumed	
Is it Friable?	No	
Original Inspection Date	7/19/2005	
Current Surveillance Date	6/11/2009	
Current Assessment Rating	NR	Not Required
Cause of Damage	No Damage	
Accessible	Yes	
Potential for Damage	Low	
Removed	No	
Planned Response Action	O & M	

Inspector

  
George William Ogle

State

IN

Accreditation Number

191003027



## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Charlestown Senior High School  
**HA#** 03  
**Type of Material** Thermal Material  
**Quantity of Material** 3,978 LF  
**Material Location**  
Tunnels and boiler room  
**Material Description**  
Pipe insulation (heat)

**Comments**

The tunnels are restricted. Overall, this material was not in poor condition.

**Does Material Contain Asbestos?** Yes  
**Is It Friable?** No  
**Original Inspection Date** 6/1/1992  
**Current Surveillance Date** 12/10/2008  
**Current Assessment Rating** NR Not Required  
**Cause of Damage** No Damage  
**Accessible** Yes  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M

**Inspector**

  
George William Ogle

**State** Indiana  
**Accreditation Number** 191003027

## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Charlestown Senior High School  
**HA#** 04  
**Type of Material** Thermal Material  
**Quantity of Material** 600 SF  
**Material Location**  
Boiler room  
**Material Description**  
Stack insulation (breeching)  
**Comments**  
The insulation is not in poor condition.  
**Does Material Contain Asbestos?** Yes  
**Is It Friable?** No  
**Original Inspection Date** 6/1/1992  
**Current Surveillance Date** 12/10/2008  
**Current Assessment Rating** NR Not Required  
**Cause of Damage** No Damage  
**Accessible** Yes  
**Potential for Damage** Med  
**Removed** No  
**Planned Response Action** O & M

**Inspector**

  
George William Ogle

**State**

Indiana

**Accreditation Number**

191003027

## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Charlestown Senior High School  
**HA#** 06  
**Type of Material** Thermal Material  
**Quantity of Material** 293 Each  
**Material Location**  
Throughout the building  
**Material Description**  
Fittings  
**Comments**  
Fittings are not in poor condition overall.  
**Does Material Contain Asbestos?** Yes  
**Is it Friable?** No  
**Original Inspection Date** 6/1/1992  
**Current Surveillance Date** 12/10/2008  
**Current Assessment Rating** NR Not Required  
**Cause of Damage** No Damage  
**Accessible** Yes  
**Potential for Damage** Med  
**Removed** No  
**Planned Response Action** O & M

**Inspector**

  
George William Ogle

**State** Indiana  
**Accreditation Number** 191003027

## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Charlestown Senior High School  
**HA#** A  
**Type of Material** Miscellaneous Material  
**Quantity of Material** Unquantified SF  
**Material Location**  
Building exterior

**Material Description**

Aggregate covered transite panels

**Comments**

The panels are not in poor condition overall.

<b>Does Material Contain Asbestos?</b>	Assumed	
<b>Is It Friable?</b>	No	
<b>Original Inspection Date</b>	7/19/2005	
<b>Current Surveillance Date</b>	12/10/2008	
<b>Current Assessment Rating</b>	NR	Not Required
<b>Cause of Damage</b>	No Damage	
<b>Accessible</b>	Yes	
<b>Potential for Damage</b>	Low	
<b>Removed</b>	No	
<b>Planned Response Action</b>	O & M	

**Inspector**

  
George William Ogle

**State** Indiana  
**Accreditation Number** 191003027

## PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools  
Building Name Charlestown Senior High School  
HA# 03  
Type of Material Thermal Material  
Quantity of Material 3,978 LF  
Material Location

Tunnels and boiler room

**Material Description**


Pipe insulation (heat)

**Comments**

The tunnels are restricted. Overall, this material was not in poor condition.

Does Material Contain Asbestos? Yes  
Is it Friable? No  
Original Inspection Date 6/1/1992  
Current Surveillance Date 6/30/2008  
Current Assessment Rating NR Not Required  
Cause of Damage No Damage  
Accessible Yes  
Potential for Damage Low  
Removed No  
Planned Response Action O & M

Inspector

  
George William Ogle

State

Indiana

Accreditation Number

191003027

## PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools  
Building Name Charlestown Senior High School  
HA# 04  
Type of Material Thermal Material  
Quantity of Material 600 SF  
Material Location  
Boiler room


Material Description  
Stack insulation (breeching)

### Comments

The insulation is not in poor condition.

Does Material Contain Asbestos?	Yes	
Is it Friable?	No	
Original Inspection Date	6/1/1992	
Current Surveillance Date	6/30/2008	
Current Assessment Rating	NR	Not Required
Cause of Damage	No Damage	
Accessible	Yes	
Potential for Damage	Med	
Removed	No	
Planned Response Action	O & M	

Inspector

  
George William Ogle

State

Indiana

Accreditation Number

191003027

## PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools  
Building Name Charlestown Senior High School  
HA# 06  
Type of Material Thermal Material  
Quantity of Material 293 Each  
Material Location  
Throughout the building  
Material Description  
Fittings  
Comments  
Fittings are not in poor condition overall.  
Does Material Contain Asbestos? Yes  
Is it Friable? No  
Original Inspection Date 6/1/1992  
Current Surveillance Date 6/30/2008  
Current Assessment Rating NR Not Required  
Cause of Damage No Damage  
Accessible Yes  
Potential for Damage Med  
Removed No  
Planned Response Action O & M

Inspector

  
George William Ogle

State

Indiana

Accreditation Number

191003027

## PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools  
Building Name Charlestown Senior High School  
HA# A  
Type of Material Miscellaneous Material  
Quantity of Material Unquantified SF  
Material Location  
Building exterior  
Material Description  
Aggregate covered transite panels  
Comments  
The panels are not in poor condition overall.  
Does Material Contain Asbestos? Assumed  
Is it Friable? No  
Original Inspection Date 7/19/2005  
Current Surveillance Date 6/30/2008  
Current Assessment Rating NR Not Required  
Cause of Damage No Damage  
Accessible Yes  
Potential for Damage Low  
Removed No  
Planned Response Action O & M

Inspector

  
George William Ogle

State

Indiana

Accreditation Number

191003027



## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Charlestown Senior High School  
**HA#** 03  
**Type of Material** Thermal Material  
**Quantity of Material** 3,978 LF  
**Material Location**

Tunnels and boiler room

**Material Description**

Pipe insulation (heat)

**Comments**

The tunnels are restricted. Overall, this material was not in poor condition.

**Does Material Contain Asbestos?** Yes  
**Is it Friable?** No  
**Original Inspection Date** 6/1/1992  
**Current Surveillance Date** 12/7/2007  
**Current Assessment Rating** NR Not Required  
**Cause of Damage** No Damage  
**Accessible** Yes  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M

**Inspector**

  
George William Ogle

**State** Indiana  
**Accreditation Number** 191003027

## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Charlestown Senior High School  
**HA#** 04  
**Type of Material** Thermal Material  
**Quantity of Material** 600 SF  
**Material Location**  
Boiler room  
**Material Description**  
Stack insulation (breeching)  
**Comments**  
The insulation is not in poor condition.  
**Does Material Contain Asbestos?** Yes  
**Is it Friable?** No  
**Original Inspection Date** 6/1/1992  
**Current Surveillance Date** 12/7/2007  
**Current Assessment Rating** NR Not Required  
**Cause of Damage** No Damage  
**Accessible** Yes  
**Potential for Damage** Med  
**Removed** No  
**Planned Response Action** O & M

**Inspector**

  
George William Ogle

**State** Indiana  
**Accreditation Number** 191003027

## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Charlestown Senior High School  
**HA#** 06  
**Type of Material** Thermal Material  
**Quantity of Material** 293 Each  
**Material Location**  
Throughout the building  
**Material Description**  
Fittings  
**Comments**  
Fittings are not in poor condition overall.  
**Does Material Contain Asbestos?** Yes  
**Is it Friable?** No  
**Original Inspection Date** 6/1/1992  
**Current Surveillance Date** 12/7/2007  
**Current Assessment Rating** NR Not Required  
**Cause of Damage** No Damage  
**Accessible** Yes  
**Potential for Damage** Med  
**Removed** No  
**Planned Response Action** O & M  
  
**Inspector** \_\_\_\_\_  
George William Ogle  
  
**State** Indiana  
**Accreditation Number** 191003027

## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Charlestown Senior High School  
**HA#** A  
**Type of Material** Miscellaneous Material  
**Quantity of Material** Unquantified SF  
**Material Location**  
Building exterior  
**Material Description**  
Aggregate covered transite panels  
**Comments**  
The panels are not in poor condition overall.  
**Does Material Contain Asbestos?** Assumed  
**Is it Friable?** No  
**Original Inspection Date** 7/19/2005  
**Current Surveillance Date** 12/7/2007  
**Current Assessment Rating** NR Not Required  
**Cause of Damage** No Damage  
**Accessible** Yes  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M

**Inspector**

  
George William Ogle

**State**

Indiana

**Accreditation Number**

191003027

## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Charlestown Senior High School  
**HA#** 03  
**Type of Material** Thermal Material  
**Quantity of Material** 3,978 LF  
**Material Location**

Tunnels and boiler room

**Material Description**


Pipe insulation (heat)

**Comments**

The tunnels are restricted. Overall, this material was not in poor condition.

**Does Material Contain Asbestos?** Yes  
**Is it Friable?** No  
**Original Inspection Date** 6/1/1992  
**Current Surveillance Date** 7/11/2007  
**Current Assessment Rating** NR Not Required  
**Cause of Damage** No Damage  
**Accessible** Yes  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M

**Inspector**

  
George William Ogle

**State**

Indiana

**Accreditation Number**

191003027

## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Charlestown Senior High School  
**HA#** 04  
**Type of Material** Thermal Material  
**Quantity of Material** 600 SF  
**Material Location**

Boiler room

**Material Description**

Stack insulation (breeching)

**Comments**

The insulation is not in poor condition.

**Does Material Contain Asbestos?** Yes  
**Is it Friable?** No  
**Original Inspection Date** 6/1/1992  
**Current Surveillance Date** 7/11/2007  
**Current Assessment Rating** NR Not Required  
**Cause of Damage** No Damage  
**Accessible** Yes  
**Potential for Damage** Med  
**Removed** No  
**Planned Response Action** O & M

**Inspector**


  
George William Ogle

**State** Indiana  
**Accreditation Number** 191003027

## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Charlestown Senior High School  
**HA#** 06  
**Type of Material** Thermal Material  
**Quantity of Material** 293 Each  
**Material Location**  
Throughout the building  
**Material Description**  
Fittings  
**Comments**  
Fittings are not in poor condition overall.  
**Does Material Contain Asbestos?** Yes  
**Is it Friable?** No  
**Original Inspection Date** 6/1/1992  
**Current Surveillance Date** 7/11/2007  
**Current Assessment Rating** NR Not Required  
**Cause of Damage** No Damage  
**Accessible** Yes  
**Potential for Damage** Med  
**Removed** No  
**Planned Response Action** O & M

**Inspector**

  
George William Ogle

**State**

Indiana

**Accreditation Number**

191003027

## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Charlestown Senior High School  
**HA#** A  
**Type of Material** Miscellaneous Material  
**Quantity of Material** Unquantified SF  
**Material Location**  
Building exterior  
**Material Description**  
Aggregate covered transite panels  
**Comments**  
The panels are not in poor condition overall.  
**Does Material Contain Asbestos?** Assumed  
**Is it Friable?** No  
**Original Inspection Date** 7/19/2005  
**Current Surveillance Date** 7/11/2007  
**Current Assessment Rating** NR Not Required  
**Cause of Damage** No Damage  
**Accessible** Yes  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M

**Inspector**

  
George William Ogle

**State**

Indiana

**Accreditation Number**

191003027



## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Charlestown Senior High School  
**HA#** 03  
**Type of Material** Thermal Material  
**Quantity of Material** 3,978 LF  
**Material Location**  
Tunnels and boiler room


**Material Description**  
Pipe insulation (heat)

**Comments**

The tunnels are restricted. Overall, this material was not in poor condition.

<b>Does Material Contain Asbestos?</b>	Yes	
<b>Is it Friable?</b>	No	
<b>Original Inspection Date</b>	6/1/1992	
<b>Current Surveillance Date</b>	12/19/2006	
<b>Current Assessment Rating</b>	NR	Not Required
<b>Cause of Damage</b>	No Damage	
<b>Accessible</b>	Yes	
<b>Potential for Damage</b>	Low	
<b>Removed</b>	No	
<b>Planned Response Action</b>	O & M	

**Inspector**

  
George William Ogle

**State** Indiana  
**Accreditation Number** 191003027

## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Charlestown Senior High School  
**HA#** 04  
**Type of Material** Thermal Material  
**Quantity of Material** 600 SF  
**Material Location**  
Boiler room  
**Material Description**  
Stack insulation (breeching)  
**Comments**  
The insulation is not in poor condition.  
**Does Material Contain Asbestos?** Yes  
**Is it Friable?** No  
**Original Inspection Date** 6/1/1992  
**Current Surveillance Date** 12/19/2006  
**Current Assessment Rating** NR Not Required  
**Cause of Damage** No Damage  
**Accessible** Yes  
**Potential for Damage** Med  
**Removed** No  
**Planned Response Action** O & M

**Inspector**

  
George William Ogle

**State** Indiana  
**Accreditation Number** 191003027

## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Charlestown Senior High School  
**HA#** 06  
**Type of Material** Thermal Material  
**Quantity of Material** 293 Each  
**Material Location**

Throughout the building

**Material Description**

Fittings

**Comments**

The only damaged fittings found in the pipe chase in the boy's restroom off the athletic storage room are to non-suspect insulation. All asbestos was removed from this area in August 1995. We need to check all restroom pipe chases next visit to look for the area where damaged fittings were found. Visible fittings are not in poor condition.

**Does Material Contain Asbestos?** Yes  
**Is it Friable?** No  
**Original Inspection Date** 6/1/1992  
**Current Surveillance Date** 12/19/2006  
**Current Assessment Rating** NR Not Required  
**Cause of Damage** No Damage  
**Accessible** Yes  
**Potential for Damage** Med  
**Removed** No  
**Planned Response Action** O & M

**Inspector**

  
George William Ogle

**State**

Indiana

**Accreditation Number**

191003027

## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Charlestown Senior High School  
**HA#** A  
**Type of Material** Miscellaneous Material  
**Quantity of Material** Unquantified SF  
**Material Location**  
Building exterior  
**Material Description**  
Aggregate covered transite panels  
**Comments**  
The panels are not in poor condition overall.  
**Does Material Contain Asbestos?** Assumed  
**Is it Friable?** No  
**Original Inspection Date** 7/19/2005  
**Current Surveillance Date** 12/19/2006  
**Current Assessment Rating** NR Not Required  
**Cause of Damage** No Damage  
**Accessible** Yes  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M

**Inspector**

  
George William Ogle

**State**

Indiana

**Accreditation Number**

191003027

## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Charlestown Senior High School  
**HA#** 03  
**Type of Material** Thermal Material  
**Quantity of Material** 3,978 LF

**Material Location**  
Tunnels and boiler room

**Material Description**  
Pipe insulation (heat)

**Comments**

Tunnels are restricted. The one mag open end in the maintenance room has been repaired. Overall, this material was not in poor condition.

**Does Material Contain Asbestos?** Yes  
**Is it Friable?** No  
**Original Inspection Date** 6/1/1992  
**Current Surveillance Date** 6/28/2006  
**Current Assessment Rating** NR Not Required  
**Cause of Damage** No Damage  
**Accessible** Yes  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M

**Inspector**

  
\_\_\_\_\_  
Christopher Ames

**State** Indiana  
**Accreditation Number** 198612124

## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Charlestown Senior High School  
**HA#** 04  
**Type of Material** Thermal Material  
**Quantity of Material** 600 SF  
**Material Location**  
Boiler room  
**Material Description**

Stack insulation (breeching)

**Comments**

The insulation is still intact and not in poor condition.

**Does Material Contain Asbestos?** Yes  
**Is it Friable?** No  
**Original Inspection Date** 6/1/1992  
**Current Surveillance Date** 6/28/2006  
**Current Assessment Rating** NR Not Required  
**Cause of Damage** No Damage  
**Accessible** Yes  
**Potential for Damage** Med  
**Removed** No  
**Planned Response Action** O & M

**Inspector**

  
\_\_\_\_\_  
Christopher Ames

**State** Indiana  
**Accreditation Number** 198612124

## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Charlestown Senior High School  
**HA#** 06  
**Type of Material** Thermal Material  
**Quantity of Material** 293 Each

**Material Location**  
Throughout the building


**Material Description**  
Fittings

**Comments**

Damaged fittings were found in the pipe chase in the boy's restroom off the athletic storage room during a previous surveillance. (This area could not be located during the last surveillance and more investigation is needed to determine the location of the damaged fittings). The fitting in the center area of the maintenance office has been repaired.

**Does Material Contain Asbestos?** Yes  
**Is it Friable?** No  
**Original Inspection Date** 6/1/1992  
**Current Surveillance Date** 6/28/2006  
**Current Assessment Rating** NR Not Required  
**Cause of Damage** No Damage  
**Accessible** Yes  
**Potential for Damage** Med  
**Removed** No  
**Planned Response Action** O & M

**Inspector**

  
\_\_\_\_\_  
Christopher Ames

**State** Indiana  
**Accreditation Number** 198612124

## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Charlestown Senior High School  
**HA#** A  
**Type of Material** Miscellaneous Material  
**Quantity of Material** Unquantified SF  
**Material Location**  
Building exterior  
**Material Description**  
Aggregate covered transite panels  
**Comments**  
The panels are not in poor condition overall.  
**Does Material Contain Asbestos?** Assumed  
**Is it Friable?** No  
**Original Inspection Date** 7/19/2005  
**Current Surveillance Date** 6/28/2006  
**Current Assessment Rating** NR Not Required  
**Cause of Damage** No Damage  
**Accessible** Yes  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M

**Inspector**

  
\_\_\_\_\_  
Christopher Ames

**State** Indiana  
**Accreditation Number** 198612124



## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Charlestown Senior High School  
**HA#** 03  
**Type of Material** Thermal Material  
**Quantity of Material** 3,978 LF

**Material Location**  
Tunnels and boiler room

**Material Description**  
Pipe insulation (heat)

**Comments**

Tunnels are restricted. The one mag open end in the maintenance room has been repaired. Overall, this material was not in poor condition.

**Does Material Contain Asbestos?** Yes  
**Is it Friable?** No  
**Original Inspection Date** 6/1/1992  
**Current Surveillance Date** 1/24/2006  
**Current Assessment Rating** NR Not Required  
**Cause of Damage** No Damage  
**Accessible** Yes  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M

**Inspector**

  
George William Ogle

**State** Indiana  
**Accreditation Number** 191523030

## PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools  
Building Name Charlestown Senior High School  
HA# 04  
Type of Material Thermal Material  
Quantity of Material 600 SF  
Material Location  
Boiler room  
Material Description


Stack insulation (breeching)

### Comments

The insulation is still intact and not in poor condition.

Does Material Contain Asbestos? Yes  
Is it Friable? No  
Original Inspection Date 6/1/1992  
Current Surveillance Date 1/24/2006  
Current Assessment Rating NR Not Required  
Cause of Damage No Damage  
Accessible Yes  
Potential for Damage Med  
Removed No  
Planned Response Action O & M

Inspector

  
George William Ogle

State Indiana  
Accreditation Number 191523030

## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Charlestown Senior High School  
**HA#** 06  
**Type of Material** Thermal Material  
**Quantity of Material** 293 Each  
**Material Location**

Throughout the building

**Material Description**

Fittings

**Comments**

Damaged fittings were found in the pipe chase in the boy's restroom off the athletic storage room during a previous surveillance. The door was jammed shut and the maintenance shop needs to work on it to get it open. The fitting in the center area of the maintenance office has been repaired. The fittings are not in poor condition overall.

**Does Material Contain Asbestos?** Yes  
**Is it Friable?** No  
**Original Inspection Date** 6/1/1992  
**Current Surveillance Date** 1/24/2006  
**Current Assessment Rating** NR Not Required  
**Cause of Damage** No Damage  
**Accessible** Yes  
**Potential for Damage** Med  
**Removed** No  
**Planned Response Action** O & M

**Inspector**

  
George William Ogle

**State** Indiana  
**Accreditation Number** 191523030

## PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools  
Building Name Charlestown Senior High School  
HA# A  
Type of Material Miscellaneous Material  
Quantity of Material Unquantified SF

**Material Location**

Building exterior

**Material Description**

Aggregate covered transite panels

**Comments**


The panels are not in poor condition overall.

Does Material Contain Asbestos? Assumed  
Is it Friable? No  
Original Inspection Date 7/19/2005  
Current Surveillance Date 1/24/2006  
Current Assessment Rating NR Not Required  
Cause of Damage No Damage  
Accessible Yes  
Potential for Damage Low  
Removed No  
Planned Response Action O & M

Inspector

  
George William Ogle

State Indiana  
Accreditation Number 191523030



## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Charlestown Senior High School  
**HA#** 01  
**Type of Material** Thermal Material  
**Quantity of Material** 225 SF  
**Material Location**  
Boiler room  
**Material Description**  
Water tank cover

**Comments**

This material was removed by an accredited contractor during the spring of 2005. This homogeneous area designation will be removed from the Management Plan.

**Does Material Contain Asbestos?** No  
**Is it Friable?** No  
**Original Inspection Date** 6/1/1992  
**Current Surveillance Date** 7/19/2005  
**Current Assessment Rating** NA Not Applicable  
**Cause of Damage** Not Applicable  
**Accessible** No  
**Potential for Damage** NA  
**Removed** Yes  
**Planned Response Action** None

**Inspector**

  
George William Ogilvie

**State** Indiana  
**Accreditation Number** 191523030

## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Charlestown Senior High School  
**HA#** 03  
**Type of Material** Thermal Material  
**Quantity of Material** 3,978 LF  
**Material Location**  
Tunnels and boiler room

**Material Description**  
Pipe insulation (heat)

**Comments**  
Tunnels are restricted. One mag open end is visible in the maintenance room. Overall, this material was not in poor condition.

**Does Material Contain Asbestos?** Yes  
**Is it Friable?** No  
**Original Inspection Date** 6/1/1992  
**Current Surveillance Date** 7/19/2005  
**Current Assessment Rating** NR Not Required  
**Cause of Damage** No Damage  
**Accessible** Yes  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M

**Inspector**


  
George William Ogle

**State** Indiana  
**Accreditation Number** 191523030

## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Charlestown Senior High School  
**HA#** 04  
**Type of Material** Thermal Material  
**Quantity of Material** 600 SF  
**Material Location**  
Boiler room  
**Material Description**  
Stack insulation (breeching)  
**Comments**  
The insulation is still intact and not in poor condition.  
**Does Material Contain Asbestos?** Yes  
**Is it Friable?** No  
**Original Inspection Date** 6/1/1992  
**Current Surveillance Date** 7/19/2005  
**Current Assessment Rating** NR Not Required  
**Cause of Damage** No Damage  
**Accessible** Yes  
**Potential for Damage** Med  
**Removed** No  
**Planned Response Action** O & M

**Inspector**

  
George William Ogle

**State** Indiana  
**Accreditation Number** 191523030



## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Charlestown Senior High School  
**HA#** 05  
**Type of Material** Thermal Material  
**Quantity of Material** 250 LF  
**Material Location**  
Along west wall in boiler room

**Material Description**  
Air cell pipe insulation

**Comments**  
This material was removed by an accredited contractor during the spring of 2005. This homogeneous area designation will be removed from the Management Plan.

**Does Material Contain Asbestos?** Yes  
**Is it Friable?** No  
**Original Inspection Date** 6/1/1992  
**Current Surveillance Date** 7/19/2005  
**Current Assessment Rating** NR Not Required  
**Cause of Damage** No Damage  
**Accessible** Yes  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M

**Inspector**

  
George William Ogle

**State**

Indiana

**Accreditation Number**

191523030

## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Charlestown Senior High School  
**HA#** 06  
**Type of Material** Thermal Material  
**Quantity of Material** 293 Each

**Material Location**  
Throughout the building

**Material Description**  
Fittings

**Comments**

Damaged fittings were found in the pipe chase in the boy's restroom off the athletic storage room during the previous surveillance. The door was jammed shut and I couldn't open it. The fitting in the center area of the maintenance office has not been repaired. The fittings are not in poor condition overall.

<b>Does Material Contain Asbestos?</b>	Yes	
<b>Is it Friable?</b>	No	
<b>Original Inspection Date</b>	6/1/1992	
<b>Current Surveillance Date</b>	7/19/2005	
<b>Current Assessment Rating</b>	NR	Not Required
<b>Cause of Damage</b>	No Damage	
<b>Accessible</b>	Yes	
<b>Potential for Damage</b>	Med	
<b>Removed</b>	No	
<b>Planned Response Action</b>	O & M	

**Inspector**

  
George William Ogle

**State**

Indiana

**Accreditation Number**

191523030

## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Charlestown Senior High School  
**HA#** A  
**Type of Material** Miscellaneous Material  
**Quantity of Material** Unquantified SF

**Material Location**  
Building exterior

**Material Description**  
Aggregate covered transite panels


**Comments**  
This material has not been previously addressed. It is suspect for asbestos content. It will be treated as ACM until it is properly sampled and analyzed. It is not in poor condition.

**Does Material Contain Asbestos?** Assumed  
**Is it Friable?** No  
**Original Inspection Date** 7/19/2005  
**Current Surveillance Date** 7/19/2005  
**Current Assessment Rating** NR Not Required  
**Cause of Damage** No Damage  
**Accessible** Yes  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M

**Inspector**

  
George William Ogle

**State** Indiana  
**Accreditation Number** 191523030



## PERIODIC SURVEILLANCE REPORT


**LEA Name** Greater Clark County Schools  
**Building Name** Charlestown Senior High School  
**HA#** 01  
**Type of Material** Thermal Material  
**Quantity of Material** 225 SF  
**Material Location**  
Boiler room  
**Material Description**  
Water tank cover

**Comments**

There is exposed material around the two elbows coming from the bottom of the tank. O & M is recommended. This material was not in poor condition overall.

**Does Material Contain Asbestos?** Yes  
**Is it Friable?** No  
**Original Inspection Date** 6/1/1992  
**Current Surveillance Date** 12/8/2004  
**Current Assessment Rating** NR Not Required  
**Cause of Damage** No Damage  
**Accessible** Yes  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M

**Inspector**

  
\_\_\_\_\_  
Christiaan Sparks

**State** Indiana  
**Accreditation Number** 190804103

## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Charlestown Senior High School  
**HA#** 03  
**Type of Material** Thermal Material  
**Quantity of Material** 3,978 LF

**Material Location**  
Tunnels and boiler room

**Material Description**  
Pipe insulation (heat)

**Comments**

Tunnels are restricted. There is delaminating canvas covering in the boiler room underneath the sink on the west wall. There are some open ends on some runs insulated with paper. One mag open end is visible in the maintenance room. Overall, this material was not in poor condition.

**Does Material Contain Asbestos?** Yes  
**Is it Friable?** No  
**Original Inspection Date** 6/1/1992  
**Current Surveillance Date** 12/8/2004  
**Current Assessment Rating** NR Not Required  
**Cause of Damage** No Damage  
**Accessible** Yes  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M

**Inspector**

  
\_\_\_\_\_  
Christian Sparks

**State** Indiana  
**Accreditation Number** 190804103

## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Charlestown Senior High School  
**HA#** 04  
**Type of Material** Thermal Material  
**Quantity of Material** 600 SF  
**Material Location**  
Boiler room


**Material Description**  
Stack insulation (breeching)

**Comments**

A large section of canvas has been cut off leaving approximately seven square feet of insulation exposed. The insulation is still intact and not in poor condition. O & M is needed as the edges are becoming frayed.

**Does Material Contain Asbestos?** Yes  
**Is it Friable?** No  
**Original Inspection Date** 6/1/1992  
**Current Surveillance Date** 12/8/2004  
**Current Assessment Rating** NR Not Required  
**Cause of Damage** No Damage  
**Accessible** Yes  
**Potential for Damage** Med  
**Removed** No  
**Planned Response Action** O & M

**Inspector**

  
\_\_\_\_\_  
Christiaan Sparks

**State** Indiana  
**Accreditation Number** 190804103

## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Charlestown Senior High School  
**HA#** 05  
**Type of Material** Thermal Material  
**Quantity of Material** 250 LF


**Material Location**  
Along west wall in boiler room

**Material Description**  
Air cell pipe insulation

**Comments**  
This material has some open ends. However, this material was not in poor condition overall.

**Does Material Contain Asbestos?** Yes  
**Is it Friable?** No  
**Original Inspection Date** 6/1/1992  
**Current Surveillance Date** 12/8/2004  
**Current Assessment Rating** NR Not Required  
**Cause of Damage** No Damage  
**Accessible** Yes  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M

**Inspector**

  
\_\_\_\_\_  
Christiaan Sparks

**State** Indiana  
**Accreditation Number** 190804103



## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Charlestown Senior High School  
**HA#** 06  
**Type of Material** Thermal Material  
**Quantity of Material** 293 Each

**Material Location**  
Throughout the building

**Material Description**  
Fittings

**Comments**


Damaged fittings were found in the pipe chase in the boys restroom off of the athletic storage room. One fitting in center area of maintenance office has insulation exposed where canvas has pulled loose. One fitting on the wall of the boiler room by the sink has fallen apart. There is debris on the floor. The fittings are not in poor condition overall with not enough damage to call the homogeneous area damaged. Some O & M has been performed, however, more is needed.

**Does Material Contain Asbestos?** Yes  
**Is it Friable?** No  
**Original Inspection Date** 6/1/1992  
**Current Surveillance Date** 12/8/2004  
**Current Assessment Rating** NR Not Required  
**Cause of Damage** No Damage  
**Accessible** Yes  
**Potential for Damage** Med  
**Removed** No  
**Planned Response Action** O & M

**Inspector**

  
\_\_\_\_\_  
Christiaan Sparks

**State** Indiana  
**Accreditation Number** 190804103



## PERIODIC SURVEILLANCE REPORT


**LEA Name** Greater Clark County Schools  
**Building Name** Charlestown Senior High School  
**HA#** 01  
**Type of Material** Thermal Material  
**Quantity of Material** 225 SF  
**Material Location**  
Boiler room  
**Material Description**  
Water tank cover

**Comments**

There is exposed material around the two elbows coming from the bottom of the tank. O & M is recommended. This material was not in poor condition overall.

**Does Material Contain Asbestos?** Yes  
**Is it Friable?** No  
**Original Inspection Date** 06/01/1992  
**Current Surveillance Date** 12/08/2003  
**Current Assessment Rating** NR Not Required  
**Cause of Damage** No Damage  
**Accessible** Yes  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M

**Inspector**

  
\_\_\_\_\_  
Christiaan Sparks

**State** Indiana  
**Accreditation Number** 190804103

## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Charlestown Senior High School  
**HA#** 03  
**Type of Material** Thermal Material  
**Quantity of Material** 3,978 LF

**Material Location**  
Tunnels and boiler room

**Material Description**  
Pipe insulation (heat)

**Comments**

Tunnels are restricted. There is delaminating canvas covering in the boiler room underneath the sink on the west wall. There are some open ends on some runs insulated with paper. One mag open end is visible in the maintenance room. Overall, this material was not in poor condition.

**Does Material Contain Asbestos?** Yes  
**Is it Friable?** No  
**Original Inspection Date** 06/01/1992  
**Current Surveillance Date** 12/08/2003  
**Current Assessment Rating** NR Not Required  
**Cause of Damage** No Damage  
**Accessible** Yes  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M

**Inspector**

  
\_\_\_\_\_  
Christiaan Sparks

**State** Indiana  
**Accreditation Number** 190804103

## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Charlestown Senior High School  
**HA#** 04  
**Type of Material** Thermal Material  
**Quantity of Material** 600 SF  
**Material Location**  
Boiler room  
**Material Description**  
Stack insulation (breeching)

**Comments**

A large section of canvas has been cut off leaving approximately seven square feet of insulation exposed. The insulation is still intact and not in poor condition. O & M is needed as the edges are becoming frayed.

**Does Material Contain Asbestos?** Yes  
**Is it Friable?** No  
**Original Inspection Date** 06/01/1992  
**Current Surveillance Date** 12/08/2003  
**Current Assessment Rating** NR Not Required  
**Cause of Damage** No Damage  
**Accessible** Yes  
**Potential for Damage** Med  
**Removed** No  
**Planned Response Action** O & M

**Inspector**

  
\_\_\_\_\_  
Christiaan Sparks

**State** Indiana  
**Accreditation Number** 190804103

## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Charlestown Senior High School  
**HA#** 05  
**Type of Material** Thermal Material  
**Quantity of Material** 250 LF

**Material Location**  
Along west wall in boiler room

**Material Description**  
Air cell pipe insulation

**Comments**  
This material has some open ends. However, this material was not in poor condition overall.

**Does Material Contain Asbestos?** Yes  
**Is it Friable?** No  
**Original Inspection Date** 06/01/1992  
**Current Surveillance Date** 12/08/2003  
**Current Assessment Rating** NR Not Required  
**Cause of Damage** No Damage  
**Accessible** Yes  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M

**Inspector**

  
\_\_\_\_\_  
Christiaan Sparks

**State** Indiana  
**Accreditation Number** 190804103

## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Charlestown Senior High School  
**HA#** 06  
**Type of Material** Thermal Material  
**Quantity of Material** 293 Each

**Material Location**  
Throughout the building


**Material Description**  
Fittings

### Comments

Damaged fittings were found in the pipe chase in the boys restroom off of the athletic storage room. One fitting in center area of maintenance office has insulation exposed where canvas has pulled loose. One fitting on the wall of the boiler room by the sink has fallen apart. There is debris on the floor. The fittings are not in poor condition overall with not enough damage to call the homogeneous area damaged. Some O & M has been performed, however, more is needed.

**Does Material Contain Asbestos?** Yes  
**Is it Friable?** No  
**Original Inspection Date** 06/01/1992  
**Current Surveillance Date** 12/08/2003  
**Current Assessment Rating** NR Not Required  
**Cause of Damage** No Damage  
**Accessible** Yes  
**Potential for Damage** Med  
**Removed** No  
**Planned Response Action** O & M

**Inspector**

  
\_\_\_\_\_  
Christiaan Sparks

**State** Indiana  
**Accreditation Number** 190804103

## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Charlestown Senior High School  
**HA#** C  
**Type of Material** Miscellaneous Material  
**Quantity of Material** Unquantified SF

**Material Location**  
Exterior fascia board

**Material Description**  
Transite board with stone texturing

**Comments**

This material has been sampled by an accredited inspector and analyzed by an accredited laboratory. It was found to be negative for asbestos content. This homogeneous area designation will be removed from the Management Plan.

**Does Material Contain Asbestos?** No  
**Is it Friable?** No  
**Original Inspection Date** 01/11/2001  
**Current Surveillance Date** 12/08/2003  
**Current Assessment Rating** NA Not Applicable  
**Cause of Damage** Not Applicable  
**Accessible** Yes  
**Potential for Damage** NA  
**Removed** No  
**Planned Response Action** None

**Inspector**

  
\_\_\_\_\_  
Christiaan Sparks

**State** Indiana  
**Accreditation Number** 190804103





## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Charlestown Senior High School  
**HA#** 01  
**Type of Material** Thermal Material  
**Quantity of Material** 225 SF  
**Material Location**  
Boiler room

**Material Description**  
Water tank cover

**Comments**

There is exposed material around the two elbows coming from the bottom of the tank. O & M is recommended. This material was not in poor condition overall.

**Does Material Contain Asbestos?** Yes  
**Is it Friable?** No  
**Original Inspection Date** 06/01/1992  
**Current Surveillance Date** 06/13/2003  
**Current Assessment Rating** NR Not Required  
**Cause of Damage** No Damage  
**Accessible** Yes  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M

**Inspector**

  
\_\_\_\_\_  
Christian Sparks

**State** Indiana  
**Accreditation Number** 190804103

## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Charlestown Senior High School  
**HA#** 03  
**Type of Material** Thermal Material  
**Quantity of Material** 3,978 LF

**Material Location**  
Tunnels and boiler room


**Material Description**  
Pipe insulation (heat)

**Comments**

Tunnels are restricted. There is delaminating canvas covering in the boiler room underneath the sink on the west wall. There are some open ends on some runs insulated with paper. One mag open end is visible in the maintenance room. Overall, this material was not in poor condition.

**Does Material Contain Asbestos?** Yes  
**Is it Friable?** No  
**Original Inspection Date** 06/01/1992  
**Current Surveillance Date** 06/13/2003  
**Current Assessment Rating** NR Not Required  
**Cause of Damage** Deterioration & Age  
**Accessible** Yes  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M

**Inspector**



---

Christiaan Sparks

**State** Indiana  
**Accreditation Number** 190804103

## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Charlestown Senior High School  
**HA#** 04  
**Type of Material** Thermal Material  
**Quantity of Material** 600 SF  
**Material Location**  
Boiler room

**Material Description**  
Stack insulation (breaching)

**Comments**

A large section of canvas has been cut off leaving approximately seven square feet of insulation exposed. The insulation is still intact and not in poor condition. O & M is needed.

**Does Material Contain Asbestos?** Yes  
**Is it Friable?** No  
**Original Inspection Date** 06/01/1992  
**Current Surveillance Date** 06/13/2003  
**Current Assessment Rating** NR Not Required  
**Cause of Damage** Delamination  
**Accessible** Yes  
**Potential for Damage** Med  
**Removed** No  
**Planned Response Action** O & M

**Inspector**



---

Christiaan Sparks

**State** Indiana  
**Accreditation Number** 190804103

## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Charlestown Senior High School  
**HA#** 05  
**Type of Material** Thermal Material  
**Quantity of Material** 250 LF

**Material Location**  
Along west wall in boiler room

**Material Description**  
Air cell pipe insulation

**Comments**  
This material has some open ends. However, this material was not in poor condition overall.

**Does Material Contain Asbestos?** Yes  
**Is it Friable?** No  
**Original Inspection Date** 06/01/1992  
**Current Surveillance Date** 06/13/2003  
**Current Assessment Rating** NR Not Required  
**Cause of Damage** Water Damage  
**Accessible** Yes  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M

**Inspector**



Christiaan Sparks

**State** Indiana  
**Accreditation Number** 190804103

## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Charlestown Senior High School  
**HA#** 06  
**Type of Material** Thermal Material  
**Quantity of Material** 293 Each

**Material Location**  
Throughout the building

**Material Description**  
Fittings

### Comments

Damaged fittings were found in the pipe chase in the boys restroom off of the athletic storage room. One fitting in center area of maintenance office has insulation exposed where canvas has pulled loose. One fitting on the wall of the boiler room by the sink has fallen apart. There is debris on the floor. The fittings are not in poor condition overall with not enough damage to call the homogeneous area damaged. Some O & M has been performed, however, more is needed.

**Does Material Contain Asbestos?** Yes  
**Is it Friable?** No  
**Original Inspection Date** 06/01/1992  
**Current Surveillance Date** 06/13/2003  
**Current Assessment Rating** NR Not Required  
**Cause of Damage** Physical Damage  
**Accessible** Yes  
**Potential for Damage** Med  
**Removed** No  
**Planned Response Action** O & M

**Inspector**



Christiaan Sparks

**State** Indiana  
**Accreditation Number** 190804103

## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Charlestown Senior High School  
**HA#** C  
**Type of Material** Miscellaneous Material  
**Quantity of Material** Unquantified SF

**Material Location**  
Exterior fascia board

**Material Description**  
Transite board with stone texturing

**Comments**

This material is damaged near the front entrance close to the fire hydrant. It is thought to be on most of the fascia board upper exterior of the building. This material was not in poor condition.

**Does Material Contain Asbestos?** Assumed  
**Is it Friable?** No  
**Original Inspection Date** 01/11/2001  
**Current Surveillance Date** 06/13/2003  
**Current Assessment Rating** NR Not Required  
**Cause of Damage** Physical Damage  
**Accessible** Yes  
**Potential for Damage** Med  
**Removed** No  
**Planned Response Action** O & M

**Inspector**



Christiaan Sparks

**State** Indiana  
**Accreditation Number** 190804103

## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Charlestown Senior High School

**HA#** D

**Type of Material** Thermal Material

**Quantity of Material** Unquantified SF

**Material Location**  
Cooling tower

**Material Description**  
Panels, slats, and fill material

### Comments

Upon further investigation it was determined that the current unit was misidentified as the unit that was in place at the time of the original AHERA inspection. That unit was removed non-friable and replaced when the new system was installed. This homogeneous area designation will be removed from the Management Plan.

**Does Material Contain Asbestos?** No

**Is it Friable?** No

**Original Inspection Date** 04/10/1989

**Current Surveillance Date** 06/13/2003

**Current Assessment Rating** NA Not Applicable

**Cause of Damage** Not Applicable

**Accessible** No

**Potential for Damage** NA

**Removed** Yes

**Planned Response Action** None

**Inspector**



Christian Sparks

**State** Indiana

**Accreditation Number** 190804103






## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Charlestown Senior High School  
**HA#** 01  
**Type of Material** Thermal Material  
**Quantity of Material** 225 SF  
**Material Location**  
Boiler room  
**Material Description**  
Water tank cover  
**Comments**  
This material was not in poor condition.  
**Does Material Contain Asbestos?** Yes  
**Is it Friable?** No  
**Original Inspection Date** 06/01/1992  
**Current Surveillance Date** 12/18/2002  
**Current Assessment Rating** NR Not Required  
**Cause of Damage** No Damage  
**Accessible** Yes  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M

**Inspector**



Christiaan Sparks

**State** Indiana  
**Accreditation Number** 190804103

## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Charlestown Senior High School  
**HA#** 03  
**Type of Material** Thermal Material  
**Quantity of Material** 3,978 LF

**Material Location**  
Tunnels and boiler room

**Material Description**  
Pipe insulation (heat)

**Comments**

Tunnels are restricted. There is delaminating canvas covering in the boiler room underneath the sink on the west wall. No insulation is exposed to inspect, except for some open ends on pipe runs of paper insulation. O & M needed.

**Does Material Contain Asbestos?** Yes  
**Is it Friable?** No  
**Original Inspection Date** 06/01/1992  
**Current Surveillance Date** 12/18/2002  
**Current Assessment Rating** NR Not Required  
**Cause of Damage** Deterioration & Age  
**Accessible** Yes  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M

**Inspector**

  
\_\_\_\_\_  
Christiaan Sparks

**State** Indiana  
**Accreditation Number** 190804103

## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Charlestown Senior High School

**HA#** 04

**Type of Material** Thermal Material

**Quantity of Material** 600 SF

**Material Location**  
Boiler room

**Material Description**  
Stack insulation (breaching)

**Comments**

Delamination of canvas has now exposed the insulation on a bottom section, but the insulation is still intact and not in poor condition. O & M is needed.

**Does Material Contain Asbestos?** Yes

**Is it Friable?** No

**Original Inspection Date** 06/01/1992

**Current Surveillance Date** 12/18/2002

**Current Assessment Rating** NR Not Required

**Cause of Damage** Delamination

**Accessible** Yes

**Potential for Damage** Med

**Removed** No

**Planned Response Action** O & M

**Inspector**

  
Christiaan Sparks

**State** Indiana

**Accreditation Number** 190804103

## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Charlestown Senior High School  
**HA#** 05  
**Type of Material** Thermal Material  
**Quantity of Material** 250 LF

**Material Location**  
Along west wall in boiler room

**Material Description**  
Air cell pipe insulation

**Comments**  
This material has some open ends. One valve and elbow located low to the ground has some minor water damage. However, this material was not in poor condition overall.

**Does Material Contain Asbestos?** Yes  
**Is it Friable?** No  
**Original Inspection Date** 06/01/1992  
**Current Surveillance Date** 12/18/2002  
**Current Assessment Rating** NR Not Required  
**Cause of Damage** Water Damage  
**Accessible** Yes  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M

**Inspector**

  
\_\_\_\_\_  
Christiaan Sparks

**State** Indiana  
**Accreditation Number** 190804103

## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Charlestown Senior High School  
**HA#** 06  
**Type of Material** Thermal Material  
**Quantity of Material** 293 Each

**Material Location**  
Throughout the building

**Material Description**  
Fittings

**Comments**

Damaged fittings found in the pipe chase in the boys restroom off of the athletic storage room. One fitting in center area of maintenance office has insulation exposed where canvas has pulled loose. The fittings are not in poor condition overall with not enough damage to call the homogeneous area damaged. Some O & M has been performed, however, more is needed.

**Does Material Contain Asbestos?** Yes  
**Is it Friable?** No  
**Original Inspection Date** 06/01/1992  
**Current Surveillance Date** 12/18/2002  
**Current Assessment Rating** NR Not Required  
**Cause of Damage** Physical Damage  
**Accessible** Yes  
**Potential for Damage** Med  
**Removed** No  
**Planned Response Action** O & M

**Inspector**

  
\_\_\_\_\_  
Christiaan Sparks

**State** Indiana  
**Accreditation Number** 190804103

## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Charlestown Senior High School  
**HA#** C  
**Type of Material** Miscellaneous Material  
**Quantity of Material** Unquantified SF

**Material Location**  
Exterior fascia board


**Material Description**  
Transite board with stone texturing

### Comments

An approximate 4' X 4' section of this material was damaged outside the cafeteria in the courtyard by a delivery truck. The area was cleaned up by school personnel. This material is also damaged near the front entrance close to the fire hydrant. It is thought to be on most of the fascia board upper exterior of the building. This material was not previously addressed. It will be treated as ACM until proper sampling is done.

**Does Material Contain Asbestos?** Assumed  
**Is it Friable?** No  
**Original Inspection Date** 01/11/2001  
**Current Surveillance Date** 12/18/2002  
**Current Assessment Rating** NR Not Required  
**Cause of Damage** Physical Damage  
**Accessible** Yes  
**Potential for Damage** Med  
**Removed** No  
**Planned Response Action** O & M

**Inspector**



Christiaan Sparks

**State** Indiana  
**Accreditation Number** 190804103

## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Charlestown Senior High School  
**HA#** D  
**Type of Material** Thermal Material  
**Quantity of Material** Unquantified SF

**Material Location**  
Cooling tower

**Material Description**  
Panels, slats, and fill material

**Comments**

Samples analyzed by Metro Service Laboratories, Inc. show the fill material in the cooling tower to be positive for asbestos content. The panels and the slats are assumed to contain asbestos until they are properly sampled and analyzed. The cooling tower was not in poor condition.

**Does Material Contain Asbestos?** Yes  
**Is it Friable?** No  
**Original Inspection Date** 04/10/1989  
**Current Surveillance Date** 12/18/2002  
**Current Assessment Rating** NR Not Required  
**Cause of Damage** No Damage  
**Accessible** Yes  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M

**Inspector**



Christiaan Sparks

**State** Indiana  
**Accreditation Number** 190804103





## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Charlestown Senior High School  
**HA#** 01  
**Type of Material** Thermal Material  
**Quantity of Material** 225 SF

**Material Location**  
Boiler room

**Material Description**  
Water tank cover

**Comments**

Material is not in poor condition with some of the canvas seams coming loose around the supports. O & M suggested.

**Does Material Contain Asbestos?** Yes  
**Is it Friable?** No  
**Original Inspection Date** 06/01/1992  
**Current Surveillance Date** 06/19/2002  
**Current Assessment Rating** NR Not Required  
**Cause of Damage** Delamination  
**Accessible** Yes  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M

**Inspector**

  
Richard D. Calvert

**State** Indiana  
**Accreditation Number** 315989970

## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Charlestown Senior High School  
**HA#** 03  
**Type of Material** Thermal Material  
**Quantity of Material** 3,978 LF

**Material Location**  
Tunnels and boiler room


**Material Description**  
Pipe insulation (heat)

**Comments**

Tunnels are restricted. There is delaminating canvas covering in the boiler room underneath the sink on the west wall. No insulation is exposed except for some open ends on pipe runs of paper insulation. O & M needed.

**Does Material Contain Asbestos?** Yes  
**Is it Friable?** No  
**Original Inspection Date** 06/01/1992  
**Current Surveillance Date** 06/19/2002  
**Current Assessment Rating** NR Not Required  
**Cause of Damage** Delamination  
**Accessible** Yes  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M

**Inspector**

  
Richard D. Calvert

**State** Indiana  
**Accreditation Number** 315989970

## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Charlestown Senior High School  
**HA#** 04  
**Type of Material** Thermal Material  
**Quantity of Material** 600 SF

**Material Location**  
Boiler room


**Material Description**  
Stack insulation (breeching)

**Comments**

Delamination of canvas has now exposed the insulation on a bottom section, but the insulation is still intact and not in poor condition overall. Some O & M has been completed, however, more is needed.

**Does Material Contain Asbestos?** Yes  
**Is it Friable?** No  
**Original Inspection Date** 06/01/1992  
**Current Surveillance Date** 06/19/2002  
**Current Assessment Rating** NR Not Required  
**Cause of Damage** Delamination  
**Accessible** Yes  
**Potential for Damage** Med  
**Removed** No  
**Planned Response Action** O & M

**Inspector**

  
Richard D. Calvert

**State** Indiana  
**Accreditation Number** 315989970

## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Charlestown Senior High School  
**HA#** 05  
**Type of Material** Thermal Material  
**Quantity of Material** 250 LF  
**Material Location**  
Along wall in boiler room  
**Material Description**  
Air cell pipe insulation  
**Comments**  
Material has some open ends, but no other damage noted.  
**Does Material Contain Asbestos?** Yes  
**Is it Friable?** No  
**Original Inspection Date** 06/01/1992  
**Current Surveillance Date** 06/19/2002  
**Current Assessment Rating** NR Not Required  
**Cause of Damage** Other  
**Accessible** Yes  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M  
**Inspector**  
  
Richard D. Calvert  
**State** Indiana  
**Accreditation Number** 315989970

## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Charlestown Senior High School  
**HA#** 06  
**Type of Material** Thermal Material  
**Quantity of Material** 293 Each

**Material Location**  
Throughout the building

**Material Description**  
Fittings

**Comments**

Damaged fittings found in the pipe chase in the boys restroom off of the athletic storage room. One fitting in center area of maintenance office has insulation exposed where canvas has pulled loose. The fittings are not in poor condition overall with not enough damage to call the homogeneous area damaged. Some O & M has been performed, however, more is needed.

**Does Material Contain Asbestos?** Yes  
**Is it Friable?** No  
**Original Inspection Date** 06/01/1992  
**Current Surveillance Date** 06/19/2002  
**Current Assessment Rating** NR Not Required  
**Cause of Damage** Physical Damage  
**Accessible** Yes  
**Potential for Damage** Med  
**Removed** No  
**Planned Response Action** O & M

**Inspector**

  
Richard D. Calvert

**State** Indiana  
**Accreditation Number** 315989970

## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Charlestown Senior High School  
**HA#** C  
**Type of Material** Miscellaneous Material  
**Quantity of Material** Unquantified SF

**Material Location**  
Exterior fascia board


**Material Description**  
Transite board with stone texturing

**Comments**

An approximate 4' X 4' section of this material was damaged outside the cafeteria in the courtyard by a delivery truck. The area was cleaned up by school personnel. This material is also damaged near the front entrance close to the fire hydrant. It is thought to be on most of the fascia board upper exterior of the building. This material was not previously addressed. It will be treated as ACM until proper sampling is done.

**Does Material Contain Asbestos?** Assumed  
**Is it Friable?** No  
**Original Inspection Date** 01/11/2001  
**Current Surveillance Date** 06/19/2002  
**Current Assessment Rating** NR Not Required  
**Cause of Damage** No Damage  
**Accessible** Yes  
**Potential for Damage** Med  
**Removed** No  
**Planned Response Action** O & M

**Inspector**

  
Richard D. Calvert

**State** Indiana  
**Accreditation Number** 315989970





## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Charlestown Senior High School  
**HA#** 01  
**Type of Material** Thermal Material  
**Quantity of Material** 225 SF

**Material Location**  
Boiler room


**Material Description**  
Water tank cover

**Comments**

Material is not in poor condition with some of the canvas seams coming loose around the supports. O & M suggested.

**Does Material Contain Asbestos?** Yes  
**Is it Friable?** No  
**Original Inspection Date** 06/01/1992  
**Current Surveillance Date** 12/11/2001  
**Current Assessment Rating** NR Not Required  
**Cause of Damage** Delamination  
**Accessible** Yes  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M

**Inspector**

  
\_\_\_\_\_  
Stephen Kimbrough

**State** Indiana  
**Accreditation Number** 191914122

## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Charlestown Senior High School  
**HA#** 03  
**Type of Material** Thermal Material  
**Quantity of Material** 3,978 LF

**Material Location**  
Tunnels and boiler room

**Material Description**  
Pipe insulation (heat)

**Comments**

Tunnels are restricted. There is delaminating canvas covering in the boiler room underneath the sink on the west wall. No insulation is exposed except for some open ends on pipe runs of paper insulation. O & M needed.

**Does Material Contain Asbestos?** Yes  
**Is it Friable?** No  
**Original Inspection Date** 06/01/1992  
**Current Surveillance Date** 12/11/2001  
**Current Assessment Rating** NR Not Required  
**Cause of Damage** Delamination  
**Accessible** Yes  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M

**Inspector**

  
\_\_\_\_\_  
Stephen Kimbrough

**State** Indiana  
**Accreditation Number** 191914122

## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Charlestown Senior High School

**HA#** 04

**Type of Material** Thermal Material

**Quantity of Material** 600 SF

**Material Location**  
Boiler room

**Material Description**  
Stack insulation (breaching)

**Comments**

Delamination of canvas has now exposed the insulation on a bottom section, but the insulation is still intact and not in poor condition overall. Some O & M has been completed, however, more is needed.

**Does Material Contain Asbestos?** Yes

**Is it Friable?** No

**Original Inspection Date** 06/01/1992

**Current Surveillance Date** 12/11/2001

**Current Assessment Rating** NR Not Required

**Cause of Damage** Delamination

**Accessible** Yes

**Potential for Damage** Med

**Removed** No

**Planned Response Action** O & M

**Inspector**

  
Stephen Kimbrough

**State** Indiana

**Accreditation Number** 191914122

## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Charlestown Senior High School  
**HA#** 05  
**Type of Material** Thermal Material  
**Quantity of Material** 250 LF  
**Material Location**  
Along wall in boiler room  
**Material Description**  
Air cell pipe insulation  
**Comments**  
Material has some open ends, but no other damage noted.  
**Does Material Contain Asbestos?** Yes  
**Is it Friable?** No  
**Original Inspection Date** 06/01/1992  
**Current Surveillance Date** 12/11/2001  
**Current Assessment Rating** NR Not Required  
**Cause of Damage** Other  
**Accessible** Yes  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M  
**Inspector**   
Stephen Kimbrough  
**State** Indiana  
**Accreditation Number** 191914122

## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Charlestown Senior High School  
**HA#** 06  
**Type of Material** Thermal Material  
**Quantity of Material** 293 Each

**Material Location**  
Throughout the building


**Material Description**  
Fittings

**Comments**

Damaged fittings found in the pipe chase in the boys restroom off of the athletic storage room. One fitting in center area of maintenance office has insulation exposed where canvas has pulled loose. The fittings are not in poor condition overall with not enough damage to call the homogeneous area damaged. Some O & M has been performed, however, more is needed.

**Does Material Contain Asbestos?** Yes  
**Is it Friable?** No  
**Original Inspection Date** 06/01/1992  
**Current Surveillance Date** 12/11/2001  
**Current Assessment Rating** NR Not Required  
**Cause of Damage** Physical Damage  
**Accessible** Yes  
**Potential for Damage** Med  
**Removed** No  
**Planned Response Action** O & M

**Inspector**

  
\_\_\_\_\_  
Stephen Kimbrough

**State** Indiana  
**Accreditation Number** 191914122

## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Charlestown Senior High School  
**HA#** C  
**Type of Material** Miscellaneous Material  
**Quantity of Material** Unquantified SF

**Material Location**  
Exterior fascia board


**Material Description**  
Transite board with stone texturing

**Comments**


An approximate 4' X 4' section of this material was damaged outside the cafeteria in the courtyard by a delivery truck. The area was cleaned up by school personnel. It is thought to be on most of the fascia board upper exterior of the building. This material was not previously addressed. It will be treated as ACM until proper sampling is done.

**Does Material Contain Asbestos?** Assumed  
**Is it Friable?** No  
**Original Inspection Date** 01/11/2001  
**Current Surveillance Date** 12/11/2001  
**Current Assessment Rating** NR Not Required  
**Cause of Damage** No Damage  
**Accessible** Yes  
**Potential for Damage** Med  
**Removed** No  
**Planned Response Action** O & M

**Inspector**

  
\_\_\_\_\_  
Stephen Kimbrough

**State** Indiana  
**Accreditation Number** 191914122



## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Charlestown Senior High School  
**HA#** 01  
**Type of Material** Thermal Material  
**Quantity of Material** 225 SF


**Material Location**  
Boiler room

**Material Description**  
Water tank cover

**Comments**  
Material is in good condition with some of the canvas seams coming loose. O & M suggested.

**Does Material Contain Asbestos?** Yes  
**Is it Friable?** No  
**Original Inspection Date** 06/01/1992  
**Current Surveillance Date** 01/11/2001  
**Current Assessment Rating** NR Not Required  
**Cause of Damage** Delamination  
**Accessible** Yes  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M

**Inspector**



Patrick E. Wilson

**State** Indiana  
**Accreditation Number** 190824065



## PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools  
Building Name Charlestown Senior High School  
HA# 03  
Type of Material Thermal Material  
Quantity of Material 3,978 LF

Material Location  
Tunnels and boiler room

Material Description  
Pipe insulation (heat)

Comments  
Tunnels are restricted. There is delaminating canvas covering in the boiler room underneath the sink on the west wall. No insulation is exposed except for some open ends on pipe runs of paper insulation. O & M needed.

Does Material Contain Asbestos? Yes  
Is it Friable? No  
Original Inspection Date 06/01/1992  
Current Surveillance Date 01/11/2001  
Current Assessment Rating NR Not Required  
Cause of Damage Delamination  
Accessible Yes  
Potential for Damage Low  
Removed No  
Planned Response Action O & M

Inspector



Patrick E. Wilson

State Indiana  
Accreditation Number 190824065

## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Charlestown Senior High School  
**HA#** 04  
**Type of Material** Thermal Material  
**Quantity of Material** 600 SF

**Material Location**  
Boiler room


**Material Description**  
Stack insulation (breeching)

**Comments**

Delamination of canvas has now exposed the insulation on a bottom section, but the insulation is still intact and in good condition overall. O & M needed.

**Does Material Contain Asbestos?** Yes  
**Is it Friable?** No  
**Original Inspection Date** 06/01/1992  
**Current Surveillance Date** 01/11/2001  
**Current Assessment Rating** NR Not Required  
**Cause of Damage** Delamination  
**Accessible** Yes  
**Potential for Damage** Med  
**Removed** No  
**Planned Response Action** O & M

**Inspector**




Patrick E. Wilson

**State** Indiana  
**Accreditation Number** 190824065

## PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools  
Building Name Charlestown Senior High School  
HA# 05  
Type of Material Thermal Material  
Quantity of Material 250 LF  
Material Location  
Along wall in boiler room  
Material Description  
Air cell pipe insulation  
Comments  
Material has some open ends, but no other damage noted.  
Does Material Contain Asbestos? Yes  
Is it Friable? No  
Original Inspection Date 06/01/1992  
Current Surveillance Date 01/11/2001  
Current Assessment Rating NR Not Required  
Cause of Damage Other  
Accessible Yes  
Potential for Damage Low  
Removed No  
Planned Response Action O & M

Inspector

  
Patrick E. Wilson

State Indiana  
Accreditation Number 190824065

## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Charlestown Senior High School  
**HA#** 06  
**Type of Material** Thermal Material  
**Quantity of Material** 293 Each

**Material Location**  
Throughout the building

**Material Description**  
Fittings

**Comments**

Damaged fittings found in the pipe chase in the boys restroom off of the athletic storage room. One fitting in center area of maintenance office has insulation exposed where canvas has pulled loose. The fittings are in good condition overall with not enough damage to call the homogeneous area damaged. Some O & M has been performed.

**Does Material Contain Asbestos?** Yes  
**Is it Friable?** No  
**Original Inspection Date** 06/01/1992  
**Current Surveillance Date** 01/11/2001  
**Current Assessment Rating** NR Not Required  
**Cause of Damage** Physical Damage  
**Accessible** Yes  
**Potential for Damage** Med  
**Removed** No  
**Planned Response Action** O & M

**Inspector**



Patrick E. Wilson

**State** Indiana  
**Accreditation Number** 190824065

## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Charlestown Senior High School  
**HA#** C  
**Type of Material** Miscellaneous Material  
**Quantity of Material** Unquantified SF

**Material Location**  
Exterior facia board


**Material Description**  
Transite board with stone texturing

**Comments**

An approximate 4' X 4' section of this material was damaged outside the cafeteria in the courtyard by a delivery truck. The area was cleaned up by school personnel. It is thought to be on most of the facia board upper exterior of the building. This material was not previously addressed. It will be treated as ACM until proper sampling is done.

**Does Material Contain Asbestos?** Assumed  
**Is it Friable?** No  
**Original Inspection Date** 01/11/2001  
**Current Surveillance Date** 01/11/2001  
**Current Assessment Rating** NR Not Required  
**Cause of Damage** No Damage  
**Accessible** Yes  
**Potential for Damage** Med  
**Removed** No  
**Planned Response Action** O & M

**Inspector**



Patrick E. Wilson

**State** Indiana  
**Accreditation Number** 190824065



## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Charlestown Senior High School  
**HA#** 01  
**Type of Material** Thermal Material  
**Quantity of Material** 225 SF  
**Material Location**  
Boiler Room  
**Material Description**  
Water Tank Cover  
**Comments**  
Material is in good condition.  
**Does Material Contain Asbestos?** Yes  
**Is it Friable?** No  
**Original Inspection Date** 06/01/1992  
**Current Surveillance Date** 06/29/2000  
**Current Assessment Rating** NR Not Required  
**Cause of Damage** No Damage  
**Accessible** Yes  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M  
  
**Inspector**   
George William Ogle  
  
**State** Indiana  
**Accreditation Number** 191523030

## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Charlestown Senior High School  
**HA#** 03  
**Type of Material** Thermal Material  
**Quantity of Material** 3978 LF

**Material Location**  
Tunnels and boiler room

**Material Description**  
Pipe Insulation (Heat)

**Comments**

Tunnels are restricted. There is delaminating canvas covering in the boiler room underneath the sink on the west wall. No insulation is exposed except for some open ends on pipe runs of paper insulation. O & M needed.

**Does Material Contain Asbestos?** Yes  
**Is it Friable?** No  
**Original Inspection Date** 06/01/1992  
**Current Surveillance Date** 06/29/2000  
**Current Assessment Rating** NR Not Required  
**Cause of Damage** No Damage  
**Accessible** Yes  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M

**Inspector**

  
George William Ogle

**State** Indiana  
**Accreditation Number** 191523030



## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Charlestown Senior High School  
**HA#** 04  
**Type of Material** Thermal Material  
**Quantity of Material** 600 SF

**Material Location**  
Boiler Room

**Material Description**  
Stack Insulation (Breeching)

**Comments**

Delamination of canvas has now exposed the insulation on a bottom section, but the insulation is still intact and in good condition overall. O & M needed.

**Does Material Contain Asbestos?** Yes  
**Is it Friable?** No  
**Original Inspection Date** 06/01/1992  
**Current Surveillance Date** 06/29/2000  
**Current Assessment Rating** NR Not Required  
**Cause of Damage** Water Damage  
**Accessible** Yes  
**Potential for Damage** Med  
**Removed** No  
**Planned Response Action** O & M

**Inspector**

  
George William Ogle

**State** Indiana  
**Accreditation Number** 191523030

## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Charlestown Senior High School  
**HA#** 05  
**Type of Material** Thermal Material  
**Quantity of Material** 250 LF  
**Material Location**  
Along Wall in Boiler Room  
**Material Description**  
Air Cell Pipe Insulation  
**Comments**  
Material has some open ends, but not other damage noted.  
**Does Material Contain Asbestos?** Yes  
**Is it Friable?** No  
**Original Inspection Date** 06/01/1992  
**Current Surveillance Date** 06/29/2000  
**Current Assessment Rating** NR Not Required  
**Cause of Damage** Other  
**Accessible** Yes  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M

**Inspector**

  
George William Ogle

**State**

Indiana

**Accreditation Number**

191523030

## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Charlestown Senior High School  
**HA#** 06  
**Type of Material** Thermal Material  
**Quantity of Material** 293 Each

**Material Location**  
Throughout building

**Material Description**  
Fittings

**Comments**

Damaged fittings found in the pipe chase in the boys restroom off of the athletic storage room. One fitting in center area of maintenance office has insulation exposed where canvas has pulled loose. The fittings are in good condition overall with not enough damage to call the homogeneous area damaged.

**Does Material Contain Asbestos?** Yes  
**Is it Friable?** No  
**Original Inspection Date** 06/01/1992  
**Current Surveillance Date** 06/29/2000  
**Current Assessment Rating** NR Not Required  
**Cause of Damage** Physical Damage  
**Accessible** Yes  
**Potential for Damage** Med  
**Removed** No  
**Planned Response Action** O & M

**Inspector**

  
George William Ogle

**State** Indiana  
**Accreditation Number** 191523030



## PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools  
Building Name Charlestown Senior High School  
HA# 01  
Type of Material Thermal Material  
Quantity of Material 225 SF  
Material Location  
Boiler Room  
Material Description  
Water Tank Cover

### Comments

Material is in good condition. It is larger than 225 SF.

Does Material Contain Asbestos? Yes  
Is it Friable? No  
Original Inspection Date 06/01/1992  
Current Surveillance Date 12/08/1999  
Current Assessment Rating NR Not Required  
Cause of Damage No Damage  
Accessible Yes  
Potential for Damage Low  
Removed No  
Planned Response Action O & M

Inspector

  
Matthew Wallace

State Indiana  
Accreditation Number 191219020

## PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools  
Building Name Charlestown Senior High School  
HA# 03  
Type of Material Thermal Material  
Quantity of Material 3978 LF

Material Location  
Tunnels and boiler room

Material Description  
Pipe Insulation (Heat)

### Comments

Tunnels are restricted. Damaged insulation found in the boiler room underneath the sink on the west wall. O & M needed.

Does Material Contain Asbestos? Yes  
Is it Friable? Yes  
Original Inspection Date 06/01/1992  
Current Surveillance Date 12/08/1999  
Current Assessment Rating 1B Damaged TSI  
Cause of Damage Physical Damage  
Accessible Yes  
Potential for Damage High  
Removed No  
Planned Response Action O & M

Inspector


  
Matthew Wallace

State Indiana  
Accreditation Number 191219020

## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Charlestown Senior High School  
**HA#** 04  
**Type of Material** Thermal Material  
**Quantity of Material** 600 SF  
**Material Location**  
Boiler Room  
**Material Description**  
Stack Insulation (Breeching)  
**Comments**  
Delamination is getting worse. O & M needed.  
**Does Material Contain Asbestos?** Yes  
**Is it Friable?** Yes  
**Original Inspection Date** 06/01/1992  
**Current Surveillance Date** 12/08/1999  
**Current Assessment Rating** 1B Damaged TSI  
**Cause of Damage** Water Damage  
**Accessible** Yes  
**Potential for Damage** Med  
**Removed** No  
**Planned Response Action** O & M

**Inspector**


  
Matthew Wallace

**State** Indiana  
**Accreditation Number** 191219020

## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Charlestown Senior High School  
**HA#** 05  
**Type of Material** Thermal Material  
**Quantity of Material** 250 LF  
**Material Location**  
Along Wall in Boiler Room  
**Material Description**  
Air Cell Pipe Insulation  
**Comments**  
Material is damaged. Some O & M has been done, but more is needed.  
**Does Material Contain Asbestos?** Yes  
**Is it Friable?** Yes  
**Original Inspection Date** 06/01/1992  
**Current Surveillance Date** 12/08/1999  
**Current Assessment Rating** 1B Damaged TSI  
**Cause of Damage** Other  
**Accessible** Yes  
**Potential for Damage** Med  
**Removed** No  
**Planned Response Action** O & M

**Inspector**

  
Matthew Wallace

**State** Indiana  
**Accreditation Number** 191219020



## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Charlestown Senior High School  
**HA#** 06  
**Type of Material** Thermal Material  
**Quantity of Material** 293 Each

**Material Location**  
Throughout building


**Material Description**  
Fittings

**Comments**

Damaged fittings found in the pipe chase at the boys restroom off of the athletic storage room. Damaged fittings in boiler room need repaired.

**Does Material Contain Asbestos?** Yes  
**Is it Friable?** Yes  
**Original Inspection Date** 06/01/1992  
**Current Surveillance Date** 12/08/1999  
**Current Assessment Rating** 1B Damaged TSI  
**Cause of Damage** Physical Damage  
**Accessible** Yes  
**Potential for Damage** Med  
**Removed** No  
**Planned Response Action** O & M

**Inspector**

  
Matthew Wallace

**State** Indiana  
**Accreditation Number** 191219020



## PERIODIC SURVEILLANCE REPORT


**LEA Name** Greater Clark County Schools  
**Building Name** Charlestown Senior High School  
**HA#** 01  
**Type of Material** Thermal Material  
**Quantity of Material** 225 SF  
**Material Location**  
Boiler Room  
**Material Description**  
Water Tank Cover

**Comments**

Material is in good condition. It is larger than 225 SF.

**Does Material Contain Asbestos?** Yes  
**Is it Friable?** No  
**Original Inspection Date** 06/01/1992  
**Current Surveillance Date** 06/24/1999  
**Current Assessment Rating** NR Not Required  
**Cause of Damage** No Damage  
**Accessible** Yes  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M

**Inspector**

  
Matthew Wallace

**State** Indiana  
**Accreditation Number** 191219020

## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Charlestown Senior High School  
**HA#** 03  
**Type of Material** Thermal Material  
**Quantity of Material** 3978 LF

**Material Location**  
Tunnels and boiler room

**Material Description**  
Pipe Insulation (Heat)

**Comments**  
Tunnels are restricted. Damaged insulation found in the boiler room underneath the sink on the west wall. O & M needed.


**Does Material Contain Asbestos?** Yes  
**Is it Friable?** Yes  
**Original Inspection Date** 06/01/1992  
**Current Surveillance Date** 06/24/1999  
**Current Assessment Rating** 1B Damaged TSI  
**Cause of Damage** Physical Damage  
**Accessible** Yes  
**Potential for Damage** High  
**Removed** No  
**Planned Response Action** O & M

**Inspector**

  
Matthew Wallace

**State** Indiana  
**Accreditation Number** 191219020

## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Charlestown Senior High School  
**HA#** 04  
**Type of Material** Thermal Material  
**Quantity of Material** 600 SF  
**Material Location**  
Boiler Room  
**Material Description**  
Stack Insulation (Breeching)  
**Comments**  
Delamination is getting worse. O & M needed.  
**Does Material Contain Asbestos?** Yes  
**Is it Friable?** Yes  
**Original Inspection Date** 06/01/1992  
**Current Surveillance Date** 06/24/1999  
**Current Assessment Rating** 1B Damaged TSI  
**Cause of Damage** Water Damage  
**Accessible** Yes  
**Potential for Damage** Med  
**Removed** No  
**Planned Response Action** O & M  
  
**Inspector**   
Matthew Wallace  
  
**State** Indiana  
**Accreditation Number** 191219020

## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Charlestown Senior High School  
**HA#** 05  
**Type of Material** Thermal Material  
**Quantity of Material** 250 LF

**Material Location**  
Along Wall in Boiler Room

**Material Description**  
Air Cell Pipe Insulation

**Comments**  
Material is damaged. Open ends need patched. No change in the last 6 months.

**Does Material Contain Asbestos?** Yes  
**Is it Friable?** Yes  
**Original Inspection Date** 06/01/1992  
**Current Surveillance Date** 06/24/1999  
**Current Assessment Rating** 1B Damaged TSI  
**Cause of Damage** Other  
**Accessible** Yes  
**Potential for Damage** Med  
**Removed** No  
**Planned Response Action** O & M

**Inspector**

  
Matthew Wallace

**State** Indiana  
**Accreditation Number** 191219020

## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools

**Building Name** Charlestown Senior High School

**HA#** 06

**Type of Material** Thermal Material

**Quantity of Material** 293 Each

**Material Location**  
Throughout building

**Material Description**  
Fittings

**Comments**

Damaged fittings found in the pipe chase at the boys restroom off of the athletic storage room. Damaged fittings in boiler room need repaired.

**Does Material Contain Asbestos?** Yes

**Is it Friable?** Yes

**Original Inspection Date** 06/01/1992

**Current Surveillance Date** 06/24/1999

**Current Assessment Rating** 1B Damaged TSI

**Cause of Damage** Physical Damage

**Accessible** Yes

**Potential for Damage** Med

**Removed** No

**Planned Response Action** O & M

**Inspector**

  
Matthew Wallace

**State** Indiana

**Accreditation Number** 191219020





## PERIODIC SURVEILLANCE REPORT


LEA Name Greater Clark County Schools  
Building Name Charlestown Senior High School  
HA# 01  
Type of Material Thermal Material  
Quantity of Material 225 SF  
Material Location  
Boiler Room  
Material Description  
Water Tank Cover

**Comments**

Material is in good condition. It is larger than 225 SF.

Does Material Contain Asbestos? Yes  
Is it Friable? No  
Original Inspection Date 06/01/1992  
Current Surveillance Date 12/29/1998  
Current Assessment Rating NR Not Required  
Cause of Damage No Damage  
Accessible Yes  
Potential for Damage Low  
Removed No  
Planned Response Action O & M

Inspector



Clint Yates

State Indiana  
Accreditation Number 193804035

## PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools  
Building Name Charlestown Senior High School

HA# 03

Type of Material Thermal Material

Quantity of Material 3978 LF

Material Location  
Tunnels and boiler room

Material Description  
Pipe Insulation (Heat)

### Comments

Tunnels are restricted. Damaged insulation found in the boiler room underneath the sink on the west wall.

Does Material Contain Asbestos? Yes

Is it Friable? Yes

Original Inspection Date 06/01/1992

Current Surveillance Date 12/29/1998

Current Assessment Rating 1B Damaged TSI

Cause of Damage Physical Damage

Accessible Yes

Potential for Damage High

Removed No

Planned Response Action O & M

Inspector

  
Clint Yates

State Indiana

Accreditation Number 193804035

## PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools  
Building Name Charlestown Senior High School  
HA# 04  
Type of Material Thermal Material  
Quantity of Material 600 SF  
Material Location  
Boiler Room  
Material Description  
Stack Insulation (Breeching)  
Comments  
Delamination is getting worse. O & M needed.  
Does Material Contain Asbestos? Yes  
Is it Friable? Yes  
Original Inspection Date 06/01/1992  
Current Surveillance Date 12/29/1998  
Current Assessment Rating 1B Damaged TSI  
Cause of Damage Water Damage  
Accessible Yes  
Potential for Damage Med  
Removed No  
Planned Response Action O & M

Inspector

  
Clint Yates

State

Indiana

Accreditation Number

193804035

## PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools  
Building Name Charlestown Senior High School  
HA# 05  
Type of Material Thermal Material  
Quantity of Material 250 LF  
Material Location  
Along Wall in Boiler Room  
Material Description  
Air Cell Pipe Insulation

### Comments

Material is damaged. Open ends need patched. No change in the last 6 months.

Does Material Contain Asbestos? Yes  
Is it Friable? Yes  
Original Inspection Date 06/01/1992  
Current Surveillance Date 12/29/1998  
Current Assessment Rating 1B Damaged TSI  
Cause of Damage Other  
Accessible Yes  
Potential for Damage Med  
Removed No  
Planned Response Action O & M

Inspector

  
Clint Yates

State

Indiana

Accreditation Number

193804035

## PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools  
Building Name Charlestown Senior High School  
HA# 06  
Type of Material Thermal Material  
Quantity of Material 293 Each  
Material Location  
Throughout building

Material Description  
Fittings

### Comments

Damaged fittings found in the pipe chase at the boys restroom off of the athletic storage room. Damaged fittings in boiler room need repaired.

Does Material Contain Asbestos? Yes  
Is it Friable? Yes  
Original Inspection Date 06/01/1992  
Current Surveillance Date 12/29/1998  
Current Assessment Rating 1B Damaged TSI  
Cause of Damage Physical Damage  
Accessible Yes  
Potential for Damage Med  
Removed No  
Planned Response Action O & M

Inspector

Clint Yates

State

Indiana

Accreditation Number

193804035

## PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools  
Building Name Charlestown Senior High School  
HA# 08  
Type of Material Miscellaneous Material  
Quantity of Material 4200 SF  
Material Location  
Throughout building


Material Description  
VAT Mastic

**Comments**

Material has been removed and replaced with non-asbestos adhesive.

Does Material Contain Asbestos? No  
Is it Friable? No  
Original Inspection Date 06/01/1992  
Current Surveillance Date 12/29/1998  
Current Assessment Rating NA Not Applicable  
Cause of Damage Not Applicable  
Accessible No  
Potential for Damage NA  
Removed Yes  
Planned Response Action None

Inspector



Clint Yates

State Indiana  
Accreditation Number 193804035

## PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools  
Building Name Charlestown Senior High School  
HA# A  
Type of Material Miscellaneous Material  
Quantity of Material Unquantified LF  
Material Location  
Throughout building

Material Description  
Cove Base

**Comments**

Material has been removed and replaced with non-asbestos cove base.

Does Material Contain Asbestos? No  
Is it Friable? No  
Original Inspection Date 05/31/1995  
Current Surveillance Date 12/29/1998  
Current Assessment Rating NA Not Applicable  
Cause of Damage Not Applicable  
Accessible No  
Potential for Damage NA  
Removed Yes  
Planned Response Action None

Inspector

  
Clint Yates

State

Indiana

Accreditation Number

193804035

## PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools  
Building Name Charlestown Senior High School  
HA# B  
Type of Material Miscellaneous Material  
Quantity of Material Unquantified LF  
Material Location  
Throughout building


Material Description  
Cove Base Mastic

**Comments**

Material has been removed and replaced with non-asbestos mastic.

Does Material Contain Asbestos? No  
Is it Friable? No  
Original Inspection Date 05/31/1996  
Current Surveillance Date 12/29/1998  
Current Assessment Rating NA Not Applicable  
Cause of Damage Not Applicable  
Accessible No  
Potential for Damage NA  
Removed Yes  
Planned Response Action None


Inspector



Clint Yates

State Indiana  
Accreditation Number 193804035





## PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools  
Building Name Charlestown Senior High School  
HA# 01  
Type of Material Thermal Material  
Quantity of Material 225 SF

Material Location  
Boiler Room

Material Description  
Water Tank Cover

Comments  
Material is in good condition. It is larger than 225 SF.

Does Material Contain Asbestos? Yes  
Is it Friable? No  
Original Inspection Date 6/ 1/92  
Current Surveillance Date 1/15/98  
Current Assessment Rating NR Not Required  
Cause of Damage No Damage  
Accessible Yes  
Potential for Damage Low  
Removed No  
Planned Response Action O & M

Inspector



---

Karen Foxx

State Indiana  
Accreditation Number 191129014

## PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools  
Building Name Charlestown Senior High School  
HA# 03  
Type of Material Thermal Material  
Quantity of Material 3,978 LF  
Material Location  
Tunnels, Boiler Room, Athletic Storage Room, and Hallway next to Locker Rooms  
Material Description  
Pipe Insulation (Heat)  
Comments  
Tunnels are restricted. Some O & M and small removal has been done.  
Does Material Contain Asbestos? Yes  
Is it Friable? Yes  
Original Inspection Date 6/ 1/92  
Current Surveillance Date 1/15/98  
Current Assessment Rating 1B Damaged TSI  
Cause of Damage Physical Damage  
Accessible Yes  
Potential for Damage High  
Removed No  
Planned Response Action O & M

Inspector



Karen Foxx

State Indiana  
Accreditation Number 191129014

## PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools  
Building Name Charlestown Senior High School  
HA# 04  
Type of Material Thermal Material  
Quantity of Material 600 SF

Material Location  
Boiler Room

Material Description  
Stack Insulation (Breeching)

### Comments

Material is delaminating and there is a large fold in the canvas.

Does Material Contain Asbestos? Yes  
Is it Friable? Yes  
Original Inspection Date 6/ 1/92  
Current Surveillance Date 1/15/98  
Current Assessment Rating 1B Damaged TSI  
Cause of Damage Water Damage  
Accessible Yes  
Potential for Damage Med  
Removed No  
Planned Response Action O & M

Inspector



---

Karen Foss

State Indiana  
Accreditation Number 191129014

## PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools  
Building Name Charlestown Senior High School  
HA# 05  
Type of Material Thermal Material  
Quantity of Material 250 LF

Material Location  
Along Wall in Boiler Room

Material Description  
Air Cell Pipe Insulation

Comments  
Material is damaged. Open ends need patched.

Does Material Contain Asbestos? Yes  
Is it Friable? Yes  
Original Inspection Date 6/ 1/92  
Current Surveillance Date 1/15/98  
Current Assessment Rating 1B Damaged TSI  
Cause of Damage Other  
Accessible Yes  
Potential for Damage Med  
Removed No  
Planned Response Action O & M

Inspector



Karen Foxx

State Indiana  
Accreditation Number 191129014

## PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools  
Building Name Charlestown Senior High School  
HA# 06  
Type of Material Thermal Material  
Quantity of Material 293 Each

Material Location  
Throughout building

Material Description  
Fittings

Comments  
Material is damaged in boiler room. The rest is in good condition.

Does Material Contain Asbestos? Yes  
Is it Friable? Yes  
Original Inspection Date 6/ 1/92  
Current Surveillance Date 1/15/98  
Current Assessment Rating 1B Damaged TSI  
Cause of Damage Physical Damage  
Accessible Yes  
Potential for Damage Med  
Removed No  
Planned Response Action O & M

Inspector



---

Karen Foxx

State Indiana  
Accreditation Number 191129014

## PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools  
Building Name Charlestown Senior High School  
HA# 08  
Type of Material Miscellaneous Material  
Quantity of Material 4,200 SF


Material Location  
Throughout building

Material Description  
VAT Mastic

Comments  
Material has been removed and replaced with non-asbestos adhesive.

Does Material Contain Asbestos? No  
Is it Friable? No  
Original Inspection Date 6/ 1/92  
Current Surveillance Date 1/15/98  
Current Assessment Rating NA Not Applicable  
Cause of Damage Not Applicable  
Accessible No  
Potential for Damage NA  
Removed Yes  
Planned Response Action None

Inspector



---

Karen Foxx

State Indiana  
Accreditation Number 191129014

## PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools  
Building Name Charlestown Senior High School  
HA# A  
Type of Material Miscellaneous Material  
Quantity of Material LF

Material Location  
Throughout building

Material Description  
Cove Base

### Comments

Material has been removed and replaced with non-asbestos cove base.

Does Material Contain Asbestos? No  
Is it Friable? No  
Original Inspection Date 5/31/95  
Current Surveillance Date 1/15/98  
Current Assessment Rating NA Not Applicable  
Cause of Damage Not Applicable  
Accessible No  
Potential for Damage NA  
Removed Yes  
Planned Response Action None

Inspector



Karen Foxx

State Indiana  
Accreditation Number 191129014



## PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools  
Building Name Charlestown Senior High School  
HA# B  
Type of Material Miscellaneous Material  
Quantity of Material LF

Material Location  
Throughout building

Material Description  
Cove Base Mastic

Comments  
Material has been removed and replaced with non-asbestos mastic.


Does Material Contain Asbestos? No  
Is it Friable? No  
Original Inspection Date 5/31/96  
Current Surveillance Date 1/15/98  
Current Assessment Rating NA Not Applicable  
Cause of Damage Not Applicable  
Accessible No  
Potential for Damage NA  
Removed Yes  
Planned Response Action None

Inspector



Karen Foxx

State Indiana  
Accreditation Number 191129014



## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Charlestown Senior High School

**HA#** 1

**Type of Material** Thermal Material

**Quantity of Material** 225 SF

**Material Location**  
Boiler Room

**Material Description**  
Water Tank Cover

**Comments**  
Material is in good condition. It is larger than 225 SF.

**Does Material Contain Asbestos?** Yes

**Is it Friable?** No

**Original Inspection Date** 6/ 1/92

**Current Surveillance Date** 7/ 1/97

**Current Assessment Rating** NR Not Required

**Cause of Damage** No Damage

**Accessible** Yes

**Potential for Damage** Low

**Removed** No

**Planned Response Action** O & M

**Inspector**



Karen Foxx

**State** Indiana

**Accreditation Number** 191129014

## PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools

Building Name Charlestown Senior High School

HA# 3

Type of Material Thermal Material

Quantity of Material 3,978 LF

**Material Location**

Tunnels, Boiler Room, Athletic Storage Room, and Hallway next to Locker Rooms

**Material Description**

Pipe Insulation (Heat)

**Comments**

Tunnels are restricted. Some O & M and small removal has been done.

Does Material Contain Asbestos? Yes

Is it Friable? Yes

Original Inspection Date 6/ 1/92

Current Surveillance Date 7/ 1/97

Current Assessment Rating 1B Damaged TSI

Cause of Damage Physical Damage

Accessible Yes

Potential for Damage High

Removed No

Planned Response Action O & M

Inspector

  
\_\_\_\_\_  
Karen Foxx

State Indiana

Accreditation Number 191129014

## PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools  
Building Name Charlestown Senior High School  
HA# 4  
Type of Material Thermal Material  
Quantity of Material 600 SF  
Material Location  
Boiler Room  
Material Description  
Stack Insulation (Breeching)

### Comments

Material is delaminating and there is a large fold in the canvas.

Does Material Contain Asbestos? Yes  
Is it Friable? Yes  
Original Inspection Date 6/ 1/92  
Current Surveillance Date 7/ 1/97  
Current Assessment Rating 1B Damaged TSI  
Cause of Damage Water Damage  
Accessible Yes  
Potential for Damage Med  
Removed No  
Planned Response Action O & M

Inspector



Karen Foxx

State Indiana  
Accreditation Number 191129014

## PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools  
Building Name Charlestown Senior High School  
HA# 5  
Type of Material Thermal Material  
Quantity of Material 250 LF  
Material Location  
Along Wall in Boiler Room  
Material Description  
Air Cell Pipe Insulation  
Comments  
Open ends need patched.  
Does Material Contain Asbestos? Yes  
Is it Friable? Yes  
Original Inspection Date 6/ 1/92  
Current Surveillance Date 7/ 1/97  
Current Assessment Rating 1B Damaged TSI  
Cause of Damage Other  
Accessible Yes  
Potential for Damage Med  
Removed No  
Planned Response Action O & M

Inspector



Karen Foxx

State Indiana  
Accreditation Number 191129014

## PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools  
Building Name Charlestown Senior High School  
HA# 6  
Type of Material Thermal Material  
Quantity of Material 293 Each

Material Location  
Throughout building

Material Description  
Fittings

### Comments

Material is damaged in boiler room. The rest is in good condition.

Does Material Contain Asbestos? Yes  
Is it Friable? Yes  
Original Inspection Date 6/ 1/92  
Current Surveillance Date 7/ 1/97  
Current Assessment Rating 1B Damaged TSI  
Cause of Damage Physical Damage  
Accessible Yes  
Potential for Damage Med  
Removed No  
Planned Response Action O & M

Inspector



---

Karen Foxx

State Indiana  
Accreditation Number 191129014

## PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools  
Building Name Charlestown Senior High School  
HA# 8  
Type of Material Miscellaneous Material  
Quantity of Material 4,200 SF  
Material Location  
Throughout building  
Material Description  
VAT Mastic

### Comments

Material is exposed as all the floor tile is being removed. It was tested in July '97 and found to be negative for asbestos content.

Does Material Contain Asbestos? No  
Is it Friable? No  
Original Inspection Date 6/ 1/92  
Current Surveillance Date 7/ 1/97  
Current Assessment Rating NR Not Required  
Cause of Damage No Damage  
Accessible Yes  
Potential for Damage Low  
Removed No  
Planned Response Action None

Inspector

  
\_\_\_\_\_  
Karen Foxx

State Indiana  
Accreditation Number 191129014



## PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools  
Building Name Charlestown Senior High School  
HA# A  
Type of Material Miscellaneous Material  
Quantity of Material LF

Material Location  
Throughout building

Material Description  
Cove Base

Comments  
Material is being removed and will be replaced with new.

Does Material Contain Asbestos? Assumed  
Is it Friable? No  
Original Inspection Date 5/31/95  
Current Surveillance Date 7/ 1/97  
Current Assessment Rating NR Not Required  
Cause of Damage No Damage  
Accessible Yes  
Potential for Damage Low  
Removed No  
Planned Response Action O & M

Inspector



Karen Foxx

State Indiana  
Accreditation Number 191129014

## PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools  
Building Name Charlestown Senior High School  
HA# B  
Type of Material Miscellaneous Material  
Quantity of Material LF

Material Location  
Throughout building

Material Description  
Cove Base Mastic

**Comments**

Material is exposed as the cove base is being removed. It was sampled in July '97 and found to be negative for asbestos content.

Does Material Contain Asbestos? No  
Is it Friable? No  
Original Inspection Date 5/31/96  
Current Surveillance Date 7/ 1/97  
Current Assessment Rating NR Not Required  
Cause of Damage No Damage  
Accessible No  
Potential for Damage Low  
Removed No  
Planned Response Action None

Inspector



Karen Foxx

State Indiana  
Accreditation Number 191129014



## PERIODIC SURVEILLANCE REPORT


LEA Name Greater Clark County Schools  
Building Name Charlestown Senior High School  
HA# 1  
Type of Material Thermal Material  
Quantity of Material 225 SF  
Material Location  
Boiler Room  
Material Description  
Water Tank Cover

**Comments**

Material is known to be asbestos containing. It is in good condition. It is larger than 225 SF.

Does Material Contain Asbestos? Yes  
Is it Friable? No  
Original Inspection Date 6/ 1/92  
Current Surveillance Date 12/16/96  
Current Assessment Rating NR Not Required  
Cause of Damage No Damage  
Accessible Yes  
Potential for Damage Low  
Removed No  
Planned Response Action O & M

Inspector



Clint Yates


State Indiana  
Accreditation Number 193804035

## PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools  
Building Name Charlestown Senior High School  
HA# 3  
Type of Material Thermal Material  
Quantity of Material 3,978 LF  
Material Location  
Tunnels, Boiler Room, Athletic Storage Room, and Hallway next to Locker Rooms  
Material Description  
Pipe Insulation (Heat)  
Comments  
Tunnels are restricted. Material is known to be asbestos containing. Some O & M and small removal has been done.

Does Material Contain Asbestos? Yes  
Is it Friable? Yes  
Original Inspection Date 6/ 1/92  
Current Surveillance Date 12/16/96  
Current Assessment Rating 1B Damaged TSI  
Cause of Damage Physical Damage  
Accessible Yes  
Potential for Damage High  
Removed No  
Planned Response Action O & M

Inspector



Clint Yates

State

Indiana

Accreditation Number

193804035

## PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools  
Building Name Charlestown Senior High School  
HA# 4  
Type of Material Thermal Material  
Quantity of Material 600 SF  
Material Location  
Boiler Room


Material Description  
Stack Insulation (Breeching)

**Comments**

Material is known to be asbestos containing. It is delaminating and there is a large fold in the canvas. No change.

Does Material Contain Asbestos? Yes  
Is it Friable? Yes  
Original Inspection Date 6/ 1/92  
Current Surveillance Date 12/16/96  
Current Assessment Rating 1B Damaged TSI  
Cause of Damage Water Damage  
Accessible Yes  
Potential for Damage Med  
Removed No  
Planned Response Action O & M

Inspector



Clint Yates

State

Indiana

Accreditation Number

193804035

## PERIODIC SURVEILLANCE REPORT


LEA Name Greater Clark County Schools  
Building Name Charlestown Senior High School  
HA# 5  
Type of Material Thermal Material  
Quantity of Material 250 LF  
Material Location  
Along Wall in Boiler Room  
Material Description  
Air Cell Pipe Insulation

**Comments**

Material is known to be asbestos containing. Open ends need patched. No change.

Does Material Contain Asbestos? Yes  
Is it Friable? Yes  
Original Inspection Date 6/ 1/92  
Current Surveillance Date 12/16/96  
Current Assessment Rating 1B Damaged TSI  
Cause of Damage Other  
Accessible Yes  
Potential for Damage Med  
Removed No  
Planned Response Action O & M

Inspector



Clint Yates

State Indiana  
Accreditation Number 193804035

## PERIODIC SURVEILLANCE REPORT


LEA Name Greater Clark County Schools  
Building Name Charlestown Senior High School  
HA# 6  
Type of Material Thermal Material  
Quantity of Material 293 Each  
Material Location  
Throughout building  
Material Description  
Fittings

**Comments**

Material is damaged in boiler room. The rest is in good condition. Material is known to be asbestos containing.

Does Material Contain Asbestos? Yes  
Is it Friable? Yes  
Original Inspection Date 6/ 1/92  
Current Surveillance Date 12/16/96  
Current Assessment Rating 1B Damaged TSI  
Cause of Damage Physical Damage  
Accessible Yes  
Potential for Damage Med  
Removed No  
Planned Response Action O & M

Inspector

  
Clint Yates

State

Indiana

Accreditation Number

193804035



## PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools  
Building Name Charlestown Senior High School  
HA# 8  
Type of Material Miscellaneous Material  
Quantity of Material 4,200 SF  
Material Location  
Throughout building  
Material Description  
VAT Mastic  
Comments  
Mastic is assumed to be asbestos containing. (Tile is negative.)

Does Material Contain Asbestos? Assumed  
Is it Friable? No  
Original Inspection Date 6/ 1/92  
Current Surveillance Date 12/16/96  
Current Assessment Rating NR Not Required  
Cause of Damage No Damage  
Accessible Yes  
Potential for Damage Low  
Removed No  
Planned Response Action O & M

Inspector



Clint Yates

State

Indiana

Accreditation Number

193804035

## PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools  
Building Name Charlestown Senior High School  
HA# A  
Type of Material Miscellaneous Material  
Quantity of Material LF

Material Location  
Throughout building


Material Description  
Cove Base

**Comments**

Material is assumed to be positive and will be treated as ACM until it is sampled.  
Material is in good condition.

Does Material Contain Asbestos? Assumed  
Is it Friable? No  
Original Inspection Date 5/31/95  
Current Surveillance Date 12/16/96  
Current Assessment Rating NR Not Required  
Cause of Damage No Damage  
Accessible Yes  
Potential for Damage Low  
Removed No  
Planned Response Action O & M

Inspector

  
Clint Yates

State Indiana  
Accreditation Number 193804035

## PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools  
Building Name Charlestown Senior High School  
HA# B  
Type of Material Miscellaneous Material  
Quantity of Material LF

Material Location  
Throughout building


Material Description  
Cove Base Mastic

**Comments**

Material is assumed to be positive and will be treated as ACM until it is sampled.  
Material is in good condition.


Does Material Contain Asbestos? Assumed  
Is it Friable? No  
Original Inspection Date 5/31/96  
Current Surveillance Date 12/16/96  
Current Assessment Rating NR Not Required  
Cause of Damage No Damage  
Accessible No  
Potential for Damage Low  
Removed No  
Planned Response Action O & M

Inspector



Clint Yates

State Indiana  
Accreditation Number 193804035



## PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools  
Building Name Charlestown Senior High School  
HA# 1  
Type of Material Thermal Material  
Quantity of Material 225 SF  
Material Location  
Boiler Room  
Material Description  
Water Tank Cover

**Comments**

Material is known to be asbestos containing. It is in good condition. It is larger than 225 SF.

Does Material Contain Asbestos? Yes  
Is it Friable? No  
Original Inspection Date 6/ 1/92  
Current Surveillance Date 6/20/96  
Current Assessment Rating NR Not Required  
Cause of Damage No Damage  
Accessible Yes  
Potential for Damage Low  
Removed No  
Planned Response Action O & M

Inspector

  
\_\_\_\_\_  
Rex Gaddis

State Indiana  
Accreditation Number 190908032

## PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools  
Building Name Charlestown Senior High School  
HA# 3  
Type of Material Thermal Material  
Quantity of Material 3,978 LF

**Material Location**

Tunnels, Boiler Room, Athletic Storage Room, and Hallway next to Locker Rooms

**Material Description**

Pipe Insulation (Heat)

**Comments**

Tunnels are restricted. Material is known to be asbestos containing. Some O & M and small removal has been done.

Does Material Contain Asbestos? Yes  
Is it Friable? Yes  
Original Inspection Date 6/ 1/92  
Current Surveillance Date 6/20/96  
Current Assessment Rating 1B Damaged TSI  
Cause of Damage Physical Damage  
Accessible Yes  
Potential for Damage High  
Removed No  
Planned Response Action O & M

Inspector



Rex Gaddis

State Indiana  
Accreditation Number 190908032

## PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools  
Building Name Charlestown Senior High School  
HA# 4  
Type of Material Thermal Material  
Quantity of Material 600 SF

Material Location  
Boiler Room

Material Description  
Stack Insulation (Breeching)

**Comments**

Material is known to be asbestos containing. It is delaminating and there is a large fold in the canvas. No change.

Does Material Contain Asbestos? Yes  
Is it Friable? Yes  
Original Inspection Date 6/ 1/92  
Current Surveillance Date 6/20/96  
Current Assessment Rating 1B Damaged TSI  
Cause of Damage Water Damage  
Accessible Yes  
Potential for Damage Med  
Removed No  
Planned Response Action O & M

Inspector

  
\_\_\_\_\_  
Rex Gaddis

State Indiana  
Accreditation Number 190908032

## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Charlestown Senior High School  
**HA#** 5  
**Type of Material** Thermal Material  
**Quantity of Material** 250 LF  
**Material Location**  
Along Wall in Boiler Room  
**Material Description**  
Air Cell Pipe Insulation

**Comments**

Material is known to be asbestos containing. Open ends need patched. No change.

**Does Material Contain Asbestos?** Yes  
**Is it Friable?** Yes  
**Original Inspection Date** 6/ 1/92  
**Current Surveillance Date** 6/20/96  
**Current Assessment Rating** 1B Damaged TSI  
**Cause of Damage** Other  
**Accessible** Yes  
**Potential for Damage** Med  
**Removed** No  
**Planned Response Action** O & M

**Inspector**



Rex Gaddis

**State** Indiana  
**Accreditation Number** 190908032



## PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools  
Building Name Charlestown Senior High School  
HA# 6  
Type of Material Thermal Material  
Quantity of Material 293 Each

Material Location  
Throughout building

Material Description  
Fittings

**Comments**

Material is damaged in boiler room. The rest is in good condition. Material is known to be asbestos containing.

Does Material Contain Asbestos? Yes  
Is it Friable? Yes  
Original Inspection Date 6/ 1/92  
Current Surveillance Date 6/20/96  
Current Assessment Rating 1B Damaged TSI  
Cause of Damage Physical Damage  
Accessible Yes  
Potential for Damage Med  
Removed No  
Planned Response Action O & M

Inspector

  
\_\_\_\_\_  
Rex Gaddis


State Indiana  
Accreditation Number 190908032

## PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools  
Building Name Charlestown Senior High School  
HA# 8  
Type of Material Miscellaneous Material  
Quantity of Material 4,200 SF  
Material Location  
Throughout building  
Material Description  
VAT Mastic  
Comments  
Mastic is assumed to be asbestos containing. (Tile is negative.)

Does Material Contain Asbestos? Assumed  
Is it Friable? No  
Original Inspection Date 6/ 1/92  
Current Surveillance Date 6/20/96  
Current Assessment Rating NR Not Required  
Cause of Damage No Damage  
Accessible Yes  
Potential for Damage Low  
Removed No  
Planned Response Action O & M

Inspector

  
\_\_\_\_\_  
Rex Gaddis

State Indiana  
Accreditation Number 190908032

## PERIODIC SURVEILLANCE REPORT

LEA Name Greater Clark County Schools  
Building Name Charlestown Senior High School  
HA# A  
Type of Material Miscellaneous Material

Quantity of Material LF

Material Location  
Throughout building

Material Description  
Cove Base

### Comments

Material is assumed to be positive and will be treated as ACM until it is sampled.  
Material is in good condition.

Does Material Contain Asbestos? Assumed  
Is it Friable? No  
Original Inspection Date 5/31/95  
Current Surveillance Date 6/20/96  
Current Assessment Rating NR Not Required  
Cause of Damage No Damage  
Accessible Yes  
Potential for Damage Low  
Removed No  
Planned Response Action O & M

Inspector



Rex Gaddis

State Indiana  
Accreditation Number 190908032

## PERIODIC SURVEILLANCE REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Charlestown Senior High School  
**HA#** B  
**Type of Material** Miscellaneous Material  
**Quantity of Material** LF

**Material Location**  
Throughout building


**Material Description**  
Cove Base Mastic

**Comments**

Material is assumed to be positive and will be treated as ACM until it is sampled.  
Material is in good condition.


**Does Material Contain Asbestos?** Assumed  
**Is it Friable?** No  
**Original Inspection Date** 5/31/96  
**Current Surveillance Date** 6/20/96  
**Current Assessment Rating** NR Not Required  
**Cause of Damage** No Damage  
**Accessible** No  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M

**Inspector**



Rex Gaddis

**State** Indiana  
**Accreditation Number** 190908032



PERIODIC SURVEILLANCE REPORT

LEA NAME: Greater Clark County Schools  
BUILDING NAME: Charlestown Senior High School  
HA#: 1  
TYPE OF MATERIAL: Thermal Material  
QUANTITY OF MATERIAL: 225SF  
MATERIAL LOCATION:

Boiler Room

MATERIAL DESCRIPTION:

Water Tank Cover

COMMENTS:

Material is known to be asbestos containing. It is in good condition and has had some O & M work done. It is larger than 225 SF.

IS MATERIAL FRIABLE? NO  
ORIGINAL INSPECTION DATE: 06/01/92  
CURRENT SURVEILLANCE DATE: 12/07/95  
CURRENT ASSESSMENT RATING: NR Not Required  
CAUSE OF DAMAGE: No Damage  
ACCESSIBLE: YES  
POTENTIAL FOR DAMAGE: Low  
REMOVED: NO  
STATE: Indiana

INSPECTOR NAME:

  
Clint Yates

PERIODIC SURVEILLANCE REPORT

LEA NAME: Greater Clark County Schools  
BUILDING NAME: Charlestown Senior High School  
HA#: 21  
TYPE OF MATERIAL: Miscellaneous Material  
QUANTITY OF MATERIAL: 12  
MATERIAL LOCATION:

Stage

MATERIAL DESCRIPTION:

Stage Light Wiring

COMMENTS:

Material is assumed to be asbestos containing but it is not covered under AHERA.

IS MATERIAL FRIABLE? NO  
ORIGINAL INSPECTION DATE: 06/01/92  
CURRENT SURVEILLANCE DATE: 12/07/95  
CURRENT ASSESSMENT RATING:  
CAUSE OF DAMAGE:  
ACCESSIBLE: NO  
POTENTIAL FOR DAMAGE:  
REMOVED: NO  
STATE: Indiana

INSPECTOR NAME:

  
Clint Yates

PERIODIC SURVEILLANCE REPORT

LEA NAME: Greater Clark County Schools  
BUILDING NAME: Charlestown Senior High School  
HA#: 3  
TYPE OF MATERIAL: Thermal Material  
QUANTITY OF MATERIAL: 3,978LF

MATERIAL LOCATION:

Tunnels, Boiler Room, Athletic Storage Room, and Hallway next to Locker Rooms

MATERIAL DESCRIPTION:

Pipe Insulation (Heat)

COMMENTS:

Tunnels are restricted. Small damage in large pipe by stage. Damage in football storage room. Material in good condition in other areas. Material is known to be asbestos containing.

IS MATERIAL FRIABLE? YES  
ORIGINAL INSPECTION DATE: 06/01/92  
CURRENT SURVEILLANCE DATE: 12/07/95  
CURRENT ASSESSMENT RATING: 1B Damaged TSI  
CAUSE OF DAMAGE: Physical Damage  
ACCESSIBLE: YES  
POTENTIAL FOR DAMAGE: High  
REMOVED: NO  
STATE: Indiana

INSPECTOR NAME:



Clint Yates



PERIODIC SURVEILLANCE REPORT

LEA NAME: Greater Clark County Schools  
BUILDING NAME: Charlestown Senior High School  
HA#: 4  
TYPE OF MATERIAL: Thermal Material  
QUANTITY OF MATERIAL: 600SF  
MATERIAL LOCATION:

Boiler Room

MATERIAL DESCRIPTION:


Stack Insulation (Breeching)

COMMENTS:

Material is known to be asbestos containing. It is delaminating and there is a large fold in the canvas.

IS MATERIAL FRIABLE? YES  
ORIGINAL INSPECTION DATE: 06/01/92  
CURRENT SURVEILLANCE DATE: 12/07/95  
CURRENT ASSESSMENT RATING: 1B Damaged TSI  
CAUSE OF DAMAGE: Water Damage  
ACCESSIBLE: YES  
POTENTIAL FOR DAMAGE: Med  
REMOVED: NO  
STATE: Indiana

INSPECTOR NAME:

  
Clint Yates

PERIODIC SURVEILLANCE REPORT

LEA NAME: Greater Clark County Schools  
BUILDING NAME: Charlestown Senior High School  
HA#: 5  
TYPE OF MATERIAL: Thermal Material  
QUANTITY OF MATERIAL: 250LF  
MATERIAL LOCATION:

Along Wall in Boiler Room

MATERIAL DESCRIPTION:


Air Cell Pipe Insulation

COMMENTS:

Material is known to be asbestos containing. Open ends need patched.

IS MATERIAL FRIABLE? YES  
ORIGINAL INSPECTION DATE: 06/01/92  
CURRENT SURVEILLANCE DATE: 12/07/95  
CURRENT ASSESSMENT RATING: 1B Damaged TSI  
CAUSE OF DAMAGE: Other  
ACCESSIBLE: YES  
POTENTIAL FOR DAMAGE: Med  
REMOVED: NO  
STATE: Indiana

INSPECTOR NAME:

  
Clint Yates

PERIODIC SURVEILLANCE REPORT

LEA NAME: Greater Clark County Schools  
BUILDING NAME: Charlestown Senior High School  
HA#: 6  
TYPE OF MATERIAL: Thermal Material  
QUANTITY OF MATERIAL: 293  
MATERIAL LOCATION:

Throughout Building

MATERIAL DESCRIPTION:

Fittings

COMMENTS:

Material is damaged in boiler room. The rest is in good condition. Material is known to be asbestos containing.

IS MATERIAL FRIABLE? YES  
ORIGINAL INSPECTION DATE: 06/01/92  
CURRENT SURVEILLANCE DATE: 12/07/95  
CURRENT ASSESSMENT RATING: 1B Damaged TSI  
CAUSE OF DAMAGE: Physical Damage  
ACCESSIBLE: YES  
POTENTIAL FOR DAMAGE: Med  
REMOVED: NO  
STATE: Indiana

INSPECTOR NAME:

  
Clint Yates

PERIODIC SURVEILLANCE REPORT

LEA NAME: Greater Clark County Schools  
BUILDING NAME: Charlestown Senior High School  
HA#: 8  
TYPE OF MATERIAL: Miscellaneous Material  
QUANTITY OF MATERIAL: 4,200SF  
MATERIAL LOCATION:

Throughout Building

MATERIAL DESCRIPTION:

VAT Mastic

COMMENTS:

Mastic is assumed to be asbestos containing. (Tile is negative.

IS MATERIAL FRIABLE? NO  
ORIGINAL INSPECTION DATE: 06/01/92  
CURRENT SURVEILLANCE DATE: 12/07/95  
CURRENT ASSESSMENT RATING: NR Not Required  
CAUSE OF DAMAGE: No Damage  
ACCESSIBLE: YES  
POTENTIAL FOR DAMAGE: Low  
REMOVED: NO  
STATE: Indiana

INSPECTOR NAME:



Clint Yates

PERIODIC SURVEILLANCE REPORT

LEA NAME: Greater Clark County Schools  
BUILDING NAME: Charlestown Senior High School  
HA#: A  
TYPE OF MATERIAL: Miscellaneous Material  
QUANTITY OF MATERIAL:  
MATERIAL LOCATION:

Throughout Building

MATERIAL DESCRIPTION:


Cove Base

COMMENTS:

This material was not addressed in the original inspection. It is assumed to be positive and will be treated as ACM until it is sampled. Material is in good condition and is non-friable and does not need an assessment rating at this time.

IS MATERIAL FRIABLE? NO  
ORIGINAL INSPECTION DATE:  
CURRENT SURVEILLANCE DATE: 12/07/95  
CURRENT ASSESSMENT RATING: NR Not Required  
CAUSE OF DAMAGE: No Damage  
ACCESSIBLE: YES  
POTENTIAL FOR DAMAGE: Low  
REMOVED: NO  
STATE: Indiana

INSPECTOR NAME:

  
Clint Yates

PERIODIC SURVEILLANCE REPORT

LEA NAME: Greater Clark County Schools  
BUILDING NAME: Charlestown Senior High School  
HA#: B  
TYPE OF MATERIAL: Miscellaneous Material  
QUANTITY OF MATERIAL:  
MATERIAL LOCATION:

Throughout Building

MATERIAL DESCRIPTION:


Cove Base Mastic

COMMENTS:

This material was not addressed in the original inspection. It is assumed to be positive and will be treated as ACM until it is sampled. Material is in good condition and is non-friable and does not need an assessment rating at this time.

IS MATERIAL FRIABLE? NO  
ORIGINAL INSPECTION DATE:  
CURRENT SURVEILLANCE DATE: 12/07/95  
CURRENT ASSESSMENT RATING: NR Not Required  
CAUSE OF DAMAGE: No Damage  
ACCESSIBLE: NO  
POTENTIAL FOR DAMAGE: Low  
REMOVED: NO  
STATE: Indiana

INSPECTOR NAME:



Clint Yates

*THIRD YEAR REINSPECTIONS*

**REINSPECTION PLAN****GREATER CLARK COUNTY SCHOOLS**

Reinspection by an accredited building inspector will be scheduled to be performed not more than three years from the date of the original inspection. The reinspection report will then be made a permanent part of this Management Plan. Reinspections will be performed every three years for as long as the building contains ACBM, and will be reinspected once within three years from the date that all ACBM has been removed.

Records of each reinspection should be maintained in this binder.

**DATE PLANNED****DATE COMPLETED****COMPLETED BY**

<u>JUNE 2007</u>	<u>July 2007</u>	<u>Bill Ogle</u>
<u>JUNE 2010</u>	<u>June 2010</u>	<u>Sandy Shadley</u>
<u>JUNE 2013</u>	<u>April 2013</u>	<u>Jeff Hechtin</u>
<u>JUNE 2016</u>	<u>April 2016</u>	<u>Benjamin K</u>
<u>JUNE 2019</u>	<u>May 16, 2019</u>	<u>SE</u>
<u>JUNE 2022</u>	<u>_____</u>	<u>_____</u>
<u>JUNE 2025</u>	<u>_____</u>	<u>_____</u>



**REINSPECTION PLAN****GREATER CLARK COUNTY SCHOOLS****CHARLESTOWN HIGH SCHOOL**

The ACBM in this building shall be reinspected every three years to determine any change in the condition of the materials for as long they remain in the building. This reinspection will be conducted tri-annually by an accredited inspector.

The following table outlines the dates on which these inspections should take place in this school building.

**REINSPECTION SCHEDULE**

<u>DATE PLANNED</u>	<u>DATE COMPLETED</u>	<u>COMPLETED BY</u>
<u>JUNE 1992</u>	<u>JUNE 1992</u>	<u>ASBESTECH</u>
<u>JUNE 1995</u>	<u>June '95</u>	<u>Alliance</u>
<u>JUNE 1998</u>	<u>June '98</u>	<u>Alliance</u>
<u>JUNE 2001</u>	<u>July '01</u>	<u>P. Wilson</u>
<u>JUNE 2004</u>	<u>July '04</u>	<u>C. Sparks</u>

# Triennial Reinspection

**LEA Name** Greater Clark County School Corporation  
**Building Name** Charlestown Senior High School  
**Building Number** 08  
**HA ID** F  
**HA Description** Stage light wiring insulation  
**HA Type** Miscellaneous Material  
**HA Location** Auditorium-Stage light wiring, upper level lighting (material can only be viewing from above the stage/catwalk)  
**Quantity** Unquantified LF  
**Comments** This material was noted by the inspector during the 12/06/2010 and will remaining in the managment plan until properly sampled. Lights all appear to be out of service/disconnected. Some are laying on the landing floor.  
**Asbestos** Assumed  
**Friable** Yes  
**Original Inspection** 12/6/2010  
**Current Inspection** 5/16/2019

## Material Assessment

**Assessment Rating** 5 ACBM with potential for damage

## Damage Assessment and Potential for Damage

**Percent Damaged** % Good Condition

**Physical Contact**

Low/None

**Vibration**

Low/None

**Air**

Low/None

**Planned Response Action** O&M

**Inspector**



Sean Stults

**State** IN

**Accreditation Number** 19A007184

# Triennial Reinspection

**LEA Name** Greater Clark County School Corporation

**Building Name** Charlestown Senior High School

**Building Number** 08

**HA ID** G

**HA Description** Stage fire curtain-off white

**HA Type** Miscellaneous Material

**HA Location** Auditorium stage

**Quantity** Unquantified Unit(s)

**Comments** This was noted by the inspector during the 12/06/2010 as suspect ACM therefore it will remain in the management plan for informational purposes. Only Building materials are required to be in the AHERA Management Plan.

**Asbestos** Assumed

**Friable** No

**Original Inspection** 12/6/2010

**Current Inspection** 5/16/2019

## Material Assessment

**Assessment Rating** 5 ACBM with potential for damage

## Damage Assessment and Potential for Damage

**Percent Damaged** % Good Condition

**Physical Contact**

Low/None

**Vibration**

Low/None

**Air**

Low/None

**Planned Response Action** O&M

**Inspector**



Sean Stults

**State** IN

**Accreditation Number** 19A007184

# Triennial Reinspection

**LEA Name** Greater Clark County School Corporation  
**Building Name** Charlestown Senior High School  
**Building Number** 08  
**HA ID** H  
**HA Description** Fire rated doors  
**HA Type** Miscellaneous Material  
**HA Location** Auditorium above the stage

**Quantity** 4 Unit(s)  
**Comments** The inspector noted these during the 12/06/2010 inspection as suspect ACM. They will remain in the management plan until properly sampled.  
**Asbestos** Assumed  
**Friable** No  
**Original Inspection** 12/6/2010  
**Current Inspection** 5/16/2019

## Material Assessment

**Assessment Rating** 5 ACBM with potential for damage

## Damage Assessment and Potential for Damage

**Percent Damaged** % Good Condition

**Physical Contact**

Low/None

**Vibration**

Low/None

**Air**

Low/None

**Planned Response Action** O&M

**Inspector**



Sean Stults

**State** IN

**Accreditation Number** 19A007184

# Triennial Reinspection

**LEA Name** Greater Clark County School Corporation  
**Building Name** Charlestown Senior High School  
**Building Number** 08  
**HA ID** I  
**HA Description** Vinyl Stair treads  
**HA Type** Miscellaneous Material  
**HA Location** Stairs to upper level - catwalk for auditorium

**Quantity** Unquantified SF  
**Comments** This material was discovered during the June 2011 6 month surveillance and will remain in the management plan until sampled properly.  
**Asbestos** Assumed  
**Friable** No

**Original Inspection** 6/27/2011  
**Current Inspection** 5/16/2019

## Material Assessment

**Assessment Rating** 5 ACBM with potential for damage

## Damage Assessment and Potential for Damage

**Percent Damaged** % Good Condition

**Physical Contact**

Low/None

**Vibration**

Low/None

**Air**

Low/None

**Planned Response Action** O&M

**Inspector**



Sean Stults

**State** IN

**Accreditation Number** 19A007184

# Triennial Reinspection

**LEA Name** Greater Clark County School Corporation  
**Building Name** Charlestown Senior High School  
**Building Number** 08  
**HA ID** J  
**HA Description** Stair tread mastic  
**HA Type** Miscellaneous Material  
**HA Location** Stairs to upper level - catwalk for auditorium

**Quantity** Unquantified SF  
**Comments** This material was discovered during the June 2011 6 month surveillance and will remain in the management plan until sampled properly.  
**Asbestos** Assumed  
**Friable** No

**Original Inspection** 6/28/2011  
**Current Inspection** 5/16/2019

## Material Assessment

**Assessment Rating** 5 ACBM with potential for damage

## Damage Assessment and Potential for Damage

**Percent Damaged** % Good Condition

**Physical Contact**

Low/None

**Vibration**

Low/None

**Air**

Low/None

**Planned Response Action** O&M

**Inspector**



Sean Stults

**State** IN

**Accreditation Number** 19A007184

# Triennial Reinspection

**LEA Name** Greater Clark County School Corporation  
**Building Name** Charlestown Senior High School  
**Building Number** 08  
**HA ID** F  
**HA Description** Stage light wiring insulation  
**HA Type** Miscellaneous Material  
**HA Location** Auditorium-Stage light wiring, upper level lighting (material can only be viewing from above the stage/catwalk)  
**Quantity** Unquantified LF  
**Comments** This material was noted by the inspector during the 12/06/2010 and will remaining in the managment plan until properly sampled. Lights all appear to be out of service/disconnected. Some are laying on the landing floor.  
**Asbestos** Assumed  
**Friable** Yes  
**Original Inspection** 12/6/2010  
**Current Inspection** 4/27/2016

## Material Assessment

**Assessment Rating** 5 ACBM with potential for damage

## Damage Assessment and Potential for Damage

**Percent Damaged** % Good Condition

**Physical Contact**

Low/None

**Vibration**

Low/None

**Air**

Low/None

**Planned Response Action** O&M

**Inspector**



Benjamin S. Hood

**State** IN

**Accreditation Number** 19A001039





# Triennial Reinspection

**LEA Name** Greater Clark County School Corporation

**Building Name** Charlestown Senior High School

**Building Number** 08

**HA ID** G

**HA Description** Stage fire curtain-off white

**HA Type** Miscellaneous Material

**HA Location** Auditorium stage

**Quantity** Unquantified Unit(s)

**Comments** This was noted by the inspector during the 12/06/2010 as suspect ACM therefore it will remain in the management plan for informational purposes. Only Building materials are required to be in the AHERA Management Plan.

**Asbestos** Assumed

**Friable** No

**Original Inspection** 12/6/2010

**Current Inspection** 4/27/2016

## Material Assessment

**Assessment Rating** 5 ACBM with potential for damage

## Damage Assessment and Potential for Damage

**Percent Damaged** % Good Condition

**Physical Contact**

Low/None

**Vibration**

Low/None

**Air**

Low/None

**Planned Response Action** O&M

**Inspector**



Benjamin S. Hood

**State** IN

**Accreditation Number** 19A001039

# Triennial Reinspection

**LEA Name** Greater Clark County School Corporation

**Building Name** Charlestown Senior High School

**Building Number** 08

**HA ID** H

**HA Description** Fire rated doors

**HA Type** Miscellaneous Material

**HA Location** Auditorium above the stage

**Quantity** 4 Unit(s)

**Comments** The inspector noted these during the 12/06/2010 inspection as suspect ACM. They will remain in the management plan until properly sampled.

**Asbestos** Assumed

**Friable** No

**Original Inspection** 12/6/2010

**Current Inspection** 4/27/2016

## Material Assessment

**Assessment Rating** 5 ACBM with potential for damage

## Damage Assessment and Potential for Damage

**Percent Damaged** % Good Condition

**Physical Contact**

Low/None

**Vibration**

Low/None

**Air**

Low/None

**Planned Response Action** O&M

**Inspector**



Benjamin S. Hood

**State** IN

**Accreditation Number** 19A001039

# Triennial Reinspection

**LEA Name** Greater Clark County School Corporation  
**Building Name** Charlestown Senior High School  
**Building Number** 08  
**HA ID** I  
**HA Description** Vinyl Stair treads  
**HA Type** Miscellaneous Material  
**HA Location** Stairs to upper level - catwalk for auditorium

**Quantity** Unquantified SF  
**Comments** This material was discovered during the June 2011 6 month surveillance and will remain in the management plan until sampled properly.  
**Asbestos** Assumed  
**Friable** No

**Original Inspection** 6/27/2011  
**Current Inspection** 4/27/2016

## Material Assessment

**Assessment Rating** 5 ACBM with potential for damage

## Damage Assessment and Potential for Damage

**Percent Damaged** % Good Condition

**Physical Contact**

Low/None

**Vibration**

Low/None

**Air**

Low/None

**Planned Response Action** O&M

**Inspector**



Benjamin S. Hood

**State** IN

**Accreditation Number** 19A001039

# Triennial Reinspection

**LEA Name** Greater Clark County School Corporation  
**Building Name** Charlestown Senior High School  
**Building Number** 08  
**HA ID** J  
**HA Description** Stair tread mastic  
**HA Type** Miscellaneous Material  
**HA Location** Stairs to upper level - catwalk for auditorium

**Quantity** Unquantified SF  
**Comments** This material was discovered during the June 2011 6 month surveillance and will remain in the management plan until sampled properly.  
**Asbestos** Assumed  
**Friable** No

**Original Inspection** 6/28/2011  
**Current Inspection** 4/27/2016

## Material Assessment

**Assessment Rating** 5 ACBM with potential for damage

## Damage Assessment and Potential for Damage

**Percent Damaged** % Good Condition

**Physical Contact**

Low/None

**Vibration**


Low/None

**Air**

Low/None

**Planned Response Action** O&M

**Inspector**




Benjamin S. Hood

**State** IN

**Accreditation Number** 19A001039

## THIRD YEAR REINSPECTION REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Charlestown Senior High School  
**HA#** F  
**Type of Material** Miscellaneous Material  
**Quantity of Material** Unquantified LF  
**Material Location**  
Auditorium-Stage light wiring, upper level lighting (material can only be viewing from above the stage/catwalk)  
**Material Description**  
Stage light wiring insulation  
**Comments**  
This material was noted by the inspector during the 12/06/2010 and will remaining in the managment plan until properly sampled. Lights all appear to be out of service/disconnected. Some are laying on the landing floor.  
**Does Material Contain Asbestos?** Assumed  
**Is it Friable?** Yes  
**Original Inspection Date** 12/6/2010  
**Current Reinspection Date** 4/24/2013  
**Current Assessment Rating** NR Not Rated  
**Cause of Damage**  
**Accessible** No  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M  
**Inspector**  
  
\_\_\_\_\_  
Jeffrey P. Rechten  
**State** Indiana  
**Accreditation Number** 19A003594

## THIRD YEAR REINSPECTION REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Charlestown Senior High School  
**HA#** G  
**Type of Material** Miscellaneous Material  
**Quantity of Material** Unquantified Each

**Material Location**  
Auditorium Stage

**Material Description**  
Stage fire curtain-off white

**Comments**

This was noted by the inspector during the 12/06/2010 as suspect ACM therefore it will remain in the management plan for informational purposes. Only Building materials are required to be in the AHERA Mangagement Plan.

**Does Material Contain Asbestos?** Assumed  
**Is it Friable?** No  
**Original Inspection Date** 12/6/2010  
**Current Reinspection Date** 4/24/2013  
**Current Assessment Rating** NR Not Rated  
**Cause of Damage**  
**Accessible** Yes  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M

**Inspector**

  
\_\_\_\_\_  
Jeffrey P. Rehtin

**State** Indiana  
**Accreditation Number** 19A003594



## THIRD YEAR REINSPECTION REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Charlestown Senior High School  
**HA#** H  
**Type of Material** Miscellaneous Material  
**Quantity of Material** Each 4

**Material Location**  
Auditorium above the stage


**Material Description**  
Fire rated doors

**Comments**

The inspector noted these during the 12/06/2010 inspection as suspect ACM. They will remain in the management plan until properly sampled.

**Does Material Contain Asbestos?** Assumed  
**Is it Friable?** No  
**Original Inspection Date** 12/6/2010  
**Current Reinspection Date** 4/24/2013  
**Current Assessment Rating** NR Not Rated  
**Cause of Damage**  
**Accessible** Yes  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M

**Inspector**



---

Jeffrey P. Rechlin

**State** Indiana  
**Accreditation Number** 19A003594

## THIRD YEAR REINSPECTION REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Charlestown Senior High School  
**HA#** 1  
**Type of Material** Miscellaneous Material  
**Quantity of Material** Unquantified SF

**Material Location**

Stairs to upper level - catwalk for auditorium

**Material Description**

Vinyl Stair treads

**Comments**

This material was discovered during the June 2011 6 month surveillance and will remain in the management plan until sampled properly.

**Does Material Contain Asbestos?** Assumed  
**Is it Friable?** No  
**Original Inspection Date** 6/27/2011  
**Current Reinspection Date** 4/24/2013  
**Current Assessment Rating** NA Not Applicable  
**Cause of Damage** No Damage  
**Accessible** Yes  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M

**Inspector**

  
\_\_\_\_\_  
Jeffrey P. Rechten

**State** Indiana  
**Accreditation Number** 19A003594

## THIRD YEAR REINSPECTION REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Charlestown Senior High School  
**HA#** J  
**Type of Material** Miscellaneous Material  
**Quantity of Material** Unquantified SF

**Material Location**

Stairs to upper level catwalk for auditorium.

**Material Description**

Stair tread mastic

**Comments**

This material was discovered during the June 2011 6 month surveillance and will remain in the management plan until sampled properly.

**Does Material Contain Asbestos?** Assumed  
**Is it Friable?** No  
**Original Inspection Date** 6/28/2011  
**Current Reinspection Date** 4/24/2013  
**Current Assessment Rating** NA Not Applicable  
**Cause of Damage** No Damage  
**Accessible** No  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M

**Inspector**

  
\_\_\_\_\_  
Jeffrey P. Rechten

**State** Indiana  
**Accreditation Number** 19A003594

## THIRD YEAR REINSPECTION REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Charlestown Senior High School  
**HA#** 03  
**Type of Material** Thermal Material  
**Quantity of Material** Unquantified LF  
**Material Location**

Tunnel exterior

**Material Description**

Pipe insulation - on pipes buried underneath the tunnels and outside the tunnel walls

**Comments**

There was additional pipe insulation discovered on overhead heat lines in the original gym and in inaccessible areas (pipe chases, above ceilings, and in wall cavities) throughout the entire original building. Most of the asbestos-containing pipe insulation was abated during the abatement project of 2009 through June 2010 by licensed contractors. The only remaining material at the time of this inspection was on pipe buried beneath and on the sides of the tunnels. This material is scheduled to be removed during the last phase of the 2010 demolition project.

**Does Material Contain Asbestos?** Yes  
**Is it Friable?** No  
**Original Inspection Date** 6/1/1992  
**Current Reinspection Date** 6/30/2010  
**Current Assessment Rating** NR Not Required  
**Cause of Damage** No Damage  
**Accessible** No  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M

**Inspector**

  
Sandra Shadley

**State** IN  
**Accreditation Number** 19A002323

## THIRD YEAR REINSPECTION REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Charlestown Senior High School  
**HA#** 04  
**Type of Material** Thermal Material  
**Quantity of Material** 0 SF  
**Material Location**  
Boiler room  
**Material Description**

Stack insulation (breeching)

### Comments

This material was abated by a licensed contractor in May 2010. This homogenous area will be removed from the management plan.

**Does Material Contain Asbestos?** Yes  
**Is it Friable?** No  
**Original Inspection Date** 6/1/1992  
**Current Reinspection Date** 6/30/2010  
**Current Assessment Rating** NR Not Required  
**Cause of Damage** No Damage  
**Accessible** Yes  
**Potential for Damage** Med  
**Removed** Yes  
**Planned Response Action** O & M

**Inspector**

  
Sandra Shadley

**State** IN  
**Accreditation Number** 19A002323

## THIRD YEAR REINSPECTION REPORT

LEA Name Greater Clark County Schools  
Building Name Charlestown Senior High School  
HA# 06  
Type of Material Thermal Material  
Quantity of Material 0 Each

**Material Location**

Throughout the building

**Material Description**

Fittings

**Comments**

There was additional fitting material discovered on overhead heat lines in the original gym and in inaccessible areas (pipe chases, above ceilings, and in wall cavities) throughout the entire original building. All remaining asbestos fittings were abated during the abatement project of 2009 through June 2010 by licensed contractors. This homogeneous area is being removed from the management plan.

Does Material Contain Asbestos? Yes  
Is it Friable? No  
Original Inspection Date 6/1/1992  
Current Reinspection Date 6/30/2010  
Current Assessment Rating NR Not Required  
Cause of Damage No Damage  
Accessible Yes  
Potential for Damage Med  
Removed Yes  
Planned Response Action O & M

**Inspector**

  
Sandra Shadley

**State**

IN

**Accreditation Number**

19A002323

### THIRD YEAR REINSPECTION REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Charlestown Senior High School  
**HA#** A  
**Type of Material** Miscellaneous Material  
**Quantity of Material** 0 SF

**Material Location**  
Building exterior


**Material Description**  
Aggregate covered transite panels

**Comments**

This material was abated by a licensed contractor in 2009 through June 2010. This material is being removed from the management plan.

**Does Material Contain Asbestos?** Yes  
**Is it Friable?** No  
**Original Inspection Date** 7/19/2005  
**Current Reinspection Date** 6/30/2010  
**Current Assessment Rating** NR Not Required  
**Cause of Damage** No Damage  
**Accessible** Yes  
**Potential for Damage** Low  
**Removed** Yes  
**Planned Response Action** O & M

**Inspector**

  
Sandra Shadley

**State** IN  
**Accreditation Number** 19A002323

## THIRD YEAR REINSPECTION REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Charlestown Senior High School  
**HA#** 03  
**Type of Material** Thermal Material  
**Quantity of Material** 3,978 LF  
**Material Location**

Tunnels and boiler room

**Material Description**

Pipe insulation (heat)

**Comments**

The tunnels are restricted. Overall, this material was not in poor condition.

**Does Material Contain Asbestos?** Yes  
**Is it Friable?** No  
**Original Inspection Date** 6/1/1992  
**Current Reinspection Date** 7/11/2007  
**Current Assessment Rating** NR Not Required  
**Cause of Damage** No Damage  
**Accessible** Yes  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M

**Inspector**

  
George William Ogle

**State** Indiana  
**Accreditation Number** 191003027



## THIRD YEAR REINSPECTION REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Charlestown Senior High School  
**HA#** 04  
**Type of Material** Thermal Material  
**Quantity of Material** 600 SF  
**Material Location**  
Boiler room  
**Material Description**  
Stack insulation (breeching)  
**Comments**  
The insulation is not in poor condition.  
**Does Material Contain Asbestos?** Yes  
**Is it Friable?** No  
**Original Inspection Date** 6/1/1992  
**Current Reinspection Date** 7/11/2007  
**Current Assessment Rating** NR Not Required  
**Cause of Damage** No Damage  
**Accessible** Yes  
**Potential for Damage** Med  
**Removed** No  
**Planned Response Action** O & M

**Inspector**

  
George William Ogle

**State**

Indiana

**Accreditation Number**

191003027

## THIRD YEAR REINSPECTION REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Charlestown Senior High School  
**HA#** 06  
**Type of Material** Thermal Material  
**Quantity of Material** 293 Each  
**Material Location**  
Throughout the building  
**Material Description**  
Fittings  
**Comments**  
Fittings are not in poor condition overall.  
**Does Material Contain Asbestos?** Yes  
**Is it Friable?** No  
**Original Inspection Date** 6/1/1992  
**Current Reinspection Date** 7/11/2007  
**Current Assessment Rating** NR Not Required  
**Cause of Damage** No Damage  
**Accessible** Yes  
**Potential for Damage** Med  
**Removed** No  
**Planned Response Action** O & M

**Inspector**

  
George William Ogle

**State**

Indiana


**Accreditation Number**

191003027

## THIRD YEAR REINSPECTION REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Charlestown Senior High School  
**HA#** A  
**Type of Material** Miscellaneous Material  
**Quantity of Material** Unquantified SF  
**Material Location**  
Building exterior  
**Material Description**  
Aggregate covered transite panels  
**Comments**  
The panels are not in poor condition overall.  
**Does Material Contain Asbestos?** Assumed  
**Is it Friable?** No  
**Original Inspection Date** 7/19/2005  
**Current Reinspection Date** 7/11/2007  
**Current Assessment Rating** NR Not Required  
**Cause of Damage** No Damage  
**Accessible** Yes  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M

**Inspector**

  
George William Ogle

**State** Indiana  
**Accreditation Number** 191003027



### THIRD YEAR REINSPECTION REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Charlestown Senior High School  
**HA#** 01  
**Type of Material** Thermal Material  
**Quantity of Material** 225 SF

**Material Location**  
Boiler room

**Material Description**  
Water tank cover

**Comments**

There is exposed material around the two elbows coming from the bottom of the tank. O & M is recommended. This material was not in poor condition overall.

**Does Material Contain Asbestos?** Yes  
**Is it Friable?** No  
**Original Inspection Date** 6/1/1992  
**Current Reinspection Date** 6/28/2004  
**Current Assessment Rating** NR Not Required  
**Cause of Damage** No Damage  
**Accessible** Yes  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M

**Inspector**

  
\_\_\_\_\_  
Christiaan Sparks

**State** Indiana  
**Accreditation Number** 190804103

## THIRD YEAR REINSPECTION REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Charlestown Senior High School  
**HA#** 03  
**Type of Material** Thermal Material  
**Quantity of Material** 3,978 LF

**Material Location**  
Tunnels and boiler room

**Material Description**  
Pipe insulation (heat)

**Comments**

Tunnels are restricted. There is delaminating canvas covering in the boiler room underneath the sink on the west wall. There are some open ends on some runs insulated with paper. One mag open end is visible in the maintenance room. Overall, this material was not in poor condition.

**Does Material Contain Asbestos?** Yes  
**Is it Friable?** No  
**Original Inspection Date** 6/1/1992  
**Current Reinspection Date** 6/28/2004  
**Current Assessment Rating** NR Not Required  
**Cause of Damage** No Damage  
**Accessible** Yes  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M

**Inspector**

  
\_\_\_\_\_  
Christiaan Sparks

**State** Indiana  
**Accreditation Number** 190804103

## THIRD YEAR REINSPECTION REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Charlestown Senior High School  
**HA#** 04  
**Type of Material** Thermal Material  
**Quantity of Material** 600 SF

**Material Location**  
Boiler room

**Material Description**  
Stack insulation (breeching)

**Comments**

A large section of canvas has been cut off leaving approximately seven square feet of insulation exposed. The insulation is still intact and not in poor condition. O & M is needed as the edges are becoming frayed.

**Does Material Contain Asbestos?** Yes  
**Is it Friable?** No  
**Original Inspection Date** 6/1/1992  
**Current Reinspection Date** 6/28/2004  
**Current Assessment Rating** NR Not Required  
**Cause of Damage** No Damage  
**Accessible** Yes  
**Potential for Damage** Med  
**Removed** No  
**Planned Response Action** O & M

**Inspector**

  
\_\_\_\_\_  
Christiaan Sparks

**State** Indiana  
**Accreditation Number** 190804103

### THIRD YEAR REINSPECTION REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Charlestown Senior High School  
**HA#** 05  
**Type of Material** Thermal Material  
**Quantity of Material** 250 LF

**Material Location**  
Along west wall in boiler room

**Material Description**  
Air cell pipe insulation

**Comments**  
This material has some open ends. However, this material was not in poor condition overall.

**Does Material Contain Asbestos?** Yes  
**Is it Friable?** No  
**Original Inspection Date** 6/1/1992  
**Current Reinspection Date** 6/28/2004  
**Current Assessment Rating** NR Not Required  
**Cause of Damage** No Damage  
**Accessible** Yes  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M

**Inspector**

  
\_\_\_\_\_  
Christiaan Sparks

**State** Indiana  
**Accreditation Number** 190804103



## THIRD YEAR REINSPECTION REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Charlestown Senior High School  
**HA#** 06  
**Type of Material** Thermal Material  
**Quantity of Material** 293 Each

**Material Location**  
Throughout the building

**Material Description**  
Fittings

**Comments**


Damaged fittings were found in the pipe chase in the boys restroom off of the athletic storage room. One fitting in center area of maintenance office has insulation exposed where canvas has pulled loose. One fitting on the wall of the boiler room by the sink has fallen apart. There is debris on the floor. The fittings are not in poor condition overall with not enough damage to call the homogeneous area damaged. Some O & M has been performed, however, more is needed.

**Does Material Contain Asbestos?** Yes  
**Is it Friable?** No  
**Original Inspection Date** 6/1/1992  
**Current Reinspection Date** 6/28/2004  
**Current Assessment Rating** NR Not Required  
**Cause of Damage** No Damage  
**Accessible** Yes  
**Potential for Damage** Med  
**Removed** No  
**Planned Response Action** O & M

**Inspector**

  
\_\_\_\_\_  
Christian Sparks

**State** Indiana  
**Accreditation Number** 190804103



### THIRD YEAR REINSPECTION REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Charlestown Senior High School  
**HA#** 01  
**Type of Material** Thermal Material  
**Quantity of Material** 225 SF

**Material Location**  
Boiler room

**Material Description**  
Water tank cover

**Comments**

Material is in good condition with some of the canvas seams coming loose around the supports. O & M suggested.

**Does Material Contain Asbestos?** Yes  
**Is it Friable?** No  
**Original Inspection Date** 06/01/1992  
**Current Reinspection Date** 07/12/2001  
**Current Assessment Rating** NR Not Required  
**Cause of Damage** Delamination  
**Accessible** Yes  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M

**Inspector**

  
\_\_\_\_\_  
Patrick E. Wilson

**State** Indiana  
**Accreditation Number** 190824065

### THIRD YEAR REINSPECTION REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Charlestown Senior High School  
**HA#** 03  
**Type of Material** Thermal Material  
**Quantity of Material** 3,978 LF

**Material Location**  
Tunnels and boiler room

**Material Description**  
Pipe insulation (heat)

**Comments**  
Tunnels are restricted. There is delaminating canvas covering in the boiler room underneath the sink on the west wall. No insulation is exposed except for some open ends on pipe runs of paper insulation. O & M needed.

**Does Material Contain Asbestos?** Yes  
**Is it Friable?** No  
**Original Inspection Date** 06/01/1992  
**Current Reinspection Date** 07/12/2001  
**Current Assessment Rating** NR Not Required  
**Cause of Damage** Delamination  
**Accessible** Yes  
**Potential for Damage** Low  
**Removed** No  
**Planned Response Action** O & M

**Inspector**

  
Patrick E. Wilson

**State** Indiana  
**Accreditation Number** 190824065

### THIRD YEAR REINSPECTION REPORT

**LEA Name** Greater Clark County Schools  
**Building Name** Charlestown Senior High School  
**HA#** 04  
**Type of Material** Thermal Material  
**Quantity of Material** 600 SF

**Material Location**  
Boiler room

**Material Description**  
Stack insulation (breeching)

**Comments**

Delamination of canvas has now exposed the insulation on a bottom section, but the insulation is still intact and in good condition overall. Some O & M has been completed, however, more is needed.

**Does Material Contain Asbestos?** Yes  
**Is it Friable?** No  
**Original Inspection Date** 06/01/1992  
**Current Reinspection Date** 07/12/2001  
**Current Assessment Rating** NR Not Required  
**Cause of Damage** Delamination  
**Accessible** Yes  
**Potential for Damage** Med  
**Removed** No  
**Planned Response Action** O & M

**Inspector**

  
Patrick E. Wilson

**State** Indiana  
**Accreditation Number** 190824065

### THIRD YEAR REINSPECTION REPORT

LEA Name Greater Clark County Schools  
Building Name Charlestown Senior High School  
HA# 05  
Type of Material Thermal Material  
Quantity of Material 250 LF  
Material Location  
Along wall in boiler room  
Material Description  
Air cell pipe insulation  
Comments  
Material has some open ends, but no other damage noted.  
Does Material Contain Asbestos? Yes  
Is it Friable? No  
Original Inspection Date 06/01/1992  
Current Reinspection Date 07/12/2001  
Current Assessment Rating NR Not Required  
Cause of Damage Other  
Accessible Yes  
Potential for Damage Low  
Removed No  
Planned Response Action O & M

Inspector

  
Patrick E. Wilson

State Indiana  
Accreditation Number 190824065

### THIRD YEAR REINSPECTION REPORT

LEA Name Greater Clark County Schools  
Building Name Charlestown Senior High School  
HA# 06  
Type of Material Thermal Material  
Quantity of Material 293 Each

Material Location  
Throughout the building

Material Description  
Fittings

**Comments**

Damaged fittings found in the pipe chase in the boys restroom off of the athletic storage room. One fitting in center area of maintenance office has insulation exposed where canvas has pulled loose. The fittings are in good condition overall with not enough damage to call the homogeneous area damaged. Some O & M has been performed, however, more is needed.

Does Material Contain Asbestos? Yes  
Is it Friable? No  
Original Inspection Date 06/01/1992  
Current Reinspection Date 07/12/2001  
Current Assessment Rating NR Not Required  
Cause of Damage Physical Damage  
Accessible Yes  
Potential for Damage Med  
Removed No  
Planned Response Action O & M

Inspector

  
Patrick E. Wilson

State Indiana  
Accreditation Number 190824065

### THIRD YEAR REINSPECTION REPORT

LEA Name Greater Clark County Schools  
Building Name Charlestown Senior High School  
HA# C  
Type of Material Miscellaneous Material  
Quantity of Material Unquantified SF

Material Location  
Exterior fascia board

Material Description  
Transite board with stone texturing

Comments  
An approximate 4' X 4' section of this material was damaged outside the cafeteria in the courtyard by a delivery truck. The area was cleaned up by school personnel. It is thought to be on most of the fascia board upper exterior of the building. This material was not previously addressed. It will be treated as ACM until proper sampling is done.


Does Material Contain Asbestos? Assumed  
Is it Friable? No  
Original Inspection Date 01/11/2001  
Current Reinspection Date 07/12/2001  
Current Assessment Rating NR Not Required  
Cause of Damage No Damage  
Accessible Yes  
Potential for Damage Med  
Removed No  
Planned Response Action O & M

Inspector

  
Patrick E. Wilson

State Indiana  
Accreditation Number 190824065





### THIRD YEAR REINSPECTION REPORT

LEA Name Greater Clark County Schools  
Building Name Charlestown Senior High School  
HA# 01  
Type of Material Thermal Material  
Quantity of Material 225 SF

Material Location  
Boiler Room

Material Description  
Water Tank Cover

Comments  
Material is in good condition. It is larger than 225 SF.

Does Material Contain Asbestos? Yes  
Is it Friable? No  
Original Inspection Date 6/ 1/92  
Current Reinspection Date 6/ 1/98  
Current Assessment Rating NR Not Required  
Cause of Damage No Damage  
Accessible Yes  
Potential for Damage Low  
Removed No  
Planned Response Action O & M

Inspector

  
Clint Yates

State Indiana  
Accreditation Number 193804035

### THIRD YEAR REINSPECTION REPORT

LEA Name Greater Clark County Schools  
Building Name Charlestown Senior High School  
HA# 03  
Type of Material Thermal Material  
Quantity of Material 3,978 LF


Material Location  
Tunnels and boiler room

Material Description  
Pipe Insulation (Heat)

Comments  
Tunnels are restricted. Damaged insulation found in the boiler room underneath the sink on the west wall.

Does Material Contain Asbestos? Yes  
Is it Friable? Yes  
Original Inspection Date 6/ 1/92  
Current Reinspection Date 6/ 1/98  
Current Assessment Rating 1B Damaged TSI  
Cause of Damage Physical Damage  
Accessible Yes  
Potential for Damage High  
Removed No  
Planned Response Action O & M

Inspector

  
Clint Yates

State Indiana  
Accreditation Number 193804035

### THIRD YEAR REINSPECTION REPORT


LEA Name Greater Clark County Schools  
Building Name Charlestown Senior High School  
HA# 04  
Type of Material Thermal Material  
Quantity of Material 600 SF  
Material Location  
Boiler Room

Material Description  
Stack Insulation (Breeching)

Comments  
Delamination is getting worse. O & M needed.

Does Material Contain Asbestos? Yes  
Is it Friable? Yes  
Original Inspection Date 6/ 1/92  
Current Reinspection Date 6/ 1/98  
Current Assessment Rating 1B Damaged TSI  
Cause of Damage Water Damage  
Accessible Yes  
Potential for Damage Med  
Removed No  
Planned Response Action O & M

Inspector

  
Clint Yates

State Indiana  
Accreditation Number 193804035

### THIRD YEAR REINSPECTION REPORT

LEA Name Greater Clark County Schools  
Building Name Charlestown Senior High School  
HA# 05  
Type of Material Thermal Material  
Quantity of Material 250 LF


Material Location  
Along Wall in Boiler Room

Material Description  
Air Cell Pipe Insulation

Comments  
Material is damaged. Open ends need patched. No change in the last 6 months.

Does Material Contain Asbestos? Yes  
Is it Friable? Yes  
Original Inspection Date 6/ 1/92  
Current Reinspection Date 6/ 1/98  
Current Assessment Rating 1B Damaged TSI  
Cause of Damage Other  
Accessible Yes  
Potential for Damage Med  
Removed No  
Planned Response Action O & M

Inspector

  
Clint Yates

State Indiana  
Accreditation Number 193804035

## THIRD YEAR REINSPECTION REPORT

LEA Name Greater Clark County Schools  
Building Name Charlestown Senior High School  
HA# 06  
Type of Material Thermal Material  
Quantity of Material 293 Each

Material Location  
Throughout building


Material Description  
Fittings

### Comments

Damaged fittings found in the pipe chase at the boys restroom off of the athletic storage room. Damaged fittings in boiler room need repaired.

Does Material Contain Asbestos? Yes  
Is it Friable? Yes  
Original Inspection Date 6/ 1/92  
Current Reinspection Date 6/ 1/98  
Current Assessment Rating 1B Damaged TSI  
Cause of Damage Physical Damage  
Accessible Yes  
Potential for Damage Med  
Removed No  
Planned Response Action O & M

Inspector



Clint Yates

State Indiana  
Accreditation Number 193804035

### THIRD YEAR REINSPECTION REPORT

LEA Name Greater Clark County Schools  
Building Name Charlestown Senior High School  
HA# 08  
Type of Material Miscellaneous Material  
Quantity of Material 4,200 SF  
Material Location  
Throughout building  
Material Description  
VAT Mastic

**Comments**

Material has been removed and replaced with non-asbestos adhesive.

Does Material Contain Asbestos? No  
Is it Friable? No  
Original Inspection Date 6/ 1/92  
Current Reinspection Date 6/ 1/98  
Current Assessment Rating NA Not Applicable  
Cause of Damage Not Applicable  
Accessible No  
Potential for Damage NA  
Removed Yes  
Planned Response Action None

**Inspector**

  
Clint Yates

State Indiana  
Accreditation Number 193804035

### THIRD YEAR REINSPECTION REPORT

LEA Name Greater Clark County Schools  
Building Name Charlestown Senior High School  
HA# A  
Type of Material Miscellaneous Material  
Quantity of Material LF

Material Location  
Throughout building


Material Description  
Cove Base

**Comments**

Material has been removed and replaced with non-asbestos cove base.

Does Material Contain Asbestos? No  
Is it Friable? No  
Original Inspection Date 5/31/95  
Current Reinspection Date 6/ 1/98  
Current Assessment Rating NA Not Applicable  
Cause of Damage Not Applicable  
Accessible No  
Potential for Damage NA  
Removed Yes  
Planned Response Action None

Inspector

  
Clint Yates

State Indiana  
Accreditation Number 193804035



### THIRD YEAR REINSPECTION REPORT

LEA Name Greater Clark County Schools  
Building Name Charlestown Senior High School  
HA# B  
Type of Material Miscellaneous Material  
Quantity of Material LF


Material Location  
Throughout building

Material Description  
Cove Base Mastic


Comments  
Material has been removed and replaced with non-asbestos mastic.

Does Material Contain Asbestos? No  
Is it Friable? No  
Original Inspection Date 5/31/96  
Current Reinspection Date 6/ 1/98  
Current Assessment Rating NA Not Applicable  
Cause of Damage Not Applicable  
Accessible No  
Potential for Damage NA  
Removed Yes  
Planned Response Action None

Inspector

  
Clint Yates

State Indiana  
Accreditation Number 193804035



THIRD YEAR REINSPECTION REPORT

LEA NAME: Greater Clark County School Corp.

BUILDING NAME: Charlestown Senior High School

HA#: 1

TYPE OF MATERIAL: Thermal Material

QUANTITY OF MATERIAL: 225SF

MATERIAL LOCATION:

Boiler Room

MATERIAL DESCRIPTION:

Water Tank Cover

COMMENTS:

Material is known to be asbestos containing. It is in good condition and has had some O & M work done. It is larger than 225 SF.

IS MATERIAL FRIABLE? NO

ORIGINAL INSPECTION DATE: 06/01/92

CURRENT REINSPECTION DATE: 06/27/95

CURRENT ASSESSMENT RATING: NR Not Required

CAUSE OF DAMAGE: No Damage

ACCESSIBLE: NO

POTENTIAL FOR DAMAGE: Low

REMOVED: NO

CURRENT VIDEO TAPE: /  
(TAPE NO/FOOTAGE)

INSPECTOR NAME:

  
Rex Gaddis

STATE: Indiana

ACCREDITATION NO.: 190908032

THIRD YEAR REINSPECTION REPORT

LEA NAME: Greater Clark County School Corp.

BUILDING NAME: Charlestown Senior High School

HA#: 2

TYPE OF MATERIAL: Miscellaneous Material

QUANTITY OF MATERIAL: 44SF

MATERIAL LOCATION:

Boiler Room

MATERIAL DESCRIPTION:

Rope Gasket on Boiler

COMMENTS:

Boiler was removed in May 1995.

IS MATERIAL FRIABLE? NO

ORIGINAL INSPECTION DATE: 06/01/92

CURRENT REINSPECTION DATE: 06/27/95

CURRENT ASSESSMENT RATING:

CAUSE OF DAMAGE:

ACCESSIBLE: NO

POTENTIAL FOR DAMAGE:

REMOVED: NO

CURRENT VIDEO TAPE: /  
(TAPE NO/FOOTAGE)

INSPECTOR NAME:

  
Rex Gaddis

STATE: Indiana

ACCREDITATION NO.: 190908032

THIRD YEAR REINSPECTION REPORT

LEA NAME: Greater Clark County School Corp.

BUILDING NAME: Charlestown Senior High School

HA#: 21

TYPE OF MATERIAL: Miscellaneous Material

QUANTITY OF MATERIAL: 12

MATERIAL LOCATION:

Stage

MATERIAL DESCRIPTION:

Stage Light Wiring

COMMENTS:

Material is assumed to be asbestos containing but it is not covered under AHERA.

IS MATERIAL FRIABLE? NO

ORIGINAL INSPECTION DATE: 06/01/92

CURRENT REINSPECTION DATE: 06/27/95

CURRENT ASSESSMENT RATING:

CAUSE OF DAMAGE:

ACCESSIBLE: NO

POTENTIAL FOR DAMAGE:

REMOVED: NO

CURRENT VIDEO TAPE:  
(TAPE NO/FOOTAGE)

/

INSPECTOR NAME:

  
Rex Gaddis

STATE: Indiana

ACCREDITATION NO.: 190908032

THIRD YEAR REINSPECTION REPORT

LEA NAME: Greater Clark County School Corp.

BUILDING NAME: Charlestown Senior High School

HA#: 3

TYPE OF MATERIAL: Thermal Material

QUANTITY OF MATERIAL: 3,978LF

MATERIAL LOCATION:

Tunnels, Boiler Room, Athletic Storage Room, and Hallway next to Locker Rooms

MATERIAL DESCRIPTION:

Pipe Insulation (Heat)

COMMENTS:

Tunnels are restricted. Small damage in large pipe by stage. Damage in football storage room. Material in good condition in other areas. Material is known to be asbestos containing.

IS MATERIAL FRIABLE? YES

ORIGINAL INSPECTION DATE: 06/01/92

CURRENT REINSPECTION DATE: 06/27/95

CURRENT ASSESSMENT RATING: 1B Damaged TSI

CAUSE OF DAMAGE: Physical Damage

ACCESSIBLE: NO

POTENTIAL FOR DAMAGE: High

REMOVED: NO

CURRENT VIDEO TAPE: /  
(TAPE NO/FOOTAGE)

INSPECTOR NAME:

  
Rex Gaddis

STATE: Indiana

ACCREDITATION NO.: 190908032

THIRD YEAR REINSPECTION REPORT

LEA NAME: Greater Clark County School Corp.

BUILDING NAME: Charlestown Senior High School

HA#: 4

TYPE OF MATERIAL: Thermal Material

QUANTITY OF MATERIAL: 600SF

MATERIAL LOCATION:

Boiler Room

MATERIAL DESCRIPTION:

Stack Insulation (Breeching)

COMMENTS:

Material is known to be asbestos containing. There is some damage.

IS MATERIAL FRIABLE? YES

ORIGINAL INSPECTION DATE: 06/01/92

CURRENT REINSPECTION DATE: 06/27/95

CURRENT ASSESSMENT RATING: 1B Damaged TSI

CAUSE OF DAMAGE: Water Damage

ACCESSIBLE: NO


POTENTIAL FOR DAMAGE: Med

REMOVED: NO

CURRENT VIDEO TAPE:  
(TAPE NO/FOOTAGE)

/

INSPECTOR NAME:

  
Rex Gaddis

STATE: Indiana

ACCREDITATION NO.: 190908032

THIRD YEAR REINSPECTION REPORT

LEA NAME: Greater Clark County School Corp.  
BUILDING NAME: Charlestown Senior High School  
HA#: 5  
TYPE OF MATERIAL: Thermal Material  
QUANTITY OF MATERIAL: 250LF  
MATERIAL LOCATION:

Along Wall in Boiler Room

MATERIAL DESCRIPTION:

Air Cell Pipe Insulation

COMMENTS:

Material is known to be asbestos containing. Open ends need patched.

IS MATERIAL FRIABLE? YES  
ORIGINAL INSPECTION DATE: 06/01/92  
CURRENT REINSPECTION DATE: 06/27/95  
CURRENT ASSESSMENT RATING: 1B Damaged TSI  
CAUSE OF DAMAGE: Other  
ACCESSIBLE: NO  
POTENTIAL FOR DAMAGE: Med  
REMOVED: NO  
CURRENT VIDEO TAPE: /  
(TAPE NO/FOOTAGE)

INSPECTOR NAME:

  
Rex Gaddis

STATE: Indiana  
ACCREDITATION NO.: 190908032



THIRD YEAR REINSPECTION REPORT

LEA NAME: Greater Clark County School Corp.

BUILDING NAME: Charlestown Senior High School

HA#: 6

TYPE OF MATERIAL: Thermal Material

QUANTITY OF MATERIAL: 293

MATERIAL LOCATION:

Throughout Building

MATERIAL DESCRIPTION:

Fittings

COMMENTS:

Material is damaged in boiler room. The rest is in good condition. Material is known to be asbestos containing.

IS MATERIAL FRIABLE? YES

ORIGINAL INSPECTION DATE: 06/01/92

CURRENT REINSPECTION DATE: 06/27/95

CURRENT ASSESSMENT RATING: 1B Damaged TSI

CAUSE OF DAMAGE: Physical Damage

ACCESSIBLE: NO

POTENTIAL FOR DAMAGE: Med

REMOVED: NO

CURRENT VIDEO TAPE: /  
(TAPE NO/FOOTAGE)

INSPECTOR NAME:

  
Rex Gaddis

STATE: Indiana

ACCREDITATION NO.: 190908032

THIRD YEAR REINSPECTION REPORT

LEA NAME: Greater Clark County School Corp.

BUILDING NAME: Charlestown Senior High School

HA#: 7

TYPE OF MATERIAL: Thermal Material

QUANTITY OF MATERIAL: 15

MATERIAL LOCATION:

Tunnel

MATERIAL DESCRIPTION:

Debris

COMMENTS:

Material is assumed to be asbesots containing. It is scheduled for clean-up in August 1995.

IS MATERIAL FRIABLE? YES

ORIGINAL INSPECTION DATE: 06/01/92

CURRENT REINSPECTION DATE: 06/27/95

CURRENT ASSESSMENT RATING: 1B Damaged TSI

CAUSE OF DAMAGE: Other

ACCESSIBLE: NO

POTENTIAL FOR DAMAGE: High

REMOVED: NO

CURRENT VIDEO TAPE: /  
(TAPE NO/FOOTAGE)

INSPECTOR NAME:

  
Rex Gaddis

STATE: Indiana

ACCREDITATION NO.: 190908032

THIRD YEAR REINSPECTION REPORT

LEA NAME: Greater Clark County School Corp.

BUILDING NAME: Charlestown Senior High School

HA#: 8

TYPE OF MATERIAL: Miscellaneous Material

QUANTITY OF MATERIAL: 4,200SF

MATERIAL LOCATION:

Throughout Building

MATERIAL DESCRIPTION:

VAT Mastic

COMMENTS:

Mastic is assumed to be asbestos containing. (Tile is negative.)

IS MATERIAL FRIABLE? NO

ORIGINAL INSPECTION DATE: 06/01/92

CURRENT REINSPECTION DATE: 06/27/95

CURRENT ASSESSMENT RATING: NR Not Required

CAUSE OF DAMAGE: No Damage

ACCESSIBLE: NO

POTENTIAL FOR DAMAGE: Low

REMOVED: NO

CURRENT VIDEO TAPE: /  
(TAPE NO/FOOTAGE)

INSPECTOR NAME:

  
Rex Gaddis

STATE: Indiana

ACCREDITATION NO.: 190908032

THIRD YEAR REINSPECTION REPORT

LEA NAME: Greater Clark County School Corp.

BUILDING NAME: Charlestown Senior High School

HA#: A

TYPE OF MATERIAL: Miscellaneous Material

QUANTITY OF MATERIAL:

MATERIAL LOCATION:

Throughout Building

MATERIAL DESCRIPTION:

Cove Base

COMMENTS:

This material was not addressed in the original inspection. It is assumed to be positive and will be treated as ACM until it is sampled. Material is in good condition and is non-friable and does not need an assessment rating at this time.

IS MATERIAL FRIABLE? NO

ORIGINAL INSPECTION DATE:

CURRENT REINSPECTION DATE: 06/27/95

CURRENT ASSESSMENT RATING: NR Not Required

CAUSE OF DAMAGE: No Damage

ACCESSIBLE: NO

POTENTIAL FOR DAMAGE: Low

REMOVED: NO

CURRENT VIDEO TAPE: /  
(TAPE NO/FOOTAGE)

INSPECTOR NAME:

  
Rex Gaddis

STATE: Indiana

ACCREDITATION NO.: 190908032

THIRD YEAR REINSPECTION REPORT

LEA NAME: Greater Clark County School Corp.

BUILDING NAME: Charlestown Senior High School

HA#: B

TYPE OF MATERIAL: Miscellaneous Material

QUANTITY OF MATERIAL:

MATERIAL LOCATION:

Throughout Building

MATERIAL DESCRIPTION:

Cove Base Mastic

COMMENTS:

This material was not addressed in the original inspection. It is assumed to be positive and will be treated as ACM until it is sampled. Material is in good condition and is non-friable and does not need an assessment rating at this time.

IS MATERIAL FRIABLE? NO

ORIGINAL INSPECTION DATE:

CURRENT REINSPECTION DATE: 06/27/95

CURRENT ASSESSMENT RATING: NR Not Required

CAUSE OF DAMAGE: No Damage

ACCESSIBLE: NO

POTENTIAL FOR DAMAGE: Low

REMOVED: NO

CURRENT VIDEO TAPE: /  
(TAPE NO/FOOTAGE)

INSPECTOR NAME:

  
Rex Gaddis

STATE: Indiana

ACCREDITATION NO.: 190908032

*ADDITIONAL BULK SAMPLES*

**EMSL Analytical, Inc.**

2001 East 52nd St., Indianapolis, IN 46205

Phone: (317) 803-2997 Fax: (317) 803-3047 Email: [Indianapolislab@emsl.com](mailto:Indianapolislab@emsl.com)

Building that  
remains  
FTM-7-1 & FTM-  
were removed  
with a chemical  
mastic  
removal  
during  
removal

Attn: **Sandy Shadley**  
**Alliance Environmental Group, Inc.**  
**5340 Commerce Circle**  
**Indianapolis, IN 46237**

Fax: (317) 865-3401 Phone: (317) 865-3400  
Project: **NGR 00A02**

Customer ID: ALLI65  
Customer PO:  
Received: 07/06/10 8:00 AM  
EMSL Order: 161010764

EMSL Proj:  
Analysis Date: 7/7/2010

### Test Report: Asbestos Analysis of Bulk Materials via EPA 600/R-93/116 Method using Polarized Light Microscopy

Sample	Description	Appearance	Non-Asbestos		Asbestos
			% Fibrous	% Non-Fibrous	% Type
CBM-7-1 161010764-0001		Brown Non-Fibrous Heterogeneous		100% Non-fibrous (other)	None Detected
CBM-7-2 161010764-0002		White Non-Fibrous Homogeneous		100% Non-fibrous (other)	None Detected
3M-7-3 161010764-0003		Brown Non-Fibrous Homogeneous		100% Non-fibrous (other)	None Detected
FTM-7-1 161010764-0004		Black Non-Fibrous Heterogeneous		98% Non-fibrous (other)	2% Chrysotile
FTM-7-2 161010764-0005		Black Non-Fibrous Homogeneous		95% Non-fibrous (other)	5% Chrysotile
FTM-7-3 161010764-0006		Black Non-Fibrous Homogeneous	3% Cellulose	97% Non-fibrous (other)	None Detected
FTM-7-4 161010764-0007		Black Non-Fibrous Homogeneous	3% Cellulose	97% Non-fibrous (other)	None Detected

Initial report from 07/07/2010 08:02:36

Analyst(s)

Melissa Wilson (8)

*Richard Harding*  
Richard Harding, Laboratory Manager  
or other approved signatory

EMSL maintains liability limited to cost of analysis. This report relates only to the samples reported and may not be reproduced, except in full, without written approval by EMSL. EMSL is not responsible for sample collection activities or analytical method limitations. Interpretation and use of test results are the responsibility of the client. This report must not be used by the client to claim product certification, approval, or endorsement by NVLAP, NIST or any agency of the federal government. Non-friable organically bound materials present a problem matrix and therefore EMSL recommends gravimetric reduction prior to analysis. Samples received in good condition unless otherwise noted.  
Samples analyzed by EMSL Analytical, Inc. 2001 East 52nd St., Indianapolis IN NVLAP Lab Code 200188-0, AZ0939, CA 2575, CO AL-15132, TX 300262

**EMSL Analytical, Inc.**

2001 East 52nd St., Indianapolis, IN 46205

Phone: (317) 803-2997 Fax: (317) 803-3047 Email: [indianapolislab@emsl.com](mailto:indianapolislab@emsl.com)

Attn: **Sandy Shadley**  
**Alliance Environmental Group, Inc.**  
**5340 Commerce Circle**  
**Indianapolis, IN 46237**

Fax: (317) 865-3401 Phone: (317) 865-3400  
Project: **NGR 00A02**

Customer ID: ALLI65  
Customer PO:  
Received: 07/06/10 8:00 AM  
EMSL Order: 161010764

EMSL Proj:  
Analysis Date: 7/7/2010

### Test Report: Asbestos Analysis of Bulk Materials via EPA 600/R-93/116 Method using Polarized Light Microscopy

Sample	Description	Appearance	Non-Asbestos		Asbestos
			% Fibrous	% Non-Fibrous	% Type
FTM-7-5 161010764-0008		Tan Non-Fibrous Homogeneous		100% Non-fibrous (other)	None Detected

Initial report from 07/07/2010 08:02:36

Analyst(s)

Melissa Wilson (8)

Richard Harding, Laboratory Manager  
or other approved signatory

EMSL maintains liability limited to cost of analysis. This report relates only to the samples reported and may not be reproduced, except in full, without written approval by EMSL. EMSL is not responsible for sample collection activities or analytical method limitations. Interpretation and use of test results are the responsibility of the client. This report must not be used by the client to claim product certification, approval, or endorsement by NVLAP, NIST or any agency of the federal government. Non-friable organically bound materials present a problem matrix and therefore EMSL recommends gravimetric reduction prior to analysis. Samples received in good condition unless otherwise noted.

Samples analyzed by EMSL Analytical, Inc. 2001 East 52nd St., Indianapolis IN NVLAP Lab Code 200188-0, AZ0939, CA 2575, CO AL-15132, TX 300262



**ALLIANCE ENVIRONMENTAL GROUP, INC.**

5340 Commerce Circle, Suite E  
Indianapolis, IN 46237  
317/865-3400 Fax 317/865-3401

24 HOUR

161010764

Project Name: Greater Clark Designated Person  
Project Location: Charlestown HS - 197X portion of Bldg  
City/State: Charlestown, IN  
Project Number: NR00A #2 Date: 7-5-10  
Samples Collected By: Sandy Shadley

SAMPLE I.D. NUMBER	LOCATION OF SAMPLE	DESCRIPTION OF SAMPLE MATERIAL
CBM-7-1	Chorus Hall	Cove Base Mastic - <sup>DK</sup> BROWN
CBM-7-2	Lower Lvl Hall Near Girls Locker Area	Cove Base Mastic - TAN
CBM-7-3	Home Econ. Area	Cove Base Mastic - BROWN
FTM-7-1	↓	Floor Mastic - Black
FTM-7-2	Choir Area Room w/ Dark Blue Tile	↓
FTM-7-3	2nd Flr Loading w/ Blue/Gray Tile	↓
FTM-7-4	Lower Level Hall Blue/Green Tile Locker	Floor Mastic - Black/TAN
FTM-7-5	Lower Level Near Elevator - DK Blue Tile	Floor Mastic - BROWN/TAN

**CHAIN OF CUSTODY**

Sample By: Sandy Shadley Received By: Ensl Recorded By: \_\_\_\_\_  
Date: 6-30-10 Date: 7-6-10 800 Date: \_\_\_\_\_ Log#: \_\_\_\_\_  
Signature: Sandy Shadley Signature: Ensl Signature: \_\_\_\_\_  
Date Shipped: 7-5-10 Shipped Via: db Shipped To: \_\_\_\_\_

Drop.

June 6, 2010

Mr. Steve Hobgood  
Director of Facilities  
Greater Clark County Schools  
2710 East 10th  
Jeffersonville, Indiana 47130

**RE: CHARLESTOWN HIGH SCHOOL – BULK SAMPLING RESULTS FOR ASBESTOS**

Dear Mr. Hobgood:

Thank you for your continued employment of our professional environmental compliance programs. We appreciate serving your needs.

In accordance with federal and state regulations, Alliance conducted an asbestos inspection of the floor tile and mastics for wall, floor and cove base at Charlestown High School, located at 1 Pirate Place, Charlestown, Clark County, Indiana on May 7, 2010. The IDEM licensed inspector was Sandra S. Shadley, IDEM #19A002323.

The inspector assessed the floor tile and mastics in the F(J) Art and Science wing, H(N) Business wing and the J(P) Gym and Industrial wing under the requirements for normal demolition/renovation as directed by the US EPA publication 340/1-92-013. The inspector noted suspect materials within the building. The inspector adequately wetted the suspect materials and removed a sufficient amount of suspect material from each location which was then sealed in a labeled container, assigned a unique identification number and submitted to an independent accredited laboratory for analysis under standard chain of custody protocol. The laboratory performed a polarized light microscopy analysis in accordance with the US EPA's NESHAP regulations.

The findings of the inspection are summarized in the following table:

<i><b>Material</b></i>	<i><b>Location</b></i>	<i><b>Asbestos?</b></i>	<i><b>Content</b></i>	<i><b>Regulated?</b></i>
brown wall mastics	business wing and auto shop	no	--	no
tan wall mastics	science wing and old boys locker room	no	--	no
cove base mastic	2 <sup>nd</sup> floor prep room – math and social studies	yes	2% chrysotile	yes
cove base mastics	auto shop hall and 1 <sup>st</sup> floor science behind lockers	no	--	no
black floor mastics	under multi-colored carpet 1 <sup>st</sup> and 2 <sup>nd</sup> floor in the F(J) wing	yes	2% chrysotile	yes
black floor mastics	under orange carpet and	no	--	no

**EMSL Analytical, Inc.**

2001 East 52nd St., Indianapolis, IN 46205

Phone: (317) 803-2997 Fax: (317) 803-3047 Email: [indianapolislabs@emsl.com](mailto:indianapolislabs@emsl.com)

Attn: **Sandy Shadley**  
**Alliance Environmental Group, Inc.**  
**5340 Commerce Circle**  
**Indianapolis, IN 46237**

Customer ID: ALLI65  
Customer PO:  
Received: 05/10/10 7:50 AM  
EMSL Order: 161006700

Fax: (317) 865-3401 Phone: (317) 865-3400  
Project: NGR08A12


EMSL Proj:  
Analysis Date: 5/10/2010

### Test Report: Asbestos Analysis of Bulk Materials via EPA 600/R-93/116 Method using Polarized Light Microscopy

Sample	Description	Appearance	Non-Asbestos		Asbestos
			% Fibrous	% Non-Fibrous	% Type
WM-01 161006700-0001		Brown Non-Fibrous Homogeneous		100% Non-fibrous (other)	None Detected
WM-02 161006700-0002		Brown Non-Fibrous Homogeneous		100% Non-fibrous (other)	None Detected
WM-03 161006700-0003		Tan Non-Fibrous Homogeneous		100% Non-fibrous (other)	None Detected
WM-04 161006700-0004		Brown Non-Fibrous Homogeneous		100% Non-fibrous (other)	None Detected
WM-05 161006700-0005		White Non-Fibrous Homogeneous		100% Non-fibrous (other)	None Detected

Analyst(s)

Melissa Wilson (5)

  
Richard Harding, Laboratory Manager  
or other approved signatory

magnification limitations inherent in PLM, asbestos fibers in dimensions below the resolution capability of PLM may not be detected. The limit of detection as stated in the report is 1%. The above test report relates only to the items tested and may not be reproduced in any form without the express written approval of EMSL Analytical, Inc. EMSL's responsibility is limited to the cost of analysis. EMSL bears no responsibility for sample collection activities or analytical method limitations. Interpretation and use of test results are the responsibility of the client. Samples received in good condition unless otherwise noted. This report must not be used to claim product endorsement by NVLAP or any agency of the U.S. Government.

Samples analyzed by EMSL Analytical, Inc. 2001 East 52nd St., Indianapolis, IN NVLAP Lab Code 200188-0, AZ0939, CA 2575, CO AL-15132, TX 300282

**ALLIANCE ENVIRONMENTAL GROUP, INC.**

5340 Commerce Circle, Suite E  
Indianapolis, IN 46237  
317/865-3400 Fax 317/865-3401

Please  
RETURN  
samples



161006700

24 HOUR TURN

Project Name- Charlestown High School  
Project Location- Wall Mastics in wings - N, J, M, P  
City/State- (Charlestown), INDIANA  
Project Number- N6R08A12 Date- 5-7-2010  
Samples Collected By- Sandy Shadley

SAMPLE I.D. NUMBER	LOCATION OF SAMPLE	DESCRIPTION OF SAMPLE MATERIAL
WM-01	H-120 <sup>SEMI-INDOOR</sup> MIRROR	BROWN MASTIC ONLY
WM-02	H-126	BROWN MASTIC ONLY
WM-03	F-105 <sup>LARGE</sup> <sup>BOARD</sup> <sup>FLOOR</sup>	TAN MASTIC ONLY
WM-04	AUTO SHOP	BROWN MASTIC ONLY
WM-05	OLD BOYS LOCKER RM BY COACH OFFICE	TAN MASTIC ONLY

**CHAIN OF CUSTODY**

Sample By: Sandy Shadley Received By: Drop Box Recorded By: \_\_\_\_\_  
Date: 5-7-2010 Date: 5-7-2010 11:30 PM Date: \_\_\_\_\_ Log#: \_\_\_\_\_  
Signature: [Signature] Signature: [Signature] Signature: \_\_\_\_\_  
Date Shipped: 5-7-2010 Shipped Via: 5/10/10 800 Shipped To: \_\_\_\_\_

**EMSL Analytical, Inc.**

2001 East 52nd St., Indianapolis, IN 46205

Phone: (317) 803-2997 Fax: (317) 803-3047 Email: indianapolislabs@emsl.com

Attn: **Sandy Shadley**  
**Alliance Environmental Group, Inc.**  
**5340 Commerce Circle**  
**Indianapolis, IN 46237**

Fax: (317) 865-3401 Phone: (317) 865-3400  
Project: NGR08A12

Customer ID: ALLI65  
Customer PO:  
Received: 05/10/10 7:56 AM  
EMSL Order: 161006702

EMSL Proj:  
Analysis Date: 5/10/2010

### Test Report: Asbestos Analysis of Bulk Materials via EPA 600/R-93/116 Method using Polarized Light Microscopy

Sample	Description	Appearance	Non-Asbestos		Asbestos
			% Fibrous	% Non-Fibrous	% Type
CM-01 161006702-0001		Brown Non-Fibrous Homogeneous		100% Non-fibrous (other)	None Detected
CM-02 161006702-0002		Brown/Black Non-Fibrous Heterogeneous		98% Non-fibrous (other)	2% Chrysotile
3 161006702-0003		Brown Non-Fibrous Homogeneous		100% Non-fibrous (other)	None Detected

Analyst(s)

Margaret Phillips (3)

Richard Harding, Laboratory Manager  
or other approved signatory

magnification limitations inherent in PLM, asbestos fibers in dimensions below the resolution capability of PLM may not be detected. The limit of detection as stated in the is 1%. The above test report relates only to the items tested and may not be reproduced in any form without the express written approval of EMSL Analytical, Inc. EMSL's is limited to the cost of analysis. EMSL bears no responsibility for sample collection activities or analytical method limitations. Interpretation and use of test results are the responsibility of the client. Samples received in good condition unless otherwise noted. This report must not be used to claim product endorsement by NVLAP or any agency of the U.S. Government.

Samples analyzed by EMSL Analytical, Inc. 2001 East 52nd St., Indianapolis, IN NVLAP Lab Code 200168-0, AZ0939, CA 2575, CO AL-15132, TX 300282

**ALLIANCE ENVIRONMENTAL GROUP, INC.**

5340 Commerce Circle, Suite E  
 Indianapolis, IN 46237  
 317/865-3400 Fax 317/865-3401

161006702

Please  
 RETURN  
 samples



24 RETURN

Project Name- CHARLESTOWN H.S.Project Location- COVE. DISC. MICHIGANCity/State- CHARLESTOWN, INProject Number- NR02A12 Date- 5-7-2010Samples Collected By- Sandy Shadley

SAMPLE I.D. NUMBER	LOCATION OF SAMPLE	DESCRIPTION OF SAMPLE MATERIAL
CM-01	1ST FLOOR SLIDING EXTERIOR DOOR	BROWN MASTIC ONLY
CM-02	2ND FLOOR REFRIG NEAR WINDOW	BROWN/EIK MASTIC ONLY
CM-03	1ST FLOOR HALLWAY	BROWN MASTIC ONLY

**CHAIN OF CUSTODY**Sample By: Sandy Shadley Received By: DIANE FOX Recorded By: \_\_\_\_\_Date: 5-7-10 Date: 5-7-10 11:30 AM Date: \_\_\_\_\_ Log#: \_\_\_\_\_Signature: Sandy Shadley Signature: Diane Fox Signature: \_\_\_\_\_Date Shipped: 5-7-10 Shipped Via: 5-10-10 800 Shipped To: \_\_\_\_\_  
 26

**EMSL Analytical, Inc.**

2001 East 52nd St., Indianapolis, IN 46205

Phone: (317) 803-2997 Fax: (317) 803-3047 Email: [indianapolislab@emsl.com](mailto:indianapolislab@emsl.com)

Attn: **Sandy Shadley**  
**Alliance Environmental Group, Inc.**  
**5340 Commerce Circle**  
**Indianapolis, IN 46237**

Customer ID: ALLI65  
Customer PO:  
Received: 05/10/10 7:52 AM  
EMSL Order: 161006701

Fax: (317) 865-3401 Phone: (317) 865-3400  
Project: NGR08A12

EMSL Proj:  
Analysis Date: 5/10/2010

### Test Report: Asbestos Analysis of Bulk Materials via EPA 600/R-93/116 Method using Polarized Light Microscopy

Sample	Description	Appearance	Non-Asbestos		Asbestos
			% Fibrous	% Non-Fibrous	% Type
FM-01 161006701-0001		Black Non-Fibrous Homogeneous		100% Non-fibrous (other)	None Detected
FM-02 161006701-0002		Black Non-Fibrous Homogeneous		98% Non-fibrous (other)	2% Chrysotile
3 161006701-0003					Stop Positive (Not Analyzed)
FM-04 161006701-0004		Black Non-Fibrous Homogeneous	5% Cellulose	95% Non-fibrous (other)	None Detected
FM-05 161006701-0005		Black/Yellow Non-Fibrous Heterogeneous		100% Non-fibrous (other)	None Detected
		Could not separate from yellow mastic.			
FM-06 161006701-0006		Black Non-Fibrous Homogeneous		98% Non-fibrous (other)	2% Chrysotile
FM-07 161006701-0007		Black Non-Fibrous Homogeneous		100% Non-fibrous (other)	None Detected

Analyst(s)

Richard Harding (6)

*Richard Harding*  
Richard Harding, Laboratory Manager  
or other approved signatory

magnification limitations inherent in PLM, asbestos fibers in dimensions below the resolution capability of PLM may not be detected. The limit of detection as stated in the report is 1%. The above test report relates only to the items tested and may not be reproduced in any form without the express written approval of EMSL Analytical, Inc. EMSL's liability is limited to the cost of analysis. EMSL bears no responsibility for sample collection activities or analytical method limitations. Interpretation and use of test results are the responsibility of the client. Samples received in good condition unless otherwise noted. This report must not be used to claim product endorsement by NVLAP or any agency of the U.S. Government.

Samples analyzed by EMSL Analytical, Inc. 2001 East 52nd St., Indianapolis, IN NVLAP Lab Code 200188-0, AZ0939, CA 2575, CO AL-15132, TX 300282

**ALLIANCE ENVIRONMENTAL GROUP, INC.**

5340 Commerce Circle, Suite E

Indianapolis, IN 46237

317/865-3400 Fax 317/865-3401

161006701

Please  
Return  
Samples  
😊

24 HOUR

Project Name- Chatterstown High SchoolProject Location- Floor MatsCity/State- Chatterstown, INProject Number- NGR08A12 Date- 5-7-2010Samples Collected By- Sandy Shadley

SAMPLE I.D. NUMBER	LOCATION OF SAMPLE	DESCRIPTION OF SAMPLE MATERIAL
<del>FM-01</del>	F-219 2ND FLOOR UNDER CARPET	Block Music ONLY
<del>FM-02</del>	Prep Room 2ND FLOOR UNDER CARPET	
<del>FM-03</del>	JUNIOR 1ST FLOOR SOI - MATHS FLORIAN UNDER CARPET	
FM-04	JUNIOR 1ST FLOOR UNDER WATER FOUNTAIN	
FM-05	1ST FLOOR JUNIOR UNILS LOCKERS ORANGE CARPET	↓ ↓
FM-06	1ST FLOOR UNDER ST 12x12 WATER FOUNTAIN	↓ ↓
FM-07	2ND FLOOR LANDING 12x12 NEAR SOI	↓ ↓

**CHAIN OF CUSTODY**Sample By: Sandy ShadleyReceived By: DIOPROX

Recorded By: \_\_\_\_\_

Date: 5-7-2010Date: 5-7-2010Date: 11:30 pm

Log#: \_\_\_\_\_

Signature: Sandy ShadleySignature: Qua Brue

Signature: \_\_\_\_\_

Date Shipped: 5-7-2010Shipped Via: 5-7-10 800

Shipped To: \_\_\_\_\_

dh



**EMSL Analytical, Inc.**

2001 East 52nd St., Indianapolis, IN 46205

Phone: (317) 803-2997 Fax: (317) 803-3047 Email: [indianapolislab@emsl.com](mailto:indianapolislab@emsl.com)

Attn: **Sandy Shadley**  
**Alliance Environmental Group, Inc.**  
**5340 Commerce Circle**  
**Indianapolis, IN 46237**

Fax: (317) 865-3401 Phone: (317) 865-3400  
Project: **NGR08A12**

Customer ID: ALLI65  
Customer PO:  
Received: 05/10/10 8:00 AM  
EMSL Order: 161006703

EMSL Proj:  
Analysis Date: 5/10/2010

### Test Report: Asbestos Analysis of Bulk Materials via EPA 600/R-93/116 Method using Polarized Light Microscopy

Sample	Description	Appearance	Non-Asbestos		Asbestos
			% Fibrous	% Non-Fibrous	% Type
FTM-04-Mastic 161006703-0004A		Black Non-Fibrous Homogeneous		100% Non-fibrous (other)	None Detected
FTM-05-Floor Tile 161006703-0005		Green Non-Fibrous Homogeneous		96% Non-fibrous (other)	4% Chrysotile
FTM-05-Mastic 161006703-0005A		Black Non-Fibrous Homogeneous		100% Non-fibrous (other)	None Detected
FTM-06-Floor Tile 161006703-0006		Gray Non-Fibrous Homogeneous		97% Non-fibrous (other)	3% Chrysotile
FTM-06-Mastic 161006703-0006A		Black Non-Fibrous Homogeneous		100% Non-fibrous (other)	None Detected

Analyst(s)

Richard Harding (12)

  
Richard Harding, Laboratory Manager  
or other approved signatory

Due to magnification limitations inherent in PLM, asbestos fibers in dimensions below the resolution capability of PLM may not be detected. The limit of detection as stated in the report is 1%. The above test report relates only to the items tested and may not be reproduced in any form without the express written approval of EMSL Analytical, Inc. EMSL's liability is limited to the cost of analysis. EMSL bears no responsibility for sample collection activities or analytical method limitations. Interpretation and use of test results are the responsibility of the client. Samples received in good condition unless otherwise noted. This report must not be used to claim product endorsement by NVLAP or any agency of the U.S. Government.

Samples analyzed by EMSL Analytical, Inc. 2001 East 52nd St., Indianapolis, IN NVLAP Lab Code 200188-0, AZ0939, CA 2575, CO AL-16132, TX 300262

**EMSL Analytical, Inc.**

2001 East 52nd St., Indianapolis, IN 46205

Phone: (317) 803-2997 Fax: (317) 803-3047 Email: [indianapolislabs@emsl.com](mailto:indianapolislabs@emsl.com)

Attn: **Sandy Shadley**  
**Alliance Environmental Group, Inc.**  
**5340 Commerce Circle**  
**Indianapolis, IN 46237**

Fax: (317) 865-3401 Phone: (317) 865-3400  
Project: **NGR08A12**

Customer ID: ALLI65  
Customer PO:  
Received: 05/10/10 8:00 AM  
EMSL Order: 161006703

EMSL Proj:  
Analysis Date: 5/10/2010

### Test Report: Asbestos Analysis of Bulk Materials via EPA 600/R-93/116 Method using Polarized Light Microscopy

Sample	Description	Appearance	Non-Asbestos		Asbestos
			% Fibrous	% Non-Fibrous	% Type
FTM-01-Floor Tile 161006703-0001		Black Non-Fibrous Homogeneous		97% Non-fibrous (other)	3% Chrysotile
FTM-01-Mastic 161006703-0001A		Gray Non-Fibrous Homogeneous		100% Non-fibrous (other)	None Detected
FTM-02-Floor Tile 161006703-0002		Tan Non-Fibrous Homogeneous		97% Non-fibrous (other)	3% Chrysotile
FTM-02-Mastic 161006703-0002A		Black Non-Fibrous Homogeneous		100% Non-fibrous (other)	None Detected
FTM-03-Floor Tile 161006703-0003		Gray Non-Fibrous Homogeneous		100% Non-fibrous (other)	None Detected
FTM-03-Mastic 161006703-0003A		Black Non-Fibrous Homogeneous		100% Non-fibrous (other)	None Detected
FTM-04-Floor Tile 161006703-0004		Black Non-Fibrous Homogeneous		97% Non-fibrous (other)	3% Chrysotile

Analyst(s)

Richard Harding (12)

  
Richard Harding, Laboratory Manager  
or other approved signatory

\* magnification limitations inherent in PLM, asbestos fibers in dimensions below the resolution capability of PLM may not be detected. The limit of detection as stated in the report is 1%. The above test report relates only to the items tested and may not be reproduced in any form without the express written approval of EMSL Analytical, Inc. EMSL's liability is limited to the cost of analysis. EMSL bears no responsibility for sample collection activities or analytical method limitations. Interpretation and use of test results are the responsibility of the client. Samples received in good condition unless otherwise noted. This report must not be used to claim product endorsement by NVLAP or any agency of the U.S. Government.

Samples analyzed by EMSL Analytical, Inc. 2001 East 52nd St., Indianapolis, IN NVLAP Lab Code 200188-0, AZ0939, CA 2575, CO AL-15132, TX 300282

**ALLIANCE ENVIRONMENTAL GROUP, INC.**

5340 Commerce Circle, Suite E  
Indianapolis, IN 46237  
317/865-3400 Fax 317/865-3401

161006703

PLEASE  
RETURN  
SAMPLE  
②

24 HOUR

Project Name- Charlie Wilson H.S.

Project Location- 1) WING - FLOOR 11E : MULTIS

City/State- Charleston H.S.

Project Number- NER09A12 Date- 5-7-2010

Samples Collected By- Sandy Shudley

SAMPLE I.D. NUMBER	LOCATION OF SAMPLE	DESCRIPTION OF SAMPLE MATERIAL
F7M-01	ROOM # 120 UNDER CARPET	BLOCK FLOOR tile & GRAY MASTIC
F7M-02	ROOM # 120 UNDER CARPET	GRAY FLOOR tile & BLOCK MASTIC
F7M-03	ROOM # 146 UNDER CARPET	GRAY FLOOR tile & BLOCK MASTIC
F7M-04	ROOM # 155 UNDER CARPET	BLOCK FLOOR tile & BLOCK MASTIC
F7M-05	ROOM # 155 UNDER CARPET	GREEN FLOOR tile & BLOCK MASTIC
F7M-06	BOOK STORE	GRAY FLOOR tile & BLOCK MASTIC
	DO NOT TEST THIS MASTIC	

## CHAIN OF CUSTODY

Sample By: Sandy Stadler Received By: Dr. J. Fox Recorded By: \_\_\_\_\_

Date: 5-7-2010 Date: 5-7-2010 11:30 PM Date: \_\_\_\_\_ Log#: \_\_\_\_\_

Signature: John A. [illegible] Signature: Paul [illegible] Signature: \_\_\_\_\_

Date Shipped: 5-7-2011 Shipped Via: 5-10-10 800 Shipped To: \_\_\_\_\_

**ENVIRONMENTAL SAFETY ASSURANCE INSTITUTE**  
**1435 Sadler Circle West Drive**  
**Indianapolis, Indiana 46239**  
**(317) 352-1270 / (317) 352-06**

**GEORGE Wm. (BILL) OGLE**

**Has Successfully Completed The Course  
Required Under TSCA Title II  
And Passed The Written Examination  
With a Score of 70% or Better  
For**

**ASBESTOS MANAGEMENT PLANNER  
REFRESHER**

**Accredited by the  
Indiana Department of Environmental Management.**

**Certificate # ES03/MPR045**

**Course Dates: 09/05/2003  
Test Date: 09/05/2003      Expires: 09/05/2004**



  
**Sharyn Reyes**  
**Instructor**

**ENVIRONMENTAL SAFETY ASSURANCE INSTITUTE**  
**1435 Sadlier Circle West Drive**  
**Indianapolis, Indiana 46239**  
**(317) 352-1270 / (317) 352-06**

**GEORGE W<sup>M</sup> (BILL) OGLE**  
**312 - 52 - 2526**

**Has Successfully Completed The Course**  
**Required Under TSCA Title II**  
**And Passed The Written Examination**  
**With a Score of 70% or Better**  
**For**

**ASBESTOS MANAGEMENT PLANNER**  
**REFRESHER**

**Accredited by the**  
**Indiana Department of Environmental Management.**

**Certificate # ES04/MPR058**

**Course Dates: 09/29/2004**  
**Test Date: 09/29/2004      Expires: 09/29/2005**



  
**Sheryn Reyes**  
**Instructor**

**ENVIRONMENTAL SAFETY ASSURANCE INSTITUTE**  
**1435 Sadler Circle West Drive**  
**Indianapolis, Indiana 46239**  
**(317) 352-1270 / (317) 352-0669**

**GEORGE WM. (BILL) OGLE**

Has Successfully Completed The Course  
Required Under TSCA Title II  
And Passed The Written Examination  
With a Score of 70% or Better  
For

**ASBESTOS MANAGEMENT PLANNER  
REFRESHER**

Management.  
Accredited by the  
Indiana Department of Environmental

**Certificate # ES02/MPR032**

Course Dates: 06/21/2002  
Test Date: 06/21/2002 Expires: 06/21/2003

*Sharyn Reyes*

**Sharyn Reyes**  
Instructor / Manager

INDIANA DEPARTMENT OF ENVIRONMENTAL  
MANAGEMENT ASBESTOS LICENSE # 191523030

INSPECTOR ☒ PLANNER ☒ DESIGNER ☐  
SUPERVISOR ☐ WORKER ☐ WASTE DISP. MGR. ☐



George (Bill) W. Ogle  
Expiration Date: 09/27/2003

BIRTH DATE: 01/17/1949  
SEX: M  
EYE COLOR: BRO  
HAIR COLOR: BRO  
HEIGHT: 5-08  
WEIGHT: 155

THIS CERTIFICATE IS ISSUED FOR THE SOLE  
USE OF THE UNDERSIGNED AND IS NON-  
TRANSFERABLE. ANY USE OR POSSESSION  
EXCEPT AS PRESCRIBED IS PROHIBITED BY  
LAW. THIS CERTIFICATE MUST BE IN THE  
POSSESSION OF THE UNDERSIGNED WHEN  
PERFORMING ASBESTOS-RELATED ACTIVITIES  
AS PRESCRIBED BY 326 IAC 18.

  
SIGNATURE

**ALLIANCE ENVIRONMENTAL GROUP, INC.**

5340 Commerce Circle, Suite E

Indianapolis, IN 46237

317/865-3400 Fax 317/865-3401

3 HOUR

Project Name- CHARLESTOWN HIGH SCHOOLProject Location- MAIN ENTRANCE CANOPYCity/State- CHARLESTOWN, INDIANAProject Number- NGR 08A12 Date- 08 JANUARY 2009Samples Collected By- BILL OGLE

SAMPLE I.D. NUMBER	LOCATION OF SAMPLE	DESCRIPTION OF SAMPLE MATERIAL
CS-01	CANOPY-NORTHWEST	GRAY CEMENTICIOUS
CS-02	CANOPY-SOUTHWEST	GRAY CEMENTICIOUS
CS-03	CANOPY-CENTER	GRAY CEMENTICIOUS

**CHAIN OF CUSTODY**

Sample By: BILL OGLE Received By: Const Recorded By: \_\_\_\_\_  
Date: 08 JANUARY 2009 Date: 1-8-09 1425 Date: \_\_\_\_\_ Log#: \_\_\_\_\_  
Signature: Bill Ogle Signature: [Signature] Signature: \_\_\_\_\_  
Date Shipped: 08 January 2009 Shipped Via: DO Shipped To: \_\_\_\_\_



**ALLIANCE ENVIRONMENTAL GROUP, INC.**

5340 Commerce Circle, Suite E

Indianapolis, IN 46237

317/865-3400 Fax 317/865-3401

3 HOUR

Project Name- CHARLESTOWN HIGH SCHOOLProject Location- MAIN ENTRANCE CANOPYCity/State- CHARLESTOWN, INDIANAProject Number- NGR 08A12 Date- 08 JANUARY 2009Samples Collected By- BILL ORLE

SAMPLE I.D. NUMBER	LOCATION OF SAMPLE	DESCRIPTION OF SAMPLE MATERIAL
CS-01	CANOPY-NORTHWEST	GRAY CEMENTICIOUS
CS-02	CANOPY-SOUTHWEST	GRAY CEMENTICIOUS
CS-03	CANOPY-CENTER	GRAY CEMENTICIOUS

**CHAIN OF CUSTODY**Sample By: BILL ORLEReceived By: Const

Recorded By: \_\_\_\_\_

Date: 08 JANUARY 2009Date: 1-8-09 1425

Date: \_\_\_\_\_ Log#: \_\_\_\_\_

Signature: Bill OrleSignature: Jim Brown

Signature: \_\_\_\_\_

Date Shipped: 08 January 2009Shipped Via: do

Shipped To: \_\_\_\_\_



# EMSL Analytical

2001 East 52nd St., Indianapolis, IN 46205

Phone: (317) 803-2997 Fax: (317) 803-3047 Email: [indianapolislab@emsl.com](mailto:indianapolislab@emsl.com)

Attn: **Bill Ogle**  
**Alliance Environmental Group, Inc.**  
**5340 Commerce Circle**  
**Indianapolis, IN 46237**

Customer ID: ALLI65  
Customer PO:  
Received: 01/08/09 4:25 AM  
EMSL Order: 160900311

Fax: (317) 865-3401 Phone: (317) 865-3400  
Project: NGR 08A12

EMSL Proj:  
Analysis Date: 1/8/2009  
Report Date: 1/9/2009


## Asbestos Analysis of Bulk Materials via EPA 600/R-93/116 Method using Polarized Light Microscopy

Sample	Location	Appearance	Non-Asbestos		Asbestos
			% Fibrous	% Non-Fibrous	% Type
CS-01 160900311-0001		Gray Non-Fibrous Homogeneous	2% Glass	30% Non-fibrous (other) 68% Quartz	None Detected
CS-02 160900311-0002		Gray Non-Fibrous Homogeneous	2% Glass	20% Non-fibrous (other) 78% Quartz	None Detected
CS-03 160900311-0003		Gray Non-Fibrous Homogeneous	2% Glass	20% Non-fibrous (other) 78% Quartz	None Detected

BQ  
RECEIVED JAN 15 2009  
W

Analyst(s)

Jeffrey Conkel (2)  
Melissa Wilson (1)

  
Richard Harding, Laboratory Manager  
or other approved signatory

Signification limitations inherent in PLM, asbestos fibers in dimensions below the resolution capability of PLM may not be detected. The limit of detection as stated in the method is 1%. The above test report relates only to the items tested and may not be reproduced in any form without the express written approval of EMSL Analytical, Inc. EMSL's liability is limited to the cost of analysis. EMSL bears no responsibility for sample collection activities or analytical method limitations. Interpretation and use of test results are the responsibility of the client. Samples received in good condition unless otherwise noted. This report must not be used to claim product endorsement by NVLAP or any agency of the U.S. Government.

ACCREDITATION: NVLAP Lab Code 200188-0

**ALLIANCE ENVIRONMENTAL GROUP, INC.**

5340 Commerce Circle, Suite E  
Indianapolis, IN 46237  
317/865-3400 Fax 317/865-3401

24 hour

Project Name- CHARLESTOWN HIGH SCHOOL

Project Location- OUTDOOR EXCAVATION AREA

City/State- CHARLESTOWN, INDIANA

Project Number- NGR-08A Date- 09 MARCH 2009

Samples Collected By- BILL OGLE

SAMPLE I.D. NUMBER	LOCATION OF SAMPLE	DESCRIPTION OF SAMPLE MATERIAL
PLEASE STOP AT FIRST POSITIVE		
UP-01	UNDERGROUND PIPE	GRAY CEMENTICIOUS
UP-02	UNDERGROUND PIPE	GRAY CEMENTICIOUS
UP-03	UNDERGROUND PIPE	GRAY CEMENTICIOUS

**CHAIN OF CUSTODY**

Sample By: BILL OGLE

Date: 09 MARCH 2009

Signature: BILL OGLE

Date Shipped: \_\_\_\_\_

Received By: Krystle Burke Recorded By: \_\_\_\_\_

Date: 3-11-09 10:57 Date: \_\_\_\_\_ Log#: \_\_\_\_\_

Signature: \_\_\_\_\_ Signature: \_\_\_\_\_

Shipped Via: \_\_\_\_\_ Shipped To: \_\_\_\_\_

160903386  
24 hour

**ALLIANCE ENVIRONMENTAL GROUP, INC.**

5340 Commerce Circle, Suite E  
Indianapolis, IN 46237  
317/865-3400 Fax 317/865-3401

Project Name- CHARLESTOWN HIGH SCHOOL

Project Location- OUTDOOR EXCAVATION AREA

City/State- CHARLESTOWN, INDIANA

Project Number- NGR-08A Date- 09 MARCH 2009

Samples Collected By- BILL OGLE

SAMPLE I.D. NUMBER	LOCATION OF SAMPLE	DESCRIPTION OF SAMPLE MATERIAL
PLEASE STOP AT FIRST POSITIVE		
UP-01	UNDERGROUND PIPE	GRAY CEMENTICIOUS MGP
UP-02	UNDERGROUND PIPE	GRAY CEMENTICIOUS
UP-03	UNDERGROUND PIPE	GRAY CEMENTICIOUS

**CHAIN OF CUSTODY**

Sample By: BILL OGLE

Date: 09 MARCH 2009

Signature: BILL OGLE

Date Shipped: \_\_\_\_\_

Received By: Krystle Burke

Date: 3-11-09 10:17

Signature: \_\_\_\_\_

Shipped Via: \_\_\_\_\_

Recorded By: \_\_\_\_\_

Date: \_\_\_\_\_ Log#: \_\_\_\_\_

Signature: \_\_\_\_\_

Shipped To: \_\_\_\_\_

RECEIVED MAR 19 2009

**EMSL Analytical**

2001 East 52nd St., Indianapolis, IN 46205

Phone: (317) 803-2997 Fax: (317) 803-3047 Email: [indianapolislabs@emsl.com](mailto:indianapolislabs@emsl.com)

Attn: **Bill Ogle**  
**Alliance Environmental Group, Inc.**  
**5340 Commerce Circle**  
**Indianapolis, IN 46237**

Fax: (317) 865-3401 Phone: (317) 865-3400  
Project: **Charlestown High School**

Customer ID: ALLI65  
Customer PO:  
Received: 03/11/09 10:57 AM  
EMSL Order: 160903386

EMSL Proj:  
Analysis Date: 3/12/2009  
Report Date: 3/12/2009

**Asbestos Analysis of Bulk Materials via EPA 600/R-93/116 Method using Polarized Light Microscopy**

Sample	Location	Appearance	Non-Asbestos		Asbestos
			% Fibrous	% Non-Fibrous	% Type
UP-01 160903386-0001		Gray Fibrous Homogeneous		62% Non-fibrous (other)	30% Chrysotile 8% Crocidolite
UP-02 160903386-0002					Stop Positive (Not Analyzed)
UP-03 160903386-0003					Stop Positive (Not Analyzed)

RECEIVED MAR 19 2009

Analyst(s)

Margaret Phillips (1)

  
Richard Harding, Laboratory Manager  
or other approved signatory

Due to the limitations inherent in PLM, asbestos fibers in dimensions below the resolution capability of PLM may not be detected. The limit of detection as stated in the methods is 1%. The above test report relates only to the items tested and may not be reproduced in any form without the express written approval of EMSL Analytical, Inc. EMSL's liability is limited to the cost of analysis. EMSL bears no responsibility for sample collection activities or analytical method limitations. Interpretation and use of test results are the responsibility of the client. Samples received in good condition unless otherwise noted. This report must not be used to claim product endorsement by NVLAP or any agency of the U.S. Government.

ACCREDITATION: NVLAP Lab Code 200188-0

**ALLIANCE ENVIRONMENTAL GROUP, INC.**

5340 Commerce Circle, Suite E

Indianapolis, IN 46237

317/865-3400 Fax 317/865-3401

3 HOURProject Name- CHARLESTOWN HIGH SCHOOLProject Location- UNITS G + HCity/State- CHARLESTOWN, INDIANAProject Number- NGR08A12Date- 12 AUGUST 2009Samples Collected By- K. SHADLEY

SAMPLE I.D. NUMBER	LOCATION OF SAMPLE	DESCRIPTION OF SAMPLE MATERIAL
EA-01	WEST SIDE UNIT H	WHITE CEMENTITIOUS
EA-02	SOUTH SIDE UNIT H	WHITE CEMENTITIOUS
EA-03	NORTH SIDE UNIT G	WHITE CEMENTITIOUS
POSITIVE	STOP. DO NOT ANALYZE	AGGREGATE, PAINT, OR
ADHERED	CONCRETE BLOCK	

**CHAIN OF CUSTODY**Sample By: KENT SHADLEY

Received By: \_\_\_\_\_

Recorded By: \_\_\_\_\_

Date: 12 AUGUST 2009

Date: \_\_\_\_\_

Date: \_\_\_\_\_ Log#: \_\_\_\_\_

Signature: [Signature]

Signature: \_\_\_\_\_

Signature: \_\_\_\_\_

Date Shipped: 8-13-09

Shipped Via: \_\_\_\_\_

Shipped To: \_\_\_\_\_

**ALLIANCE ENVIRONMENTAL GROUP, INC.**

5340 Commerce Circle, Suite E

Indianapolis, IN 46237

317/865-3400 Fax 317/865-3401

3 HOUR160912725Project Name- CHARLESTOWN HIGH SCHOOLProject Location- UNITS G + HCity/State- CHARLESTOWN, INDIANAProject Number- NGR08A12 Date- 12 AUGUST 2009Samples Collected By- K. SHADLEY

SAMPLE I.D. NUMBER	LOCATION OF SAMPLE	DESCRIPTION OF SAMPLE MATERIAL
EA-01	WEST SIDE UNIT H	WHITE CEMENTITIOUS
EA-02	SOUTH SIDE UNIT H	WHITE CEMENTITIOUS
EA-03	NORTH SIDE UNIT G	WHITE CEMENTITIOUS
POSITIVE	STOP. DO NOT ANALYZE	AGGREGATE, PAINT, OR <sup>M/G</sup>
ADHERED CONCRETE BLOCK		

**CHAIN OF CUSTODY**Sample By: KENT SHADLEYReceived By: MSL

Recorded By: \_\_\_\_\_

Date: 12 AUGUST 2009Date: 8-13-09 800

Date: \_\_\_\_\_ Log#: \_\_\_\_\_

Signature: Kent ShadleySignature: MSL

Signature: \_\_\_\_\_

Date Shipped: 8-13-09Shipped Via: db

Shipped To: \_\_\_\_\_

**EMSL Analytical, Inc.**

2001 East 52nd St., Indianapolis, IN 46205

Phone: (317) 803-2997 Fax: (317) 803-3047 Email: [indianapolislab@emsl.com](mailto:indianapolislab@emsl.com)

Attn: **Bill Ogle**  
**Alliance Environmental Group, Inc.**  
**5340 Commerce Circle**  
**Indianapolis, IN 46237**

Fax: (317) 865-3401 Phone: (317) 865-3400  
Project: **NGR 08A12**

Customer ID: ALLI65  
Customer PO:  
Received: 08/13/09 7:07 AM  
EMSL Order: 160912725

EMSL Proj:  
Analysis Date: 8/13/2009

**Asbestos Analysis of Bulk Materials via EPA 600/R-93/116 Method using Polarized Light Microscopy**

Sample	Description	Appearance	<u>Non-Asbestos</u>		<u>Asbestos</u>
			% Fibrous	% Non-Fibrous	% Type
EA-01 160912725-0001		White Non-Fibrous Homogeneous		100% Non-fibrous (other)	None Detected
EA-02 160912725-0002		White Non-Fibrous Homogeneous		80% Non-fibrous (other) 20% Quartz	None Detected
EA-03 160912725-0003		White Non-Fibrous Homogeneous		90% Non-fibrous (other) 10% Quartz	None Detected

RECEIVED AUG 17 2009

Analyst(s)

Margaret Phillips (3)

*Richard Harding*  
Richard Harding, Laboratory Manager  
or other approved signatory

Signification limitations inherent in PLM, asbestos fibers in dimensions below the resolution capability of PLM may not be detected. The limit of detection as stated in the report is 1%. The above test report relates only to the items tested and may not be reproduced in any form without the express written approval of EMSL Analytical, Inc. EMSL's liability is limited to the cost of analysis. EMSL bears no responsibility for sample collection activities or analytical method limitations. Interpretation and use of test results are the responsibility of the client. Samples received in good condition unless otherwise noted. This report must not be used to claim product endorsement by NVLAP or any agency of the U.S. Government.

Samples analyzed by EMSL Analytical, Inc. Indianapolis 2001 East 52nd St., Indianapolis IN NVLAP Lab Code 200188-0, AIHA IHLAP 157245, AZ0939, CA 2575, CO AL-15132, TX 300262



**ALLIANCE ENVIRONMENTAL GROUP, INC.**

5340 Commerce Circle, Suite E

Indianapolis, IN 46237

317/865-3400 Fax 317/865-3401

48 HOUR

Project Name- CHARLESTOWN HIGH SCHOOLProject Location- TUNNELCity/State- CHARLESTOWN, INDIANAProject Number- NGR-08A12 Date- 30 SEPTEMBER 2009Samples Collected By- BILL OGLE

SAMPLE I.D. NUMBER	LOCATION OF SAMPLE	DESCRIPTION OF SAMPLE MATERIAL
BM-01	TUNNEL - ON PIPE LOCATED INSIDE CORRUGATED METAL PIPE ON TUNNEL FLOOR	BROWN (WET) MASS
PC-01	EXTER PIPE COVERING ON PIPE LOCATED INSIDE CORRUGATED METAL PIPE ON TUNNEL FLOOR	DARK BROWN FIBROUS

**CHAIN OF CUSTODY**Sample By: BILL OGLEDate: 30 SEPTEMBER 2009Signature: BILL OGLEDate Shipped: 01 October 2009Received By: ConskDate: 10-1-09 2:35Signature: Anna BrunsShipped Via: Shipoff

Recorded By: \_\_\_\_\_

Date: \_\_\_\_\_ Log#: \_\_\_\_\_

Signature: \_\_\_\_\_

Shipped To: \_\_\_\_\_

**ALLIANCE ENVIRONMENTAL GROUP, INC.**

5340 Commerce Circle, Suite E  
Indianapolis, IN 46237  
317/865-3400 Fax 317/865-3401

48 HOUR

160915970

Project Name- CHARLESTOWN HIGH SCHOOLProject Location- TUNNELCity/State- CHARLESTOWN, INDIANA

mcp

Project Number- NGR-P8A12 Date- 30 SEPTEMBER 2009Samples Collected By- BILL OGLE

SAMPLE I.D. NUMBER	LOCATION OF SAMPLE	DESCRIPTION OF SAMPLE MATERIAL
BM-01	TUNNEL - ON PIPE LOCATED INSIDE CORRUGATED METAL PIPE ON TUNNEL FLOOR	BROWN (WET) MASS
PC-01	OUTER PIPE COVERING ON PIPE LOCATED INSIDE CORRUGATED METAL PIPE ON TUNNEL FLOOR	DARK BROWN FIBROUS

**CHAIN OF CUSTODY**Sample By: BILL OGLEDate: 30 SEPTEMBER 2009Signature: [Signature]Date Shipped: 01 October 2009Received By: [Signature]Date: 10-1-09 7:35Signature: [Signature]Shipped Via: [Signature]

Recorded By: \_\_\_\_\_

Date: \_\_\_\_\_ Log#: \_\_\_\_\_

Signature: \_\_\_\_\_

Shipped To: \_\_\_\_\_

**EMSL Analytical, Inc.**

2001 East 52nd St., Indianapolis, IN 46205

Phone: (317) 803-2997 Fax: (317) 803-3047 Email: indianapolislabs@emsl.com

Attn: **Bill Ogle**  
**Alliance Environmental Group, Inc.**  
**5340 Commerce Circle**  
**Indianapolis, IN 46237**

Customer ID: ALLI65  
Customer PO:  
Received: 10/01/09 2:35 PM  
EMSL Order: 160915970

Fax: (317) 865-3401 Phone: (317) 865-3400  
Project: NGR 08A12

EMSL Proj:  
Analysis Date: 10/5/2009

**Test Report: Asbestos Analysis of Bulk Materials via EPA 600/R-93/116 Method using  
Polarized Light Microscopy**

Sample	Description	Appearance	<u>Non-Asbestos</u>		<u>Asbestos</u>
			% Fibrous	% Non-Fibrous	% Type
BM-01 160915970-0001		Tan Fibrous Homogeneous	90% Min. Wool	10% Non-fibrous (other)	None Detected
PC-01 160915970-0002		Brown Fibrous Homogeneous	10% Cellulose	55% Non-fibrous (other)	35% Chrysotile

Analyst(s)

Margaret Phillips (2)

Richard Harding, Laboratory Manager  
or other approved signatory

magnification limitations inherent in PLM, asbestos fibers in dimensions below the resolution capability of PLM may not be detected. The limit of detection as stated in the method. The above test report relates only to the items tested and may not be reproduced in any form without the express written approval of EMSL Analytical, Inc. EMSL's liability is limited to the cost of analysis. EMSL bears no responsibility for sample collection activities or analytical method limitations. Interpretation and use of test results are the responsibility of the client. Samples received in good condition unless otherwise noted. This report must not be used to claim product endorsement by NVLAP or any agency of the U.S. Government. Samples analyzed by EMSL Analytical, Inc. Indianapolis 2001 East 52nd St., Indianapolis IN NVLAP Lab Code 200188-0, AIHA IHLAP 157245, AZ0939, CA 2575, CO AL-15132, TX 300262

**ALLIANCE INDIANA, INC.**

1433 Sadlier Circle West Dr.

Indianapolis, IN 46239

317/351-5600 Fax 317/351-5610

Project Name- CHARLESTOWN HIGH SCHOOLProject Location- THROUGHOUT BUILDINGCity/State- CHARLESTOWN INDIANAProject Number- NGR- Date- 06 JUNE 1997Samples Collected By- BILL OGLE

SAMPLE I.D. NUMBER	LOCATION OF SAMPLE	DESCRIPTION OF SAMPLE MATERIAL
E-103	Room E-103	BROWN FLOOR TILE - 9X9
E-115	Room E-115	GRAY FLOOR TILE - 9X9
E-116	Room E-116	RED FLOOR TILE - 9X9
E-116B	Room E-116	BLACK FLOOR TILE TRIM - 9X18
F-205	Room F-205	GREEN FLOOR TILE - 9X9
F-A219	CONFERENCE ROOM	BLACK FLOOR TILE - 9X9
	ACROSS FROM F-219	

**CHAIN OF CUSTODY**Sample By: BILL OGLEDate: 06 JUNE 1997Signature: Bill OgleDate Shipped: 06 June 97

Received By: \_\_\_\_\_

Date: \_\_\_\_\_

Signature: [Signature]Shipped Via: 6/6/97

Recorded By: \_\_\_\_\_

Date: \_\_\_\_\_ Log#: \_\_\_\_\_

Signature: \_\_\_\_\_

Shipped To: \_\_\_\_\_

**ALLIANCE INDIANA, INC.**

1433 Sadler Circle West Dr.

Indianapolis, IN 46239

317/351-5600 Fax 317/351-5610

9709 SS

6/6

Project Name- CHARLESTOWN HIGH SCHOOLProject Location- THROUGHOUT BUILDINGCity/State- CHARLESTOWN INDIANAProject Number- NGR- Date- 06 JUNE 1997Samples Collected By- BILL OGLE

SAMPLE I.D. NUMBER	LOCATION OF SAMPLE	DESCRIPTION OF SAMPLE MATERIAL
E-103	Room E-103	BROWN FLOOR TILE - 9X9
E-115	Room E-115	GRAY FLOOR TILE - 9X9
E-116	Room E-116	RED FLOOR TILE - 9X9
E-116B	Room E-116	BLACK FLOOR TILE TRIM - 9X18
F-205	Room F-205	GREEN FLOOR TILE - 9X9
F-A219	CONFERENCE ROOM	BLACK FLOOR TILE - 9X9
	ACROSS FROM F-219	
E-103 -	1.75	Point Count
E-115 -	1.50	
E-116 -	1.75	
E-116B =	1.25	
		F-205 - 1.50 %
		F-A219 - 1.25

**CHAIN OF CUSTODY**Sample By: BILL OGLEDate: 06 JUNE 1997Signature: BILL OGLEDate Shipped: 06 June 97

Received By: \_\_\_\_\_

Date: \_\_\_\_\_

Signature: [Signature]Shipped Via: 6/6/97

Recorded By: \_\_\_\_\_

Date: \_\_\_\_\_ Log#: \_\_\_\_\_

Signature: \_\_\_\_\_

Shipped To: \_\_\_\_\_

ATC Associates, Inc.  
Point Count Analysis Report  
NVLAP Number 101265-00

DATE: June 12, 1997

CLIENT: Alliance Indiana Inc.  
1433 Sadlier Circle West Drive  
Indianapolis, IN 46239

PROJECT IDENTIFICATION: Charlestown High School  
DATE RECEIVED: 06-11-97  
ATC LAB BATCH NUMBER: A-970955

---

<u>Sample ID</u>	<u>Sample Description</u>	<u>Percent Asbestos</u>	<u>Type(s) of Asbestos</u>
E-103	Brown Floor Tile	1.8	Chrysotile
E-115	Gray Floor Tile	1.5	Chrysotile
F-16	Red Floor Tile	1.8	Chrysotile
F-6B	Black Floor Tile	1.3	Chrysotile
F-205	Green Floor Tile	1.5	Chrysotile
F-A219	Black Floor Tile	1.3	Chrysotile

Analytical Method: EPA-600/R-93/116, July 1993  
Analytical Instrument: Olympus Polarizing Microscope BHTP-2  
Sample Homogenized  
NVLAP Accredited Bulk Asbestos Quality Assurance Program  
Percentages determined using Point Count Procedure  
Test Report Relates Only To Item Tested  
Report Cannot Be Used To Claim Product Endorsement

Analyst: Jennifer Crawford

Signature



Respectfully submitted,  
ATC Associates, Inc.



Environmental/Analytical Testing Division

**ALLIANCE INDIANA, INC.**

1433 Sadlier Circle West Dr.

Indianapolis, IN 46239

317/351-5600 Fax 317/351-5610

971246

7/9

Project Name- Greater Clark County Schools

Project Location- \_\_\_\_\_

City/State- Jeffersonville, IndianaProject Number- NGR 00A02Date- 3 July 97Samples Collected By- Karen Fox

SAMPLE I.D. NUMBER	LOCATION OF SAMPLE	DESCRIPTION OF SAMPLE MATERIAL
PV-01	Main Hall	cove base & CB - NAD mastic M - NAD
JS-01	Boiler	Gasket NAD
CT-01	Main Hall	Floor Tile Mastic NAD
CT-02	Main Hall	Cove Base Mastic NAD
SH-01	Classroom	Floor Tile & FT - Chr 5-10% mastic M - Chr 3-5%
SH-02	Classroom	cove base & CB - NAD mastic M - NAD

7.23.97  
(P)**CHAIN OF CUSTODY**Sample By: KAREN FOXDate: 3 July 97Signature: Karen FoxDate Shipped: 9 July 97Received By: DC 247Date: 7 9 97Signature: (Signature)

Shipped Via: \_\_\_\_\_

Recorded By: \_\_\_\_\_

Date: \_\_\_\_\_ Log#: \_\_\_\_\_

Signature: \_\_\_\_\_

Shipped To: \_\_\_\_\_

**ATC ASSOCIATES INC.**  
**BULK SAMPLE ANALYSIS REPORT**  
 NVLAP Accredited  
 NVLAP Code Number 101265-00

Date: July 24, 1997

Client: Alliance Indiana, Inc.

Project Identification: NGR-00A02 - Greater Clark County Schools  
 Date Sample Received: July 9, 1997  
 ATC Lab Batch Number: 971246

Lab ID	Client ID	Color / Description	Layer(s)	Asbestos Type	%	Other Fibrous Material	%	Non-Fibrous Material
001	PV-01	Tan Covebase	1	No Asbestos Detected		None Detected		Binder
002	PV-01	Yellow Mastic	1	No Asbestos Detected		None Detected		Adhesive
003	JJ-01	Tan Material	1	No Asbestos Detected		Glass	80-90	Binder
004	CT-01	Black Mastic	1	No Asbestos Detected		Manmade	2-3	Adhesive
005	CT-02	Brown Mastic	1	No Asbestos Detected		Cellulose Wollastonite	<1 2-3	Adhesive
006	SH-01	Tan Floor Tile	1	Chrysotile	5-10	None Detected		Vinyl Binder
007	SH-01	Black Mastic	1	Chrysotile	3-5	Cellulose	<1	Adhesive
008	SH-02	Black Covebase	1	No Asbestos Detected		None Detected		Vinyl Binder

- Analytical Methods: EPA 600/M4-82-020, December 82, EPA 600/R-93/116, July 1993
- Enclosed test results relates only to items tested.
- This report shall not be reproduced, except in full without written approval of the laboratory.
- This report can not be used to claim product endorsement by NVLAP or any agency of the U.S. Government.
- Method limitations: Analysis of floor tile and other resinously bound materials by Polarized Light Microscopy (PLM) may yield false negative results due to method limitations. In these cases ATC recommends alternative methods of analysis.
- For all heterogeneous samples easily separated into sub-samples each component will be analyzed separately. When layers cannot be separated without compromising the layer they will be analyzed as one sample. When a heterogeneous sample contains no asbestos in any layer reported results will be combined into one. When asbestos is detected in a layer or layers of a heterogeneous sample each individual layer will be reported separately.



**ATC ASSOCIATES INC.**  
**BULK SAMPLE ANALYSIS REPORT**  
NVLAP Accredited  
NVLAP Code Number 101265-00

Date: July 24, 1997

Client: Alliance Indiana, Inc.

Project Identification: NGR-00A02 - Greater Clark County Schools  
Date Sample Received: July 9, 1997  
ATC Lab Batch Number: 971246

Lab ID	Client ID	Color / Description	Layer(s)	Asbestos Type	%	Other Fibrous Material	%	Non-Fibrous Material
009	SH-02	Brown Mastic	1	No Asbestos Detected		Cellulose	<1	Adhesive

Scott Frosch (PS)  
Scott Frosch, Analyst

Patricia Stanford  
Patrick Stanford, Group Leader

- Analytical Methods: EPA 600/M4-82-020, December 82, EPA 600/R-93/116, July 1993
- Enclosed test results relates only to items tested.
- This report shall not be reproduced, except in full without written approval of the laboratory.
- This report can not be used to claim product endorsement by NVLAP or any agency of the U.S. Government.
- Method limitations: Analysis of floor tile and other resinously bound materials by Polarized Light Microscopy (PLM) may yield false negative results due to method limitations. In these cases ATC recommends alternative methods of analysis.
- For all heterogeneous samples easily separated into sub-samples each component will be analyzed separately. When layers cannot be separated without compromising the layer they will be analyzed as one sample. When a heterogeneous sample contains no asbestos in any layer reported results will be combined into one. When asbestos is detected in a layer or layers of a heterogeneous sample each individual layer will be reported separately.

**ALLIANCE INDIANA, INC.**

1433 Sadler Circle West Dr.

Indianapolis, IN 46239

317/351-5600 Fax 317/351-5610

24 HR  
TAT

Project Name- CHARLESTOWN SR HIGHProject Location- EXTERIOR FACIA PANELINGCity/State- ~~IND~~ CHARLESTOWN INProject Number- NGR00A02 Date- 7-3-03Samples Collected By- CHRIS SPARKS

SAMPLE I.D. NUMBER	LOCATION OF SAMPLE	DESCRIPTION OF SAMPLE MATERIAL
T-01	EXTERIOR OF BLDG BY CAFE	EXTERIOR FACIA BOARD
T-02	EXTERIOR OF BLDG BY CAFE	EXTERIOR FACIA BOARD
T-03	EXTERIOR OF BLDG BY CAFE	EXTERIOR FACIA BOARD
← STOP @ 1st		positive →

**CHAIN OF CUSTODY**Sample By: CHRIS SPARKSDate: 7-3-03Signature: [Signature]Date Shipped: 7-3-03Received By: EMSLDate: 7/3/03 11:30Signature: [Signature]

Shipped Via: \_\_\_\_\_

Recorded By: \_\_\_\_\_


Date: \_\_\_\_\_ Log#: \_\_\_\_\_

Signature: \_\_\_\_\_

Shipped To: \_\_\_\_\_

**ALLIANCE INDIANA, INC.**  
1433 Sadler Circle West Dr.  
Indianapolis, IN 46239  
317/351-5600 Fax 317/351-5610

160304595



Project Name- CHARLESTOWN SR HIGH  
Project Location- EXTERIOR FACIA PANELING  
City/State- ~~IND~~ CHARLESTOWN IN  
Project Number- NGR00A02 Date- 7-3-03  
Samples Collected By- CHRIS SPARKS

SAMPLE I.D. NUMBER	LOCATION OF SAMPLE	DESCRIPTION OF SAMPLE MATERIAL
T-01	EXTERIOR OF BLDG BY CAFE	EXTERIOR FACIA BOARD
T-02	EXTERIOR OF BLDG BY CAFE	EXTERIOR FACIA BOARD
T-03	EXTERIOR OF BLDG BY CAFE	EXTERIOR FACIA BOARD
	← STOP @ 1st	positive →

## CHAIN OF CUSTODY

Sample By: CHRIS SPARKS Received By: EMSL Recorded By: \_\_\_\_\_  
Date: 7-3-03 Date: 7/3/03 11:30 Date: \_\_\_\_\_ Log#: \_\_\_\_\_  
Signature: [Signature] Signature: [Signature] Signature: \_\_\_\_\_  
Date Shipped: 7-3-03 Shipped Via: \_\_\_\_\_ Shipped To: \_\_\_\_\_

## EMSL Analytical

2001 East 52nd St., Indianapolis, IN 46205

Phone: (317) 803-2997 Fax: (317) 803-3047 Email: indianapolislabs@emsl.com

EMSL

Attn: Bill Ogle  
Alliance Indiana, Inc.  
1433 Sadler Circle West Dr.  
Indianapolis, IN 46239

Fax: (317) 351-5610

Phone: (317) 351-5600

Project: NGR 00A02

Customer ID: ALLI65

Customer PO:

Received: 07/03/03 11:30 AM

EMSL Order: 160304595

EMSL Project ID:

Analysis Date: 7/7/2003

### Asbestos Analysis of Bulk Materials via EPA 600/R-93/116 Method using Polarized Light Microscopy

Sample	Location	Appearance	Treatment	Non-Asbestos		Asbestos
				% Fibrous	% Non-Fibrous	% Type
T-01 160304595-0001		White Non-Fibrous Homogeneous	Crushed		25% Quartz 75% Non-fibrous (other)	None Detected
T-02 160304595-0002		White Non-Fibrous Homogeneous	Crushed		25% Quartz 75% Non-fibrous (other)	None Detected
T-03 160304595-0003		White Non-Fibrous Homogeneous	Crushed		25% Quartz 75% Non-fibrous (other)	None Detected

Analyst(s)

Margaret Phillips (3)

RECEIVED  
JUL 11 2003  
BY: *Kw*

*John W. Harkins*

or other approved signatory

It has been known to miss asbestos in a small percentage of samples which contain asbestos. Negative PLM results cannot be guaranteed. Samples reported as <1% or none detected should be tested with TEM. The above test report relates only to the items tested. This report may not be reproduced, except in full, without written approval by EMSL Analytical, Inc. The above test must not be used by the client to claim product endorsement by NVLAP nor any agency of the United States Government.

Analysis performed by EMSL Indianapolis (NVLAP #200188-0)

PLM-1

THIS IS THE LAST PAGE OF THE REPORT.

**ALLIANCE ENVIRONMENTAL GROUP, INC.**

5340 Commerce Circle, Suite E  
Indianapolis, IN 46237  
317/865-3400 Fax 317/865-3401

24 HOUR

Project Name- CHARLESTOWN HIGH SCHOOL

Project Location- EXTERIOR PANELS

City/State- CHARLESTOWN, INDIANA

Project Number- NGR 08A12 Date- 07 DECEMBER 2007

Samples Collected By- BILL OGLE

SAMPLE I.D. NUMBER	LOCATION OF SAMPLE	DESCRIPTION OF SAMPLE MATERIAL
BP-01	EASTERN WING	GRAY CEMENTICIOUS

**CHAIN OF CUSTODY**

Sample By: BILL OGLE Received By: EMSL Recorded By: \_\_\_\_\_  
Date: 07 DECEMBER 2007 Date: 12/10/07 3:15 Date: \_\_\_\_\_ Log#: \_\_\_\_\_  
Signature: Bill Ogle Signature: Justin Brun Signature: \_\_\_\_\_  
Date Shipped: 0 December 2007 Shipped Via: \_\_\_\_\_ Shipped To: \_\_\_\_\_

**ALLIANCE ENVIRONMENTAL GROUP, INC.**

5340 Commerce Circle, Suite E  
Indianapolis, IN 46237  
317/865-3400 Fax 317/865-3401

24 HOUR

160715615

Project Name- CHARLESTOWN HIGH SCHOOL

Project Location- EXTERIOR PANELS

City/State- CHARLESTOWN, INDIANA

Project Number- NGR 08A12 Date- 07 DECEMBER 2007

Samples Collected By- BILL OGLE

SAMPLE I.D. NUMBER	LOCATION OF SAMPLE	DESCRIPTION OF SAMPLE MATERIAL
EP-01	EASTERN WING	GRAY CEMENTICIOUS

**CHAIN OF CUSTODY**

Sample By: BILL OGLE Received By: ERASL Recorded By: \_\_\_\_\_  
Date: 07 DECEMBER 2007 Date: 12/10/07 315 Date: \_\_\_\_\_ Log#: \_\_\_\_\_  
Signature: Bill Ogle Signature: Justin [unclear] Signature: \_\_\_\_\_  
Date Shipped: 0 December 2007 Shipped Via: \_\_\_\_\_ Shipped To: \_\_\_\_\_

RECEIVED DEC 13 2007

Form F-013

**EMSL Analytical**

2001 East 52nd St., Indianapolis, IN 46205

Phone: (317) 803-2997 Fax: (317) 803-3047 Email: [indianapolislab@emsl.com](mailto:indianapolislab@emsl.com)

Attn: **Bill Ogle**  
**Alliance Environmental Group, Inc.**  
**5340 Commerce Circle**  
**Indianapolis, IN 46237**

Fax: (317) 865-3401 Phone: (317) 865-3400  
Project: **NGR 08A12**

Customer ID: ALLI65  
Customer PO:  
Received: 12/10/07 3:17 PM  
EMSL Order: 160715615

EMSL Proj:  
Analysis Date: 12/11/2007  
Report Date: 12/11/2007

### Asbestos Analysis of Bulk Materials via EPA 600/R-93/116 Method using Polarized Light Microscopy

Sample	Location	Appearance	Non-Asbestos		Asbestos
			% Fibrous	% Non-Fibrous	% Type
EP-01 160715615-0001		Gray Non-Fibrous Heterogeneous		80% Non-fibrous (other)	20% Chrysotile

RECEIVED DEC 13 2007  
BQ

Analyst(s)

Melissa Wilson (1)

*Richard Harding*  
Richard Harding, Laboratory Manager  
or other approved signatory

Due to magnification limitations inherent in PLM, asbestos fibers in dimensions below the resolution capability of PLM may not be detected. The limit of detection as stated in the method is 1%. The above test report relates only to the items tested and may not be reproduced in any form without the express written approval of EMSL Analytical, Inc. EMSL's liability is limited to the cost of analysis. EMSL bears no responsibility for sample collection activities or analytical method limitations. Interpretation and use of test results are the responsibility of the client. Samples received in good condition unless otherwise noted. This report must not be used to claim product endorsement by NVLAP or any agency of the U.S. Government.

Analysis performed by EMSL Indianapolis (NVLAP Lab Code 200188-0)

**ALLIANCE ENVIRONMENTAL GROUP, INC.**

5340 Commerce Circle, Suite E

Indianapolis, IN 46237

317/865-3400 Fax 317/865-3401

24 HOUR

Project Name- CHARLESTOWN HIGH SCHOOLProject Location- BUILDING EXTERIORCity/State- CHARLESTOWN, INDIANAProject Number- NGR-08A12 Date- 01 JULY 2008Samples Collected By- BILL OGLE

SAMPLE I.D. NUMBER	LOCATION OF SAMPLE	DESCRIPTION OF SAMPLE MATERIAL
TP-01	EXTERIOR PANEL-EAST SIDE	GRAY CEMENTICIOUS
PL-01	EXTERIOR PANEL-EAST SIDE	WHITE CEMENTICIOUS
PL-02	EXTERIOR PANEL-EAST SIDE	WHITE CEMENTICIOUS

**CHAIN OF CUSTODY**Sample By: BILL OGLEDate: 01 JULY 2008Signature: Bill OgleDate Shipped: 02 July 2008Received By: ENSL Recorded By: \_\_\_\_\_Date: 7-2-08 Date: \_\_\_\_\_ Log#: \_\_\_\_\_Signature: David S. ... Signature: \_\_\_\_\_

Shipped Via: \_\_\_\_\_ Shipped To: \_\_\_\_\_



**ALLIANCE ENVIRONMENTAL GROUP, INC.**

5340 Commerce Circle, Suite E  
Indianapolis, IN 46237  
317/865-3400 Fax 317/865-3401

24 HOUR

160809304

Project Name- CHARLESTOWN HIGH SCHOOL

Project Location- BUILDING EXTERIOR

City/State- CHARLESTOWN, INDIANA

Project Number- NGR-08A12 Date- 01 JULY 2008

Samples Collected By- BILL OGLE

SAMPLE I.D. NUMBER	LOCATION OF SAMPLE	DESCRIPTION OF SAMPLE MATERIAL
TP-01	EXTERIOR PANEL-EAST SIDE	GRAY CEMENTICIOUS
PL-01	EXTERIOR PANEL-EAST SIDE	WHITE CEMENTICIOUS
PL-02	EXTERIOR PANEL-EAST SIDE	WHITE CEMENTICIOUS

**CHAIN OF CUSTODY**

Sample By: BILL OGLE

Date: 01 JULY 2008

Signature: Bill Ogle

Date Shipped: 02 July 2008

Received By: EnSL

Date: 7-2-08

Signature: David B...

Shipped Via: \_\_\_\_\_

Recorded By: \_\_\_\_\_

Date: \_\_\_\_\_ Log#: \_\_\_\_\_

Signature: \_\_\_\_\_

Shipped To: \_\_\_\_\_

RECEIVED JUL 14 2008



## EMSL Analytical

2001 East 52nd St., Indianapolis, IN 46205

Phone: (317) 803-2997 Fax: (317) 803-3047 Email: [indianapolislaboratory@emsl.com](mailto:indianapolislaboratory@emsl.com)

Attn: **Bill Ogle**  
**Alliance Environmental Group, Inc.**  
**5340 Commerce Circle**  
**Indianapolis, IN 46237**

Fax: (317) 865-3401 Phone: (317) 865-3400  
Project: **NGR-08A12**

Customer ID: ALLI65  
Customer PO:  
Received: 07/02/08 11:45 PM  
EMSL Order: 160809304

EMSL Proj:  
Analysis Date: 7/3/2008  
Report Date: 7/3/2008

### Asbestos Analysis of Bulk Materials via EPA 600/R-93/116 Method using Polarized Light Microscopy

Sample	Location	Appearance	Non-Asbestos		Asbestos
			% Fibrous	% Non-Fibrous	% Type
TP-01 160809304-0001		Gray Non-Fibrous Homogeneous	5% Glass	85% Non-fibrous (other)	10% Chrysotile
PL-01 160809304-0002		White Non-Fibrous Homogeneous		60% Non-fibrous (other) 40% Quartz	None Detected
PL-01 160809304-0003		White Non-Fibrous Heterogeneous		40% Non-fibrous (other) 60% Quartz	None Detected

Analyst(s)

Jeffrey Conkel (3)

Richard Harding, Laboratory Manager  
or other approved signatory

Due to magnification limitations inherent in PLM, asbestos fibers in dimensions below the resolution capability of PLM may not be detected. The limit of detection as stated in the method is 1%. The above test report relates only to the items tested and may not be reproduced in any form without the express written approval of EMSL Analytical, Inc. EMSL's liability is limited to the cost of analysis. EMSL bears no responsibility for sample collection activities or analytical method limitations. Interpretation and use of test results are the responsibility of the client. Samples received in good condition unless otherwise noted. This report must not be used to claim product endorsement by NVLAP or any agency of the U.S. Government.

ACCREDITATION: NVLAP Lab Code 200188-0

**ANNUAL NOTIFICATIONS  
ACCREDITATIONS  
TRAINING  
INFORMATION**

Indiana Department of Environmental Management  
100 N. Senate Avenue  
Mail Code 61-52 IGCN 1003  
Indianapolis, IN 46204-2251



April 17, 2014

RECEIVED APR 22 2014

Benjamin S. Hood  
Alliance Environmental Group  
5340 Commerce Circle, Ste E  
Indianapolis IN 46237

Re: Asbestos Inspector # 19A001039

Based upon the review of your license application, the Office of Air Quality has determined that you have fulfilled the requirements of 326 IAC 18 and are eligible for licensing in the following discipline:

**Asbestos Inspector**

Your Asbestos Inspector license is attached below. The license is waterproof and tear resistant. Please sign your license and do not laminate or alter your license in anyway. Your license must be available for review at all times while implementing an asbestos project. This license may be revoked, pursuant to 326 IAC 18-1-7, if you:

- (1) Violate any requirements of these rules (326 IAC 18), 326 IAC 14-10, or any requirement of the Asbestos-Containing Materials in Schools Rule or any other federal, state, or local regulation pertaining to asbestos in buildings or to asbestos projects.
- (2) Falsify information on your application for licensing.
- (3) Fail to meet any qualifications specified in 326-IAC 18-1-4.
- (4) Conduct asbestos project, or related asbestos handling activity, in a manner which is hazardous to the public health.

Your license is valid effective 05/05/2014, and will expire on 05/05/2015, as indicated on your card. We suggest that you attend the required training and submit an application for license renewal early to insure your license does not lapse. NOTE: 326 IAC 18-1-4(h) and 326 IAC 18-1-6(e) require that any individual who has an eighteen (18) month lapse between any two training courses of the same discipline to attend an initial training course for the discipline in which they are seeking a license. In order to avoid re-taking the initial training course you must have attended a refresher in the discipline you are seeking a license within eighteen (18) months from the date of issuance of your last training course certificate.

Office of Air Quality, Asbestos Licensing Section (317) 233-3861



Indiana Dept. of Environmental Management

**Benjamin S. Hood**

Asbestos Inspector License #: 19A001039

Effective: 05/05/2014	Expiration: 05/05/2015
Birth Date: 04/10/1978	Gender: M
Height: 6-00	Eye Color: Brown
Weight: 285	Hair Color: Brown

*NOTICES*

## NOTIFICATION LOG

# GREATER CLARK COUNTY SCHOOLS

**DATE OF NOTIFICATION**

COPY IN BOOK

YEAR

(X)

2009

2010

2011

2012

2013

2014

2015

2016

2017

2018

2019

2020

2021

2022

2023

**2024**

**2025**

2026

2027

2028

2029

2030

## NOTIFICATION LOG

LEA Name - Greater Clark County Schools

<u>Date of Notification</u>	<u>Copy of Notification in Supplemental Book?</u>
<u>1989</u>	
<u>1990</u>	
<u>1991</u>	
<u>1992</u>	
<u>1993</u>	
<u>1994</u>	
<u>1995</u>	✓
<u>1996</u>	✓
<u>1997</u>	✓
<u>1998</u>	✓
<u>1999</u>	✓
<u>2000</u>	✓
<u>2001</u>	✓
<u>2002</u>	✓
<u>2003</u>	✓
<u>2004</u>	✓
<u>2005</u>	✓
<u>2006</u>	✓
<u>2007</u>	✓
<u>2008</u>	✓
<u>2009</u>	✓

March 2015

AHERA ANNUAL NOTICE  
GREATER CLARK COUNTY SCHOOLS

This information is being published to comply with the requirements of 40 CFR 763, Subpart E, Asbestos Containing Materials in Schools. This regulation, commonly known as the "AHERA" rule, requires local education agencies, such as this one, to perform certain tasks in regards to the presence and control of asbestos containing materials in the buildings under the jurisdiction of the local education agency.

These include but are not limited to:

1. Developing an asbestos management plan which is designed to outline procedures and guidelines for the initial inspection, triennial reinspections, and 6 month periodic surveillance of asbestos-containing materials that are present in the buildings.
2. Provide awareness training and additional training to selected school employees.
3. Periodically notify all workers and occupants, or their local guardians, parent teacher organizations, and collective bargaining organizations of the availability of asbestos management plans, the location of same and the times that the plans may be reviewed.

This notification is to advise all patrons, occupants, or their legal guardians, collective bargaining organizations, and parent-teachers organizations, that the asbestos management plans required under this act are available for review upon request. The plans can be viewed by any person during normal business hours of the particular school. Interested parties wishing to inquire about the plans should contact the individual school office. Master copies of the plans for all buildings under the jurisdiction of this local education agency are available in the Auxiliary Services at River Valley Middle School, which is located at 2220 Veteran's Parkway, Jeffersonville, Indiana 47130; telephone number (812) 288-4821. Inquiries regarding any facet of the regulation or the management plans should be directed to Mr. Steve Hobgood at the above telephone number during regular business hours.

Greater Clark County Schools, school facilities, and buildings which contain asbestos-containing materials (ACMs) and must comply with the 40 CFR 763, Subpart E (AHERA) regulations include:

**Jeffersonville, Charlestown and New Washington High Schools; Parkview, River Valley and Charlestown Middle Schools; Wilson, Thomas Jefferson, Northaven, New Washington, Jonathan Jennings, Bridgepoint, Maple, Spring Hill, and Parkwood Elementary Schools, Service Center, Corden Porter Storage, Auto Tech Program- Witten Property, and Corden Porter Center with Gym.**

Listed is a brief description of asbestos projects currently ongoing and completed at our facilities this past school year, as well as activities currently scheduled for the 2015/2016 school year. Detailed reports of each activity will become a part of each school's asbestos management plan and may be reviewed in the school office.

\* The required triennial re-inspection will be performed in April 2016.

\* The required six month periodic surveillance was performed in October 2014.

\* The required six month periodic surveillance activities are scheduled for April and October each year.

School facilities and buildings that are asbestos free and require no surveillance or reinspection are:

**Pleasant Ridge Elementary School, Utica Elementary School, Cordon Porter former Options Building and the Administration Building**



March 2014

AHERA ANNUAL NOTICE  
GREATER CLARK COUNTY SCHOOLS

This information is being published to comply with the requirements of 40 CFR 763, Subpart E, Asbestos Containing Materials in Schools. This regulation, commonly known as the "AHERA" rule, requires local education agencies, such as this one, to perform certain tasks in regards to the presence and control of asbestos containing materials in the buildings under the jurisdiction of the local education agency.

These include but are not limited to:

1. Developing an asbestos management plan which is designed to outline procedures and guidelines for the initial inspection, triennial reinspections, and 6 month periodic surveillance of asbestos-containing materials that are present in the buildings.
2. Provide awareness training and additional training to selected school employees.
3. Periodically notify all workers and occupants, or their local guardians, parent teacher organizations, and collective bargaining organizations of the availability of asbestos management plans, the location of same and the times that the plans may be reviewed.

This notification is to advise all patrons, occupants, or their legal guardians, collective bargaining organizations, and parent-teachers organizations, that the asbestos management plans required under this act are available for review upon request. The plans can be viewed by any person during normal business hours of the particular school. Interested parties wishing to inquire about the plans should contact the individual school office. Master copies of the plans for all buildings under the jurisdiction of this local education agency are available in the Auxiliary Services building, which is located at 2220 Veteran's Parkway, Jeffersonville, Indiana 47130; telephone number (812) 288-4821. Inquiries regarding any facet of the regulation or the management plans should be directed to Mr. Steve Hobgood at the above telephone number during regular business hours.

Greater Clark County Schools, school facilities, and buildings which contain asbestos-containing materials (ACMs) and must comply with the 40 CFR 763, Subpart E (AHERA) regulations include:

**Jeffersonville, Charlestown and New Washington High Schools; Parkview, River Valley and Charlestown Middle Schools; Wilson, Thomas Jefferson, Northaven, New Washington, Jonathan Jennings, Bridgepoint, Maple, Spring Hill, and Parkwood Elementary Schools, the Auxiliary Services Building, Service Center, Corden Porter Storage, and Corden Porter Center with Gym.**

Listed is a brief description of asbestos projects currently ongoing and completed at our facilities this past school year, as well as activities currently scheduled for the 2014/2015 school year. Detailed reports of each activity will become a part of each school's asbestos management plan and may be reviewed in the school office.

\* The required triennial re-inspection will be performed in April 2013.

\* The required six month periodic surveillance was performed in October 2013.

\* The required six month periodic surveillance activities are scheduled for April and October each year.

School facilities and buildings that are asbestos free and require no surveillance or reinspection are:

**Pleasant Ridge Elementary School, Utica Elementary School, Cordon Porter former Options Building and the Administration Building**

March 2013

AHERA ANNUAL NOTICE  
GREATER CLARK COUNTY SCHOOLS

This information is being published to comply with the requirements of 40 CFR 763, Subpart E, Asbestos Containing Materials in Schools. This regulation, commonly known as the "AHERA" rule, requires local education agencies, such as this one, to perform certain tasks in regards to the presence and control of asbestos containing materials in the buildings under the jurisdiction of the local education agency.

These include but are not limited to:

1. Developing an asbestos management plan which is designed to outline procedures and guidelines for the initial inspection, triennial reinspections, and 6 month periodic surveillance of asbestos-containing materials that are present in the buildings.
2. Provide awareness training and additional training to selected school employees.
3. Periodically notify all workers and occupants, or their local guardians, parent teacher organizations, and collective bargaining organizations of the availability of asbestos management plans, the location of same and the times that the plans may be reviewed.

This notification is to advise all patrons, occupants, or their legal guardians, collective bargaining organizations, and parent-teachers organizations, that the asbestos management plans required under this act are available for review upon request. The plans can be viewed by any person during normal business hours of the particular school. Interested parties wishing to inquire about the plans should contact the individual school office. Master copies of the plans for all buildings under the jurisdiction of this local education agency are available in the Auxiliary Services building, which is located at 2710 E 10<sup>th</sup> Street, Jeffersonville, Indiana 47130; telephone number (812) 288-4821. Inquiries regarding any facet of the regulation or the management plans should be directed to Mr. Steve Hobgood at the above telephone number during regular business hours.

Greater Clark County Schools, school facilities, and buildings which contain asbestos-containing materials (ACMs) and must comply with the 40 CFR 763, Subpart E (AHERA) regulations include:

**Jeffersonville, Charlestown and New Washington High Schools; Parkview, River Valley and Charlestown Middle Schools; Wilson, Thomas Jefferson, Northaven, New Washington, Jonathan Jennings, Bridgepoint, Maple, Spring Hill, and Parkwood Elementary Schools, the Auxiliary Services Building, Service Center, Corden Porter Storage, and Corden Porter Center with Gym.**

Listed is a brief description of asbestos projects currently ongoing and completed at our facilities this past school year, as well as activities currently scheduled for the 2013/2014 school year. Detailed reports of each activity will become a part of each school's asbestos management plan and may be reviewed in the school office.

- \* The required triennial re-inspection will be performed in April 2013.
- \* The required six month periodic surveillance was performed in October 2012.
- \* The required six month periodic surveillance activities are scheduled for April and October each year.
- \* Projects completed in 2012: Parkview Middle School.

School facilities and buildings that are asbestos free and require no surveillance or reinspection are:

**Pleasant Ridge Elementary School, Utica Elementary School, Cordon Porter former Options Building and the Administration Building**

March 2012

AHERA ANNUAL NOTICE  
GREATER CLARK COUNTY SCHOOLS

This information is being published to comply with the requirements of 40 CFR 763, Subpart E, Asbestos Containing Materials in Schools. This regulation, commonly known as the "AHERA" rule, requires local education agencies, such as this one, to perform certain tasks in regards to the presence and control of asbestos containing materials in the buildings under the jurisdiction of the local education agency.

These include but are not limited to:

1. Developing an asbestos management plan which is designed to outline procedures and guidelines for the initial inspection, triennial reinspections, and 6 month periodic surveillance of asbestos-containing materials that are present in the buildings.
2. Provide awareness training and additional training to selected school employees.
3. Periodically notify all workers and occupants, or their local guardians, parent teacher organizations, and collective bargaining organizations of the availability of asbestos management plans, the location of same and the times that the plans may be reviewed.

This notification is to advise all patrons, occupants, or their legal guardians, collective bargaining organizations, and parent-teachers organizations, that the asbestos management plans required under this act are available for review upon request. The plans can be viewed by any person during normal business hours of the particular school. Interested parties wishing to inquire about the plans should contact the individual school office. Master copies of the plans for all buildings under the jurisdiction of this local education agency are available in the Auxiliary Services building, which is located at 2710 E 10<sup>th</sup> Street, Jeffersonville, Indiana 47130; telephone number (812) 288-4821. Inquiries regarding any facet of the regulation or the management plans should be directed to Mr. Steve Hobgood at the above telephone number during regular business hours.

Greater Clark County Schools, school facilities, and buildings which contain asbestos-containing materials (ACMs) and must comply with the 40 CFR 763, Subpart E (AHERA) regulations include:

**Jeffersonville, Charlestown and New Washington High Schools; Parkview, River Valley and Charlestown Middle Schools; Wilson, Thomas Jefferson, Northaven, New Washington, Jonathan Jennings, Bridgepoint, Maple, Spring Hill, and Parkwood Elementary Schools, the Auxiliary Services Building, Service Center, and Cordon Porter Center with Gym.**

Listed is a brief description of asbestos projects currently ongoing and completed at our facilities this past school year, as well as activities currently scheduled for the 2012/2013 school year. Detailed reports of each activity will become a part of each school's asbestos management plan and may be reviewed in the school office.

- \* The required triennial re-inspection will be performed in June 2013.
- \* The required six month periodic surveillance was performed in December 2011.
- \* The required six month periodic surveillance activities are scheduled for June and December each year.
- \* Projects completed in 2011: Options building and Parkwood Elementary.
- \* Projects scheduled for 2012: Parkview Middle School and Bridgepoint Elementary.
- \* Cordon Porter storage building was sold in 2012.

School facilities and buildings that are asbestos free and require no surveillance or reinspection are:

**Pleasant Ridge Elementary School, Utica Elementary School, Cordon Porter former Options Building and the Administration Building**

**AHERA ANNUAL NOTICE  
GREATER CLARK COUNTY SCHOOLS**

This information is being published to comply with the requirements of 40 CFR 763 Subpart E Asbestos Containing Materials in Schools. This regulation, commonly known as the "AHERA" rule, requires local education agencies, such as this one, to perform certain tasks in regards to the presence and control of asbestos containing materials in the buildings under the jurisdiction of the local education agency.

These include but are not limited to:

1. Developing an asbestos management plan which is designed to outline procedures and guidelines for the inspection, reinspection and periodic surveillance of asbestos containing materials that are present in the buildings.
2. Provide awareness training and additional training to selected school employees.
3. Periodically notify all workers and occupants, or their local guardians, parent teacher organizations, and collective bargaining organizations of the availability of asbestos management plans, the location of same and the times that the plans may be reviewed.

This notification is to advise all patrons, occupants, or their legal guardians, collective bargaining organizations, and parent-teachers organizations, that the asbestos management plans required under this act are available for review upon request. A copy of the plans for all buildings under the jurisdiction of this local education agency are available in the Auxillary Services building, which is located at 2710 E 10<sup>th</sup> Street, Jeffersonville, Indiana 47130; telephone number (812) 288-4821. Plans for individual schools and other buildings are located in the administration office of each school. The plans can be viewed by any person during normal business hours of the particular school. Interested parties wishing to inquire about the hours and times that the plans are available should call the above number.

At this time, the management plans can provide information regarding inspections, response actions, and post-response action activities, including periodic reinspection and surveillance activities that are planned or in progress. Inquiries regarding any facet of the regulation or the management plans should be directed to Mr. Steve Hobgood at the above telephone number during regular business hours.

Listed is a brief description of asbestos work that has been completed in our schools this year. Detailed reports have become part of each school's asbestos management plan and may be reviewed in the school office.

**Jeffersonville, Charlestown and New Washington High Schools; Parkview, River Valley and Charlestown Middle Schools; Wilson, Thomas Jefferson, Northaven, New Washington, Jonathan Jennings, Bridgepoint, Maple, Spring Hill, and Parkwood Elementary Schools; the former Administration Building, Service Center, Options and Corden Porter Center Buildings and Alternative School-**

- \* The required triennial reinspection will be performed in June 2013.
- \* The required six month periodic surveillance was performed in December 2010.
- \* The next scheduled activity is the required six month periodic surveillance in June 2011.
- \* Charlestown High School asbestos removal project was completed in 2010.
- \* Options Building is under renovation in 2011.
- \* Parkwood Elementary is under renovation in 2011.

**Pleasant Ridge Elementary School, Utica Elementary School and the (New) Administration Building**  
– These buildings are asbestos free and **Riverside Elementary** was demolished in 2006.  
No surveillances or reinspections are required for these buildings.

March 2011

**AHERA ANNUAL NOTICE  
GREATER CLARK COUNTY SCHOOLS**

This information is being published to comply with the requirements of 40 CFR 763 Subpart E Asbestos Containing Materials in Schools. This regulation, commonly known as the "AHERA" rule, requires local education agencies, such as this one, to perform certain tasks in regards to the presence and control of asbestos containing materials in the buildings under the jurisdiction of the local education agency.

These include but are not limited to:

1. Developing an asbestos management plan which is designed to outline procedures and guidelines for the inspection, reinspection and periodic surveillance of asbestos containing materials that are present in the buildings.
2. Provide awareness training and additional training to selected school employees.
3. Periodically notify all workers and occupants, or their local guardians, parent teacher organizations, and collective bargaining organizations of the availability of asbestos management plans, the location of same and the times that the plans may be reviewed.

This notification is to advise all patrons, occupants, or their legal guardians, collective bargaining organizations, and parent-teachers organizations, that the asbestos management plans required under this act are available for review upon request. A copy of the plans for all buildings under the jurisdiction of this local education agency are available in the Auxillary Services building, which is located at 2710 E 10<sup>th</sup> Street, Jeffersonville, Indiana 47130; telephone number (812) 288-4821. Plans for individual schools and other buildings are located in the administration office of each school. The plans can be viewed by any person during normal business hours of the particular school. Interested parties wishing to inquire about the hours and times that the plans are available should call the above number.

At this time, the management plans can provide information regarding inspections, response actions, and post-response action activities, including periodic reinspection and surveillance activities that are planned or in progress. Inquiries regarding any facet of the regulation or the management plans should be directed to Mr. Steve Hobgood at the above telephone number during regular business hours.

Listed is a brief description of asbestos work that has been completed in our schools this year. Detailed reports have become part of each school's asbestos management plan and may be reviewed in the school office.

**Jeffersonville, Charlestown and New Washington High Schools; Parkview, River Valley and Charlestown Middle Schools; Wilson, Thomas Jefferson, Northaven, New Washington, Jonathan Jennings, Bridgepoint, Maple, Spring Hill, and Parkwood Elementary Schools; the former Administration Building, Service Center, and Corden Porter Center Buildings -**

- \* The required triennial reinspection will be performed in June 2010.
  - \* The required six month periodic surveillance was performed in December 2009.
  - \* The next scheduled activity is the required six month periodic surveillance in December 2010.
- Charlestown High School is an ongoing asbestos removal project which will be complete prior to partial demolition.

**Pleasant Ridge Elementary School, Utica Elementary School and the (New) Administration Building -**  
These buildings are asbestos free and Riverside Elementary was demolished in 2006.  
No surveillances or reinspections are required for these buildings.

March 2010

**AHERA ANNUAL NOTICE  
GREATER CLARK COUNTY SCHOOLS**

This information is being published to comply with the requirements of 40 CFR 763 Subpart E Asbestos Containing Materials in Schools. This regulation, commonly known as the "AHERA" rule, requires local education agencies, such as this one, to perform certain tasks in regards to the presence and control of asbestos containing materials in the buildings under the jurisdiction of the local education agency.

These include but are not limited to:

1. Developing an asbestos management plan which is designed to outline procedures and guidelines for the inspection, reinspection and periodic surveillance of asbestos containing materials that are present in the buildings.
2. Provide awareness training and additional training to selected school employees.
3. Periodically notify all workers and occupants, or their local guardians, parent teacher organizations, and collective bargaining organizations of the availability of asbestos management plans, the location of same and the times that the plans may be reviewed.

This notification is to advise all patrons, occupants, or their legal guardians, collective bargaining organizations, and parent-teachers organizations, that the asbestos management plans required under this act are available for review upon request. A copy of the plans for all buildings under the jurisdiction of this local education agency are available in the Service Center building, which is located at 301 E. 11th Street, Jeffersonville, Indiana 47130; telephone number (812) 288-4821. Plans for individual schools and other buildings are located in the administration office of each school. The plans can be viewed by any person during normal business hours of the particular school. Interested parties wishing to inquire about the hours and times that the plans are available should call the above number.

At this time, the management plans can provide information regarding inspections, response actions, and post-response action activities, including periodic reinspection and surveillance activities that are planned or in progress. Inquiries regarding any facet of the regulation or the management plans should be directed to Mr. Steve Hobgood at the above telephone number during regular business hours.

Listed is a brief description of asbestos work that has been completed in our schools this year. Detailed reports have become part of each school's asbestos management plan and may be reviewed in the school office.

**Jeffersonville, Charlestown and New Washington High Schools; Parkview, River Valley and Charlestown Middle Schools; Wilson, Thomas Jefferson, Northaven, New Washington, Jonathan Jennings, Bridgepoint, Maple, Spring Hill, and Parkwood Elementary Schools; the former Administration Building, Service Center, and Corden Porter Center Buildings -**

- \* The required triennial reinspection was performed in June 2007.
- \* The required six month periodic surveillance was performed in December 2008.
- \* The next scheduled activities are the required six month periodic surveillance in June 2009 and Dec 2009. Charlestown High School has undergone an asbestos removal project prior to partial demolition.

**Pleasant Ridge Elementary School, Utica Elementary School and the (New) Administration Building -**  
These buildings are asbestos free and **Riverside Elementary** was demolished in 2006.  
No surveillances or re-inspections are required for these buildings.

April 2009

**AHERA ANNUAL NOTICE  
GREATER CLARK COUNTY SCHOOLS**

This information is being published to comply with the requirements of 40 CFR 763 Subpart E asbestos containing materials in schools. This regulation, commonly known as the "AHERA" rule, requires local education agencies, such as this one, to perform certain tasks in regards to the presence and control of asbestos containing materials in the buildings under the jurisdiction of the local education agency.

These include but are not limited to:

1. Developing an asbestos management plan which is designed to outline procedures and guidelines for the inspection, reinspection and periodic surveillance of asbestos containing materials that are present in the buildings.
2. Provide awareness training and additional training to selected school employees.
3. Periodically notify all workers and occupants, or their local guardians, parent teacher organizations, and collective bargaining organizations of the availability of asbestos management plans, the location of same and the times that the plans may be reviewed.

This notification is to advise all patrons, occupants, or their legal guardians, collective bargaining organizations, and parent-teachers organizations, that the asbestos management plans required under this act are available for review upon request. A copy of the plans for all buildings under the jurisdiction of this local education agency are available in the Service Center building, which is located at 301 E. 11th Street, Jeffersonville, Indiana 47130; telephone number (812)288-4821. Plans for individual schools and other buildings are located in the administration office of each school. The plans can be viewed by any person during normal business hours of the particular school. Interested parties wishing to inquire about the hours and times that the plans are available should call the above number.

At this time, the management plans can provide information regarding inspections, response actions, and post-response action activities, including periodic reinspection and surveillance activities that are planned or in progress. Inquiries regarding any facet of the regulation or the management plans should be directed to Mr. Steve Hobgood at the above telephone number during regular business hours.

Listed is a brief description of asbestos work that has been completed in our schools this year. Detailed reports have become part of each school's asbestos management plan and may be reviewed in the school office.

**Jeffersonville, Charlestown, and New Washington High Schools; Parkview, Charlestown, and River Valley Middle Schools; Wilson, Thomas Jefferson, Northaven, New Washington, Jonathan Jennings, Bridgepoint, Maple, Spring Hill, and Parkwood Elementary Schools; the former Administration Building, Service Center, and Corden Porter Center Buildings -**

- \* The required triennial reinspection was performed in June 2007.
- \* The required six month periodic surveillance was performed in December 2007.
- \* The next scheduled activities are the required six month periodic surveillance in June 2008 and Dec 2008.

**Pleasant Ridge Elementary School, Utica Elementary School and the (New) Administration Building -** These buildings are asbestos free. **Riverside Elementary** was Demolition in 2006. No surveillances or reinspections are required.

April 2008

**AHERA ANNUAL NOTICE  
GREATER CLARK COUNTY SCHOOLS**

This information is being published to comply with the requirements of 40 CFR 763 Subpart E asbestos containing materials in schools. This regulation, commonly known as the "AHERA" rule, requires local education agencies, such as this one, to perform certain tasks in regards to the presence and control of asbestos containing materials in the buildings under the jurisdiction of the local education agency.

These include but are not limited to:

1. Developing an asbestos management plan which is designed to outline procedures and guidelines for the inspection, reinspection and periodic surveillance of asbestos containing materials that are present in the buildings.
2. Provide awareness training and additional training to selected school employees.
3. Periodically notify all workers and occupants, or their local guardians, parent teacher organizations, and collective bargaining organizations of the availability of asbestos management plans, the location of same and the times that the plans may be reviewed.

This notification is to advise all patrons, occupants, or their legal guardians, collective bargaining organizations, and parent-teachers organizations, that the asbestos management plans required under this act are available for review upon request. A copy of the plans for all buildings under the jurisdiction of this local education agency are available in the Service Center building, which is located at 301 E. 11th Street, Jeffersonville, Indiana 47130; telephone number 288-4821. Plans for individual schools and other buildings are located in the administration office of each school. The plans can be viewed by any person during normal business hours of the particular school. Interested parties wishing to inquire about the hours and times that the plans are available should call the above number.

At this time, the management plans can provide information regarding inspections, response actions, and post-response action activities, including periodic reinspection and surveillance activities that are planned or in progress. Inquiries regarding any facet of the regulation or the management plans should be directed to Mr. Chuck Graves at the above telephone number during regular business hours.

Listed is a brief description of asbestos work that has been completed in our schools this year. Detailed reports have become part of each school's asbestos management plan and may be reviewed in the school office.

**Jeffersonville, Charlestown, and New Washington High Schools; Parkview, Charlestown, and River Valley Middle Schools; Wilson, Thomas Jefferson, Northaven, New Washington, Jonathan Jennings, Bridgepoint, Maple, Spring Hill, and Parkwood Elementary Schools; the former Administration Building, Service Center, and Corden Porter Center Buildings -**

- \* The required six month periodic surveillance was performed in June 2006.
- \* The required six month periodic surveillance was performed in December 2006.
- \* The next scheduled activities are the required six month periodic surveillance in June 2007 and Dec 2007.

**Pleasant Ridge Elementary School, Utica Elementary School and the (New) Administration Building –** These buildings are asbestos free. **Riverside Elementary** was Demolition in 2006. No surveillances or reinspections are required.

March 2007



**AHERA ANNUAL NOTICE  
GREATER CLARK COUNTY SCHOOLS**

This information is being published to comply with the requirements of 40 CFR 763 Subpart E asbestos containing materials in schools. This regulation, commonly known as the "AHERA" rule, requires local education agencies, such as this one, to perform certain tasks in regards to the presence and control of asbestos containing materials in the buildings under the jurisdiction of the local education agency.

These include but are not limited to:

1. Developing an asbestos management plan which is designed to outline procedures and guidelines for the inspection, reinspection and periodic surveillance of asbestos containing materials that are present in the buildings.
2. Provide awareness training and additional training to selected school employees.
3. Periodically notify all workers and occupants, or their local guardians, parent teacher organizations, and collective bargaining organizations of the availability of asbestos management plans, the location of same and the times that the plans may be reviewed.

This notification is to advise all patrons, occupants, or their legal guardians, collective bargaining organizations, and parent-teachers organizations, that the asbestos management plans required under this act are available for review upon request. A copy of the plans for all buildings under the jurisdiction of this local education agency are available in the Service Center building, which is located at 301 E. 11th Street, Jeffersonville, Indiana 47130; telephone number 288-4821. Plans for individual schools and other buildings are located in the administration office of each school. The plans can be viewed by any person during normal business hours of the particular school. Interested parties wishing to inquire about the hours and times that the plans are available should call the above number.

At this time, the management plans can provide information regarding inspections, response actions, and post-response action activities, including periodic reinspection and surveillance activities that are planned or in progress. Inquiries regarding any facet of the regulation or the management plans should be directed to Mr. Chuck Graves at the above telephone number during regular business hours.

Listed is a brief description of asbestos work that has been completed in our schools this year. Detailed reports have become part of each school's asbestos management plan and may be reviewed in the school office.

**Jeffersonville, Charlestown, and New Washington High Schools; Parkview, Charlestown, and River Valley Middle Schools; Wilson, Thomas Jefferson, Northaven, New Washington, Jonathan Jennings, Bridgepoint, Maple, Riverside, Spring Hill, and Parkwood Elementary Schools; the former Administration Building, Service Center, and Corden Porter Center Buildings -**

- \* The required triennial reinspection was performed in June 2005.
- \* The required six month periodic surveillance was performed in December 2005.
- \* The next scheduled activities are the required six month periodic surveillance in June 2006 and Dec 2006.

**Pleasant Ridge Elementary School, Utica Elementary School and the (New) Administration Building -**  
These buildings are asbestos free. No surveillances or reinspections are required.

March 2006

**AHERA Annual Notice  
GREATER CLARK COUNTY SCHOOLS**

This information is being published to comply with the requirements of 40 CFR 763 Subpart E asbestos containing materials in schools. This regulation, commonly known as the "AHERA" rule, requires local education agencies, such as this one, to perform certain tasks in regards to the presence and control of asbestos containing materials in the buildings under the jurisdiction of the local education agency.

These include but are not limited to:

1. Developing an asbestos management plan which is designed to outline procedures and guidelines for the inspection, reinspection and periodic surveillance of asbestos containing materials that are present in the buildings.
2. Provide awareness training and additional training to selected school employees.
3. Periodically notify all workers and occupants, or their local guardians, parent teacher organizations, and collective bargaining organizations of the availability of asbestos management plans, the location of same and the times that the plans may be reviewed.

This notification is to advise all patrons, occupants, or their legal guardians, collective bargaining organizations, and parent-teachers organizations, that the asbestos management plans required under this act are available for review upon request. A copy of the plans for all buildings under the jurisdiction of this local education agency are available in the Service Center building, which is located at 301 E. 11th Street, Jeffersonville, Indiana 47130; telephone number 288-4821. Plans for individual schools and other buildings are located in the administration office of each school. The plans can be viewed by any person during normal business hours of the particular school. Interested parties wishing to inquire about the hours and times that the plans are available should call the above number.

At this time, the management plans can provide information regarding inspections, response actions, and post-response action activities, including periodic reinspection and surveillance activities that are planned or in progress. Inquiries regarding any facet of the regulation or the management plans should be directed to Mr. Chuck Graves at the above telephone number during regular business hours.

Listed is a brief description of asbestos work that has been completed in our schools this year. Detailed reports have become part of each school's asbestos management plan and may be reviewed in the school office.

**Jeffersonville, Charlestown, and New Washington High Schools; Parkview, Charlestown, and River Valley Middle Schools; Wilson, Thomas Jefferson, Northaven, New Washington, Jonathan Jennings, Bridgepoint, Maple, Riverside, Spring Hill, and Parkwood Elementary Schools; the former Administration Building, Service Center, and Corden Porter Center Buildings -**

- \* The required triennial reinspection was performed in June 2004.
- \* The required six month periodic surveillance was performed in December 2004.
- \* The next scheduled activities are the required six month periodic surveillance in June 2005 and December 2005.

**Pleasant Ridge Elementary School, Utica Elementary School and the (New) Administration Building -**

- \* These buildings are asbestos free. No surveillances or reinspections are required.

AHERA Annual Notice  
GREATER CLARK COUNTY SCHOOLS

This information is being published to comply with the requirements of 40 CFR 763 Subpart E asbestos containing materials in schools. This regulation, commonly known as the "AHERA" rule, requires local education agencies, such as this one, to perform certain tasks in regards to the presence and control of asbestos containing materials in the buildings under the jurisdiction of the local education agency.

These include but are not limited to:

1. Developing an asbestos management plan which is designed to outline procedures and guidelines for the inspection, reinspection and periodic surveillance of asbestos containing materials that are present in the buildings.
2. Provide awareness training and additional training to selected school employees.
3. Periodically notify all workers and occupants, or their local guardians, parent teacher organizations, and collective bargaining organizations of the availability of asbestos management plans, the location of same and the times that the plans may be reviewed.

This notification is to advise all patrons, occupants, or their legal guardians, collective bargaining organizations, and parent-teachers organizations, that the asbestos management plans required under this act are available for review upon request. A copy of the plans for all buildings under the jurisdiction of this local education agency are available in the Service Center building, which is located at 301 E. 11th Street, Jeffersonville, Indiana 47130; telephone number 288-4821. Plans for individual schools and other buildings are located in the administration office of each school. The plans can be viewed by any person during normal business hours of the particular school. Interested parties wishing to inquire about the hours and times that the plans are available should call the above number.

At this time, the management plans can provide information regarding inspections, response actions, and post-response action activities, including periodic reinspection and surveillance activities that are planned or in progress. Inquiries regarding any facet of the regulation or the management plans should be directed to Mr. Tony Nauert at the above telephone number during regular business hours.

Listed is a brief description of asbestos work that has been completed in our schools this year. Detailed reports have become part of each school's asbestos management plan and may be reviewed in the school office.

**Jeffersonville, Charlestown, and New Washington High Schools; Parkview, Charlestown, and River Valley Middle Schools; Wilson, Thomas Jefferson, Northaven, New Washington, Jonathan Jennings, Bridgepoint, Maple, Riverside, Spring Hill, and Parkwood Elementary Schools; the former Administration Building, Service Center, and Corden Porter Center Buildings -**

- \* The required six month periodic surveillance was performed in June 2003.
- \* The required six month periodic surveillance was performed in December 2003.
- \* The next scheduled activities are the required triennial reinspection in June 2004 and a required six month periodic surveillance in December 2004.

**Pleasant Ridge Elementary School, Utica Elementary School and the (New) Administration Building -**

- \* These buildings are asbestos free. No surveillances or reinspections are required.

**AHERA Annual Notice  
GREATER CLARK COUNTY SCHOOLS**

This information is being published to comply with the requirements of 40 CFR 763 Subpart E asbestos containing materials in schools. This regulation, commonly known as the "AHERA" rule, requires local education agencies, such as this one, to perform certain tasks in regards to the presence and control of asbestos containing materials in the buildings under the jurisdiction of the local education agency.

These include but are not limited to:

1. Developing an asbestos management plan which is designed to outline procedures and guidelines for the inspection, reinspection and periodic surveillance of asbestos containing materials that are present in the buildings.
2. Provide awareness training and additional training to selected school employees.
3. Periodically notify all workers and occupants, or their local guardians, parent teacher organizations, and collective bargaining organizations of the availability of asbestos management plans, the location of same and the times that the plans may be reviewed.

This notification is to advise all patrons, occupants, or their legal guardians, collective bargaining organizations, and parent-teachers organizations, that the asbestos management plans required under this act are available for review upon request. A copy of the plans for all buildings under the jurisdiction of this local education agency are available in the Service Center building, which is located at 301 E. 11th Street, Jeffersonville, Indiana 47130; telephone number 288-4821. Plans for individual schools and other buildings are located in the administration office of each school. The plans can be viewed by any person during normal business hours of the particular school. Interested parties wishing to inquire about the hours and times that the plans are available should call the above number.

At this time, the management plans can provide information regarding inspections, response actions, and post-response action activities, including periodic reinspection and surveillance activities that are planned or in progress. Inquiries regarding any facet of the regulation or the management plans should be directed to Mr. Tony Nauert at the above telephone number during regular business hours.

Listed is a brief description of asbestos work that has been completed in our schools this year. Detailed reports have become part of each school's asbestos management plan and may be reviewed in the school office.

**Jeffersonville, Charlestown, and New Washington High Schools; Parkview, Charlestown, and River Valley Middle Schools; Wilson, Thomas Jefferson, Northaven, New Washington, Jonathan Jennings, Bridgepoint, Maple, Riverside, Spring Hill, and Parkwood Elementary Schools; the former Administration Building, Service Center, and Corden Porter Center Buildings -**

- \* The required six month periodic surveillance was performed in June 2002.
- \* The required six month periodic surveillance was performed in December 2002.
- \* The next scheduled activity is the required periodic surveillance in June 2003.

**Pleasant Ridge Elementary School, Utica Elementary School and the (New) Administration Building -**

- \* These buildings are asbestos free. No surveillances or reinspections are required.

May 2003

AHERA Annual Notice  
GREATER CLARK COUNTY SCHOOLS

This information is being published to comply with the requirements of 40 CFR 763 Subpart E asbestos containing materials in schools. This regulation, commonly known as the "AHERA" rule, requires local education agencies, such as this one, to perform certain tasks in regards to the presence and control of asbestos containing materials in the buildings under the jurisdiction of the local education agency.

These include but are not limited to:

1. Developing an asbestos management plan which is designed to outline procedures and guidelines for the inspection, reinspection and periodic surveillance of asbestos containing materials that are present in the buildings.
2. Provide awareness training and additional training to selected school employees.
3. Periodically notify all workers and occupants, or their local guardians, parent teacher organizations, and collective bargaining organizations of the availability of asbestos management plans, the location of same and the times that the plans may be reviewed.

This notification is to advise all patrons, occupants, or their legal guardians, collective bargaining organizations, and parent-teachers organizations, that the asbestos management plans required under this act are available for review upon request. A copy of the plans for all buildings under the jurisdiction of this local education agency are available in the Service Center building, which is located at 301 E. 11th Street, Jeffersonville, Indiana 47130; telephone number 288-4821. Plans for individual schools and other buildings are located in the administration office of each school. The plans can be viewed by any person during normal business hours of the particular school. Interested parties wishing to inquire about the hours and times that the plans are available should call the above number.

At this time, the management plans can provide information regarding inspections, response actions, and post-response action activities, including periodic reinspection and surveillance activities that are planned or in progress. Inquiries regarding any facet of the regulation or the management plans should be directed to Mr. Tony Nauert at the above telephone number during regular business hours.

Listed is a brief description of asbestos work that has been completed in our schools this year. Detailed reports have become part of each school's asbestos management plan and may be reviewed in the school office.

**Jeffersonville, Charlestown, and New Washington High Schools; Parkview, Charlestown, and River Valley Middle Schools; Wilson, Thomas Jefferson, Northaven, New Washington, Jonathan Jennings, Bridgepoint, Maple, Riverside, Spring Hill, and Parkwood Elementary Schools; the Administration Building, Service Center, and Corden Porter Center Buildings -**

- \* The required triennial reinspection was performed in July 2001.
- \* The required six month periodic surveillance was performed in December 2001.
- \* The next scheduled activities are the required periodic surveillances in June 2002 and December 2002.

**Pleasant Ridge Elementary School and (New) Utica Elementary School -**

- \* These buildings are asbestos free. No surveillances or reinspections are required.

**(Old) Utica Elementary School -**

- \* In accordance with information collected from the GCCS this building has been deeded to the town of Utica. No further AHERA periodic surveillances or triennial reinspections will be conducted by the designated person.

AHERA Annual Notice  
GREATER CLARK COUNTY SCHOOLS

This information is being published to comply with the requirements of 40 CFR 763 Subpart E asbestos containing materials in schools. This regulation, commonly known as the "AHERA" rule, requires local education agencies, such as this one, to perform certain tasks in regards to the presence and control of asbestos containing materials in the buildings under the jurisdiction of the local education agency.

These include but are not limited to:

1. Developing an asbestos management plan which is designed to outline procedures and guidelines for the inspection, reinspection and periodic surveillance of asbestos containing materials that are present in the buildings.
2. Provide awareness training and additional training to selected school employees.
3. Periodically notify all workers and occupants, or their local guardians, parent teacher organizations, and collective bargaining organizations of the availability of asbestos management plans, the location of same and the times that the plans may be reviewed.

This notification is to advise all patrons, occupants, or their legal guardians, collective bargaining organizations, and parent-teachers organizations, that the asbestos management plans required under this act are available for review upon request. A copy of the plans for all buildings under the jurisdiction of this local education agency are available in the Service Center building, which is located at 301 E. 11th Street, Jeffersonville, Indiana 47130; telephone number 288-4821. Plans for individual schools and other buildings are located in the administration office of each school. The plans can be viewed by any person during normal business hours of the particular school. Interested parties wishing to inquire about the hours and times that the plans are available should call the above number.

At this time, the management plans can provide information regarding inspections, response actions, and post-response action activities, including periodic reinspection and surveillance activities that are planned or in progress. Inquiries regarding any facet of the regulation or the management plans should be directed to Mr. Tony Nauert at the above telephone number during regular business hours.

Listed is a brief description of asbestos work that has been completed in our schools this year. Detailed reports have become part of each school's asbestos management plan and may be reviewed in the school office.

**Jeffersonville, Charlestown, and New Washington High Schools; Parkview, Charlestown, and River Valley Middle Schools; Wilson, Thomas Jefferson, Northaven, (Old) Utica, New Washington, Jonathan Jennings, Bridgepoint, Maple, Riverside, Spring Hill, and Parkwood Elementary Schools; the Administration Building, Service Center, and Corden Porter Center -**

- \* The required six month periodic surveillance was performed in June 2000.
- \* The required six month periodic surveillance was performed in January 2001.
- \* The next scheduled activity is a required triennial reinspection in June 2001.

**Pleasant Ridge Elementary School and (New) Utica Elementary School -**

- \* This building is asbestos free. No surveillances or reinspections are required.

June 2001

AHERA Annual Notice  
GREATER CLARK COUNTY SCHOOLS

This information is being published to comply with the requirements of 40 CFR 763 Subpart E asbestos containing materials in schools. This regulation, commonly known as the "AHERA" rule, requires local education agencies, such as this one, to perform certain tasks in regards to the presence and control of asbestos containing materials in the buildings under the jurisdiction of the local education agency.

These include but are not limited to:

1. Developing an asbestos management plan which is designed to outline procedures and guidelines for the inspection, reinspection and periodic surveillance of asbestos containing materials that are present in the buildings.
2. Provide awareness training and additional training to selected school employees.
3. Periodically notify all workers and occupants, or their local guardians, parent teacher organizations, and collective bargaining organizations of the availability of asbestos management plans, the location of same and the times that the plans may be reviewed.

This notification is to advise all patrons, occupants, or their legal guardians, collective bargaining organizations, and parent-teachers organizations, that the asbestos management plans required under this act are available for review upon request. A copy of the plans for all buildings under the jurisdiction of this local education agency are available in the Service Center building, which is located at 301 E. 11th Street, Jeffersonville, Indiana 47130; telephone number 288-4821. Plans for individual schools and other buildings are located in the administration office of each school. The plans can be viewed by any person during normal business hours of the particular school. Interested parties wishing to inquire about the hours and times that the plans are available should call the above number.

At this time, the management plans can provide information regarding inspections, response actions, and post-response action activities, including periodic reinspection and surveillance activities that are planned or in progress. Inquiries regarding any facet of the regulation or the management plans should be directed to Mr. Tony Nauert at the above telephone number during regular business hours.

Listed is a brief description of asbestos work that has been completed in our schools this year. Detailed reports have become part of each school's asbestos management plan and may be reviewed in the school office.

**Jeffersonville, Charlestown, and New Washington High Schools; Parkview, Charlestown, and River Valley Middle Schools; Wilson, Thomas Jefferson, Northaven, Utica, New Washington, Jonathan Jennings, Bridgepoint, Maple, Riverside, Spring Hill, and Parkwood Elementary Schools; the Administration Building, Service Center, and Corden Porter Center -**

- \* The required six month periodic surveillance was performed in June 1999.
- \* The required six month periodic surveillance was performed in December 1999.
- \* The next scheduled activity is a required periodic surveillance in June 2000.

**Pleasant Ridge Elementary School -**

- \* This building is asbestos free. No surveillances or reinspections are required.

June 2000

## **AHERA Annual Notice**

This information is being published to comply with the requirements of 40 CFR 763 Subpart E asbestos containing materials in schools. This regulation, commonly known as the "AHERA" rule, requires local education agencies, such as this one, to perform certain tasks in regards to the presence and control of asbestos containing materials in the buildings under the jurisdiction of the local education agency.

These include but are not limited to:

1. Developing an asbestos management plan which is designed to outline procedures and guidelines for the inspection, reinspection and periodic surveillance of asbestos containing materials that are present in the buildings.
2. Provide awareness training and additional training to selected school employees.
3. Periodically notify all workers and occupants, or their local guardians, parent teacher organizations, and collective bargaining organizations of the availability of asbestos management plans, the location of same and the times that the plans may be reviewed.

This notification is to advise all patrons, occupants, or their legal guardians, collective bargaining organizations, and parent-teachers organizations, that the asbestos management plans required under this act are available for review upon request. A copy of the plans for all buildings under the jurisdiction of this local education agency are available in the Service Center building, which is located at 301 E. 11th Street, Jeffersonville, Indiana 47130; telephone number 288-4821. Plans for individual schools and other buildings are located in the administration office of each school. The plans can be viewed by any person during normal business hours of the particular school. Interested parties wishing to inquire about the hours and times that the plans are available should call the above number.

At this time, the management plans can provide information regarding inspections, response actions, and post-response action activities, including periodic reinspection and surveillance activities that are planned or in progress. Inquiries regarding any facet of the regulation or the management plans should be directed to Mr. Steve Meredith at the above telephone number during regular business hours.

Listed is a brief description of asbestos work that has been completed in our schools this year. Detailed reports have become part of each school's asbestos management plan and may be reviewed in the school office.

### **All school and support buildings where it is required -**

- \* The required six month periodic surveillance was performed in June 1998.
- \* The required six month periodic surveillance was performed in December 1998.
- \* The next scheduled activity is a required periodic surveillance in June 1999.

### **Parkwood Elementary School**

- \* O & M was performed in the boiler room in May 1998.

June 1999



## AHERA Annual Notice

This information is being published to comply with the requirements of 40 CFR 763 Subpart E asbestos containing materials in schools. This regulation, commonly known as the "AHERA" rule, requires local education agencies, such as this one, to perform certain tasks in regards to the presence and control of asbestos containing materials in the buildings under the jurisdiction of the local education agency.

These include but are not limited to:

1. Developing an asbestos management plan which is designed to outline procedures and guidelines for the inspection, reinspection and periodic surveillance of asbestos containing materials that are present in the buildings.
2. Provide awareness training and additional training to selected school employees.
3. Periodically notify all workers and occupants, or their local guardians, parent teacher organizations, and collective bargaining organizations of the availability of asbestos management plans, the location of same and the times that the plans may be reviewed.

This notification is to advise all patrons, occupants, or their legal guardians, collective bargaining organizations, and parent-teachers organizations, that the asbestos management plans required under this act are available for review upon request. A copy of the plans for all buildings under the jurisdiction of this local education agency are available in the Service Center building, which is located at 301 E. 11th Street, Jeffersonville, Indiana 47130; telephone number 288-4821. Plans for individual schools and other buildings are located in the administration office of each school. The plans can be viewed by any person during normal business hours of the particular school. Interested parties wishing to inquire about the hours and times that the plans are available should call the above number.

At this time, the management plans can provide information regarding inspections, response actions, and post-response action activities, including periodic reinspection and surveillance activities that are planned or in progress. Inquiries regarding any facet of the regulation or the management plans should be directed to Mr. Steve Meredith at the above telephone number during regular business hours.

Listed is a brief description of asbestos work that has been completed in our schools this year. Detailed reports have become part of each school's asbestos management plan and may be reviewed in the school office.

### **All school and support buildings where it is required -**

- \* The required periodic surveillance was performed in June 1997 and December 1997.
- \* Next activity scheduled activity is a required third year reinspection in June 1998.

## AHERA Annual Notice

This information is being published to comply with the requirements of 40 CFR 763 Subpart E asbestos containing materials in schools. This regulation, commonly known as the "AHERA" rule, requires local education agencies, such as this one, to perform certain tasks in regards to the presence and control of asbestos containing materials in the buildings under the jurisdiction of the local education agency.

These include but are not limited to:

1. Developing an asbestos management plan which is designed to outline procedures and guidelines for the inspection, reinspection and periodic surveillance of asbestos containing materials that are present in the buildings.
2. Provide awareness training and additional training to selected school employees.
3. Periodically notify all workers and occupants, or their local guardians, parent teacher organizations, and collective bargaining organizations of the availability of asbestos management plans, the location of same and the times that the plans may be reviewed.

This notification is to advise all patrons, occupants, or their legal guardians, collective bargaining organizations, and parent-teachers organizations, that the asbestos management plans required under this act are available for review upon request. A copy of the plans for all buildings under the jurisdiction of this local education agency are available in the Service Center building, which is located at 301 E. 11th Street, Jeffersonville, Indiana 47130; telephone number 288-4821. Plans for individual schools and other buildings are located in the administration office of each school. The plans can be viewed by any person during normal business hours of the particular school. Interested parties wishing to inquire about the hours and times that the plans are available, should call the above number.

At this time, the management plans can provide information regarding inspections, response actions, and post-response action activities, including periodic reinspection and surveillance activities that are planned or in progress. Inquiries regarding any facet of the regulation or the management plans should be directed to Mr. Steve Meredith at the above telephone number during regular business hours.

Listed is a brief description of asbestos work that has been completed in our schools this year. Detailed reports have become part of each school's asbestos management plan and may be reviewed in the school office.

### **All school and support buildings where it is required -**

- \* The required periodic surveillance was performed in June 1996 and December 1996.
- \* The next required periodic surveillance will be performed in June 1997 and December 1997.

June 97

This information is being published to comply with the requirements of 40 CFR 763 Subpart E asbestos containing materials in schools. This regulation, commonly known as the "AHERA" rule, requires local education agencies, such as this one, to perform certain tasks in regards to the presence and control of asbestos containing materials in the buildings under the jurisdiction of the local education agency.

These include but are not limited to:

1. Developing an asbestos management plan which is designed to outline procedures and guidelines for the inspection, reinspection and periodic surveillance of asbestos containing materials that are present in the buildings.
2. Provide awareness training and additional training to selected school employees.
3. Periodically notify all workers and occupants, or their local guardians, parent teacher organizations, and collective bargaining organizations of the availability of asbestos management plans, the location of same and the times that the plans may be reviewed.

This notification is to advise all patrons, occupants, or their legal guardians, collective bargaining organizations, and parent-teachers organizations, that the asbestos management plans required under this act are available for review upon request. A copy of the plans for all buildings under the jurisdiction of this local education agency are available in the Service Center building, which is located at 301 E. 11th Street, Jeffersonville, Indiana 47130; telephone number 288-4821. Plans for individual schools and other buildings are located in the administration office of each school. The plans can be viewed by any person during normal business hours of the particular school. The plans can be viewed by any person during normal business hours of the particular school. Interested parties wishing to inquire about the hours and times that the plans are available should call the above number.

At this time, the management plans can provide information regarding inspections, response actions, and post-response action activities, including periodic reinspection and surveillance activities that are planned or in progress. Inquiries regarding any facet of the regulation or the management plans should be directed to Mr. Denny Johanson at the above telephone number during regular business hours.

Listed is a brief description of asbestos work that has been completed in our schools this year. Detailed reports have become part of each school's asbestos management plan and may be reviewed in the school office.

**All buildings where it is required -**

- \* The required third year reinspection was performed in June 1995.
- \* The required periodic surveillance was performed in December 1995.
- \* Next activity scheduled is a periodic surveillance in June 1996.

**Charlestown High School -**

- \* Transite panels were compliantly removed from the exterior of the building.

**Corden Porter Building #3 -**

- \* TSI was compliantly removed from the boiler room.

June 96

This information is being published to comply with the requirements of 40 CFR 763 Subpart E asbestos containing materials in schools. This regulation, commonly known as the "AHERA" rule, requires local education agencies, such as this one, to perform certain tasks in regards to the presence and control of asbestos containing materials in the buildings under the jurisdiction of the local education agency.

These include but are not limited to:

1. Developing an asbestos management plan which is designed to outline procedures and guidelines for the inspection, reinspection and periodic surveillance of asbestos containing materials that are present in the buildings.
2. Provide awareness training and additional training to selected school employees.
3. Periodically notify all workers and occupants, or their local guardians, parent teacher organizations, and collective bargaining organizations of the availability of asbestos management plans, the location of same and the times that the plans may be reviewed.

This notification is to advise all patrons, occupants, or their legal guardians, collective bargaining organizations, and parent-teachers organizations, that the asbestos management plans required under this act are available for review upon request. A copy of the plans for all buildings under the jurisdiction of this local education agency are available in the Service Center building, which is located at 301 E. 11th Street, Jeffersonville, Indiana 47130; telephone number 288-4821. Plans for individual schools and other buildings are located in the administration office of each school. The plans can be viewed by any person during normal business hours of the particular school. Interested parties wishing to inquire about the hours and times that the plans are available, should call the above number.

At this time, the management plans can provide information regarding inspections, response actions, and post-response action activities, including periodic reinspection and surveillance activities that are planned or in progress. Inquiries regarding any facet of the regulation or the management plans should be directed to Mr. Dennis Johanson at the above telephone number during regular business hours.

Listed is a brief description of asbestos work that has been completed in our schools this year. Detailed reports have become part of each school's asbestos management plan and may be reviewed in the school office.

**All school and support buildings where it is required -**

- \* The required periodic surveillance was performed in June 1995 and December 1995.
- \* The required triennial reinspection was performed in June 1995.
- \* The next required periodic surveillance will be performed in June 1996 and December 1996.

June 95

## *ACCREDITATIONS*



# **Environmental Management Institute**

**5610 Crawfordsville Road, Suite 15, Indianapolis, Indiana 46224-3714**

**317/248-4848 • 800/488-8842 • FAX 317/248-4846**

**[www.envtlmgmt.org](http://www.envtlmgmt.org)**

This confirms that

## **Sandy Shadley**

Completed the Required Initial Training for  
Asbestos Accreditation Under TSCA Title II  
and has  
passed with a Score of 70 or Greater the Examination for

### **Asbestos Management Planner**

Course Date  
December 10 - 11, 2009

Examination Date  
December 11, 2009



Jack E. Leonard, President

Certificate: MP(I) 2248

Expires: December 11, 2010

Approved by:: Illinois Department of Public Health  
Indiana Department of Environmental Management

Indiana Department of Environmental Management  
100 N. Senate Avenue  
Mail Code 61-52 IGCN 1003  
Indianapolis, IN 46204-2251



January 21, 2010

RECEIVED JAN 23 2010

Sandra S. Shadley  
Alliance Environmental Grp  
5340 Commerce Circle Ste E  
Indianapolis IN 46237

Re: Asbestos Management Planner # 19A002720

Based upon the review of your license application, the Office of Air Quality has determined that you have fulfilled the requirements of 326 IAC 18 and are eligible for licensing in the following discipline:

**Asbestos Management Planner**

Your Asbestos Management Planner license is attached below. The license is waterproof and tear resistant. Please sign your license and do not laminate or alter your license in anyway. Your license must be available for review at all times while implementing an asbestos project. This license may be revoked, pursuant to 326 IAC 18-1-7, if you:

- (1) Violate any requirements of these rules (326 IAC 18), 326 IAC 14-10, or any requirement of the Asbestos-Containing Materials in Schools Rule or any other federal, state, or local regulation pertaining to asbestos in buildings or to asbestos projects.
- (2) Falsify information on your application for licensing.
- (3) Fail to meet any qualifications specified in 326-IAC 18-1-4.
- (4) Conduct asbestos project, or related asbestos handling activity, in a manner which is hazardous to the public health.

Your license is valid effective 01/21/2010, and will expire on 01/21/2011, as indicated on your card. We suggest that you attend the required training and submit an application for license renewal early to insure your license does not lapse. NOTE: 326 IAC 18-1-4(h) and 326 IAC 18-1-6(e) require that any individual who has an eighteen (18) month lapse between any two training courses of the same discipline to attend an initial training course for the discipline in which they are seeking a license. In order to avoid re-taking the initial training course you must have attended a refresher in the discipline you are seeking a license within eighteen (18) months from the date of issuance of your last training course certificate.

Office of Air Quality, Asbestos Licensing Section (317) 233-3861



Indiana Dept. of Environmental Management

**Sandra S. Shadley**

Asbestos Management Planner License #: 19A002720

Effective: 01/21/2010  
Birth Date: 04/21/1959  
Height: 5-08  
Weight: 140

Expiration: 01/21/2011  
Gender: F  
Eye Color: Blue  
Hair Color: Brown

**ENVIRONMENTAL SAFETY ASSURANCE INSTITUTE**

**1435 Sadler Circle West Drive  
Indianapolis, Indiana 46239  
(317) 352 -1270 / (317) 352 - 0669**

**CHRISTIAAN SPARKS**

**306 - 04 - 2616**

**Has Successfully Completed The Course  
Required Under TSCA Title II  
And Passed The Written Examination  
With a Score of 70% or Better**

**For  
ASBESTOS BUILDING INSPECTOR REFRESHER**

**Accredited by the  
Indiana Department of Environmental Management.**

**Certificate # ES03/BIR755**

**Course Dates: 09/26/2003  
Test Date: 09/26/ 2003   Expires: 09/26/2004**



*Sharyn Reyes*

**Sharyn Reyes  
Instructor / Manager**



**ENVIRONMENTAL SAFETY ASSURANCE INSTITUTE**  
1435 Sadlier Circle West Drive  
Indianapolis, Indiana 46239  
(317) 352-1270 / (317) 352-06

**GEORGE Wm. (BILL) OGLE**

Has Successfully Completed The Course  
Required Under TSCA Title II  
And Passed The Written Examination  
With a Score of 70% or Better  
For

**ASBESTOS MANAGEMENT PLANNER  
REFRESHER**

Accredited by the  
Indiana Department of Environmental Management.

**Certificate # ES03/MPR045**

Course Dates: 09/05/2003  
Test Date: 09/05/2003      Expires: 09/05/2004



  
Sharyn Reyes  
Instructor

**ENVIRONMENTAL SAFETY ASSURANCE INSTITUTE**  
**1435 Sadlier Circle West Drive**  
**Indianapolis, Indiana 46236**  
**(317) 352-1270 / (317) 352 - 0669**

**PATRICK E. WILSON**  
**309 - 90 - 6909**


**Has Successfully Completed The Course**  
**Required Under TSCA Title II**  
**And Passed The Written Examination**  
**With a Score of 70% or Better**  
**For**

**ASBESTOS BUILDING INSPECTOR REFRESHER**

**Accredited by the**  
**Indiana Department of Environmental Management.**

**Certificate # ES00/BIR482**

**Course Dates: 11/29/2000**  
**Test Date: 11/29/2000   Expires: 11/29/2001**

  
**Sharyn Reyes**  
**Instructor**



# Environmental Management Institute

5610 Crawfordsville Road, Suite 15, Indianapolis, Indiana 46224-3714

317/248-4848 • 800/488-8842 • FAX 317/248-4846

[www.spea.iupui.edu/Envtl\\_mgmt](http://www.spea.iupui.edu/Envtl_mgmt)

This confirms that

**George Wm. (Bill) Ogle**



Completed the Requisite Initial Training for  
Asbestos Accreditation Under TSCA Title II  
and has  
Passed with a Score of 70 or Greater the Examination for  
**Asbestos Management Planner**

Course date  
March 2 - 3, 2000

Examination Date  
March 3, 2000

Jack E. Leonard, President

Certificate: MP(I) 2157  
Expires March 3, 2001

Approved by: Illinois Department of Public Health  
Indiana Department of Environmental Management



ENVIRONMENTAL SAFETY ASSURANCE INSTITUTE  
1435 Sadlier Circle West Drive  
Indianapolis, Indiana 46239  
(317) 352-1270 / (317) 352-0669

**CLINT YATES**

316 - 92 - 7065

Has Successfully Completed The Course  
Required Under TSCA Title II  
And Passed The Written Examination  
With a Score of 70% or Better  
For

**ASBESTOS BUILDING INSPECTOR REFRESHER**

Accredited by the  
Indiana Department of Environmental Management.

Certificate # ES/BIR98/004.

Course Dates: 01/22/98 - 01/22/98  
Test Date: 01/22/98 Expires: 01/22/99

*Sharyn Reyes*

Sharyn Reyes  
Assistant / Instructor

# Environmental Management Institute

Environmental and Occupational Training Service

5610 Crawfordsville Road, Suite 15

Indianapolis, Indiana 46224-3714

317/248-4848

This confirms that

**Rex Gaddis**

Completed the Requisite Refresher Training for

Asbestos Accreditation Under TSCA Title II

and has

Passed with a Score of 70 or Greater the Examination for


**Asbestos Building Inspector**

Course date

November 22, 1994

Examination Date

November 22, 1994



Jack E. Leonard, President

Certificate: IN(R) 2713

Expires November 22, 1995

Approved by:

Illinois Department of Public Health

Indiana Department of Environmental Management

INDIANA DEPARTMENT OF  
ENVIRONMENTAL MANAGEMENT  
ASBESTOS CERTIFICATE OF ACCREDITATION  
CERTIFICATE # 192240026 EXPIRATION DATE 2/18/96  
Rex Gaddis  
IS CERTIFIED IN THE FOLLOWING DISCIPLINE(S)  
INSPECTOR ☐ PLANNER ☒ DESIGNER ☐  
SUPERVISOR ☐ WORKER ☐  
WASTE DISPOSAL MANAGER ☐  
BIRTHDATE: 3/24/52 SEX: M EYES: BLU  
HEIGHT: 5-10 WEIGHT: 220 HAIR: BRO

INDIANA DEPARTMENT OF  
ENVIRONMENTAL MANAGEMENT  
ASBESTOS CERTIFICATE OF ACCREDITATION  
CERTIFICATE # 190908032 EXPIRATION DATE 3/16/96  
Rex Gaddis  
IS CERTIFIED IN THE FOLLOWING DISCIPLINE(S)  
INSPECTOR ☒ PLANNER ☐ DESIGNER ☐  
SUPERVISOR ☐ WORKER ☐  
WASTE DISPOSAL MANAGER ☐  
BIRTHDATE: 3/24/52 SEX: M EYES: BLU  
HEIGHT: 5-10 WEIGHT: 220 HAIR: BRO

*TRAINING*

### **MINOR FIBER RELEASE EPISODE**

The local education agency shall ensure that the procedures described below are followed in the event of a minor fiber release episode (i.e., the falling or dislodging of not more than 3 square or linear feet of friable ACBM):

1. Thoroughly saturate the debris using wet methods.
2. Clean the area using wet methods, protective clothing, HEPA-vacuums, mini-enclosures, glove bags, as necessary to inhibit the spread of any released fibers. At a minimum, workers should use air-purifying respirators with HEPA filters.
3. Place the asbestos debris in a sealed, leak-tight container, preferably a 6 mil. labeled plastic bag.
4. Repair the area of damaged ACM with materials such as asbestos-free spackling, plaster, cement, or insulation, or seal with latex paint or an encapsulant, or immediately have the appropriate response action implemented.
5. Each fiber release episode should be documented.



## **MAJOR FIBER RELEASE EPISODE**

The local education agency shall ensure that the procedures described below are followed in the event of a major fiber release episode (i.e., the falling or dislodging of more than 3 square or linear feet of friable ACBM):

1. Restrict entry into the area and post signs to prevent entry into the area by persons other than those necessary to perform the response action.
2. Shut off or temporarily modify the air-handling system to prevent the distribution of fibers to other areas in the building.
3. AHERA requires that major fiber release episodes be designed by accredited Project Designers. However, the following response procedures should form the basis for response actions.
4. All the procedures recommended by EPA and required by OSHA for large-scale removal of ACM should be used. These include containment barrier, negative pressure ventilation, personal respiratory protection and protective clothing, decontamination facilities, and air testing.
5. Workers should wear "type C" respirators and protective clothing, including a body suit, hood, boots and gloves. Personal air monitoring may be conducted on representative workers, but is not required by OSHA when "type C" respirators are used.
6. Fallen debris should be sprayed with amended water and placed in plastic bags for disposal. Shovels are useful for collecting the debris. The floor should be thoroughly cleaned with a HEPA vacuum cleaner.
7. Walls, ceiling, pipes, boilers, or other surfaces where ACM was damaged or delaminated should be repaired temporarily. This might involve replastering with asbestos-free material, spraying with an encapsulant, or taping with duct tape. In some cases, ACM beyond the immediate area of damage may need to be removed to prevent additional episodes.
8. The air should be tested for asbestos fibers before the plastic barriers are removed and the area reoccupied. Testing should follow guidelines in Chapter 6 of the Purple Book and Chapter 4 of the Silver Book. That is, air should be sampled at the specified number of locations and analyzed by either phase contrast microscopy or transmission electron microscopy. However, sampling should not be done aggressively since the use of blowers and fans may dislodge fibers from the remaining ACM.

9. After the barriers have been taken down, a decontamination of the entire building or a portion of it should be considered. The need for this will depend on how rapidly the response team reacted to the episode and, in particular, how quickly the HVAC system was turned off. A thorough decontamination includes HEPA-vacuuming and/or wet wiping all carpets, furniture, and other surfaces. Decontamination of the HVAC system would involve disassembling and cleaning (HEPA-vacuuming or wet wiping) ducts, ventilators, registers, and other system parts. System filters should also be removed and replaced.

10. All equipment used in the cleanup operation should be washed or wiped with damp cloths. All disposable materials (e.g., cloths, mop heads, filters, coveralls) should be discarded as asbestos wastes.

11. Each fiber release episode should be documented.

**OPERATIONS AND MAINTENANCE REPORT**  
(Use only for O&M work less than 3 square or 3 linear feet)

**L.E.A.:** \_\_\_\_\_

**BUILDING:** \_\_\_\_\_

**DATE:** \_\_\_\_\_

The following information is provided in accordance with 40 CFR 763.91 and 763.94.

1. Location: \_\_\_\_\_

Homogeneous Area/Material Description \_\_\_\_\_

2. Response: Clean \_\_\_\_\_ Repair \_\_\_\_\_ Encapsulation \_\_\_\_\_

Enclosure \_\_\_\_\_ Removal \_\_\_\_\_

Reason: \_\_\_\_\_

3. Work Description: \_\_\_\_\_

4. Date: Start \_\_\_\_\_ Stop \_\_\_\_\_

Time: Start \_\_\_\_\_ Stop \_\_\_\_\_

5. Material: Surface \_\_\_\_\_ SF Thermal \_\_\_\_\_ LF

Other: \_\_\_\_\_ SF or \_\_\_\_\_ LF

6. Asbestos Control Method: Wet Methods \_\_\_\_\_ HEPA Vacuum \_\_\_\_\_

Glovebag \_\_\_\_\_ Mini-Enclosure \_\_\_\_\_

7. Respiratory Protection: N.A.P.R. \_\_\_\_\_ P.A.P.R. \_\_\_\_\_

Were all employees properly fit tested? YES NO NOT APPLICABLE

8. Equipment Used:

Low Vol. Pumps  
FAM  
HEPA Vac

\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

High Vol. Pumps  
AFD

\_\_\_\_\_  
\_\_\_\_\_

Other: \_\_\_\_\_

9. Material Used:

6 Mil. Disposable Bags  
Glovebags  
Duct Tape  
Disposable Coveralls  
Sponges

\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

Poly  
HEPA Filters  
Spray Glue  
3M Pads

\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

Encapsulants: Penetrating \_\_\_\_\_ Bridging \_\_\_\_\_

Other: \_\_\_\_\_

10. Work Personnel:

NAME 16 HOUR TRAINED - IDEM ACCREDITED

Supervisor: \_\_\_\_\_ YES NO YES NO

Worker(s): \_\_\_\_\_ YES NO YES NO

\_\_\_\_\_ YES NO YES NO

\_\_\_\_\_ YES NO YES NO

\_\_\_\_\_ YES NO YES NO

\_\_\_\_\_ YES NO YES NO

11. ACBM Disposal: Storage: YES NO, If yes, where stored: \_\_\_\_\_

If no, where disposed: Landfill: \_\_\_\_\_

12. Final Visual Inspection Approved: \_\_\_\_\_  
(LEA Designated Person - Printed Name)

\_\_\_\_\_  
(LEA Designated Person - Signature)

**OPERATIONS AND MAINTENANCE  
INFORMATION**

*REMOVAL PROJECT  
INFORMATION*

*SHORT TERM WORKER PROGRAM*

## GREATER CLARK COUNTY SCHOOLS

## SHORT-TERM WORKER SIGN OFF SHEET

This form should be signed each and every time before a "short-term worker" (telephone repair worker, utility worker, etc.) performs work that may cause him to come in contact with ACBM or suspected ACBM assumed to be ACM. One copy of this form should then be forwarded to the LEA designated person, and one copy should be maintained in the school building's copy of the supplemental binder provided by Alliance Indiana, Inc., in order to fulfill the LEA's recordkeeping requirements. The third copy should be forwarded to Alliance Indiana, Inc. for placement in its copy of the supplemental binder.

School Building Name - Charlestown Senior High School Date                     

I certify that before performing any work which would possibly cause me to come in contact with Asbestos Containing Building Materials (ACBM), I was provided with adequate information regarding the locations of ACBM and suspected ACBM assumed to be ACM in the above-mentioned school building where I performed the work.

Signature - \_\_\_\_\_

Company - \_\_\_\_\_

Description of work (including number of days on site) - \_\_\_\_\_

---

---

---

---

---

---

---

---

---

---



## SHORT-TERM WORKER SIGN IN LOG

**BUILDING NAME -** Charlestown Senior High School

**SIGNATURE**

[illegible]